



**TOGETHER**  
*for a sustainable future*

## OCCASION

This publication has been made available to the public on the occasion of the 50<sup>th</sup> anniversary of the United Nations Industrial Development Organisation.



**TOGETHER**  
*for a sustainable future*

## DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

## FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

## CONTACT

Please contact [publications@unido.org](mailto:publications@unido.org) for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at [www.unido.org](http://www.unido.org)

22671

*Maurice Ind.*

**ICEBERG**

موريس الصناعية

## **FINAL REPORT**

*For*

**Contract Number 01/314**

***Abdoullah Factory for Refrigeration & Cooling, Emad Addin Al-Sareegy  
Establishment, Ma'nna Workshop, Al- Mansour workshop, Al Ostath  
Workshop and Raed Workshop***

In this final report we describe our activities as well as providing all documents prepared from our previous reports. Some test sheets results are attached to this report for your evaluation and any suggestion to improve the performance criteria of the prototypes manufactured by the counterpart. This report could be used as a guideline for counterparts for future use, especially on selection of new components. Special consideration must be taken to select proper R134a compressor to replace with conventional R12 compressor. It is also important to adjust refrigerant charge balance to the existing refrigeration cycle with any major changes to the evaporator and condenser. In high back pressure type compressor it might needed to adjust capillary tube to balance pressure increase into the refrigeration system. All necessary advises were given to the counterparts during our several visit to their premises and conduction of technical course.

Since these companies are the same in nature and usually do not have any testing facility to test their new and existing models during changing compressor models. It is seriously recommended to use one of existing hot chamber in the city, to assure safe and economical operation of refrigeration system.

We are proud to have the opportunity to be UNIDO's team member to phase out OSD from many companies. We will attempt to use our experience and capabilities to continue assisting UNIDO and small commercial refrigerator sector to improve

UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION

INTER-OFFICE MEMORANDUM

To: Ms. H. Yalcindag, Director  
SES/MPR

Date: 19 February 2002

Attn.: Mr. A. Malayeri

From:  M. Latrech, Contracts Officer  
General Services/FPC/FOA

Ref.: ML/sb

Subject: **Final Report** - MP/JOR/01/152 – Development of Prototypes at Abu Azmi Factory, Hasoumi Refrigeration Factory and Majdi Factory - Contract No. 01/315

1. In accordance with the stipulations of paragraph 2.10 c) of Contract No. 01/315, Maurice Industries (Maurice Al-Deek Co.), Hashemite Kingdom of Jordan, has provided this Office with five (5) copies, in English, of their final version of their Report, on the subject project, and three (3) copies are forwarded herewith, for your review and comments.
2. We would appreciate your reviewing this Report as soon as feasible and your advising this Service of its acceptability.  
..... If acceptable, please sign the attached invoice and return it to us.
3. If the Contractor's Report is acceptable, copies should be distributed in accordance with the instructions contained in the UNDP Policies and Procedures Manual (UNDP/PPM/TL/2 of 27 January 1978, Section 4.0, paragraph 5, pages 9-14).
4. Please note that:
  - a) one (1) copy of the Contractor's Report is being sent to Registry for their own records, and that
  - b) one (1) copy is being sent to Ms. K. Puff, who upon perusal, will transfer it to the Library for micro-filming.
5. We would also appreciate your completing and returning the enclosed copy of the "Evaluation of Contractor's Performance" form.

cc.: Registry (with one (1) copy of the report under consideration)  
Ms. K. Puff (with one (1) copy of the report under consideration)

their technical awareness, and count us as a focal point to access to up to date information and technical assistance.

**Activities**

- 1- Visiting counterparts premises several times to assure precise technical data for providing necessary information for calculating refrigeration load calculation.
- 2- Assisting counterparts to select most common and well selling prototype models to be made and test under new circumstances.
- 3- Supervising related activities concerning making prototypes.
- 4- Conducting several briefing meeting and training session at our classroom located beside our hot chamber at our factory and counterparts premises to familiarize the counterparts technical staff with new refrigerant physical, chemical and operation properties and behavior.
- 5- Contacting UNDP and Ozone office in several occasion to plan for implementation of the project in time.
- 6- Coordinating with UNIDO staff and Ozone office staff in Beirut for execution of different activities foreseen in the contract.
- 7- Storing and preserving charging equipment at our warehouse to assure safe and trustful stocking as requested by UNIDO's project manager and Ozone Office.
- 8- Deliver all charging equipment to counterparts as they were received in accordance with packing list and project documents.
- 9- Assuring safe handling and equipment free of any defects by visual inspection due to possible mechanical damages, before delivery to the counterparts.
- 10- Explaining to the counterparts operation purposes and application of each machines as purchased and supplied by UNIDO and manufacturer.

UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION

INTER-OFFICE MEMORANDUM

To: Ms. H. Yalcindag, Director  
SES/MPR

Date: 19 February 2002

Attn.: Mr. A. Malayeri

From:  M. Latrech, Contracts Officer  
for General Services/FPC/FOA

Ref.: ML/sb

Subject: **Final Report** - MP/JOR/01/152 – Development of Prototypes at Abdoulah Factory for Refrigeration & Cooling, Emad Addin Al-Sareegy Establishment, Ma'na Workshop, Al-Mansour Factory for Refrigeration, Al-Ostath Workshop and Raed Workshop - Contract No. 01/314

1. In accordance with the stipulations of paragraph 2.10 c) of Contract No. 01/314, Maurice Industries (Maurice Al-Deek Co.), Hashemite Kingdom of Jordan, has provided this Office with five (5) copies, in English, of their final version of their Report, on the subject project, and three (3) copies are forwarded herewith, for your review and comments.
2. We would appreciate your reviewing this Report as soon as feasible and your advising this Service of its acceptability.  
..... If acceptable, please sign the attached invoice and return it to us.
3. If the Contractor's Report is acceptable, copies should be distributed in accordance with the instructions contained in the UNDP Policies and Procedures Manual (UNDP/PPM/TL/2 of 27 January 1978, Section 4.0, paragraph 5, pages 9-14).
4. Please note that:
  - a) one (1) copy of the Contractor's Report is being sent to Registry for their own records, and that
  - b) one (1) copy is being sent to Ms. K. Puff, who upon perusal, will transfer it to the Library for micro-filming.
5. We would also appreciate your completing and returning the enclosed copy of the "Evaluation of Contractor's Performance" form.

cc.: Registry (with one (1) copy of the report under consideration)  
Ms. K. Puff (with one (1) copy of the report under consideration)

- 11-Conducting an orientation course for technical staff of counterparts to be familiarized with application of equipments and use of them.
- 12-Testing Performance test on all prototypes to assure accomplishment of contract to fulfill new R134a refrigerant.
- 13-Evaluation on performance test results of prototypes to adjust and do necessary changes to refrigeration cycle in retrofit program foreseen in the contract.
- 14-Advise the counterpart to do necessary changes to all models produced. These changes could be defined as proper amount of refrigerant weight and proper compressor selection, using cooling capacity calculated in this program.
- 15- This to notice that amount of cooling capacity could be used as guidance, obviously it is almost impossible to find a compressor model to fit excite cooling capacity. There are a lot of factors which should be into consideration while selecting compressor.
- 16-The counterparts were advised to do performance test on all new compressor models selected to replace the old model, regardless of performance and technical characteristics defined by the manufactures.
- 17-A comprehensive explanation given to the counterparts to use different compressor manufacturers brochure and technical data.

In this report we explain our activities and technical data gathered for component selection and also determine proper configuration for new design criteria.

We spent a lot of time in market to suggest to the counterparts the new component replacement to fit R134a ozone friendly refrigerant system circuit.

Compressor selection was the main concern in this regard due to certain limitation of compressor capacity availability in Jordan market.

Our main concern in implementation of project is testing prototypes which are the most important part of project.

Counterparts showed good role and cooperation to make prototypes and testing them are on process, the test results will be submitted to you whenever they are completed and pass performance test requirement.

The new criteria is defined as new operating condition under usage of R134a Ozone friendly refrigerant. As we learnt through our experience, following components have significant role to be adapted for new environmental and technical circumference.

- Compressor
- Drier
- Capillary tube
- Refrigerant Charge

**Introduction**

Please find below our first progress report, concerning calculation and redesign of the prototypes to be made by the counterparts and they will be tested at our hot chamber, at our site in Amman. These prototypes are to be manufactured under our engineering supervision and will be tested in accordance with appropriate ISO standard test procedure and relevant performance test characteristics for functionality and performance of the new Ozone friendly R134a refrigerant. We hope that this first report could have satisfied the UNIDO in order to comply with our contract. In the second progress report we will provide you more technical details of all prototypes to be made by the counterparts.

The refrigeration load calculation is made here for following companies subjected to the UNIDO contract number 01/314 implementation of CFC phase out projects at,

- Abdullah Workshop
- Emad Addin Al-Sareegy Workshop
- M'anna Workshop
- Al- MansourFactory for Refrigeration
- Al- Ostath Workshop
- Raed Workshop



**Load Calculation for Water Cooler**  
**Abdullah Workshop**

$Q1 = m C \Delta T$ , Where:

**Q1** Total heat removed from total drinking water tank volume capacity (lit.) during specific period, related to compressor cooling capacity power in Watts, at initial compressor start up, and early in the morning. When the water temperature is 28 C.

**m** total weight of original water in the water cooler storage tank in Kg. Considering that one liter of water at 25 C is equal to approximately one Kg.

Tank Volume = 30 lit

$$M = 70 \text{ liter} = 30 \text{ Kg.}$$

**C** Specific heat factor of water in Kcal/Kg °C = 1

**$\Delta T$**  Temperature difference ( $T_i - T_c$ ), where,  $T_i$  is inlet water temperature, and  $T_c$  is final cooled water.

$$T_i = 28 \text{ }^\circ\text{C} \text{ and } T_c = 7 \text{ }^\circ\text{C}$$

$$T_i - T_c = 28 - 7 = 21 \text{ }^\circ\text{C}$$

$$Q1 = m C \Delta T = 70 \times 1 \times 21 = 1470 \text{ Kcal} = 1470 \times 1.163 = 1710 \text{ Watts/24 hrs}$$

$$Q1 = 1710 / 24 \text{ water cooler operating time per day} = 71.2 \text{ Watts}$$

$$Q1 = 71.2 \text{ Watts}$$

$$Q2 = \dot{M} C \Delta T$$

**Q2** Total heat removed from total drinking water flow (lit.) during specific period, 16 hours. In Kcal.

**$\dot{M}$**  total weight of water flow during 16 hours. in Kg. =  $H \times N \times M$  where:

**H** = Total Water Cooler Usage Time (Hours) = 16

**N** = Number of Glass of Drinking Water per Hour = 20

**M** = Kg weight of water in one Glass of Water = 0.2 Kg

$$\dot{M} = (16 \times 20 \times 0.2) = \text{lit.} + 20\% \text{ Waste Water} = 77$$

C Specific heat factor of water in Kcal/Kg °C = 1

$\Delta T$  Temperature d( $T_i - T_c$ ), where,  $T_i$  is inlet water temperature, and  $T_c$  is final cooled water temperature.

$$T_i = 28 \text{ }^\circ\text{C} \text{ and } T_c = 7 \text{ }^\circ\text{C}$$

$$T_i - T_c = 28 - 7 = 21 \text{ }^\circ\text{C}$$

$$Q_2 = m C \Delta T = 77 \times 1 \times 21 = 1617 \text{ Kcal} = 1617 \times 1.163 = 1880 \text{ Watts/16 hrs}$$

$$Q_2 = 1880/12 \text{ compressor operating time per day} = 156 \text{ Watts}$$

$$\underline{Q_2 = 156 \text{ Watts}}$$

$Q_3 = UA \Delta T$ , Where:

$Q_3$  Total Leak, gained through side wall of drinking water storage tank by conduction in Kcal..

U Heat Resistance Coefficient Factor in Kcal/Sq. mt. C

K = 0.0178 W/mt.K

$$U = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}} = 0.40$$

$$h_i = h_o = 9.37 \text{ W/m}^2 \cdot \text{K}$$

A Total Area which heat is transmitted by. In Sq. Mt.

$$A = [(3.14 \times 0.3 \times 0.3) / 4] \times 0.8 = 0.56 \text{ Sq.mt.}$$

$\Delta T$  Temperature difference ( $T_a - T_c$ ), where,  $T_a$  is ambient temperature, and  $T_c$  is final cooled water temperature.

$$T_a = 32 \text{ }^\circ\text{C} \text{ and } T_c = 7 \text{ }^\circ\text{C}$$

$$T_a - T_c = 32 - 7 = 25 \text{ }^\circ\text{C}$$

$$Q_3 = (UA, \Delta T) = (0.40 \times 0.56 \times 25) = 1.4 \text{ Watts}$$

$$Q_3 = 1.4 \text{ Watts}$$

$$Q_t = Q_1 + Q_2 + Q_3 = 71.2 + 156 + 1.4 = 228 + 10\% \text{ safety factor} =$$

$$251.5 \text{ Watts}$$

Refrigeration Load Calculation  
Emad Alddin Workshop Meat Upright Refrigerator

a) Transmission load calculation

Refrigerator Compartment	Dimension Cm.	Area (sq.mt.)	Insulation Thickness	Temp. Difference
Side Walls	2 x (70x205)	2.87	40mm	27 c
Back Panel	140x205	2.87	40mm	27 c
Bottom	70x140	0.98	40mm	27 C
Top	70x140	0.98	40mm	37 c
Doors	140x205	2.87	40mm	27 c

Insulation Type: Pu Foam with R141b blowing agent.

Thermal Conductivity for Foam = 0.027 W/ mt. ° C

Temperature Difference Refrigerator Compartment:

$$\Delta T = 32 - (+5) = 27 \text{ ° C}$$

Ambient Temperature = 32 °C

Refrigerator Air Temperature = +5 °C

Calculation :

Heat Leak For Refrigerator Compartment.

$$Q_{TL} = Q_{SW} + Q_{Back\ Panel} + Q_{door} + Q_{Bottom} + Q_{top}$$

$$Q = U A (T_a - T_r)$$

$$U = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}}$$

Where :

U = Heat Resistance Coefficient Factor

K<sub>1</sub> = Foam Thermal Conductivity

h<sub>i</sub> = h<sub>o</sub> = Air Convection Factor = 9.37 Watt/Mt<sup>^</sup> K

Due to the short thickness of cabinet out side panel and Metal inner liner heat resistance of these materials have been considered negligible.

Therefore:

$$1- Q_{\text{SideWalls}} = [U A (T_a - T_r)]$$

$T_a$  = Ambient Temperature 32

$T_r$  = refrigerator air Temperature 5

$U = 0.59 \text{ W/ sq.m } ^\circ\text{C}$

$A = 2.87 \text{ Sq. Mt.}, T_a = 32 ^\circ\text{C}, T_r = +5 ^\circ\text{C}$

therefore

$$Q_{\text{SideWalls}} = 0.59 \times 2.87 \times 27 = 46 \text{ Watts}$$

$$Q_{\text{SideWalls}} = 46 \text{ Watts}$$

$$2- Q_{\text{doors}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ W/ sq.m } ^\circ\text{C}, T_a - T_r = 27, A = 2.87$

$$Q_{\text{doors}} = 0.59 \times 2.87 \times 27 = \text{Watts } Q_{\text{doors}} = 46 \text{ Watts}$$

$$3- Q_{\text{top}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ w/sq. Mt. } ^\circ\text{C},$

$T_a - T_r = 37,$

$A = 0.98$

$$Q_{\text{top}} = 0.59 \times 0.98 \times 37 = 21 \text{ Watts}$$

$$Q_{\text{top}} = 21 \text{ Watts}$$

$$4 - Q_{\text{back panel}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ w/sq. Mt. } ^\circ\text{C},$

$T_a - T_r = 27, A = 2.87$

$$Q_{\text{back panel}} = 0.59 \times 2.87 \times 27 = 46 \text{ Watts}$$

$$Q_{\text{back panel}} = 46 \text{ Watts}$$

$$5 - Q_{\text{Bottom}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ w/sq. Mt. } ^\circ\text{C},$

$T_a - T_r = 27, A = 0.98$

$$Q_{\text{Bottom Surface}} = 0.59 \times 0.98 \times 27 = 16 \text{ Watt}$$

$$Q_{\text{Bottom Surface}} = 16 \text{ Watts}$$

$$\text{Total Refrigerator Heat Leak} = 46 + 46 + 21 + 16 + 46 = 175 \text{ W}$$

Product Load

A product placed in a refrigerator at a temperature higher than the storage temperature will lose heat until it reaches the storage temperature. The quantity of heat to be removed may be calculated from knowledge of the product, including its state upon entering the refrigerator, its final state, its weight, specific heat above and below freezing point, its freezing temperature and latent heat.

When a definite weight of product is cooled from one state and temperature to another state and temperature, some or all of the following calculations must be made:

Heat removal from initial temperature to some lower temperature above freezing.

$$Q = mc(T_1 - T_2)$$

Heat removal from initial temperature to freezing point of product.

$$Q = mc(T_i - T_f)$$

Heat removal to freeze product.

$$Q = mh_{if}$$

Heat removal from freezing point to final temperature below freezing.

$$Q = mc(T_f - T_3)$$

Where

Q = heat removed, Kj

M = weight of product, kg

C = specific heat of product above freezing point, Kj/Kg. K

T<sub>1</sub> = initial temp. C

T<sub>2</sub> = lower temperature above freezing, C

T<sub>f</sub> = freezing temperature of product, C

H<sub>if</sub> = latent heat of fusion, kj per kg

Since this product is mainly used for storing fresh Lamb meet and beef above

freezing point at +5 C, we consider 600 Kg of meet to be stored in this refrigerator therefore we calculate as follow,

$$Q = mc(T_1 - T_2)$$

$$M = 600 \text{ kg}$$

$$C = 0.67 \text{ Btu}/(\text{lb})\text{F deg} = 0.67 \times 4.184 = 2.8 \text{ j/g K}$$

$$T_1 = 25 \text{ C}$$

$$T_2 = 5 \text{ C}$$

$$Q = 600000 \times 2.8 \times (25-5) = 33600000 \text{ jul}/86400 = 389 \text{ Watt}$$

Internal Load

N/A

Door Opening

Refrigerator Internal Volume 2000 lit.

Number of air change as per ASHREA standard = 70 per day

Heat removed per cubic meter of air 75000 j

$$\text{Air Change load} = 2 \times 70 \times 75000 / 86400 = 121 \text{ Watt}$$

$$Q_{\text{Total}} = Q_{\text{heat leak}} + Q_{\text{product load}} + Q_{\text{internal load}} + Q_{\text{air change}}$$

$$Q_{\text{Total}} = 175 + 389 + 121 = 685$$

Considering 10 % of Q total for safety factor

$$\text{Cooling Capacity Required} = Q_{\text{Grand Total}} = 685 + 10\%(685) = 753 \text{atts}$$

**Refrigeration Load Calculation**  
**Ma'anna Chest Freezer**

a) Transmission load calculation

Freezer Compartment	Dimension Cm.	Area (sq.mt.)	Insulation Thickness	Temp. Difference
Side Walls	2 x (65x88)	1.444	40mm	55 c
Back Panel	125x88	1.1	40mm	55 c
Bottom	65x88	0.572	40mm	65 C
Top	65x88	0.572	40mm	55 c
Doors	125x88	1.1	40mm	55 c

Insulation Type: Pu Foam with R141b blowing agent.

Thermal Conductivity for Foam = 0.027 W/ mt. ° C

Temperature Difference Refrigerator Compartment:

$$\Delta T = 32 - (-23) = 55 \text{ ° C}$$

Ambient Temperature = 32 °C

Freezer Air Temperature = -23 °C

Calculation :

Heat Leak For Freezer Compartment.

$$Q_{TL} = Q_{SW} + Q_{Back\ Panel} + Q_{door} + Q_{Bottom} + Q_{top}$$

$$Q = U A (T_a - T_r)$$

$$U = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}}$$

Where :

U = Heat Resistance Coefficient Factor

K<sub>1</sub> = Foam Thermal Conductivity

h<sub>i</sub> = h<sub>o</sub> = Air Convection Factor = 9.37 Watt/Mt<sup>^</sup> K

Due to the short thickness of cabinet out side panel and Metal inner liner heat resistance of these materials have been considered negligible.

Therefore:

$$1- Q_{\text{SideWalls}} = [U A (T_a - T_r)]$$

$T_a$  = Ambient Temperature 32

$T_r$  = refrigerator air Temperature -23

$U = 0.59 \text{ W/ sq.m } ^\circ\text{C}$

$A = 1.444 \text{ Sq. Mt.}, T_a = 32 ^\circ\text{C}, T_r = -23 ^\circ\text{C}$

therefore

$$Q_{\text{SideWalls}} = 0.59 \times 1.444 \times 55 = 48.9 \text{ Watts}$$

$$Q_{\text{SideWalls}} = 48.9 \text{ Watts}$$

$$2- Q_{\text{Top door}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ W/ sq.m } ^\circ\text{C}, T_a - T_r = 55, A = 0.572,$

$$Q_{\text{doors}} = 0.59 \times 0.572 \times 55 = \text{Watts } Q_{\text{doors}} = 18.6 \text{ Watts}$$

$$3- Q_{\text{Front Panel}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ w/sq. Mt. } ^\circ\text{C},$

$T_a - T_r = 55,$

$A = 1.1$

$$Q_{\text{Front Panel}} = 0.59 \times 1.1 \times 55 = 35.7 \text{ Watts}$$

$$Q_{\text{Front Panel}} = 35.7 \text{ Watts}$$

$$4 -Q_{\text{back panel}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ w/sq. Mt. } ^\circ\text{C},$

$T_a - T_r = , A = 1.1$

$$Q_{\text{back panel}} = 0.59 \times 1.1 \times 55 = 35.7 \text{ Watts}$$

$$Q_{\text{back panel}} = 35.7 \text{ Watts}$$

$$5 -Q_{\text{Bottom}} = [U A (T_a - T_r)]$$

$U = 0.59 \text{ w/sq. Mt. } ^\circ\text{C},$

$T_a - T_r = 65, A = 0.572$

$$Q_{\text{Bottom Surface}} = 0.59 \times 0.572 \times 65 = 22 \text{ Watt}$$

$$Q_{\text{Bottom Surface}} = 22 \text{ Watts}$$

$$\text{Total Refrigerator Heat Leak} = 48.9 + 35.7 + 18.6 + 35.7 + 22 = 158.8 \text{ W}$$



**Product Load**

A product placed in a refrigerator at a temperature higher than the storage temperature will lose heat until it reaches the storage temperature. The quantity of heat to be removed may be calculated from knowledge of the product, including its state upon entering the refrigerator, its final state, its weight, specific heat above and below freezing point, its freezing temperature and latent heat.

When a definite weight of product is cooled from one state and temperature to another state and temperature, some or all of the following calculations must be made:

Heat removal from initial temperature to some lower temperature above freezing.

$$Q = mc(T_1 - T_2)$$

Heat removal from initial temperature to freezing point of product.

$$Q = mc(T_1 - T_f)$$

Heat removal to freeze product.

$$Q = mh_{if}$$

Heat removal from freezing point to final temperature below freezing.

$$Q = mc(T_f - T_3)$$

Where

Q = heat removed, Kj

M = weight of product, kg

C = specific heat of product above freezing point, Kj/Kg. K

T<sub>1</sub> = initial temp. C

T<sub>2</sub> = lower temperature above freezing, C

T<sub>f</sub> = freezing temperature of product, C

H<sub>if</sub> = latent heat of fusion, kj per kg

Since this product is mainly used for storing fresh Lamb meet and beef above

freezing point at -23 C, we consider 30 Kg of meet to be stored in this Freezer therefore we calculate as follow,

$$Q_1 = mc(T_1 - T_2)$$

$$M = 30 \text{ kg}$$

$$C_{\text{Above Freezing}} = 3.2 \text{ Kj/kg K}$$

$$T_1 = 25 \text{ C}$$

$$T_2 = 0 \text{ C}$$

$$Q = 30000 \times 3.2 \times [25 - 0] = 2400000 \text{ jul} / 86400 = 28 \text{ Watt}$$

$$Q_2 = mc(T_1 - T_2)$$

$$M = 40 \text{ kg}$$

$$C_{\text{Below Freezing}} = 1.61 \text{ Kj}/(\text{kg. K})$$

$$T_1 = 0 \text{ C}$$

$$T_2 = -23 \text{ C}$$

$$Q = 30000 \times 1.61 \times [(0 - (-23))] = 1110900 \text{ jul} / 86400 = 12.8 \text{ Watt}$$

$$Q_3 = mh$$

$$Q_3 = 30000 \times 204 / 86400 = 71$$

$$Q_{\text{total for product loaded}} = 28 + 13 + 71 = 112$$

Internal Load

N/A

Door Opening

Refrigerator Internal Volume 400 lit.

Number of air change as per ASHREA standard = 70 per day

Heat removed per cubic meter of air 75000 j

$$\text{Air Change load} = 0.4 \times 20 \times 75000 / 86400 = 6.9$$

Watt

$$Q_{\text{Total}} = Q_{\text{heat leak}} + Q_{\text{product load}} + Q_{\text{internal load}} + Q_{\text{air change}}$$

$$Q_{\text{Total}} = 159 + 112 + 7 = 278 \text{ Watts}$$

Considering 10 % of Q total for safety factor

$$\text{Cooling Capacity Required} = Q_{\text{Grand Total}} = 278 + 10\%(81) = 306 \text{ watts}$$

### Load Calculation for Water Cooler Al- Mansour Workshop

$Q1 = m C \Delta T$ , Where:

**Q1** Total heat removed from total drinking water tank volume capacity (lit.) during specific period, related to compressor cooling capacity power in Watts, at initial compressor start up, and early in the morning. When the water temperature is 28 C.

**m** total weight of original water in the water cooler storage tank in Kg. Considering that one litter of water at 25 C is equal to approximately one Kg.

Tank Volume = 30 lit

$$M = 30 \text{ liter} = 30 \text{ Kg.}$$

**C** Specific heat factor of water in Kcal/Kg °C = 1

**ΔT** Temperature difference (Ti-Tc), where, Ti is inlet water temperature, and Tc is final cooled water.

$$Ti = 28 \text{ °C and } Tc = 7 \text{ °C}$$

$$Ti - Tc = 28 - 7 = 21 \text{ °C}$$

$$Q1 = m C \Delta T = 30 \times 1 \times 21 = 630 \text{ Kcal} = 630 \times 1.163 = 733 \text{ Watts/24 hrs}$$

$$Q1 = 733 / 24 \text{ water cooler operating time per day} = 30.54 \text{ Watts}$$

$$Q1 = 30.54 \text{ Watts}$$

$$Q2 = \dot{M} C \Delta T$$

**Q2** Total heat removed from total drinking water flow (lit.) during specific period, 16 hours. In Kcal.

**$\dot{M}$**  total weight of water flow during 16 hours. in Kg. = H x N x M where:

H = Total Water Cooler Usage Time (Hours) = 16

N = Number of Glass of Drinking Water per Hour = 20

M = Kg weight of water in one Glass of Water = 0.2 Kg

$$\dot{M} = (16 \times 20 \times 0.2) = \text{lit.} + 20\% \text{ Waste Water} = 77$$

C Specific heat factor of water in Kcal/Kg °C = 1

$\Delta T$  Temperature d( $T_i - T_c$ ), where,  $T_i$  is inlet water temperature, and  $T_c$  is final cooled water temperature.

$$T_i = 28 \text{ °C and } T_c = 7 \text{ °C}$$

$$T_i - T_c = 28 - 7 = 21 \text{ °C}$$

$$Q_2 = m C \Delta T = 77 \times 1 \times 21 = 1617 \text{ Kcal} = 1617 \times 1.163 = 1880 \text{ Watts/16 hrs}$$

$$Q_2 = 1880/12 \text{ compressor operating time per day} = 156 \text{ Watts}$$

$$\underline{Q_2 = 156 \text{ Watts}}$$

$Q_3 = UA \Delta T$ , Where:

$Q_3$  Total Leak, gained through side wall of drinking water storage tank by conduction in Kcal..

U Heat Resistance Coefficient Factor in Kcal/Sq. mt. C

K = 0.0178 W/mt.K

$$U = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}} = 0.40$$

$$h_i = h_o = 9.37 \text{ W/m}^2 \cdot \text{K}$$

A Total Area which heat is transmitted by. In Sq. Mt.

$$A = [(3.14 \times 0.3 \times 0.3) / 4] \times 0.45 = 0.32 \text{ Sq.mt.}$$

$\Delta T$  Temperature difference ( $T_a - T_c$ ), where,  $T_a$  is ambient temperature, and  $T_c$  is final cooled water temperature.

$$T_a = 32 \text{ °C and } T_c = 7 \text{ °C}$$

$$T_a - T_c = 32 - 7 = 25 \text{ °C}$$

$$Q_3 = (UA_1 \Delta T) + (UA_2 \Delta T) = (0.40 \times 0.32 \times 25) = 0.32 \text{ Watts}$$

$$\underline{Q_3 = 0.32 \text{ Watts}}$$

$$Q_t = Q_1 + Q_2 + Q_3 = 30.54 + 156 + 0.32 = 186 + 10\% \text{ safety factor} =$$

$$\underline{205.5 \text{ Watts}}$$

## Load Calculation for Water Cooler Al- Raed Workshop

$Q1 = m C \Delta T$ , Where:

**Q1** Total heat removed from total drinking water tank volume capacity (lit.) during specific period, related to compressor cooling capacity power in Watts, at initial compressor start up, and early in the morning. When the water temperature is 28 C.

**m** total weight of original water in the water cooler storage tank in Kg. Considering that one litter of water at 25 C is equal to approximately one Kg.

Tank Volume = 30 lit

$$M = 30 \text{ liter} = 30 \text{ Kg.}$$

**C** Specific heat factor of water in Kcal/Kg °C = 1

**$\Delta T$**  Temperature difference ( $T_i - T_c$ ), where,  $T_i$  is inlet water temperature, and  $T_c$  is final cooled water.

$$T_i = 28 \text{ }^\circ\text{C} \text{ and } T_c = 7 \text{ }^\circ\text{C}$$

$$T_i - T_c = 28 - 7 = 21 \text{ }^\circ\text{C}$$

$$Q1 = m C \Delta T = 30 \times 1 \times 21 = 630 \text{ Kcal} = 630 \times 1.163 = 733 \text{ Watts/24 hrs}$$

$$Q1 = 733 / 24 \text{ water cooler operating time per day} = 30.54 \text{ Watts}$$

$$Q1 = 30.54 \text{ Watts}$$

$$Q2 = \dot{M} C \Delta T$$

**Q2** Total heat removed from total drinking water flow (lit.) during specific period, 16 hours. In Kcal.

**$\dot{M}$**  total weight of water flow during 16 hours. in Kg. =  $H \times N \times M$  where:  
**H** = Total Water Cooler Usage Time (Hours) = 16

N = Number of Glass of Drinking Water per Hour = 20

M = Kg weight of water in one Glass of Water = 0.2 Kg

$\dot{M} = (16 \times 20 \times 0.2) = \text{lit.} + 20\% \text{ Waste Water} = 77$

C Specific heat factor of water in Kcal/Kg °C = 1

$\Delta T$  Temperature d( $T_i - T_c$ ), where,  $T_i$  is inlet water temperature, and  $T_c$  is final cooled water temperature.

$T_i = 28 \text{ }^\circ\text{C}$  and  $T_c = 7 \text{ }^\circ\text{C}$

$T_i - T_c = 28 - 7 = 21 \text{ }^\circ\text{C}$

$Q_2 = m C \Delta T = 77 \times 1 \times 21 = 1617 \text{ Kcal} = 1617 \times 1.163 = 1880 \text{ Watts}/16 \text{ hrs}$

$Q_2 = 1880/12 \text{ compressor operating time per day} = 156 \text{ Watts}$

**$Q_2 = 156 \text{ Watts}$**

$Q_3 = UA \Delta T$ , Where:

**Q3** Total Leak, gained through side wall of drinking water storage tank by conduction in Kcal..

**U** Heat Resistance Coefficient Factor in Kcal/Sq. mt. C

**K** = 0.0178 W/mt.K

$$U = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}} = 0.40$$

$h_i = h_o = 9.37 \text{ W/m}^2 \cdot \text{K}$

**A** Total Area which heat is transmitted by. In Sq. Mt.

$A = [(3.14 \times 0.3 \times 0.3)/4] \times 0.45 = 0.32 \text{ Sq.mt.}$

$\Delta T$  Temperature difference ( $T_a - T_c$ ), where,  $T_a$  is ambient temperature, and  $T_c$  is final cooled water temperature.

$T_a = 32 \text{ }^\circ\text{C}$  and  $T_c = 7 \text{ }^\circ\text{C}$

$T_a - T_c = 32 - 7 = 25 \text{ }^\circ\text{C}$

$Q_3 = (U A_1 \Delta T) + (U A_2 \Delta T) = (0.40 \times 0.32 \times 25) = 0.32 \text{ Watts}$

**$Q_3 = 0.32 \text{ Watts}$**

**$Q_t = Q_1 + Q_2 + Q_3 = 30.54 + 156 + 0.32 = 186 + 10\% \text{ safety factor} = 205.5 \text{ Watts}$**

### Load Calculation for Water Cooler Al-Ostath Workshop

$Q1 = m C \Delta T$ , Where:

**Q1** Total heat removed from total drinking water tank volume capacity (lit.) during specific period, related to compressor cooling capacity power in Watts, at initial compressor start up, and early in the morning. When the water temperature is 28 C.

**m** total weight of original water in the water cooler storage tank in Kg. Considering that one litter of water at 25 C is equal to approximately one Kg.

Tank Volume = 20 lit

$$M = 20 \text{ liter} = 20 \text{ Kg.}$$

**C** Specific heat factor of water in Kcal/Kg °C = 1

**ΔT** Temperature difference (Ti-Tc), where, Ti is inlet water temperature, and Tc is final cooled water.

$$Ti = 28 \text{ °C and } Tc = 7 \text{ °C}$$

$$Ti - Tc = 28 - 7 = 21 \text{ °C}$$

$$Q1 = m C \Delta T = 20 \times 1 \times 21 = 410 \text{ Kcal} = 410 \times 1.163 = 477 \text{ Watts/24 hrs}$$

$$Q1 = 477 / 24 \text{ water cooler operating time per day} = 20 \text{ Watts}$$

$$Q1 = 20 \text{ Watts}$$

$$Q2 = \dot{M} C \Delta T$$

**Q2** Total heat removed from total drinking water flow (lit.) during specific period, 16 hours. In Kcal.

**$\dot{M}$**  total weight of water flow during 16 hours. in Kg. = H x N x M where:

H = Total Water Cooler Usage Time (Hours) = 16

N = Number of Glass of Drinking Water per Hour = 20

M = Kg weight of water in one Glass of Water = 0.2 Kg

$\dot{M} = (16 \times 20 \times 0.2) = \text{lit.} + 20\% \text{ Waste Water} = 77$

C Specific heat factor of water in Kcal/Kg °C = 1

$\Delta T$  Temperature d( $T_i - T_c$ ), where,  $T_i$  is inlet water temperature, and  $T_c$  is final cooled water temperature.

$$T_i = 28 \text{ }^\circ\text{C} \text{ and } T_c = 7 \text{ }^\circ\text{C}$$

$$T_i - T_c = 28 - 7 = 21 \text{ }^\circ\text{C}$$

$$Q_2 = m C \Delta T = 77 \times 1 \times 21 = 1617 \text{ Kcal} = 1617 \times 1.163 = 1880 \text{ Watts/16 hrs}$$

$$Q_2 = 1880/12 \text{ compressor operating time per day} = 156 \text{ Watts}$$

$$\underline{Q_2 = 156 \text{ Watts}}$$

$Q_3 = UA \Delta T$ , Where:

$Q_3$  Total Leak, gained through side wall of drinking water storage tank by conduction in Kcal..

U Heat Resistance Coefficient Factor in Kcal/Sq. mt. C

K = 0.0178 W/mt.K

$$U = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}} = 0.40$$

$$h_i = h_o = 9.37 \text{ W/m}^2 \cdot \text{K}$$

A Total Area which heat is transmitted by. In Sq. Mt.

$$A = [(3.14 \times 0.3 \times 0.3)/4] \times 0.45 = 0.32 \text{ Sq.mt.}$$

$\Delta T$  Temperature difference ( $T_a - T_c$ ), where,  $T_a$  is ambient temperature, and  $T_c$  is final cooled water temperature.

$$T_a = 32 \text{ }^\circ\text{C} \text{ and } T_c = 7 \text{ }^\circ\text{C}$$

$$T_a - T_c = 32 - 7 = 25 \text{ }^\circ\text{C}$$

$$Q_3 = (U A_1 \Delta T) + (U A_2 \Delta T) = (0.40 \times 0.32 \times 25) = 0.32 \text{ Watts}$$

$$\underline{Q_3 = 0.32 \text{ Watts}}$$

$$Q_t = Q_1 + Q_2 + Q_3 = 20 + 156 + 0.32 = 176.32 + 10\% \text{ safety factor} = 194 \text{ Watts}$$



**Product Technical Specification**  
**Al-Mansour Workshop**

<b>Description</b>	<b>Specification</b>
Company Name	Al-Mansour Workshop
Product Name	Water Cooler
Product Model	ST100
Product Application	Water Cooler
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	65*44*139 cm
Freezer Compartment Overall Dimension and Wall Thickness	N/A
Refrigerator Compartment Overall Dimension and Wall Thickness	N/A
Product Shape, Double Doors, Upright, Chest, etc	Stand
Freezer Internal Net Volume	N/A
Refrigerator Net Volume	N/A
Product Net Volume	N/A
Product Inside Temperature C	+ 7 C
Water Storage Tank Capacity, Water Cooler	35 Liters
Type of Water Storage Tank Cylinder, Cubic, etc.	Cylindrical
Water Fellow per hour for water cooler	80 Liters/H
Water Storage Tank Dimension	40*30 cm
Water Outlet Temperature	+7 C
Water Inlet Temperature	+28 C
Freezer Inside Temperature	N/A
Refrigerator Inside Temperature	N/A
Evaporating Temperature	-23 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	40 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Total amount of Foam Injection, Kg	6 Kg
Refrigerant Type	R 12
Refrigerant Charge Weight Gr.	250 Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic

Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity Watt	250 Watts
Compressor input Power, Watt	¼ Hp, 184 Watts
Compressor Model Number	
Compressor Manufacturer	Tecumseh
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	Two Rows , 5/16 inch
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper and Aluminum
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Copper Tubes Surrounding the Tank
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	15 m. Length
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Ranco
Dryer Material, Weight and Size	Silica, Cylindrical, 15 Gr.
Capillary Tube Diameter and Length	1 mm , 1800 mm length

**Product Technical Specification**

**Ma-nna Workshop**

<b>Description</b>	<b>Specification</b>
Company Name	Ma-nna Workshop
Product Name	Chest Freezer,
Product Model	KH-300
Product Application	Freezer
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	140x64x85
Freezer Compartment Overall Dimension and Wall Thickness	N/A
Refrigerator Compartment Overall Dimension and Wall Thickness	50 mm
Product Shape, Double Doors, Upright, Chest, etc	Chest Freezer
Freezer Internal Net Volume	600 liter
Refrigerator Net Volume	N/A
Product Net Volume	650 liter
Product Inside Temperature C	- 18 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Fellow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	N/A
Refrigerator Inside Temperature	N/A
Evaporating Temperature	- 23.3 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	50 mm
Type of PU Foam	R11 PU Foam
Foam Density, Kg/Cu. Mt.	40 Kg/ Cu Cm
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%

Total amount of Foam Injection, Kg	15 Kg.
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	500 gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity Watt	400Watts
Compressor input Power, Watt	450 Watts
Compressor Model Number	L88 TX
Compressor Manufacturer	Electrelux
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	Four Rows Tube Coil, and Fins
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Tube
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	Tube Coils 40 mt.
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Cylindrical
Dryer Material, Weight and Size	Ranco, 30 gr.
Capillary Tube Diameter and Length	0.8 mm Dim, 3000 mm Length

**Product Technical Specification**

**Al-Ostath Workshop**

<b>Description</b>	<b>Specification</b>
Company Name	Al-Ostath Workshop
Product Name	Water Cooler
Product Model	OS-WC75
Product Application	Water Cooler
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	35*35*95 cm
Freezer Compartment Overall Dimension and Wall Thickness	N/A
Refrigerator Compartment Overall Dimension and Wall Thickness	N/A
Product Shape, Double Doors, Upright, Chest, etc	Stand, Two water Tabs
Freezer Internal Net Volume	N/A
Refrigerator Net Volume	N/A
Product Net Volume	N/A
Product Inside Temperature C	+ 7 C
Water Storage Tank Capacity, Water Cooler	8 Litters
Type of Water Storage Tank Cylinder, Cubic, etc.	Cylindrical
Water Fellow per hour for water cooler	60 Litters/H
Water Storage Tank Dimension	21*32 cm
Water Outlet Temperature	+7 C
Water Inlet Temperature	+28 C
Freezer Inside Temperature	N/A
Refrigerator Inside Temperature	N/A
Evaporating Temperature	-23 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	40 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Total amount of Foam Injection, Kg	4.5 Kg
Refrigerant Type	R 12

Refrigerant Charge Weight Gr.	240 Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity Watt	250 Watts
Compressor input Power, Watt	¼ Hp, 184 Watts
Compressor Model Number	L88 FW
Compressor Manufacturer	Electrelux
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	Two Rows , 5/16 inch
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper and Aluminum
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, . Fin and Tube, Roll Bond, Wire and Tube, etc.	Copper Tubes Surrounding the Tank
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	15 m. Length
Evaporator Material, . Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Ranco
Dryer Material, Weight and Size	Silica, Cylindrical, 15 Gr.
Capillary Tube Diameter and Length	1 mm , 1800 mm length

**Product Technical Specification**  
**Abdullah Factory for Air-cond & Refrigeration**

<b>Description</b>	<b>Specification</b>
Company Name	Abdullah Factory for air-cond. & ref.
Product Name	Water Cooler
Product Model	Abd.50
Product Application	Water Cooler
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	43*76*127 cm
Freezer Compartment Overall Dimension and Wall Thickness	N/A
Refrigerator Compartment Overall Dimension and Wall Thickness	N/A
Product Shape, Double Doors, Upright, Chest, etc	Stand
Freezer Internal Net Volume	N/A
Refrigerator Net Volume	N/A
Product Net Volume	N/A
Product Inside Temperature C	+7 C
Water Storage Tank Capacity, Water Cooler	25 Liters
Type of Water Storage Tank Cylinder, Cubic, etc.	Cylindrical
Water Fellow per hour for water cooler	100 Liters
Water Storage Tank Dimension	80*35 cm
Water Outlet Temperature	+7 C
Water Inlet Temperature	+28 C
Freezer Inside Temperature	N/A
Refrigerator Inside Temperature	N/A
Evaporating Temperature	-23 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	40 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Total amount of Foam Injection, Kg	8 Kg
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	250 Gr.

Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity Watt	250 Watts
Compressor input Power, Watt	¼ Hp, 184 Watts
Compressor Model Number	FR8.5B
Compressor Manufacturer	Danfoss
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	Two Rows, 5/16 Inch
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper and Aluminum Fins
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Tubes Surrounding the Tank
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	15 M. Copper Tubes
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Ranco
Dryer Material, Weight and Size	Silica, 15 Gr. Cylindrical
Capillary Tube Diameter and Length	1.5 mm dim, 3000 length



**Product Technical Specification**

**Emad Addin Al-Sareegy Est.**

<b>Description</b>	<b>Specification</b>
Company Name	Emad Addin Al-Sareegy Est.
Product Name	One Door Refrigerator
Product Model	EMD 100
Product Application	Food Storage
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	800*700*2300 mm.
Freezer Compartment Overall Dimension and Wall Thickness	N/A
Refrigerator Compartment Overall Dimension and Wall Thickness	40 mm
Product Shape, Double Doors, Upright, Chest, etc	Upright with one Door
Freezer Internal Net Volume	N/A
Refrigerator Net Volume	1148 Lit.
Product Net Volume	600 Lit.
Product Inside Temperature C	+5 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Fellow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	N/A
Refrigerator Inside Temperature	+5 C
Evaporating Temperature	-10 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	40 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% +13% + 50%
Total amount of Foam Injection, Kg	17 Kg
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	400 Gr.


Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity Watt	450 Gr.
Compressor input Power, Watt	400
Compressor Model Number	SC10B
Compressor Manufacturer	Danfoss
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	3 Rows Tube Coils and Fins
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Top
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Fin and Tube
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Cylindrical
Dryer Material, Weight and Size	20 Gr
Capillary Tube Diameter and Length	1 mm 2500 mm

**Product Technical Specification**

**Raed Workshop**

<b>Description</b>	<b>Specification</b>
Company Name	Raed Workshop
Product Name	Water Cooler
Product Model	Raed 50
Product Application	Water Cooler
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	
Freezer Compartment Overall Dimension and Wall Thickness	N/A
Refrigerator Compartment Overall Dimension and Wall Thickness	60*40*90 Cm
Product Shape, Double Doors, Upright, Chest, etc	
Freezer Internal Net Volume	N/A
Refrigerator Net Volume	60 Liters
Product Net Volume	315 Liters
Product Inside Temperature C	18
Water Storage Tank Capacity, Water Cooler	60 Liters
Type of Water Storage Tank Cylinder, Cubic, etc.	Cubic
Water Flow per hour for water cooler	60 Lit/H
Water Storage Tank Dimension	60 Liters
Water Outlet Temperature	18 C
Water Inlet Temperature	25 C
Freezer Inside Temperature	N/A
Refrigerator Inside Temperature	18 C
Evaporating Temperature	-10 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	40 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Total amount of Foam Injection, Kg	6 Kg
Refrigerant Type	R 12
Refrigerant Charge Weight Gr.	250 Gr.

Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity Watt	200 Watt
Compressor input Power, Watt	180 Watt
Compressor Model Number	SC8.5b
Compressor Manufacturer	Danfoss
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	2 Rows
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Roll Tube
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper Coated
Dryer Type,	Cylindrical
Dryer Material, Weight and Size	10 Gr.
Capillary Tube Diameter and Length	0.7 mm diameter 2500 mm length



**TestDate:** 02/01/16 11:57  
**TestName:** Energy Consumption

**Report No.:** Spec & Remark  
**ReportDate:** 2002/02/15 15:08

### Total Result :

1 - Total Test Time	96 Hours
2 - Working Percent	22 %On
3 - Energy	0.766 kwh
4 - Zoom Time	96:34 Hour
5 - Compr Current	00 Amp
6 - Evaprator Mean Temp	33.4 C
7 - Cabin Mean Temp	15.1 C
8 - Crisp Temp	12.9 C
9 - Compr Temp	51.7 C
10- Condensor In Temp	54 C
11- Condensor Out Temp	2.2 C
12- Condition	42.6 C 35 %H
13- Volt	Max=221 Mean=221 Min=221
14-	
15-	
16-	
17-	

### Product Spec :

1 - File Name	02011611.k57
2 - Test Kind	G Performanc
3 - Product Serial	
4 - Product Name	Water Cool
5 - Product Model	ST-100
6 - Product Capacity	100 LIT/h.
7 - Compressor Name	Electrolux
8 - Compressor Model	GL 90 AN
9 - Compressor Power	1/4
10- Compressor Amper	2
11- Thermostat No.	3
12- Thermostat Type	Ranco
13-	
14-	

**Technical Manager:** ICRC  
**Lab Chief :** MARIO AL-DEEK  
**Lab Specialist:** ZIAD

### Remark :

Remark1  
Remark2  
Remark3

**Remark :**

sign :



TestDate: 02/01/16 11:57


Report No.: ( ) - Page 1

PageTestName: Energy Consumption


ReportDate: 2002/02/15 15:08


**Page Result :**

- 1 - Page Test Time            96 Hours
- 2 - Working Percent         22 %On
- 3 - Energy (Accord to page) 0.766 kwh
- 4 - Zoom Time                96:34 Hour
- 5 - Compr Current            00 Amp
- 6 - Evaprator Mean Temp    33.4 C
- 7 - Cabin Mean Temp         15.1 C
- 8 - Crisp Temp               12.9 C
- 9 - Compr Temp              51.7 C
- 10- Condensor In Temp      54 C
- 11- Condensor Out Temp    2.2 C
- 12- Condition                42.6 C 35 %H
- 13- Volt    Max=221 Mean=221 Min=221
- 14-
- 15-
- 16-
- 17-



Industrial Control Research Center HotRoom Ver 5





TestDate: 02/01/16 11:57


Report No.: ( ) - Page 1

PageTestName: Energy Consumption


ReportDate: 2002/02/15 15:09

**Page Result :**

- 1 - Page Test Time            20 Hours
- 2 - Working Percent         17 %On
- 3 - Energy (Accord to page) 0.594 kwh
- 4 - Zoom Time                12:56 Hour
- 5 - Compr Current           0.11 Amp
- 6 - Evaprator Mean Temp   21.6 C
- 7 - Cabin Mean Temp        10.8 C
- 8 - Crisp Temp              9.1 C
- 9 - Compr Temp              38.1 C
- 10- Condensor In Temp     35.1 C
- 11- Condensor Out Temp    14.2 C
- 12- Condition                27.1 C 36 %H
- 13- Volt    Max=221 Mean=221 Min=221
- 14-
- 15-
- 16-
- 17-



Industrial Control Research Center HotRoom Ver 5





TestDate: 02/01/16 11:57


Report No.: ( ) - Page 1

PageTestName: Energy Consumption


ReportDate: 2002/02/15 15:12

### Page Result :

- 1 - Page Test Time            **10 Hours**
- 2 - Working Percent         **17 %On**
- 3 - Energy (Accord to page) **0.553 kwh**
- 4 - Zoom Time                **21:53 Hour**
- 5 - Compr Current           **00 Amp**
- 6 - Evaprator Mean Temp    **21 C**
- 7 - Cabin Mean Temp        **10.7 C**
- 8 - Crisp Temp              **9 C**
- 9 - Compr Temp              **37.8 C**
- 10- Condensor In Temp      **28.4 C**
- 11- Condensor Out Temp     **17.6 C**
- 12- Condition               **26.3 C 36 %H**
- 13- Volt    **Max=221 Mean=221 Min=221**
- 14-
- 15-
- 16-
- 17-



21:52







**TestDate:** 01/11/15 10:38  
**TestName:** Energy Consumption

**Report No.:** Spec & Remark  
**ReportDate:** 2002/02/15 15:28

### Total Result :

1 - Total Test Time	77 Hours
2 - Working Percent	58 %On
3 - Energy	1.538 kwh
4 - Zoom Time	76:00 Hour
5 - Compr Current	1.96 Amp
6 - Evaprator Mean Temp	.1 C
7 - Cabin Mean Temp	-10.2 C
8 - Crisp Temp	-12.1 C
9 - Compr Temp	60.5 C
10- Condensor In Temp	61.1 C
11- Condensor Out Temp	-3.7 C
12- Condition	43.2 C 35 %H
13- Volt	Max=221 Mean=221 Min=221
14-	
15-	
16-	
17-	

### Product Spec :

1 - File Name	01111510.k38
2 - Test Kind	G Perform.
3 - Product Serial	
4 - Product Name	Meat Ref.
5 - Product Model	EM-310
6 - Product Capacity	700 Lit.
7 - Compressor Name	Electrolux
8 - Compressor Model	GP12 FB
9 - Compressor Power	1/3 Hp
10- Compressor Amper	3 Amp
11- Thermostat No.	3
12- Thermostat Type	Ranco
13-	
14-	

**Technical Manager:** ICRC  
**Lab Chief :** MARIO AL-DEEK  
**Lab Specialist:** ZIAD

### Remark :

Remark1
Remark2
Remark3

### Remark :

sign :



TestDate: 01/11/15 10:38


Report No.: ( ) - Page 1

PageTestName: Energy Consumption


ReportDate: 2002/02/15 15:28

**Page Result :**

- 1 - Page Test Time 77 Hours
- 2 - Working Percent 58 %On
- 3 - Energy (Accord to page) 1.538 kwh
- 4 - Zoom Time 76:00 Hour
- 5 - Compr Current 1.96 Amp
- 6 - Evaprator Mean Temp .1 C
- 7 - Cabin Mean Temp -10.2 C
- 8 - Crisp Temp -12.1 C
- 9 - Compr Temp 60.5 C
- 10- Condensor In Temp 61.1 C
- 11- Condensor Out Temp -3.7 C
- 12- Condition 43.2 C 35 %H
- 13- Volt Max=221 Mean=221 Min=221
- 14-
- 15-
- 16-
- 17-



Industrial Control Research Center HoRoom Ver 5





TestDate: 01/11/15 10:38


Report No.: ( ) - Page 1

PageTestName: Energy Consumption


ReportDate: 2002/02/15 15:30

### Page Result :

- 1 - Page Test Time 10 Hours
- 2 - Working Percent 50 %On
- 3 - Energy (Accord to page) 1.323 kwh
- 4 - Zoom Time 5:35 Hour
- 5 - Compr Current 1.89 Amp
- 6 - Evaprator Mean Temp 1 C
- 7 - Cabin Mean Temp -12.5 C
- 8 - Crisp Temp -14.4 C
- 9 - Compr Temp 41.3 C
- 10- Condensor In Temp 46 C
- 11- Condensor Out Temp 20.8 C
- 12- Condition 28.4 C 35 %H
- 13- Volt Max=221 Mean=221 Min=221
- 14-
- 15-
- 16-
- 17-



Industrial Control Research Center HotRoom Ver 5





TestDate: 01/11/15 10:38


Report No.: ( ) - Page 1

PageTestName: Energy Consumption


ReportDate: 2002/02/15 15:31

**Page Result :**

- 1 - Page Test Time 20 Hours
- 2 - Working Percent 48 %On
- 3 - Energy (Accord to page) 1.316 kwh
- 4 - Zoom Time 21:41 Hour
- 5 - Compr Current 1.91 Amp
- 6 - Evaprator Mean Temp 1.2 C
- 7 - Cabin Mean Temp -11.7 C
- 8 - Crisp Temp -13.8 C
- 9 - Compr Temp 42.2 C
- 10- Condensor In Temp 46.2 C
- 11- Condensor Out Temp 21.6 C
- 12- Condition 28.7 C 35 %H
- 13- Volt Max=221 Mean=221 Min=221
- 14-
- 15-
- 16-
- 17-



Industrial Control Research Center HotRoom Ver 5





**TestDate:** 01/11/15 10:38  
**TestName:** Energy Consumption

**Report No.:** Spec & Remark  
**ReportDate:** 2002/02/15 15:33

### Total Result :

1 - Total Test Time	77 Hours
2 - Working Percent	84 %On
3 - Energy	0.927 kwh
4 - Zoom Time	76:00 Hour
5 - Compr Current	2.12 Amp
6 - Evaprator Mean Temp	-14.2 C
7 - Cabin Mean Temp	-14.9 C
8 - Crisp Temp	-14.2 C
9 - Compr Temp	73.8 C
10- Condensor In Temp	76.7 C
11- Condensor Out Temp	41.8 C
12- Condition	43.2 C 35 %H
13- Volt	Max=221 Mean=221 Min=221
14-	
15-	
16-	
17-	

### Product Spec :

1 - File Name	01111510.k38
2 - Test Kind	G Perform.
3 - Product Serial	
4 - Product Name	Chest Fre.
5 - Product Model	KH-310
6 - Product Capacity	500 Lit
7 - Compressor Name	Electrolux
8 - Compressor Model	GL90 AN
9 - Compressor Power	1/4 Hp
10- Compressor Amper	2
11- Thermostat No.	4
12- Thermostat Type	Ranco
13-	
14-	


**Technical Manager:** ICRC  
**Lab Chief :** MARIO AL-DEEK  
**Lab Specialist:** ZIAD

### Remark :

Remark1  
Remark2  
Remark3

### Remark :

sign :




TestDate: 01/11/15 10:38  
PageTestName: Energy Consumption


Report No.: ( ) - Page 1  
ReportDate: 2002/02/15 15:33


### Page Result :

- 1 - Page Test Time 77 Hours
- 2 - Working Percent 84 %On
- 3 - Energy (Accord to page) 0.927 kwh
- 4 - Zoom Time 76:00 Hour
- 5 - Compr Current 2.12 Amp
- 6 - Evaprator Mean Temp -14.2 C
- 7 - Cabin Mean Temp -14.9 C
- 8 - Crisp Temp -14.2 C
- 9 - Compr Temp 73.8 C
- 10- Condensor In Temp 76.7 C
- 11- Condensor Out Temp 41.8 C
- 12- Condition 43.2 C 35 %H
- 13- Volt Max=221 Mean=221 Min=221
- 14-
- 15-
- 16-
- 17-



Industrial Control Research Center HotRoom Ver 5





TestDate: 01/11/15 10:38


Report No.: ( ) - Page 1

PageTestName: Energy Consumption


ReportDate: 2002/02/15 15:33

### Page Result :

1 - Page Test Time	20 Hours
2 - Working Percent	77 %On
3 - Energy (Accord to page)	0.907 kwh
4 - Zoom Time	16:01 Hour
5 - Compr Current	0.11 Amp
6 - Evaprator Mean Temp	-18.2 C
7 - Cabin Mean Temp	-18.9 C
8 - Crisp Temp	-18.7 C
9 - Compr Temp	60.7 C
10- Condensor In Temp	48.1 C
11- Condensor Out Temp	35.4 C
12- Condition	27.2 C 35 %H
13- Volt	Max=221 Mean=221 Min=221
14-	
15-	
16-	
17-	



Industrial Control Research Center HoRoom Ver 5






TestDate: 01/11/15 10:38  
PageTestName: Energy Consumption

Report No.: ( ) - Page 1  
ReportDate: 2002/02/15 15:34

### Page Result :

- 1 - Page Test Time 10 Hours
- 2 - Working Percent 79 %On
- 3 - Energy (Accord to page) 0.924 kwh
- 4 - Zoom Time 4:41 Hour
- 5 - Compr Current 2.19 Amp
- 6 - Evaprator Mean Temp -18.1 C
- 7 - Cabin Mean Temp -19 C
- 8 - Crisp Temp -18.6 C
- 9 - Compr Temp 54.8 C
- 10- Condensor In Temp 57.4 C
- 11- Condensor Out Temp 28.1 C
- 12- Condition 28 C 35 %H
- 13- Volt Max=221 Mean=221 Min=221
- 14-
- 15-
- 16-
- 17-



Industrial Control Research Center HotRoom Ver 5

