



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as "developed", "industrialized" and "developing" are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

22688

SAHAND MINA ENGINEERING CO LTD.



*Conversion and Development of
Prototype from R12 to R134a Ozone
Friendly Refrigerant System at
Avaj Sarma, Donyae Mojdeh,
Gasso, Roshan
Companies*

PROJECT NUMBERS
MP/IRA/01/140, 141, 143, 145

Contract Number
01/297

Final Report

April 2002

Sahandmina Engineering Company Ltd.

Final Report

PROJECTS NO.

MP/IRA/01/140, 141, 143, 145

Contract Number 01/297

*Avaj Sarma, Gasso, Donyaye Mojdeh,
and Roshan Companies*

Introduction

We are delighted to submit to you herewith, our draft Final Report, concerning calculation and redesign of the prototypes that have been made the counterparts and they have been tested at counterparts hot chamber. These prototypes have been manufactured under our close engineering supervision and have been tested in accordance with appropriate ISO standard test procedure and relevant performance test characteristics for functionality and performance of the new Ozone friendly R134a refrigerant. Our preliminarily review of test results revealed that majorities of prototypes responded to the new R134a refrigerant functional behavior. The final assessment and evaluation of prototypes test results together with original copies of prototypes performance sheets will be submitted to you together with our final reports after UNIDO's approval of our this report and we hope that this

Sahandmina Engineering Company Ltd.

report could have satisfied the UNIDO in order to comply with our contract.

Synopsis

This report has been prepared based on the Contract between UNIDO and Sahandmina Engineering company.

This project will phase out the use of CFC-11 and CFC-12 in the production of Domestic/commercial refrigeration equipment at Avaj Sarma, Gasso, Donyaye Mojdeh, and Roshan Companies. CFC-11, which is used, as a foam-blown agent in the production of polyurethane foam will be replaced by HCFC-141b and CFC-12, which is used as the refrigerant in the cooling circuit of appliances, will be replaced by HFC-134a. The project includes the modification of all cooling equipment produced and the conversion of the production facilities. The model redesign element of the project includes testing, trial manufacture and reliability tests. The cost of converting foaming machines to use HCFC-141b will be covered by the counterpart organizations.

General Background

The objective of this project is to eliminate the use of CFC-11 and CFC-12 in the production of commercial and domestic refrigeration equipment at the Avaj Sarma, Gasso, Donyaye Mojdeh, and Roshan Companies, through conversion to the use of HFC-134a refrigerant for the cooling system and HCFC-141b as blowing agent for the polyurethane insulation foam.

The same operating parameters and the same quality level is guaranteed on completion of the conversion process, but no increase in production capacity will be brought about by the project. The company involved is aware of the financial limitations of the funding process and is prepared to use its own funds to share some of the cost of the conversion process.

SECTOR BACKGROUND

Sahandmina Engineering Company Ltd.

The Islamic Republic of Iran ratified the Montreal Protocol in March 1990. Subsequently, Iran's Country Programme has outlined a plan for the reduction of the domestic use of ODS by 75% before 1999, and aims to be ODS free by 2005.

Based on the data provided by the Ozone Layer Protection Center/Department of Environment of Iran, the Refrigeration Sector in Iran is estimated to comprise of about 300 enterprises. The annual ODS consumption in the domestic and commercial refrigeration sectors is reported to be about 2,500 ODP MT as of 1998, representing the bulk of the overall ODS consumption in Iran. The domestic and commercial refrigeration sub-sector each contributes about 50% of the total ODS consumption in this sector. The average growth rate in this sector has been about 6.5% annually.

In the domestic refrigeration sub-sector, there are about 10 large manufacturers and about 15 medium-sized manufacturers, with a combined production of about 2 million units. In the commercial refrigeration sub-sector, there are about 30 relatively large-sized enterprises, and the remaining (estimated to be about 300) are small and medium sized. Due to the relatively unsophisticated technology and practices prevailing in the small and medium enterprises, and being unorganized, they will present a challenge to reach out to for purposes of participation in the Montreal Protocol programme for ODS phase-out.

There are two indigenous manufacturers of hermetic refrigeration compressors in Iran, which produce compressors suitable for domestic refrigeration appliances using CFC-12 technology. Their combined production is estimated to be about 800,000 units, which meets only a part of the domestic demand, the balance being imported. The hermetic and semi-hermetic compressors required by the commercial refrigeration sub-sector are predominantly imported.

Sahandmina Engineering Company Ltd.

The Ozone Layer Protection Center/Department of Environment is leading the efforts for ODS phase-out under the Montreal Protocol, in co-operation with the consuming and supplying industry and with the assistance of the implementing agencies. Complete ODS phase-out is targeted for 2005 except essential uses. The Refrigeration Sector has been identified as a priority sector for ODS phase-out.

In terms of technology and equipment employed the commercial refrigeration sector is very similar to the domestic appliance sector. The primary differences are in the scale of equipment used, which is bigger in commercial applications, and the variety of products which are manufactured. Most companies manufacture several types of equipment from a wide ranges of applications, including the following:

- display and sales cabinets for supermarkets and individual suppliers of food,
- upright and chest freezers for commercial application,
- different sizes of drinking water coolers,
- blood cooling cabinets,
- milk coolers, water coolers,
- soft ice freezers,
- cooling chambers, cooling stores
- insulated panels for larger cold stores,
- window-type air conditioners and fan coil,
- refrigeration equipment for trucks

In common with the domestic refrigeration sub-sector ozone depleting substances are consumed in commercial applications for:

- Charging of new appliances with CFC-12, R-502 and R-22
- Refilling/topping up of appliances with CFC-12, R-502 and R-22 after repair work

Sahandmina Engineering Company Ltd.

Insulation foam blowing using CFC-11

Counterpart Data

The baseline data for the company covered by this project contains:

- baseline production data
- baseline ODS consumption data
- baseline production equipment data

The Avaj Sarma, Gasso, Donyaye Mojdeh, and Roshan Companies, are manufacturers of commercial and domestic refrigerators and freezers. These enterprises are 100% indigenously owned by the same group people and report no exports and being financially sound.

PROJECT SUMMARY

The companies have recognized the need to comply with the Montreal Protocol and have agreed to participate in Iran's ODS phase-out programme. The company is committed to phase out CFCs by converting their foaming equipment to HCFC-141b and adopting HFC-134a as refrigerant. This project document describes the activities needed to carry out the phase out process. The conversion technology and expertise will be acquired from equipment, component and chemical suppliers and external foam and refrigeration experts. The impact on the plant/process due to the use of HCFC-141b as the blowing agent and HFC-134a as the refrigerant, would need to be addressed by implementing plant modifications and through the introduction of new equipment, components and processes, as below:

Refrigeration operation

Sahandmina Engineering Company Ltd.

The conversion to HFC-134a as the replacement for CFC-12 will involve the following changes:

- Compressors suitable for HFC-134a will be required. These will be available from existing suppliers.
- The chemical stability of HFC-134a and of the synthetic lubricants compatible with HFC-134a are highly sensitive to moisture and impurities in the system, as compared to CFC-12 system. The evacuation/charging process for HFC-134a and polyol-ester lubricant will need to ensure the required level of cleanliness and dryness in the system. To ensure this the following is proposed:
 - The vacuum pumps will need to be suitable for use with HFC134a of the existing vacuum pumps, are replaced.
 - The existing refrigerant charging units are not suitable for use with HFC - 134a and cannot be retrofitted, and will therefore be replaced with two charging units suitable for HFC-134a duty.

The design/sizing of the refrigeration system will need to be suitably changed, to ensure the viability of the process and to maintain the product standards for performance, such as:

1. Up sizing the condensers and re engineering evaporators and condensers, so as to ensure the levels of cleanliness and contamination that can be tolerated with HFC-134a

Sahandmina Engineering Company Ltd.

2. Lengthening of the capillary tubes.
3. Use of filter-dryers with finer pores, suitable for use with HFC-134a
4. The existing leak detectors are suitable for detecting CFC-12 only and will therefore need to be replaced with leak detectors suitable for detecting HFC-134a.
5. Provision for technical assistance from external international refrigeration experts and also from compressor suppliers will be required to be made to ensure smooth transition to the new technology and the successful implementation of the project.
6. In-house and field trials on prototypes of each model will be needed to be carried out, to establish performance and reliability with the HFC-134a based refrigeration systems.
7. The system dryness/cleanliness with the use of HFC-134a being of crucial nature, careful re-assessment of the production program, re-training/orientation of the staff for the new technology would be required.

Aim of the Project

The aim of the immediate project is to;

- Design, calculation for model redefinition.
- Testing prototypes for functionality and performance criteria.
- Redesign the cooling units of the all models so that they could run on the new Ozone friendly R134a instead of the ODP active CFC12.

Sahandmina Engineering Company Ltd.

Scope of the Contract

A study will be made for 8 models of commercial refrigerators made by Avaj Sarma, Gasso, Donyaye Mojdeh, and Roshan Companies to specify;

- Dimensional specification;
- Type and thickness of insulation
- Refrigeration unit component details
- Working performance
- Energy consumption

Selection of HFC 134a compatible components
Redesign of the refrigeration circuit as necessary
Specifying necessary changes in the cooling system if required

Preparation of the trial equipment one prototype per model
Testing of two prototypes for functionality and performance
Evaluation of the test results

Supply of the Material

Following components and material have been used to make prototypes .

- R134a Compressors
- R134a Refrigerant
- Refrigerant Accumulators
- Specially designed filter drier
- Specially designed evaporator and condenser

Activities

The activities for implementation of this contract could be summarized as below.

Sahandmina Engineering Company Ltd.

- Site survey of the counterpart premises in order to be familiar with the counterpart facility and production line and also define the prototypes for conversion.
- Site survey of the counterpart premises in order to collect necessary data for calculation of prototype.
- Preparation of Technical data sheet in order to define detail technical specification
- Review the existing technical drawing for the purpose of assessment of possible changes in the design criteria.
- Review each prototype refrigeration circuit for determination of cooling circuit components
- Review and assessment of design criteria following cooling circuit component in order to minimize possible changes and design improvement.
 - Compressor technical specification
 - Condenser type, material and design criteria
 - Evaporator type, material and design criteria
 - Capillary tube design, dimensions and material
 - Filter drier, size and material
 - Determination of R12 refrigerant charge for each prototype in order to adjust R134a charge weight
- Coordination with the counterparts for performing performance test after completion of making prototypes
- Calculation of prototypes in order to determine the size of R134a compressor and implement necessary changes to the cooling circuits
- Preparation of Performance Test Results Sheet, in order to record all data obtained during functional test.
- Testing Prototypes at Hot Chamber.
- Evaluation of Performance test results.
- Corrective action on defective parts and components.
- Replacement of defected parts.
- Adjustment of refrigerant charge for each prototype.
- Assembly line preparation of trial test and production to fulfill R134a cleanliness requirement.

Sahandmina Engineering Company Ltd.

- On the job training to counterpart technical staff to operate new R134a equipment such as new refrigerant charger machine, new vacuum pump, and new leak detector.
- Coordination with equipment supplier to conduct suitable training program to the counterpart technical staff.
- Final visit of the counterpart to assure trial production of R134a products as foreseen in the project investment documents in case of new equipment availability.

Preparation of prototypes for performance test as

The prototypes shall be tested under designated ambient temperature mostly at + 32 C, the test performance revealed that no significant changes is necessary for refrigeration system circuit, because the original size of evaporator and condensers are much bigger than cooling requirements.

The adjustment will be applied to the mainly to the amount of refrigerant charge and length of capillary tube.

Each prototypes should under go for performance test at the following test criteria.

Pull down test at + 32 C

Continues run Test at = 32 C ambient temperature

Cyclic run test at + 32 C ambient temperature.

The test condition was selected in accordance with appropriate ISO test standards.

The material as sample for making prototypes are supplied mainly from local market, due to the limitation for purchasing R134a compressor from local market we had to contact several manufacturers to find out the technical specification for appropriate compressor.

The prices for material specially R134a and R141b blended polyol are much higher than R12 and R11,

Sahandmina Engineering Company Ltd.

Training

Before making prototypes we conducted a training course to train the technical staffs to make their own prototypes and also make them familiar with the new technology.

The following topics were thought during the theatrical training course.

- An orientation to UNIDO CFC phases out project.
- Montreal Protocol
- Ozone Layer and CFC side effect to Ozone layer
- Familiarization with new R134a Refrigerant, application, safety precaution, use and maintenance.
- Familiarization with the new vacuum and charging equipment, vacuum pump and charging board.
- Recovery and recycling of R12 refrigerant, and also R134a.
- Alternative for R11 and R12.
- Some explanation about R141b blowing agent,
- Selection of refrigeration components to be replaced with R12 refrigeration system.
- Calculation and redesign of prototypes

- Performance test
- Test results Evaluation.
- Refrigeration system adjustment
- Selecting Prototype Model
- Refrigeration System components Familiarization
- Refrigeration Load Calculation
- Thermostat Selection and Adjustment
- Refrigerant Charging Methods
- Testing Prototypes
- Analyzing Prototype Test Results

Making Prototypes

- Prototype Model Selection

Sahandmina Engineering Company Ltd.

- Refrigeration System Components Selection
 - 1- Defrost Type
 - 2- No-Frost Typ
- Familiarization with Refrigeration System Components
 - 1- Condenser
 - a. Wire on Tube
 - b. Tube welded on Plate
 - c. Tune on Plate
 - d. Tube in the Body
 - e. Tube on the fins
 - 2- Capillary Tube
 - a. Tube Length
 - b. Tube Diameter
 - c. Tube Material
 - 3- Expansion Valve
 - a. Size
 - b. Capacity
 - c. Material
 - 4- Filter Direr
 - a. Weight
 - b. Material
 - c. Model
 - 5- Evaporator
 - a. Roll Bond
 - b. Wire on Tube
 - c. Tube welded on Plate
 - d. Tune on Plate
 - e. Tube in the Body
 - f. Tube on the fins
- Refrigeration Load Calculation
 - 1- Aim of Calculation
 - a. Model Re-Definition
 - b. Model Improvement
 - c. Model Modification
 - d. Conversion of Prototype
 - e. Model New Design
 - 2- Methods of Refrigeration Load Calculation

Sahandmina Engineering Company Ltd.

- a. ASHREA
- b. Manufacturer
- c. Institutes and Universities

3- Different Elements Required for Calculation

- a. Heat Transfer

Dimension, Insulation, Ambient, Working Condition
Gasket, etc.

- b. Product Load

Food, Material, Ice, Etc.

- c. Infiltration

Door Opening, Air Replacement

- d. Miscellaneous devices and apparatus

Light, Fan, Etc.

- Compressor

Cooling System (Static, Oil, Air)

1- Pressure

- a. LBP (Low Back Pressure)
- b. HBP (High Back Pressure)
- c. MBP (Medium Back Pressure)

2- Model

- a. Hermetic
- b. Semi-Hermetic
- c. Open

3- Type of Refrigerant

- a. R12
- b. R134a
- c. Isobutene
- d. Blend

4- Accessories

- a. Capacitor Type
- b. Starting Relay
- c. Voltage, Frequency and Current
- d. Electrical Circuit

5- Mounting Compressor

- a. Refrigerant Fellow Direction
- b. Top on the Roof

Sahandmina Engineering Company Ltd.

- c. Bottom on Base
- d. Double Compressor Mounted

6- Compressor Capacity

- a. Watt
- b. Horse Power
- c. B.T.U/Hr
- d. Kcal/Hr

7- Compressor Test Condition

CECOMAF

| | |
|-------------------|---------------------------|
| Evaporating Temp. | -25° C |
| Condensing Temp. | 55° C |
| Ambiant Temp. | 32° C |
| Suction Gas Temp. | 32° C |
| Liquid Temp. | 55° C |
| Volatage/Hertz | 220V/50 Hz |
| Heat out Put= | Capacity+Watt Consumption |

ASHRAE

| | |
|-------------------|---------------------------|
| Evaporating Temp. | -23.3° C |
| Condensing Temp. | 55° C |
| Ambiant Temp. | 32° C |
| Suction Gas Temp. | 32° C |
| Liquid Temp. | 32° C |
| Volatage/Hertz | 220V/50 Hz |
| Heat out Put= | Capacity+Watt Consumption |

ASHRAE to CECOMAF

Conversion of Capacity From CECOMAF into ASHRAE

R134a Multiply by 1.231

R22 Multiply by 1.097

R404 Multiply by 1.183

1 Watt = 0.86 Kcal/h

1 Watt = 3.41 BTU/h

1 Kcal/h = 1.0162 Watt

1 BTU/h = 0.293 Watt

8- Evaporating Temp. and Selection of Compressor

Sahandmina Engineering Company Ltd.

- 9- Thermostat
 - Thermostat Adjustment
 - a. Cut-in Time - 5 to -15 Compressor Connected
 - b. Cut-out time -15 to -25 Compressor Dis-Connected
 - c. Thermostat Setting, Max. Med, Min
 - d. Thermostat Temperature Difference
 - Refrigerant Type
 - 1- CFC- 12
 - 2- HFC-134a
 - 3- Isobutene, R-600
 - 4- Blend, (Isobutene+ Propane)
 - Methods of Refrigerant Charging
 - 1- Bottle, 13.5 Kg. Cylinder
 - 2- Portable Charger
 - 3- Production, Evacuation and Charging Equipment
 - Refrigerant Charge Weight
 - 1- Experimental, trial and error
 - 2- Calculation
 - 3- Comparison with other Refrigerants
 - Refrigeration Leak Detection Procedure
 - 1- Conventional Method, (water and Soap)
 - 2- Portable Electronic Leak Detector
 - 3- Production Electronic Leak Detector
 - 4- Nitrogen, and Helium Leak Detection Procedure
 - Accuracy and Precision of Leak Detection Procedure
 - 5- Conventional Method, (water and Soap)
 - 6- Portable Electronic Leak Detector
 - 7- Production Electronic Leak Detector
 - 8- Nitrogen, and Helium Leak Detection Procedure
 - Recovery
 - Recycling
 - Reclaiming

Testing Prototypes

- Test Prototypes with R12 Refrigerant to get desired test results.

Sahandmina Engineering Company Ltd.

- Hot Chamber Specification
- Placing Prototypes at Hot Chamber
- Mounting Sensors and their Place and Location
- Testing Condition
 - 1- Tropical "T" 43 °C
 - 2- Sub-Tropical 38 °C
 - 3- Normal 32 °C
 - 4- Sub-Normal 28 °C
 - 5- Cold 18 °C
 - 6- Relative Humidity
- Test Package
- « M » Package
- Meat
- Ice
- Different Tests
 - 1- Operational
 - 2- Performance
 - 3- Energy Consumption
 - 4- Ice Making
 - 5- Humidity
- Testing Procedure
 - 1- Pull Down
 - 2- Continuous Run
 - 3- Cyclic Run
- Duration of Test
- Reading Test Result
- Test Results Analysis

Conclusion

All prototypes were tested successfully at the counterparts premises. The test results have been evaluated for proper functioning of refrigeration system components specially R134a compressor. The main difficulties and problems during implementation of the contract were hot chamber design and performance. The hot chambers are being constructed locally and improper insulation and air distribution inside the hot room and software affected the test performance quality.

Recommendation

Sahandmina Engineering Company Ltd.

An up to dated and user-friendly Testing system for the enterprises is recommended to be supplied to the counterparts, to improve quality of model redesign and performance test.

Kindest Regards

Sahandmina Engineering Company Limited

AVAJ SARMA

Setting


| | |
|----------------|----------------|
| Test Date | Tue Feb 12-02 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 60 |
| File Name | R-4060L23BAH80 |

Product Specification


| | |
|------------------|-------|
| Product Type | 40/60 |
| Compressor Type | - |
| Refrigerant | R134 |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|--------|
| Total Test Time(h:m) | 16:07 |
| Working Time(h:m) | 16:07 |
| Working Percentage | 100.0% |
| Energy Cons.(KWh) | 2.544 |
| Av. En. Cons.(KWh/Day) | 3.788 |
| No. of Thermostat | 0 |
| No. of Over Load | 0 |



Tue Feb 12 -02





شماره:
تاریخ:
پیوست:

شرکت برودتی آوج سرما (سهامی خاص)

تولید کننده لوازم خانگی،
یخچال، یخچال فریزر و فریزر

ساید بای ساید

AVAJ SARMA Co.
Test : P.D

40/60 / 23 به 80

سدل / تاره مالی

32 - 50

هاس محیط / صدوبت نسبت

2.544 KW/24

صف ازرس

تمدد تقطیر دهل

159 N - 1.4

دانت / آرسیر

220 - 50

دلز / هرمن

% 100

سنه / هربر

-17.1

نیز / س

-4.6

شکول / -

-3.5

سدسی / -

+66.3

کسری / -

+51 - 35 - 3

سر / س

-15.9 / 1 - 9.5

سر / خوش لذای

O.C

سشن / س

Roll - bonel

فریز / زع

R134a

ستار / ستار

967 min

زمان / زمان

درجه / درجه

زان رسین / هاس منفعت هندر سلولزی سندم = -18 =

110' = +5 = آزاد = +5 =

AVAJ SARMA

Setting


| | |
|----------------|----------------|
| Test Date | Mon Jan 21-02 |
| Test Type | Cycling |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 60 |
| File Name | D:\F-13\1BAH80 |

Product Specification


| | |
|------------------|----------------------|
| Product Type | F-13 |
| Compressor Type | OA77 G17 GBX60 621a |
| Refrigerant | R134a-Charged by han |
| Capil. Length | 031 |
| Evap. Volume | - |
| Condensor Length | 12pass |
| Thermostat Type | 1 |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 23:59 |
| Working Time(h:m) | 21:27 |
| Working Percentage | 89.5% |
| Energy Cons.(KWh) | 2.678 |
| Av. En. Cons.(KWh/Day) | 2.680 |
| No. of Thermostat | 11 |
| No. of Over Load | 0 |



Mon Jan 21 -02





شماره:
تاریخ:
پیوست:

شرکت برودتی آوج سرما (سهامی خاص)

تولید کننده لوازم خانگی،
یخچال، یخچال فریزر و فریزر

ساید بای ساید

AVAJ SARMA Co.
Test : Cycling

| | |
|-----------------|----------------------|
| F-13 / 1 Bah 80 | سدل / نثاره مال |
| 32 / 50 | دای محیط / سلوب نیز |
| 2.578 kW / 24h | صرف از روی |
| 11 | تعداد قطعه دار |
| 175W 1.2A | واتر / آمپر |
| 220V - 50Hz | ولتاژ / فرکانس |
| 89.5% | درجه ۶۰/۶ |
| -26 | دای فریزر |
| — | برخاک |
| — | سد سرمه |
| +71.6 | کمپرسور |
| — | سرمه / خردل کنکا |
| -27 / -22.1 | معادل / خردل دای اکس |
| 28 | دای سائنس |
| 0.0 | فرع نیتراس |
| R-134a | فرع دی‌اکس |
| سائرنیست دی‌کس | سترنز |
| 1439 min | زبان |
| 1 | درجه گرماست |

AVAJ SARMA

Setting


| | |
|----------------|------------------|
| Test Date | Tue Feb 12-02 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 60 |
| File Name | :\\F-13\\23BAH80 |

Product Specification


| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |


Test Result

| | |
|------------------------|--------|
| Total Test Time(h:m) | 16:07 |
| Working Time(h:m) | 16:07 |
| Working Percentage | 100.0% |
| Energy Cons.(KWh) | 1.972 |
| Av. En. Cons.(KWh/Day) | 2.937 |
| No. of Thermostat | 0 |
| No. of Over Load | 0 |



Tue Feb 12 -02





شماره :
تاریخ :
پیوست :

شرکت برودت آوج سرما (سهامی خاص)

تولید کننده لوازم خانگی،
یخچال، یخچال فریزر و فریزر
ساید بای ساید

AVAJ SARMA Co.
Test : P.D - Run

E-13 / 23 dah 80

سدل / گازر میل

32 / 50

های سفید / رطوبت نیز

1.972 kw/24h

سرمهن ارزی

119 - 1.1

واتر آسم

220 / 50

دستار / مریم

100 %

جیم

- 26

هال

73.8

-

39.6 / 39.7

معادل / خودکار

- 28.8 / - 22.9

فسر / خودکار

28.1

هال

0. C

منع

R134a

فرع / لایکا

967 min

ستار / شرکت

shorted

زهل / هربر

زعنون / های منطقه نمک لکر سراو تدان سندب = -18

درجه / کیمیت

AVAJ SARMA

Setting


| | |
|-----------------------|----------------|
| Test Date | Mon Jan 21-02 |
| Test Type | Cycling |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | FR-4060\1BAH80 |

Product Specification


| | |
|-------------------------|-----------------------------|
| Product Type | 40/60 |
| Compressor Type | 91 20G XOO 609b |
| Refrigerant | 134a-Charged by hand |
| Cappil. Length | 031-310cm |
| Evap. Volume | 120cc |
| Condensor Length | 12pass |
| Thermostat Type | 2 |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 23:59 |
| Working Time(h:m) | 16:14 |
| Working Percentage | 67.7% |
| Energy Cons.(KWh) | 2.947 |
| Av. En. Cons.(KWh/Day) | 2.949 |
| No. of Thermostat | 28 |
| No. of Over Load | 0 |



Mon Jan 21 -02





شماره :
تاریخ :
پیوست :

شرکت برودتی آوج سرما (سهامی خاص)

تولید کننده لوازم خانگی ،
یخچال ، یخچال فریزر و فریزر

ساید بای ساید

AVAJ SARMA Co.

Test: Cycling

| | |
|------------------|--------------------|
| 40/60 / 1 Bah 80 | سل / طبقه های |
| 32 - 50 | مس میلی / بعدت بین |
| 2.947 kw/24h | سیم ارز |
| 28 | ساده مطلع در محل |
| 180 - 1.4 | دلت / کسر |
| 220 - 50 | رسان / مرکز |
| 67.7% | مرج |
| -15.4 | هزار |
| +0.5 | برخال |
| +3 | - |
| +64.4 | سیم |
| 52.2 / 35.8 | مس / خود تنه ای |
| -13.5 / -8.4 | مس / خود لوله ای |
| 12.3 | مس کش |
| 0.0 | نوع |
| Roll-band | که از |
| R-134a | درک |
| 1439 min | لوله ای از |
| 2 | ستاره |
| | زمان |
| | درجه |

AVAJ SARMA

Setting


| | |
|----------------|-----------------|
| Test Date | Mon Jul 02-01 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | : \F-13\11TIR80 |

Product Specification


| | |
|------------------|-------------------|
| Product Type | F 13 |
| Compressor Type | 20 G-1/3 National |
| Refrigerant | 210 gr |
| Cappil. Length | 031 |
| Evap. Volume | - |
| Condensor Length | 1/3-6 |
| Thermostat Type | 1 |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 16:59 |
| Working Time(h:m) | 09:15 |
| Working Percentage | 54.6% |
| Energy Cons.(KWh) | 1.581 |
| Av. En. Cons.(KWh/Day) | 2.234 |
| No. of Thermostat | 29 |
| No. of Over Load | 0 |



Mon Jul 02 -01



AVAJ SARMA

Setting


| | |
|----------------|----------------|
| Test Date | Sun Sep 09-01 |
| Test Type | with load |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | -4060\18SHA801 |

Product Specification


| | |
|------------------|-------|
| Product Type | 40/60 |
| Compressor Type | 20g |
| Refrigerant | 240gr |
| Cappil. Length | 031 |
| Evap. Volume | 80cc |
| Condensor Length | 12p |
| Thermostat Type | 2 |

Test Result


| | |
|------------------------|-------|
| Total Test Time(h:m) | 23:59 |
| Working Time(h:m) | 16:41 |
| Working Percentage | 69.6% |
| Energy Cons.(KWh) | 3.015 |
| Av. En. Cons.(KWh/Day) | 3.017 |
| No. of Thermostat | 31 |
| No. of Over Load | 0 |



Sun Sep 09 -01



16:016:3017:017:3018:018:3019:019:3020:020:3021:021:3022:022:3023:023:30



شماره:

تاریخ:

پیوست:

شرکت برودتی آوج سرما (سهامی خاص)

AVAJ SARMA Co.

تولید کننده لوازم خانگی،
یخچال، یخچال فریزر و فریزر
ساید بای ساید

۱۲۹۷

تاریخ ۲۰/۱۱/۸

| | | | | | |
|-----------|------------------|----------|-------------------|-----------------|------------------|
| ۳۰.۳ °C | دما - رطوبت : | ۱ bah 80 | سُرمه فایل | F ₁₃ | مدل |
| ۱.۴ - ۱۷۵ | دات رامبر : | ۱۱ | نقد احتساب دوصل : | ۲.۵۷۸ kwh | صرف انرژی : |
| ۵۰ - ۲۲۰ | ولتاژ - فرکانس : | ۸۹.۵ % | درصد کارکرد : | R 134a | مقدار ستاره شاخص |

| دما (Kelvin) | ضریب | دما (Kelvin) | دما (Kelvin) | لکنه استر | |
|-----------------|---------|---------------------------|----------------|---|-----------|
| T ₉ | - 20.6 | T ₁₃ آجور دردی | 41.6 | سرع | O.C |
| T ₁₀ | - 23.4 | T ₁₄ آجور | 41.8 | تند اردیب | - 12 pass |
| T ₁₁ | - 23.6 | T ₁₅ آجور | 41.8 | | |
| T ₁₂ | - 21.9 | T ₁₆ آجور اتر | 41.8 | اداگر استر | |
| T ₁₃ | - 21.9 | | | | |
| T ₁₄ | - 23.1 | | | | |
| | - 22.41 | T ₁₆ آجور دار | - 26.8 | سرع - حجم | |
| | | T ₈ خود چک | - 22.1 | تعداد ردیب - ایندا | |
| | | | | زمان رسیدن های محفظه نیمه ای سرادنگ ای منتهی به | |
| | | دما سائنس | | زمان رسیدن های محفظه نیمه ای سرادنگ ای خدای تا ۰.۵ | |
| | | T ₁₅ | +27.5 | +5 | |



شماره:
تاریخ:
پیوست:

شرکت برودتی آوج سرما (سهامی خاص)

AVAJ SARMA Co.

تولید کننده لوازم خانگی،
یخچال، یخچال فریزر و فریزر
ساید بای ساید

۲۹:۲۲

تاریخ: ۸۰/۱۱/۲

| | | | | |
|------------------------|----------|-------------------|-------------|----------------|
| ۳۲°C : دما - رطوبت: | 1 bah 80 | مساره مایل | 40x60 | مدل |
| ۱.۴ - ۱۷۵ وات - آمپر: | 28 | نقداد مطلع و دصل: | 2.947 (kwh) | صرف انرژی: |
| ۵۰-۲۲۰ ولتاژ - فرکانس: | 67.7% | دجه کارکرد: | R134a | متقدار سارکوز: |

| | | | | |
|---|---------------|---------------------|---------------------|-----------|
| دما کابین مردمی | 15.52 | دما کابین مردمی | کند اسندر | |
| T ₈ | -12.3 | 3 تا درجه | سرع | 0.C |
| T ₉ | -16.2 | دما کابین مردمی | تدارد دین | 12 pass |
| T ₁₀ | -17.4 | دما کابین مردمی | ادوات اتر | Roll-band |
| T ₁₁ | -16.2 | دما کابین مردمی | برگ-چشم | 120 CC |
| دما کابین یخچال | | T ₆ درجه | رمان رسین ۴۴ | |
| T ₄ باب | -15 | T ₃ درجه | حفظه نهاده ای مردار | |
| T ₁ کابین } T ₂ } | { 1.7 -0.9 | | دما ای منجذب -18 | |
| T ₅ سبد مردمی | 3 | دما ساردن | رمان رسین دما | |
| | | T ₁₅ | حفظه نهاده ای مردار | |
| | | | دما ای تازه +5 | |

Kwh/24h

Central Office Tel: 7523649 - 7523791 Fax: 7526747
Sale Office Tel: 3127668 - 352474 Fax: 354476

تلفن مفتر مرکزی: ۷۰۷۷۶۶۹ - ۷۰۷۷۷۶۱ تلفن فکس: ۷۰۷۷۷۶۷ - ۷۰۷۷۷۶۸ تلفن فکس: ۷۰۷۷۷۶۷ - ۷۰۷۷۷۶۸ تلفن فکس: ۷۰۷۷۷۶۷ - ۷۰۷۷۷۶۸



شماره:
تاریخ:
پیوست:

شرکت برودتی آوج سرما (سهامی خاص)

AVAJ SARMA Co.

تولید کننده لوازم خانگی،
یخچال، یخچال فریزر و فریزر
ساید بای ساید

Test .. P.D

تاریخ: ۱۰/۱۱/۱

| | | |
|------------------------|----------------------|--|
| دما - روبرت: 32 | تاریخ نام: 29 Day 80 | سل: F-13 |
| دستگاه سرمه: ۱.۴ - ۱۷۵ | - سطح مطلع روشن: | صرف از دیسک: 2.528 kWh/ m^2h |
| دستگاه - غوش: ۵۰ - ۲۲۰ | %/۱۰۰ درجه همراه: | سدارت ساز: R 134 a |

| دما - سین میز | جای کند اسبر | کند اسبر | نوع | O.C |
|-----------------|--------------|---------------------|--------------------|---------|
| T ₉ | -22.9 | +45.8 | | |
| T ₁₀ | -24.8 | +45.5 | | |
| T ₁₁ | -25.6 | | سد درون | 12 pass |
| T ₁₂ | -24.7 | | | |
| T ₁₃ | -24.5 | | اکریلیک | |
| T ₁₄ | -26.1 | | | |
| دما - سین زنگل | بلندی ۲۴,۷ | T ₁₆ صدر | نوع - حجم | |
| | | -28.1 | سد درون - ابزار | |
| | | | زبان رسین دار | |
| | | | تفصیل تسبیح برداشت | |
| | | | -18 | |
| | | | زبان رسین دار | 118 |
| | | | تفصیل تسبیح برداشت | |
| | | | +5 | |
| | | T ₁₅ | +30.9 | |

شاندیل آزاد تسبیت دستی (عایق برد)



..... شماره : تاریخ : پیوست :

شرکت برودتی آوج سرما (سهامی خاص)

تولید کننده لوازم خانگی،
یخچال، یخچال فریزر و فریزر

ساید بای ساید

AVAJ SARMA Co.

Test: p.D

مکتبہ ملی

| حالت | مقدار | جهاز | مقدار | حالة | مقدار |
|------|--------|-----------|-------|------------|---------|
| جاف | -13.3 | جهاز اسبر | +55 | جاف | 0°C |
| جاف | -17.3 | جهاز سبر | +42.5 | تمدد درين | 12 pass |
| جاف | -18.3 | جهاز اسبر | +75 | اداري ازير | |
| جاف | -16.9 | جهاز اسبر | +75 | جاف | 120°C |
| جاف | 19.8°C | جهاز سبر | -18.8 | تمدد درين | -11°C |
| جاف | -16.4 | جهاز سبر | -15.9 | تمدد درين | - |
| جاف | -2.5 | | | تمدد درين | - |
| جاف | -5 | | | تمدد درين | - |
| جاف | -2.6 | جهاز سبر | +4.4 | تمدد درين | 118' |

مشاذ ماذ حضرت رسمی (نحو) درید

**Central Office Tel : 7523649 - 7523791 Fax : 7526747
Sale Office Tel : 3127668 - 352474 Fax : 354476**

مختار مرکزی : خایابان پهلوی ، نرسوی پل پلیز ، بن بست مهابی ، ساختمان ۶۱ طبقه سوم ، شماره ۷
تلفن مختار مرکزی : ۷۸۴۲۶۶۹ - ۷۸۴۲۷۷۹۱ - ۷۸۴۴۷۶ - ۷۸۴۴۷۶ - ۷۸۴۴۷۶

GASSO Co.

BASET P.N.

Setting

| | |
|----------------|-----------------|
| Test Date | Sun Apr 21-02 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50% |
| File Name | : \UNIDO\ZARIF6 |



Product Specification

| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|-------------------------|--------|
| Total Test Time(h:m) | 16:59 |
| Working Time(h:m) | 14:42 |
| Working Percentage | 86.68 |
| Energy Cons. (KWh) | 0.0000 |
| Av. En. Cons. (KWh/Day) | 0.000 |
| No. of Thermostat | 1566 |
| No. of Over Load | 0 |

Sun Apr 21 -02



Gasso 6

BASET P.N.

Setting

| | |
|----------------|-----------------|
| Test Date | Sun Apr 21-02 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50% |
| File Name | : \UNIDO\ZARIF6 |


Product Specification

| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|-------------------------|--------|
| Total Test Time(h:m) | 16:59 |
| Working Time(h:m) | 14:42 |
| Working Percentage | 86.6% |
| Energy Cons. (KWh) | 0.0000 |
| Av. En. Cons. (KWh/Day) | 0.000 |
| No. of Thermostat | 1566 |
| No. of Over Load | 0 |

Sun Apr 21 -02



175.0

150.0

125.0

100.0

75.0

50.0

25.0

0.0

-25.0

-50.0

-75.0

-100.0

5:00

10:00

15:00

20:00


Product Technical Specification

| Description | Specification |
|--|---|
| Company Name | Gasso Co ltd |
| Product Name | Water coolr |
| Product Model | Model GW 45 |
| Product Application | Drinking Water |
| Operating Temperature | 7°C |
| Climatic Condition | Max 38°C |
| Product Overall Dimension WxLxH mm | 600x400x1200 |
| Freezer Compartment Overall Dimension and | |
| Wall Thickness | |
| Refrigerator Compartment Overall Dimension and | 50 lit Capacity Of Tank With 50mm Isolation |
| Wall Thickness | |
| Product Shape, | Chest |
| Double Doors, Upright, Chest, etc | |
| Freezer Internal Net Volume | |
| Refrigerator Net Volume | |
| Product Net Volume | |
| Product Inside Temperature C | 7°C |
| Water Storage Tank Capacity, Water Cooler | 50 Lit |
| Type of Water Storage Tank | Cylinder |
| Cylinder, Cubic, etc. | |
| Water Fellow per hour for water cooler | 45 Lit |
| Water Storage Tank Dimension | |
| Water Outlet Temperature | 7°C |
| Water Inlet Temperature | 20 To 26°C |
| Freezer Inside Temperature | 45 cm x 38 Ø |
| Refrigerator Inside Temperature | |
| Evaporating Temperature | -2°C |
| Foam Insulation Thickness mm | 30 mm |
| Side Walls, Top, Bottom, Door, Back Panel | |
| Type of PU Foam | Poly Urtane |
| Foam Density, Kg/Cu. Mt. | 40 |
| Foam Mixture, Percentage | 50% +55% + 20% R11 |
| Pol% + R11% + Isocyanate% | |
| Total amount of Foam Injection, Kg | 3.4kg in 550x500x500mm Container |
| Refrigerant Type | R12 |
| Refrigerant Charge Weight Gr. | 350 gr |

: PHONE NO.

1002 00 53PM 22

| | |
|--|-------------------------------|
| Type of Compressor, Hermetic, Semi Hermetic, Open | Hermetic |
| Compressor Cooling System Static, Oil Cooled, Fan Cooled | Fan cooled |
| Compressor Cooling Capacity Watt | 850 W |
| Compressor input Power, Watt | 600 W |
| Compressor Model Number | Cs12B |
| Compressor Manufacturer | Danffos |
| Compressor Mounting Place Top, Bottom, Front, Back | Bottom |
| Condenser Type, Static, Fan Cooled | 325x44x325mm 12.8 in |
| Condenser Dimension, Length, Inside Tube Diameter, | 325x44x325mm 12.8 in |
| Condenser Material, Aluminum, Copper, Copper Coated, etc, | Al - Cu |
| Condenser mounting Place, Back Wall, Top, Bottom | Bottom |
| Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc. | Shell & Tube |
| Evaporator Dimension, Length, Surface Area, Inside Tube Diameter | 400mm |
| Evaporator Material, Aluminum, Copper, Copper Coated, etc, | Copper Tube |
| Dryer Type, | Cartrig |
| Dryer Material, Weight and Size | MolecularSive - 30gr - 1/4 in |
| Capillary Tube Diameter and Length | 0.054 in - 6.4 ft Length |



Product Technical Specification

| | |
|--|------------------------|
| Description | Specification |
| Company Name | Gasso Co Ltd |
| Product Name | Closed Cabinet Display |
| Product Model | MRG |
| Product Application | Catering & Kitchen |
| Operating Temperature | 2°C |
| Chimatic Condition | 38°C Max |
| Product Overall Dimension WxLxH mm | 1500x800x2050 |
| Freezer Compartment Overall Dimension and | |
| Wall Thickness | |
| Refrigerator Compartment Overall Dimension and | 1400x700x1700 |
| Wall Thickness | |
| Product Shape, | |
| Double Doors, Upright, Chest, etc | Upright four Doors |
| Freezer Internal Net Volume | |
| Refrigerator Net Volume | 58 Cu ft |
| Product Net Volume | |
| Product Inside Temperature C | 2°C |
| Water Storage Tank Capacity, Water Cooler | |
| Type of Water Storage Tank | |
| Cylinder, Cubic, etc. | |
| Water Fellow per hour for water cooler | |
| Water Storage Tank Dimension | |
| Water Outlet Temperature | |
| Water Inlet Temperature | |
| Freezer Inside Temperature | |
| Refrigerator Inside Temperature | 2°C |
| Evaporating Temperature | -5°C |
| Foam Insulation Thickness mm | |
| Side Walls, Top, Bottom, Door, Back Panel | 50mm all |
| Type of PU Foam | Poly Urtane |
| Foam Density, Kg/Cu. Mt. | |
| Foam Mixture, Percentage | 50+50+ 20% R11 |
| POL% + R11% + Isocyanate% | |
| Total amount of Foam Injection, Kg | 15 Kg |
| Refrigerant Type | R12 |
| Refrigerant Charge Weight Gr. | 650gr |

0.00128 w/m°C 25°C

| | |
|--|--------------------------|
| Type of Compressor, Hermetic, Semi Hermetic, Open | Hermetic |
| Compressor Cooling System Static, Oil Cooled, Fan Cooled | Fan cooled |
| Compressor Cooling Capacity Watt | 950W |
| Compressor input Power, Watt | 850 W |
| Compressor Model Number | Sc21 B |
| Compressor Manufacturer | Danffos |
| Compressor Mounting Place Top, Bottom, Front, Back | Top |
| Condenser Type, Static, Fan Cooled | Fan Cooled |
| Condenser Dimension, Length, Inside Tube Diameter, | 325 x 66 x325mm |
| Condenser Material, Aluminum, Copper, Copper Coated, etc, | Aluminum - Copper |
| Condenser mounting Place, Back Wall, Top, Bottom | Top |
| Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc. | Fin & Tube |
| Evaporator Dimension, Length, Surface Area, Inside Tube Diameter | 560 x300x 100 |
| Evaporator Material, Aluminum, Copper, Copper Coated, etc, | Aluminum fin copper Tube |
| Dryer Type, | Cartrig |
| Dryer Material, Weight and Size | Molecular Sive to gr |
| Capillary Tube Diameter and Length | 0.54 in -5.7 ftLength |

Donyaye Mojdeh

Mozhdeh

Setting


| | |
|----------------|---------------|
| Test Date | Sat May 12-01 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | test1 |

Product Specification


| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Capil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|--------|
| Total Test Time(h:m) | 08:59 |
| Working Time(h:m) | 05:33 |
| Working Percentage | 61.8% |
| Energy Cons.(KWh) | 0.9975 |
| Av. En. Cons.(KWh/Day) | 2.665 |
| No. of Thermostat | 55 |
| No. of Over Load | 0 |




Sat May 12-01




د. س. موزده مراجعته اینجا نیست
جیل خود را بخواهید

Mozhdeh

| Setting | |
|------------------------|---------------|
| Test Date | Tue Apr 10-01 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | test1 |
| Product Specification | |
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |
| Test Result | |
| Total Test Time(h:m) | 23:33 |
| Working Time(h:m) | 21:41 |
| Working Percentage | 92.0% |
| Energy Cons.(KWh) | 4.585 |
| Av. En. Cons.(KWh/Day) | 4.673 |
| No. of Thermostat | 11 |
| No. of Over Load | 0 |



Tue Apr 10-01



Dongye Mozdah

Mozdah

Setting

| | |
|----------------|---------------|
| Test Date | Mon Apr 09-01 |
| Test Type | |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |

| | |
|-----------|-------|
| File Name | test2 |
|-----------|-------|


Product Specification

| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 17:10 |
| Working Time(h:m) | 09:58 |
| Working Percentage | 58.0% |
| Energy Cons.(KWh) | 2.216 |
| Av. En. Cons.(KWh/Day) | 3.098 |
| No. of Thermostat | 52 |
| No. of Over Load | 0 |

Mon Apr 09 -01



ریزگار مخصوص پمپ

Mozhdeh

Setting


| | |
|----------------|---------------|
| Test Date | Mon Jan 28-02 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | test1 |

Product Specification


| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 16:25 |
| Working Time(h:m) | 13:15 |
| Working Percentage | 80.8% |
| Energy Cons.(KWh) | 1.779 |
| Av. En. Cons.(KWh/Day) | 2.601 |
| No. of Thermostat | 33 |
| No. of Over Load | 0 |



Mon Jan 28-02



Mozende

Setting

| | |
|----------------|---------------|
| Test Date | Tue Feb 05-02 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | test2 |



Product Specification

| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 18:04 |
| Working Time(h:m) | 12:51 |
| Working Percentage | 71.1% |
| Energy Cons.(KWh) | 2.671 |
| Av. En. Cons.(KWh/Day) | 3.548 |
| No. of Thermostat | 16 |
| No. of Over Load | 0 |

Tue Feb 05 -02



Mozhdeh

Setting

| | |
|----------------|---------------|
| Test Date | Tue Feb 05-02 |
| Test Type | |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | test2 |



Product Specification

| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|--------|
| Total Test Time(h:m) | 05:40 |
| Working Time(h:m) | 05:40 |
| Working Percentage | 100.0% |
| Energy Cons.(KWh) | 0.9778 |
| Av. En. Cons.(KWh/Day) | 4.141 |
| No. of Thermostat | 0 |
| No. of Over Load | 0 |

Tue Feb 05 -02



Mozhdeh

Setting


| | |
|----------------|---------------|
| Test Date | Mon Feb 04-02 |
| Test Type | - |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | test2 |

Product Specification


| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 18:39 |
| Working Time(h:m) | 06:35 |
| Working Percentage | 35.4% |
| Energy Cons.(KWh) | 2.376 |
| Av. En. Cons.(KWh/Day) | 3.058 |
| No. of Thermostat | 104 |
| No. of Over Load | 0 |



Mon Feb 04-02



Mozhdeh

Setting

| | |
|----------------|---------------|
| Test Date | Mon Feb 04-02 |
| Test Type | |
| Hot Room Temp. | 32 |
| Hot Room Hum. | 50 |
| File Name | test1 |



Product Specification

| | |
|------------------|---|
| Product Type | - |
| Compressor Type | - |
| Refrigerant | - |
| Cappil. Length | - |
| Evap. Volume | - |
| Condensor Length | - |
| Thermostat Type | - |

Test Result

| | |
|------------------------|-------|
| Total Test Time(h:m) | 18:48 |
| Working Time(h:m) | 07:16 |
| Working Percentage | 38.7% |
| Energy Cons.(KWh) | 1.252 |
| Av. En. Cons.(KWh/Day) | 1.598 |
| No. of Thermostat | 97 |
| No. of Over Load | 0 |

Mon Feb 04-02



FROM :

PHONE NO. :

P04

FROM :

PHONE NO. :

NOV. 08 2001 11:53AM P1

K, A, 19 0, 256

1

Freezer & Refrigerator 20

Product Technical Specification

| Description | Specification |
|---|---|
| Company Name | DONYAYE MOJDEH Co. |
| Product Name | Freezer & Refrigerator |
| Product Model | 40 X 60 |
| X Product Application | X |
| Operating Temperature | 39 Centigrade |
| Climatic Condition | N |
| Product Overall Dimension WxLxH mm | 65 X 200 Cent. |
| Freezer Compartment Overall Dimension and Wall Thickness | 65 X 98 Cent. |
| Refrigerator Compartment Overall Dimension and Wall Thickness | 65 X 102 Cent. |
| Product Shape, | (STAND)  |
| Double Door | |
| Freezer Internal Net Volume | 67 Liter |
| Refrigerator Net Volume | 208 Liter |
| Product Net Volume | 410 Liter |
| Product Inside Temperature C | -24.8 +3 Cent |
| Water Storage Tank Capacity, Water Cooler | / |
| Type of Water Storage Tank Cylinder, Cubic, etc. | / |
| Water Fellow per hour for water cooler | / |
| Water Storage Tank Dimension | / |
| Water Outlet Temperature | / |
| Water Inlet Temperature | / |
| Freezer Inside Temperature | about -24 Cent |
| Refrigerator Inside Temperature | about +3 Cent |
| Evaporating Temperature | |
| Foam Insulation Thickness mm | Side Wall 60 mm Bottom 40 mm |
| Side Walls, Top, Bottom, Door, Back Panel | Top 40 mm Door 50 mm Back 60 mm |
| Type of PU Foam | LPC |
| Foam Density, Kg/Cu. Mt. | 55 & 45 |
| Foam Mixture, Percentage | |
| POL% + R11% + Isocyanate% | |
| Total amount of Foam Injection, Kg | 12 Kg |
| Refrigerant Type | Frion 12 |
| Refrigerant Charge Weight Gr | 320 Gr |

Freezer & Refrigerator 20

| | |
|---|----------|
| Type of Compressor | Hermetic |
| Hermetic, Semi Hermetic, Open | |
| Compressor Cooling System | |
| Static, On Coupled, Fan Cooled | |
| Compressor Cooling Capacity | * |
| Watt | |
| Compressor Input Power, Watt | X |
| Compressor Model Number | |
| Compressor Manufacturer | |
| Compressor Mounting Place | |
| Top, Bottom, Front, Back | |
| Condenser Type | |
| Static, Fan Cooled | |
| Condenser Dimension, Length, Inside | |
| Tube Diameter | |
| Condenser Material | |
| Aluminum, Copper, Copper Coated, etc. | |
| Condenser mounting Place, | |
| Back Wall, Top, Bottom | |
| Evaporator Type | |
| Fins and Tube, Roll Band, Wire and Tube etc. | |
| Evaporator Dimension | |
| Length, Surface Area, Inside Tube | |
| Diameter | |
| Evaporator Material | |
| Aluminum, Copper, Copper Coated, etc. | |
| Dryer Type | X |
| Dryer Material, Weight and Size | X |
| Capillary Tube Diameter and Length | X |

FROM :

PHONE NO. :

A,A,19

0,2500

1

Refrigerator 12Product Technical Specification

| Description | Specification |
|--|--------------------------------|
| Company Name | DONYAYE MOJDEH Co. |
| Product Name | Refrigerator |
| Product Model | 12 FOOT |
| Product Application | X |
| Operating Temperature | 32 Centigrade |
| Climatic Condition | N |
| Product Overall Dimension WxLxH mm | 63 X 165 Cent.m |
| Freezer Compartment Overall Dimension and | |
| Wall Thickness | |
| Refrigerator Compartment Overall Dimension and | |
| Wall Thickness | |
| Product Shape, | (STAND) |
| Double Door | |
| Freezer Internal Net Volume | |
| Refrigerator Net Volume | About 265 Liter |
| Product Net Volume | About 280 Liter |
| Product Inside Temperature C | About 3 Centigrade |
| Water Storage Tank Capacity, Water Cooler | |
| Type of Water Storage Tank | |
| Cylinder, Cubic, etc. | |
| Water Fellow per hour for water cooler | |
| Water Storage Tank Dimension | |
| Water Outlet Temperature | |
| Water Inlet Temperature | |
| Freezer Inside Temperature | |
| Refrigerator Inside Temperature | About ± 3 Centigrade |
| Evaporating Temperature | About -19 |
| Foam Insulation Thickness mm | Side Walls 40mm Bottom - |
| Side Walls, Top, Bottom, Door, Back Panel | Top 40mm Door 40 mm Back 40 mm |
| Type of PU Foam | IPC |
| Foam Density, Kg/Cu. Mt. | |
| Foam Mixture, Percentage | % 55 & % 45 |
| POL% + R11% + Isocyanate% | |
| Total amount of Foam Injection, Kg | 8.600 Kg |
| Refrigerant Type | Frion 12 |
| Refrigerant Charge Weight Gr | 280 Gr. |

Refrigerator 12

2

| | | |
|--|---|----------------------------|
| Type of Compressor | Hermetic, Semi Hermetic, Open | Hermetic |
| Compressor Cooling System | Single Oil Cooled, Fan Cooled | Oil Cooled |
| Compressor Cooling Capacity | | |
| Vac. | | |
| Compressor Input Power, Watt | | |
| Compressor Model Number | | 1/5 & 3/6 |
| Compressor Manufacturer | | National |
| Compressor Mounting Place | Top Bottom, Front Back | Back & Bottom |
| Condenser Type | Static, Fan Cooled | STATIC |
| Condenser Dimension, Length, Inside | | Length 6 Cent.m |
| Tube Diameter | | Inside Tube 90 X 50 Cent.m |
| Condenser Material | Aluminum, Copper, Copper Coated, etc. | Aluminum - E.T.C. |
| Condenser mounting Place | Back Wall, Top, Bottom | Back Wall |
| Evaporator Type | Fin and Tube, Roll Bond, Wire and Tube etc. | Roll Bond e.t.c |
| Evaporator Dimension, | | |
| Length, Surface Area, Inside Tube Diameter | 48 X 23 | Cent.m |
| Evaporator Material | Aluminum, Copper, Copper Coated, etc. | Aluminum - E.T.C |
| Dryer Type | | x |
| Dryer Material, Weight and Size | | x |
| Capillary Tube Diameter and Length | | x |

Roshan

Test Sheet

Roshan

Setting


| | |
|----------------|---------------|
| Test Date | Thu Feb 07-02 |
| Hot Room Temp. | 32.0 (E-E) |
| Hot Room Hum. | 60.0% (E) |
| File Name | 406032A4 |

Product Specification

| | |
|-------------------|------------|
| Refrigerator Type | RF 6040 |
| Compressor Type | Necchi 10K |
| Gas Weight | 250 gr |
| Capil. Length | |
| Evap. Volume | |
| Condens. Length | |

Test Result

| | |
|------------------|---------|
| Test Time (m) | 1474 |
| Work. Time (m) | 828 |
| Duty Cycle | 56.2% |
| Energy Con.(wH) | 3002.22 |
| No. of Therm. | 27 |
| No. of Over Load | 0 |



789.09

Thu Feb 07 -02

Time = -6:-4

300.00

250.00

200.00

150.00

100.00

50.00

0.00

-50.00

| |
|--------|
| Volt |
| I*100. |
| P.F. |
| Ac. P. |
| Re. P. |

5:0

10:0

15:0

20:0

25:0

30:0

Roshan

Test Sheet

Roshan

Setting


| | |
|----------------|---------------|
| Test Date | Thu Feb 07-02 |
| Hot Room Temp. | 32.0 (E-E) |
| Hot Room Hum. | 60.0% (E) |
| File Name | 406032A4 |

Product Specification

| | |
|-------------------|------------|
| Refrigerator Type | RF 6040 |
| Compressor Type | Necchi 10K |
| Gas Weight | 250 gr |
| Cappil. Length | |
| Evap. Volume | |
| Condens. Length | |

Test Result


| | |
|------------------|---------|
| Test Time (m) | 1474 |
| Work. Time (m) | 828 |
| Duty Cycle | 56.2% |
| Energy Con.(wH) | 3002.22 |
| No. of Therm. | 27 |
| No. of Over Load | 0 |



T. : 29.34

Thu Feb 07 -02

Time = 0:-3



Product Technical Specification

| Description | Specification | |
|--|------------------------------|-------------------|
| Company Name | Roshan Ind. Group | |
| Product Name | ROSHAN | |
| Product Model | RF 70 30 | RF 60 40 |
| Product Application | Household | |
| Operating Temperature | +18 +43 | +16 +32 |
| Climatic Condition | Tropical | Normal |
| Product Overall Dimension WxLxH mm | 63 x 67 x 185 | 64 x 67 x 195 |
| Freezer Capacity and Overall Dimension mm | 32x52x40 mm | 50x46x77 mm |
| Refrigerator Capacity and Overall Dimension mm | 56x48x110 mm | 52x48x88.5 mm |
| Wall Thickness | | |
| Product Shape etc | Double Doors upright, chest, | Double Doors |
| Freezer internal volume | 98 litr | 75 litr |
| Refrigerator net volume | 219 litr | 166 litr |
| Product net weight | 317 litr | 241 litr |
| Product inside temperature C | | |
| Water Storage Capacity, Water Cooler | | |
| Type of Water etc | large Tank Cylinder, Cubic, | |
| Water Fellow tank Dimension | | |
| Water Storage tank Dimension | | |
| Water Outlet Temperature | | |
| Water Inlet Temperature | | |
| Freezer Inside Temperature | -20 1 -18c | -20 1 -18c |
| Refrigerator Inside Temperature | tAv -75 c | |
| Evaporating Temperature | | |
| Foam Insulation thickness mm Side Walls, Top, Bottom, Back Panel | 6 7 3-5 6 | |
| Type Of PU Foam | Cold Rigid Foam | |
| Foam Density, CU.Mt | 32- 33 | Kg/m ³ |
| Foam Mixture Percentage | | |
| Poly% / R11% | | |
| Total amount of foam Injection, Kg | 8 | 9 |
| Refrigerant Type | R12 | |
| Refrigerant Charge Weight Gr | 280gr | 270gr |

24°
24°
10°
4°

| Product Technical Specification | | |
|--|--|--|
| Description | Specification | |
| Type of compressor hermetic, open | Hermetic, Semi hermetic, open | Hermetic |
| Compressor Cool. Cooled, fan Cool | System Static, Oil Cooled, fan Cool | Oil cooled |
| Compressor Cool. Power, Watt | Capacity Watt Power, Watt | 230 W 207 W |
| Compressor Model number | PN- 91F-20G | |
| Compressor Manufacturer | Matsushita | |
| Compressor Mounting place Front , Back | Top , Bottom Front , Back | Bottom |
| Condenser Type Static, Fan cooled | Static | |
| Condenser Dimensions Tube Diameter | Length, inside Tube Diameter | 16.67m ϕ 5 mm |
| Condenser Material Aluminum, Copper | Copper Coated, etc | Steel Copper Coated |
| Condenser mounting place Back Wall, Top, Back | place Back Wall, Top, Back | Back wall |
| Evaporator Type Fin and Tube, Roll Bond, Wire and Tube, etc | Fin & Tube & Plate R: Roll Bond | F: Wire & Tube R: Roll Bond |
| Evaporator Dimensions inside Tube Diameter | Length, Surface Area, inside Tube Diameter | 20m ϕ 6.6mm 22m ϕ 6.6mm |
| Evaporator Material Aluminum, copper | coated, etc | CU- Al |
| Dryer Type | | XIIS |
| Dryer Material, Weight and Size | | 15g |
| Capillary Tube Diameter and Length | | ϕ 0.78mm 2.9m |

Roshan

Test Sheet

Roshan

Setting


| | |
|----------------|---------------|
| Test Date | Thu Feb 07-02 |
| Hot Room Temp. | 32.0 (E-E) |
| Hot Room Hum. | 60.0% (E) |
| File Name | 307032A2 |

Product Specification

| | |
|-------------------|-----------|
| Refrigerator Type | RF 7030 |
| Compressor Type | Necchi 9K |
| Gas Weight | 250 gr |
| Cappil. Length | |
| Evap. Volume | |
| Condens. Length | |

Test Result

| | |
|------------------|---------|
| Test Time (m) | 1475 |
| Work. Time (m) | 999 |
| Duty Cycle | 67.7% |
| Energy Con.(wH) | 3019.11 |
| No. of Therm. | 16 |
| No. of Over Load | 0 |



501.27

Thu Feb 07 -02

Time = 24:37

300.00

250.00

200.00

150.00

100.00

50.00

0.00

-50.00

0:0

5:0

10:0

15:0

20:0

25:0

30:0

| |
|--------|
| Volt |
| I*100. |
| P.F. |
| Ac. P. |
| Re. P. |

Roshan**Test Sheet****Roshan****Setting**


| | |
|----------------|---------------|
| Test Date | Thu Feb 07-02 |
| Hot Room Temp. | 32.0 (E-E) |
| Hot Room Hum. | 60.0% (E) |
| File Name | 307032A2 |

Product Specification

| | |
|-------------------|-----------|
| Refrigerator Type | RF 7030 |
| Compressor Type | Necchi 9K |
| Gas Weight | 250 gr |
| Cappil. Length | |
| Evap. Volume | |
| Condens. Length | |

Test Result

| | |
|------------------|---------|
| Test Time (m) | 1475 |
| Work. Time (m) | 999 |
| Duty Cycle | 67.7% |
| Energy Con.(wH) | 3019.11 |
| No. of Therm. | 16 |
| No. of Over Load | 0 |



T. : 50.91

Thu Feb 07 -02

Time = 18:44

