



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as "developed", "industrialized" and "developing" are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org



06712

Distribution
LIMITEDID/WG.221/1
6 November 1975

Original: ENGLISH

United Nations Industrial Development Organization

UNIDO/FAI International Meeting on Safety in
the Design and Operation of Ammonia Plants

New Delhi, India,
20 - 24 January 1976

1
Safety in
Ammonia Plants

SAFETY IN THE DESIGN CONSIDERATIONS OF AMMONIA PLANTS
FACT EXPERIENCES AT COCHIN AND UDYOGAMANDAL PLANTS

(1975).

by

J. Chidambaram*

* Sr. Process Engineer, PADI Engineering and Design Organisation, Udyogamandal
Via. Cochin, India

1/ The views and opinions expressed in this paper are those of the author and do
not necessarily reflect the views of the Secretariat of UNIDO.
This document has been reproduced without formal editing.

We regret that some of the pages in the microfiche copy of this report may not be up to the proper legibility standards even though the best possible copy was used for preparing the master fiche.



067/2

Distribution
LIMITEDID/WO.221/1/SUMMARY
5 November 1975

United Nations Industrial Development Organization

Original: ENGLISH

UNIDO/FAI Interregional Meeting on Safety in
the Design and Operation of Ammonia Plants

New Delhi, India,
20 - 24 January 1976

SAFETY IN THE DESIGN CONSIDERATIONS OF AMMONIA PLANTS 1/
FACT EXPERIENCES AT COCHIN AND UDYGAMANDAL PLANTS

SUMMARY

by

S. Chidambaram*


Some of FACT experiences in Cochin and Udyogamandal Naphtha reforming ammonia plants are listed as checklists of safety for future modern plants in India.

Due to improved high heat flux designs in superheater and boiler, Indian Boiler Regulations arbitrary design temperature basis of steam temperature = fixed constant was discussed as inadequate. The effect of wide turn down demanded from waste heat boilers, and silicon migration with water carry over are mentioned for necessity of silicon wash with feed water.

Reformer manifold material with cast instead of wrought high temperature steel is brought in the topic for safe substitution. The importance of using two layer refractory lining for hydrogen service is reproduced from API reports as many plants have experienced hot spots. Cochin experiences of burner performance in a high turbulent furnace, low steam production in synthesis loop due to insufficient insulation, NH₃ contamination in hydrofining, recycle hydrogen by the centrifugal compressor anti-surge system and cavitation in CO₂ solution pumps by dissolved gas rich requirement are mentioned as consultation topics. A small suggestion to design reformer with steam/charbon ratio of 3.5 instead of 3 is made considering naphtha specification, LT activity and Benfield steam requirement.

* Mr. Process Engineer, FACT Engineering and Design Organisation, Udyogamandal
Via. Cochin, India

1/The views and opinions expressed in this paper are those of the author and do not necessarily reflect the views of the secretariat of UNIDO.
This document has been reproduced without formal editing.
ID.75-B469



1.0 INTRODUCTION.

Based on 10 years experience operating units, 120 TPH has two operating Ammonia plants with 60 TPH and 120 TPH capacities. The unit 1 plant was designed to use existing and equipment with some re-designed equipment. The 120 TPH plant was engineered by itself with IELAS - 101. The experience gained in these plants can help to know how to compromised for safety in the process designs of Ammonium plants in our country.

2.0 HEAT RECOVERY UNITS AND THEIR DESIGN.

The total energy concept with power recovery (1) has been found to reduce operating cost by implant steam generated at pressures between 100-135 kg/cm². This type of high pressure steam net work is of very specialized nature and are ordered with reputed boiler manufacturers. The only consideration, owner bothers is its statutory acceptance by Indian Boiler Regulations. Unfortunately I.B.R. rules for waste heat boilers are inadequate in many respects and failures are not uncommon in the system if the owner does not pay attention to various emergency conditions and cross-check with other codes.

A typical example is the present free supply natural draft direct fired steam superheater for Kochi plant improvement. Figure 1 and Table 1 explain clearly that the design temperature as stipulated by I.B.R. in relation with steam temperature does not necessarily mean to be a safe condition for the equipment. It can be argued that API RP530 - a design code for direct fired heaters - gives correspondingly a lower thickness when $P = \frac{2.44t}{D}$, is compared with IER formula of $t = \frac{2.81t - 0.61}{D + 0.6}$, when t is the allowable stress value is same. However, API RP530 limits the application to only above 50 mm D and below this API or TRD 301 gives much safer thicknesses when calculated with metal temperature as the basis of design conditions.

For convective type superheaters mounted in primary receiver flue gas duct, different type of problems arises. Normal NH₃ plants have the following heat recovery sources either as boilers or economizers:

3

a) normal operation
b) converted
c) synthesis gas
d) low gas

However the only emergency that occurs during normal steady-state operation is loss of load or load variation. But to take account of this, or to be back on stream quickly, similar safety margin must be taken, still this is not enough. One must also consider a gas level, so that no boil over may occur. The acceptable gas temperature is to be calculated for these items. Safe and material lifetime safety must be assured. For this type of emergency, simply designing for normal steam generation is not enough. It is therefore, to be considered, to have at least some experience in practice, would be able to estimate a design factor and with a reasonable probability and basis his design on this (18).

In conclusion, boiling out condition must be checked and avoided by suitably sizing the gas side bypass when the production conditions agrees with process side condition none or low pressure maintained.

Table adapt 100% average stress to rupture at 10 000 hours as allowable stress at the design temperature. Table 10.1000 article (2) disagree about this basis and considers from metallurgical point of view, a conservative design criteria must be used as an insurance.

3.0 SILICON PROBLEMS IN THE DRUM, DEPC 12, APR 1980.

Cochin synthesis turbine performance visibly deteriorated due to silicon deposits and washing with D₁ steam and condensate was necessary to restore its original performance. Figures 2 & 3 (3) and table 1 give data on silicon solubility in steam and VDI specification on boiler water. For the operating pressure of 134 kg/cm² Cochin has boiler water quality in silicon as 0.4 ppm. And for this, silicon volatility in steam should be limited to 0.01 ppm only. The high silicon deposit was attributed to water carry over from different drums. The wide turn down demand and various operating conditions may probably be one reason for ineffective separation and water carry over. As such regular operation at low level was found necessary in the drums.

Another condition that may contribute to higher silicon in steam may be pH lower range operation in the stipulated 9-10. Without caustic injection, it was found not possible to operate at high pH. Its use is still disputed even though the supplier has recommended it for pH adjustment. Synthesis gas drum supplier recommend K13 injection, but its quantity and proportional loss with steam will affect turbine condensing parts and hence could not be tried.

One can only conclude that in selecting the high pressure waste heat boiler between 10-134 kg/cm², silicon problem must be given due importance unless feedwater silicon wash is incorporated in the drum as a mandatory item.

4.0 REFORMER SECTION

It is a well known fact that in some units the other items are more and more being replaced by the imported equipment data.

Reformer material - steel 316. The precipitation alloys are offered as cheaper alternatives to wrought stainless steel 316L (12, 13) for chloride material. However, experience has shown that in different environments the 316L is more prone to attack than 316. The formation of ferrite can cause embrittlement and the formation of sigma phase embrittles austenitic stainless steels. Ray's fraction crossover of 316L is about 10% ferrite and 90% austenite. The aim of the method of testing is to find the temperature at which the strength should not be decreased. It is found that the ferrite content of 10% is seen Miller junction, which is considered to be acceptable. The thickness (10) with allowances for expansion and contraction formula taking only 75% of the metal is given in the following diagram.

WEC has used Layde 5000 ft of 316L-316LRA in HUO hydrogen plant and this has given trouble-free operation many shutdowns.

Refractory linings - secondary reformer, G-tube, spool piece and transfer lines are the most potential refractory areas which have caused many shut downs due to frequent hot spots. There are many publications and methods of lining with such materials as refractory bricks or the consulting firms. It is worthwhile to adopt American standard two layer lining as minimum requirement. Ininitely bolted cladding before selection must give suitable attention to ASCE recommendations.

A typical spool piece can be given in fig. 1a reproduced as figure 4 & in Section, modification to these lines are being carried out.

5.0 FURNACE

Cochin has an auxiliary combustion chamber after primary reformer coffins to satisfy the steam network heat losses. This type of furnaces are to be compact to ensure thorough mixing for completing the combustion, are to have high turn-down firing flexibility and are to withstand the high hurricane wind incising fire-primary coffins.

For most of the services with DPH mechanical/air atomised combustion, normal test beds firing volume of 2.5-105 Kcal/m³ are found quite adequate, but in bed's service, furnace effective volume is determined by the type of burner and other aerodynamic considerations (13).

Cochin has DPH burner fitted with 12 side swirlers for spread out flame to confine in effective volume. But due to the heavy eddies, the whole combustion chamber is turned to be a flame box with severe damage to burner tips, swirler, quill block, refractory and mortar. Presently it is planned to be replaced with jet flame characteristic burner with increased length of flame for its resistance against

high inside turbulence. It is recommended to provide 0.8 to 1.0 m. for after combustion section. This is also recommended by other suppliers.

Correct specification of furnace condition must be prepared for this type of combustion chamber for finding the suitable burners.

6.0 LT CATALYST USE

Most of the recent publications about the applications made sulphur, chlorine and bromine. However, there is another important aspect of LTS is noted due to severe poisoning and related frequent plant down. The effect of activity deterioration as reported by Tropae (14) is given below:

Reformer depth to active kibbles per m ³ catalyst	LNG/NH ₃ 100% conversion	
	hr.	hr.
Design case	40	0,29
LTS 75% active	70	0,25
LTS 50% active	190	0,19

In a typical kinetic study for deciding allowances of LFT volume, it was found that it is worth to have primary steam/catalyst ratio of 2,5 instead of 3,0 for the following reasons:

1. Naphtha feedstock specification given by LFT is always for worst crude derivative like sea oil. These 2,0% WH naphthas have increased specific gravity and aromatics before and after hydrofining and stripping by dehydrogenation of naphthalenes. Thus PONA analysis on aromatics will be minimum 26,5% Vol. for which reformer catalyst loading need be reduced from 1 to 0,7 kg naphtha/hr.m³ catalyst (15). Thus the number of reformer tubes are controlled by catalysts volume and not for heat flux consideration. The investment difference between S/C of 3 & 3,5 will not be appreciable.
2. Incorporation of quench vessels for increasing steam/gas ratio at downstream has given many mechanical problems and failures due to 'wind and water' interface (16).
3. LTS catalyst cost constitutes approximately 35% of total catalysts in NH₃ plant. For a typical 2,8% to 0,3% CO conversion, operation at S/C 3,5 requires 7,27 m³/100 TPD NH₃ and S/C 3,0 require 8,1 m³/100 TPD NH₃ (15). LT Catalysts.
4. For a typical split flow single stage regeneration (with no flush cooling) Benfield system, operation with S/C of 3,5 alone will satisfy the regeneration efficiency of 0,45 Nm³ CO₂/kg steam.

It is recommended that certain plant be designed on a similar basis, with 15% increased capacity, a slight decrease in the plant performance compared to the present basis.

7.0 ANTI-SURGE SYSTEM

Anti-surge system is considered to be important to maintain the highest efficiency of the plant. It is required to prevent the following gases. These gases are mainly ammonia, nitrogen, hydrogen, and other inert gases. The maximum pressure of hydrogen is about 100 bar. The hydrogen is obtained by reforming hydrocarbons by steam. The steam is obtained by heat exchanger by heat exchanger. The design of the anti-surge system for the plant lean solution pump impeller is as follows:

8.0 HEAT EXCHANGER AT THE TOP

Cochin has simple anti-surge system for combined synthesis and recycle compressor similar to rev. 16), with a small omission of manual leading station between the synthesis and recycle discharge lines. As these gases are to go to chillers combined for stripping carbon oxides, it was considered that they can be connected at our reactor discharge itself, after anti-surge trapping. However, such an arrangement caused difficulties to keep after anti-surge trapping. However, such an arrangement caused difficulties to keep hydrogen through anti-surge line into the low pressure stages and to recycle hydrogen through anti-surge line during compression increasing operations. A double anti-surge system is ideal or an isolation leading valve may be an alternative to avoid this problem.

9.0 NE3 THERMOCOUPLE

A brief sketch of Cochlin NH₃ converter is shown in Fig. 5. The internal boilers are designed to recover 1.58 kg steam/kg NH₃ with feed water at 200°C. But in actual operation, 1.1 is the maximum attained figure and any attempt to reduce the converter exit temperature by boiler valves resulted only in thermal load augmentation in catalyst beds with no effect in steam production percentage.

It is attributed that insufficient insulation over the Reactor-exchangers shown in Fig. 6 is the causing this problem. As a part of plant operation improvement for Cochlin, another gas to gas exchanger in series outside mounted in plant, so that the design steam production rate can be achieved.

Another interesting disparity noted is the equilibrium NH₃ vapour content and dew point. This is given as 100% of the dilute air used by the process designer. Cochlin operation and cold air refrigeration loop suggest that literature data is more reliable. It is advised to note each factor in sizing the refrigeration loop to avoid ending with a very tightly designed loop.

10.0 CONCLUSION

A brief sketch of safety in design, in the points listed by INTech/FAI expert., with all experience is attempted in this article.




FIG. 1 DIRECT FIRE
STEAM SUPERHEATER

TABLE I
COMPARISON OF ISR DESIGN
WITH ACTUAL PERFORMANCE

POSITION	STEAM TEMP. °C	ISR DESIGN TEMP. °C	APPROXIMATE THERMAL REDUCTION PERCENTAGE	N ALLOWABLE PRESS. VALUE kg/cm²
WELDED COALS	325	335+39 = 374	350 + 55 = 405	4
UNSHELDED COALS	355	555 + 50 = 605	454 + 55 = 509	26
RADIATION COALS	450	450 + 50 = 500	476 + 55 = 531	2.2

FIG. 2 RATIO OF SILICA IN STEAM TO SILICA
IN BOILER AS A FUNCTION OF PRESSURE
AND TEMP.




FIG. 5: COLLECTOR PLATE DESIGN FOR
A 250 KW TURBINE
15% DEFLUXATION




TABLE 2: GERMAN BOILER WATER
SPECIFICATION

PRESSURE BAR	64	80	110	125	716.0
CONDUCTIVITY AT 25°	<2500	<300	<50		
T VALUE mV/dL	0.1 to 1.0			40.1	
pH VALUE AT 25°C	10.11	9.10.5	7.7	7.4	
SiO ₂ mg/kg	<9	<1.8	<1.2	<3	
PO ₄ mg/kg	<15	2.15			





FIG. 6
SECTION AA

FIG. 5: NH3 CONVERTER SKETCH

REFERENCE

1. Energy Recovery in NH₃ synthesis plants - Mr. Nimmo - Davy Power Gas - The Chemical Engineer - London July/Aug. 1967.
2. New creep rupture data on furnace tubes - Mr. Thomas W. Krebs - Babcock & Wilcox - HCP & PR - Aug. 1962.
3. Causes and cures for silica deposits in steam turbines - Mr. John S. Schre - HCP & PR - Dec. 1972.
4. New materials of construction for steam hydrocarbon reforming service - Mr. S.N. Anant Narayanan - Fertiliser News - June 1975.
5. Thermalloys' - Lloyds brochure book.
6. High pressure hydrogen with special reference to material of construction - Chemical Engineer - Nov. 1975.
7. Case history - Failure of steam CH₄ reformer furnace - wrought material recommendation - Shell Oil Co. - HCP & PR - May 1971.
8. Reformer manifold cracking - CEP - March 1969.
9. API Report - Piping design for hydrogen service - Esso Research And Engg. Co. - HCP & PR - May 1967.
10. Catalyst tubes in primary reformer furnace - Kellogg - CEP July '70.
11. API Report - H₂ plant shut down reduced - HCP & PR - May 1972.
12. Preventing flange fires - ICI - CEP - August 1969.
13. Airoil brochure EE/00/02 on furnace effective volume.
14. Catalytic processes and Ammonia plant - Topsoe - CEP Oct. 1967.
15. Private communications with various catalyst manufacturers and recommendations for FACT plants.
16. The use of centrifugal compressors in ammonia production plants - Quaderni Pignone 9 - Dec. 1967.
17. Find NH₃ recycle gas equilibrium - Enam Progetti - HCP & PR Dec. 1970.
18. Furnace rating procedure - Oct. 1963 - HCP & PR - R.N. Wimbress - C. F. Braun.



76.01.16