



**TOGETHER**  
*for a sustainable future*

## OCCASION

This publication has been made available to the public on the occasion of the 50<sup>th</sup> anniversary of the United Nations Industrial Development Organisation.



**TOGETHER**  
*for a sustainable future*

## DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

## FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

## CONTACT

Please contact [publications@unido.org](mailto:publications@unido.org) for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at [www.unido.org](http://www.unido.org)

22808

# ***SAHAND MINA ENGINEERING CO LTD.***



*Conversion and Development of  
Prototype from R12 to R134a Ozone  
Friendly Refrigerant System at  
Borna Sanaat Arak, Ariz, Abbaspour, Sard va  
Garm Iran, Sardin Tous, and Bouran Saz  
Karaj Companies*

## **PROJECT NUMBERS**

**MP/TRA/01/203 209, 210, 211, 212, 213**

**Contract Number**

**02/088**

**Final Report**

**December 2002**

Sahandmina Engineering Company Ltd.

## Final Report

PROJECTS NO.

MP/IRA/01/208, 209, 210, 211, 212, 213

Contract Number 02/088

Borna Sanaat Arak, Ariz, Abbaspour,  
Sard va Garm Iran, Sardin Tous, and  
Bouran Saz Karaj, Companies

## Introduction

We are delighted to submit to you herewith, our Final Report, concerning calculation and redesign of the prototypes that have been made the counterparts and they have been tested at counterparts hot chamber. These prototypes have been manufactured under our close engineering supervision and have been tested in accordance with appropriate ISO standard test procedure and relevant performance test characteristics for functionality and performance of the new Ozone friendly R134a refrigerant. Our preliminarily review of test results revealed that majorities of prototypes responded to the new R134a refrigerant functional behavior. The final assessment and evaluation of

# Sahandmina Engineering Company Ltd.

prototypes test results together with original copies of prototypes performance sheets will be submitted to you together with our final reports after UNIDO's approval of our this report and we hope that this report could have satisfied the UNIDO in order to comply with our contract.

## Synopsis

This report has been prepared based on the Contract between UNIDO and Sahandmina Engineering company.

This project will phase out the use of CFC-11 and CFC-12 in the production of Domestic/commercial refrigeration equipment at *Borna Sanaat Arak, Ariz, Abbaspour, Sard va Garm Iran, Sardin Tous, and Bouran Saz Karaj, Companies*

. CFC-11, which is used, as a foam-blowing agent in the production of polyurethane foam will be replaced by HCFC-141b and CFC-12, which is used as the refrigerant in the cooling circuit of appliances, will be replaced by HFC-134a. The project includes the modification of all cooling equipment produced and the conversion of the production facilities. The model redesign element of the project includes testing, trial manufacture and reliability tests. The cost of converting foaming machines to use HCFC-141b will be covered by the counterpart organizations.

## General Background

The objective of this project is to eliminate the use of CFC-11 and CFC-12 in the production of commercial and domestic refrigeration equipment at the *Borna Sanaat Arak, Ariz, Abbaspour, Sard va Garm Iran, Sardin Tous, and Bouran Saz Karaj, Companies*, through conversion to the use of HFC-134a refrigerant for the cooling system and HCFC-141b as blowing agent for the polyurethane insulation foam.

The same operating parameters and the same quality level is guaranteed on completion of the conversion process, but no increase in production

# Sahandmina Engineering Company Ltd.

capacity will be brought about by the project. The company involved is aware of the financial limitations of the funding process and is prepared to use its own funds to share some of the cost of the conversion process.

## SECTOR BACKGROUND

The Islamic Republic of Iran ratified the Montreal Protocol in March 1990. Subsequently, Iran's Country Programme has outlined a plan for the reduction of the domestic use of ODS by 75% before 1999, and aims to be ODS free by 2005.

Based on the data provided by the Ozone Layer Protection Center/Department of Environment of Iran, the Refrigeration Sector in Iran is estimated to comprise of about 300 enterprises. The annual ODS consumption in the domestic and commercial refrigeration sectors is reported to be about 2,500 ODP MT as of 1998, representing the bulk of the overall ODS consumption in Iran. The domestic and commercial refrigeration sub-sector each contributes about 50% of the total ODS consumption in this sector. The average growth rate in this sector has been about 6.5% annually.

In the domestic refrigeration sub-sector, there are about 10 large manufacturers and about 15 medium-sized manufacturers, with a combined production of about 2 million units. In the commercial refrigeration sub-sector, there are about 30 relatively large-sized enterprises, and the remaining (estimated to be about 300) are small and medium sized. Due to the relatively unsophisticated technology and practices prevailing in the small and medium enterprises, and being unorganized, they will present a challenge to reach out to for purposes of participation in the Montreal Protocol programme for ODS phase-out.

There are two indigenous manufacturers of hermetic refrigeration compressors in Iran, which produce compressors suitable for domestic refrigeration appliances using CFC-12 technology. Their combined

## Sanandmina Engineering Company Ltd.

of the domestic demand, the balance being imported. The hermetic and semi-hermetic compressors required by the commercial refrigeration sub-sector are predominantly imported.

The Ozone Layer Protection Center/Department of Environment is leading the efforts for ODS phase-out under the Montreal Protocol, in co-operation with the consuming and supplying industry and with the assistance of the implementing agencies. Complete ODS phase-out is targeted for 2005 except essential uses. The Refrigeration Sector has been identified as a priority sector for ODS phase-out.

In terms of technology and equipment employed the commercial refrigeration sector is very similar to the domestic appliance sector. The primary differences are in the scale of equipment is used, which is bigger in commercial applications, and the variety of products which are manufactured. Most companies manufacture several types of equipment from a wide ranges of applications, including the following:

- display and sales cabinets for supermarkets and individual suppliers of food,
- upright and chest freezers for commercial application,
- different sizes of drinking water coolers,
- blood cooling cabinets,
- milk coolers, water coolers,
- soft ice freezers,
- cooling chambers, cooling stores
- insulated panels for larger cold stores,
- window-type air conditioners and fan coil,
- refrigeration equipment for trucks

In common with the domestic refrigeration sub-sector ozone depleting substances are consumed in commercial applications for:

## Sahnamine Engineering Company Ltd.

- \_ Charging of new appliances with CFC-12, R-502 and R-22
- \_ Refilling/topping up of appliances with CFC-12, R-502 and R-22 after repair work
- \_ Insulation foam blowing using CFC-11

### Counterpart Data

The baseline data for the company covered by this project contains:

- \_ baseline production data
- \_ baseline ODS consumption data
- \_ baseline production equipment data

The Borna Samat Arah, Ariz, Abbaspour, Sard va Garm Iran, Sardin Tous, and Bouran Saz Karaj, Companies are manufacturers of commercial and domestic refrigerators and freezers. These enterprises are 100% indigenously owned by the same group people and report no exports and being financially sound.

### PROJECT SUMMARY

The companies have recognized the need to comply with the Montreal Protocol and have agreed to participate in Iran's ODS phase-out programme. The company is committed to phase out CFCs by converting their foaming equipment to HCFC-141b and adopting HFC-134a as refrigerant. This project document describes the activities needed to carry out the phase out process. The conversion technology and expertise will be acquired from equipment, component and chemical suppliers and external foam and refrigeration experts. The impact on the plant/process due to the use of HCFC-141b as the blowing agent and HFC-134a as the refrigerant, would need to be addressed by implementing plant modifications and

# Sahandmina Engineering Company Ltd.

through the introduction of new equipment, components and processes, as below:

## Refrigeration operation

The conversion to HFC-134a as the replacement for CFC-12 will involve the following changes:

- Compressors suitable for HFC-134a will be required. These will be available from existing suppliers.
- The chemical stability of HFC-134a and of the synthetic lubricants compatible with HFC-134a are highly sensitive to moisture and impurities in the system, as compared to CFC-12 system. The evacuation/charging process for HFC-134a and polyol-ester lubricant will need to ensure the required level of cleanliness and dryness in the system. To ensure this the following is proposed:
- The vacuum pumps will need to be suitable for use with HFC134a of the existing vacuum pumps, are replaced.
- The existing refrigerant charging units are not suitable for use with HFC - 134a and cannot be retrofitted, and will therefore be replaced with two charging units suitable for HFC-134a duty.

The design/sizing of the refrigeration system will need to be suitably changed, to ensure the viability of the process and to maintain the product standards for performance, such as:

1. Up sizing the condensers and re engineering evaporators and condensers, so as to ensure the levels of cleanliness and contamination that can be tolerated with HFC-134a



# Sahandmina Engineering Company Ltd.

2. Lengthening of the capillary tubes.
3. Use of filter-dryers with finer pores, suitable for use with HFC-134a
4. The existing leak detectors are suitable for detecting CFC-12 only and will therefore need to be replaced with leak detectors suitable for detecting HFC-134a.
5. Provision for technical assistance from external international refrigeration experts and also from compressor suppliers will be required to be made to ensure smooth transition to the new technology and the successful implementation of the project.
6. In-house and field trials on prototypes of each model will be needed to be carried out, to establish performance and reliability with the HFC-134a based refrigeration systems.
7. The system dryness/cleanliness with the use of HFC-134a being of crucial nature, careful re-assessment of the production program, re-training/orientation of the staff for the new technology would be required.

## *Aim of the Project*

The aim of the immediate project is to;

- Design, calculation for model redefinition.
- Testing prototypes for functionality and performance criteria.
- Redesign the cooling units of the all models so that they could run on the new Ozone friendly R134a instead of the ODP active CFC12.

# Sahandmina Engineering Company Ltd.

## *Scope of the Contract*

A study will be made for 6 models of commercial refrigerators made by Borna Sanaat Arak, Ariz, Abbaspour, Sard va Garm Iran, Sardin Tous, and Bouran Saz Karaj, Companies to specify;

- Dimensional specification;
- Type and thickness of insulation
- Refrigeration unit component details
- Working performance
- Energy consumption

Selection of HFC 134a compatible components

Redesign of the refrigeration circuit as necessary

Specifying necessary changes in the cooling system if required

Preparation of the trial equipment one prototype per model

Testing of two prototypes for functionality and performance

Evaluation of the test results

## *Supply of the Material*

Following components and material have been used to make prototypes .

- R134a Compressors
- R134a Refrigerant
- Refrigerant Accumulators
- Specially designed filter drier
- Specially designed evaporator and condenser

## *Activities*

The activities for implementation of this contract could be summarized as below.

# Sahandmina Engineering Company Ltd.

- Site survey of the counterpart premises in order to be familiar with the counterpart facility and production line and also define the prototypes for conversion.
- Site survey of the counterpart premises in order to collect necessary data for calculation of prototype.
- Preparation of Technical data sheet in order to define detail technical specification
- Review the existing technical drawing for the purpose of assessment of possible changes in the design criteria.
- Review each prototype refrigeration circuit for determination of cooling circuit components
- Review and assessment of design criteria following cooling circuit component in order to minimize possible changes and design improvement.
  - Compressor technical specification
  - Condenser type, material and design criteria
  - Evaporator type, material and design criteria
  - Capillary tube design, dimensions and material
  - Filter drier, size and material
  - Determination of R12 refrigerant charge for each prototype in order to adjust R134a charge weight
- Coordination with the counterparts for performing, performance test after completion of making prototypes
- Calculation of prototypes in order to determine the size of R134a compressor and implement necessary changes to the cooling circuits
- Preparation of Performance Test Results Sheet, in order to record all data obtained during functional test.
- Testing Prototypes at Hot Chamber.
- Evaluation of Performance test results.
- Corrective action on defective parts and components.
- Replacement of defected parts.
- Adjustment of refrigerant charge for each prototype.
- Assembly line preparation of trial test and production to fulfill R134a cleanliness requirement.

# Sahandmina Engineering Company Ltd.

- On the job training to counterpart technical staff to operate new R134a equipment such as new refrigerant charger machine, new vacuum pump, and new leak detector.
- Coordination with equipment supplier to conduct suitable training program to the counterpart technical staff.
- Final visit of the counterpart to assure trial production of R134a products as foreseen in the project investment documents in case of new equipment availability.

## *Preparation of prototypes for performance test as*

The prototypes shall be tested under designated ambient temperature mostly at + 32 C, the test performance revealed that no significant changes is necessary for refrigeration system circuit, because the original size of evaporator and condensers are much bigger than cooling requirements.

The adjustment will be applied to the mainly to the amount of refrigerant charge and length of capillary tube.

Each prototypes should under go for performance test at the following test criteria.

Pull down test at + 32 C

Continues run Test at = 32 C ambient temperature

Cyclic run test at + 32 C ambient temperature.

The test condition was selected in accordance with appropriate ISO test standards.

The material as sample for making prototypes are supplied mainly from local market, due to the limitation for purchasing R134a compressor from local market we had to contact several manufacturers to find out the technical specification for appropriate compressor.

The prices for material specially R134a and R141b blended polyol are much higher than R12 and R11,

# Sahandmina Engineering Company Ltd.

## Training

Before making prototypes we conducted a training course to train the technical staffs to make their own prototypes and also make them familiar with the new technology.

The following topics were thought during the theatrical training course.

- An orientation to UNIDO CFC phases out project.
- Montreal Protocol
- Ozone Layer and CFC side effect to Ozone layer
- Familiarization with new R134a Refrigerant, application, safety precaution, use and maintenance.
- Familiarization with the new vacuum and charging equipment, vacuum pump and charging board.
- Recovery and recycling of R12 refrigerant, and also R134a.
- Alternative for R11 and R12.
- Some explanation about R141b blowing agent,
- Selection of refrigeration components to be replaced with R12 refrigeration system.
- Calculation and redesign of prototypes
- Performance test
- Test results Evaluation.
- Refrigeration system adjustment
- Selecting Prototype Model
- Refrigeration System components Familiarization
- Refrigeration Load Calculation
- Thermostat Selection and Adjustment
- Refrigerant Charging Methods
- Testing Prototypes
- Analyzing Prototype Test Results

## Making Prototypes

- Prototype Model Selection
- Refrigeration System Components Selection

# Sahandmina Engineering Company Ltd.

- 1- Defrost Type
- 2- No-Frost Type
- Familiarization with Refrigeration System Components
  - 1- Condenser
    - a. Wire on Tube
    - b. Tube welded on Plate
    - c. Tube on Plate
    - d. Tube in the Body
    - e. Tube on the fins
  - 2- Capillary Tube
    - a. Tube Length
    - b. Tube Diameter
    - c. Tube Material
  - 3- Expansion Valve
    - a. Size
    - b. Capacity
    - c. Material
  - 4- Filter Drier
    - a. Weight
    - b. Material
    - c. Model
  - 5- Evaporator
    - a. Roll Bond
    - b. Wire on Tube
    - c. Tube welded on Plate
    - d. Tube on Plate
    - e. Tube in the Body
    - f. Tube on the fins
- Refrigeration Load Calculation
  - 1- Aim of Calculation
    - a. Model Re-Definition
    - b. Model Improvement
    - c. Model Modification
    - d. Conversion of Prototype
    - e. Model New Design
  - 2- Methods of Refrigeration Load Calculation
    - a. ASHREA
    - b. Manufacturer
    - c. Institutes and Universities

# Sahandmina Engineering Company Ltd.

## 3- Different Elements Required for Calculation

- a. Heat Transfer  
Dimension, Insulation, Ambient, Working  
Condition  
Gasket, etc.
- b. Product Load  
Food, Material, Ice, Etc.
- c. Infiltration  
Door Opening, Air Replacement
- d. Miscellaneous devices and apparatus  
Light, Fan, Etc.

## - Compressor

Cooling System (Static, Oil, Air)

### 1- Pressure

- a. LBP (Low Back Pressure)
- b. HBP ( High Back Pressure)
- c. MBP ( Medium Back Pressure)

### 2- Model

- a. Hermetic
- b. Semi-Hermetic
- c. Open

### 3- Type of Refrigerant

- a. R12
- b. R134a
- c. Isobutene
- d. Blend

### 4- Accessories

- a. Capacitor Type
- b. Starting Relay
- c. Voltage, Frequency and Current
- d. Electrical Circuit

### 5- Mounting Compressor

- a. Refrigerant Flow Direction
- b. Top on the Roof
- c. Bottom on Base
- d. Double Compressor Mounted

### 6- Compressor Capacity

# Sahandmina Engineering Company Ltd.

- a. Watt
- b. Horse Power
- c. B.T.U/Hr
- d. Kcal/Hr

## 7- Compressor Test Condition CECOMAF

Evaporating Temp.	-25° C
Condensing Temp.	55° C
Ambiant Temp.	32° C
Suction Gas Temp.	32° C
Liquid Temp.	55° C
Volatage/Hertz	220V/50 Hz
Heat out Put= Capacity + Watt Consumption	

### ASHRAE

Evaporating Temp.	-23.3° C
Condensing Temp.	55° C
Ambiant Temp.	32° C
Suction Gas Temp.	32° C
Liquid Temp.	32° C
Volatage/Hertz	220V/50 Hz
Heat out Put= Capacity + Watt Consumption	

### ASHRAE to CECOMAF

## Conversion of Capacity From CECOMAF into ASHRAE

R134a Multiply by 1.231

R22 Multiply by 1.097

R404 Multiply by 1.183

1 Watt = 0.86 Kcal/h

1 Watt = 3.41 BTU/h

1 Kcal/h = 1.0162 Watt

1 BTU/h = 0.293 Watt

8- Evaporating Temp. and Selection of Compressor

9- Thermostat

Thermostat Adjustment

- a. Cut-in Time - 5 to -15 Compressor Connected



# Sahandmina Engineering Company Ltd.

- b. Cut-out time -15 to -25 Compressor Dis-Connected
- c. Thermostat Setting, Max. Med, Min
- d. Thermostat Temperature Difference
- Refrigerant Type
  - 1- CFC- 12
  - 2- HFC-134a
  - 3- Isobutene, R-600
  - 4- Blend, (Isobutene+ Propane)
- Methods of Refrigerant Charging
  - 1- Bottle, 13.5 Kg. Cylinder
  - 2- Portable Charger
  - 3- Production, Evacuation and Charging Equipment
- Refrigerant Charge Weight
  - 1- Experimental, trial and error
  - 2- Calculation
  - 3- Comparison with other Refrigerants
- Refrigeration Leak Detection Procedure
  - 1- Conventional Method, (water and Soap)
  - 2- Portable Electronic Leak Detector
  - 3- Production Electronic Leak Detector
  - 4- Nitrogen, and Helium Leak Detection Procedure
- Accuracy and Precision of Leak Detection Procedure
  - 5- Conventional Method, (water and Soap)
  - 6- Portable Electronic Leak Detector
  - 7- Production Electronic Leak Detector
  - 8- Nitrogen, and Helium Leak Detection Procedure
- Recovery
- Recycling
- Reclaiming

## Testing Prototypes

- Test Prototypes with R12 Refrigerant to get desired test results.
- Hot Chamber Specification
- Placing Prototypes at Hot Chamber
- Mounting Sensors and their Place and Location
- Testing Condition

# Sahandmina Engineering Company Ltd.

- 1- Tropical "T" 43 °C
  - 2- Sub-Tropical 38 °C
  - 3- Normal 32 °C
  - 4- Sub-Normal 28 °C
  - 5- Cold 18 °C
  - 6- Relative Humidity
- Test Package
  - « M » Package
  - Meat
  - Ice
  - Different Tests
    - 1- Operational
    - 2- Performance
    - 3- Energy Consumption
    - 4- Ice Making
    - 5- Humidity
  - Testing Procedure
    - 1- Pull Down
    - 2- Continuous Run
    - 3- Cyclic Run
  - Duration of Test
  - Reading Test Result
  - Test Results Analysis

## **Conclusion**

All prototypes were tested successfully at the counterparts premises. The test results are being evaluated for proper functioning of refrigeration system components specially R134a compressor. The main difficulties and problems during implementation of the contract were hot chamber design and performance. The hot chambers are being constructed locally and improper insulation and air distribution inside the hot room, ineffective testing system and software affected the test performance quality.

## **Recommendation**

An up to dated, effective, and user-friendly Testing system for the enterprises is recommended to be supplied to the counterparts, to improve quality of model redesign and performance test.

Kindest Regards  
SMC.

# Sahand Mina Engineering Co. Ltd.

## Refrigeration Load Calculation Heat Leaks Through Walls Borna Sanat Arak

$$Q = U \cdot A \cdot \Delta T$$

Description	Dimension	Surface Area Sq. Mt.	Ambient Temp. °C	Reference Inside Temp.	$\Delta T$ Temp. Diff.	X Insulation Thickness	K Thermal Conductivity	U Coeff. Heat Resistance	Q U. A. $\Delta T$ Watt
Upper Side Walls	2x 90x45	0.81	32	+5	27	40	0.0184	0.46	10.06
Upper Back Panel	90x55	0.495	45	+5	40	40	0.0184	0.46	9.11
Top surface	55x45	0.25	32	+5	27	40	0.0184	0.46	3.11
Bottom surface	55x45	0.25	50	-18	68	60	0.0184	0.31	5.27
Upper Door Panel	90x55	0.495	32	+5	27	40	0.0184	0.46	6.15
Lower Door Panel	70x55	0.385	32	-18	50	60	0.0184	0.31	5.97
Lower Side Walls	2x70x45	0.63	32	-18	50	60	0.0184	0.31	9.77
Lower Back Panel	70x55	0.385	45	-18	63	60	0.0184	0.31	7.52
Total									56.96

# Sahand Mina Engineering Co. Ltd.

## Product Load Calculation

### Borna Sanat Arak

Product to be loaded	Product Mass Load Kg.	Product Specific heat Above Freezing Point J/Kg. K	Product Specific heat Below Freezing Point J/Kg K	Latent Heat of Fusion J/Kg.	Product Initial Temp C	Product Final Temp. C	Temp. Diff.	$Q_1$ $m \cdot C_1 \cdot \Delta T$	$Q_2$ $m \cdot C_2 \cdot \Delta T$	$Q_3$ M. h
ICE	10	4180	1950	333000	25	-18	43	12.1	4.06	38.54

$$Q_1 = (10 \times 25 \times 4180) / 86400 = 12.1, Q_2 = (10 \times 18 \times 1950) / 86400 = 4.06, Q_3 = (10 \times 333000) / 86400 = 38.54$$

$$Total = Q_1 + Q_2 + Q_3 = 54.7 \text{ Watts}$$


### Miscellaneous Heat Load

Air Change = $V \cdot N \cdot H$ V = Refrigerator Internal Volume N = Number of Air Change per Day H = Heat removed from cubic meter of air = 75000 jul/sec.	Gasket U. A. $\Delta T$ U = 0.07 L = 5.4 Ml. $\Delta T$ mean = 45	Electrometer	Florescent Lamp	Total
$(0.35) \times 30 \times 75000 = 9.11$	17.01	N/A	N/A	26.12

### Total refrigeration Load

Heat Leaks Through Walls	Product Load	Miscellanies Load	Safety Factors	Grand Total
56.96	54.7	26.12	25	172.23

# Sahand Mina Engineering Co. Ltd.



Refrigerator and Freezer  
Borna Sanat Arak

<b><i>Product Technical Specification</i></b>	
<b><i>Borna Sanat Arak</i></b>	
<b>Description</b>	<b>Specification</b>
Company Name	Borna Sanat Arak
Product Name	Refrigerator & Freezer
Product Model	F110
Product Application	Domestic
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	180x54x65
Freezer Compartment Overall Dimension and Wall Thickness	55x70x45 60 mm
Refrigerator Compartment Overall Dimension and Wall Thickness	55x90x45 60mm
Product Shape, Double Doors, Upright, Chest, etc	Double Door
Freezer Internal Net Volume	130 Liter
Refrigerator Internal Net Volume	220 Liter
Product Overall Volume	630 Liters
Product Inside Temperature C	-18 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Fellow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	-18 C
Refrigerator Inside Temperature	5 C
Evaporating Temperature	-23 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	Ref 40mm; Fre 60mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	290Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Oil Cooled
Compressor Cooling Capacity	200 Watts

Watt	
Compressor Model Number	20 G
Compressor Manufacturer	Danfoss Germany
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Static Cooled
Condenser Dimension, Length, Inside Tube Diameter,	Length 19; 26 Tube; 5mm
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Wire & Tubes & Roll bond
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	Length(Fre.) 19m, Ref.40x40
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	XH5
Dryer Material, Weight and Size	10 Gr.; Silica Jell
Capillary Tube Diameter and Length	0.36 mm dim. 3.6mm length





# Sahand Mina Engineering Co. Ltd.

## Product Load Calculation

ARIZ RF4060

Product to be loaded	Product Mass Load Kg.	Product Specific heat Above Freezing Point J/Kg. K	Product Specific heat Below Freezing Point J/Kg. K	Latent Heat of Fusion J/Kg.	Product Initial Temp C	Product Final Temp. C	Temp. Diff.	$Q_1$ $m C_1 \Delta T$	$Q_2$ $m. C_2. \Delta T$	$Q_3$ M. h
ICE	10	4180	1950	333000	25	-18	43	12.1	4.06	38.54

$$Q_1 = (10 \times 25 \times 4180) / 86400 = 12.1, Q_2 = (10 \times 18 \times 1950) / 86400 = 4.06, Q_3 = (10 \times 333000) / 86400 = 38.54$$

$$Total = Q_1 + Q_2 + Q_3 = 54.7 \text{ Watts}$$


### Miscellanies Heat Load

Air Change = V . N . H V = Refrigerator Internal Volume N = Number of Air Change per Day H = Heat removed from cubic meter of air = 75000 jul/sec.	Gasket U . A . $\Delta T$ U = 0.07 L = 5.34 Mt. $\Delta T$ mean = 45	Electrometer	Florescent Lamp	Total
$(0.25) \times 30 \times 75000 / 86400 = 6.51$	16.82	N/A	N/A	23.33

### Total refrigeration Load

Heal Leaks Through Walls	Product Load	Miscellanies Load	Safety Factors	Grand Total
59.5	54.7	23.33	25	171.91

# Sahand Mina Engineering Co. Ltd.



Refrigerator and Freezer  
Ariz 40/60

**Product Technical Specification****Ariz**

<b>Description</b>	<b>Specification</b>
Company Name	Ariz
Product Name	Refrigerator & Freezer
Product Model	Rf 40/60
Product Application	Domestic
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	185x65x50
Freezer Compartment Overall Dimension and Wall Thickness	45x51x71 60mm
Refrigerator Compartment Overall Dimension and Wall Thickness	47x56x88 40mm
Product Shape, Double Doors, Upright, Chest, etc	Double Door
Freezer Internal Net Volume	78 Liter
Refrigerator Internal Net Volume	172 Liter
Product Overall Volume	600 Liters
Product Inside Temperature C	-18 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Fellow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	-18 C
Refrigerator Inside Temperature	5 C
Evaporating Temperature	-23 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	Ref 40mm; Fre 60mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	265Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Oil Cooled
Compressor Cooling Capacity	220 Watts

Watt	
Compressor Model Number	20 G
Compressor Manufacturer	Danfoss Germany
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Static Cooled
Condenser Dimension, Length, Inside Tube Diameter,	Length 18; 24 Tube
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Wire & Tubes
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	Length 22m; Internal Diameter 6mm;
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	XH5
Dryer Material, Weight and Size	15 Gr
Capillary Tube Diameter and Length	0.31 mm dim. 3600 mm length



# Sahand Mina Engineering Co. Ltd.

## Product Load Calculation

### Abbaspour

Product to be loaded	Product Mass Load Kg.	Product Specific heat Above Freezing Point J/Kg. K	Product Specific heat Below Freezing Point J/Kg. K	Latent Heat of Fusion J/Kg.	Product Initial Temp C	Product Final Temp. C	Product Temp. Diff.	$Q_1$ $m C_1 \Delta T$	$Q_2$ $m. C_2. \Delta T$	$Q_3$ $M. h$
ICE	35	4180	1950	333000	25	-18	43	42.33	14.22	134.9

$$Q_1 = (35 \times 25 \times 4180) / 86400 = 42.33, Q_2 = (35 \times 18 \times 1950) / 86400 = 14.22, Q_3 = (35 \times 333000) / 86400 = 134.9$$

$$\text{Total} = Q_1 + Q_2 + Q_3 = 191.45 \text{ Watts}$$


### Miscellanies Heat Load

Air Change = V . N . H	Gasket	Electrometer	Florescent Lamp	Total
V = Refrigerator Internal Volume N = Number of Air Change per Day H = Heat removed from cubic meter of air = 75000 jul/sec.	U. A. $\Delta T$ U=0.07 L = 7 Ml. $\Delta T$ mean=63			
$(0.85 \times 30 \times 75000) / 86400 = 22.14$	30.87	N/A	N/A	53.01

### Total refrigeration Load

Heal Leaks Through Walls	Product Load	Miscellanies Load	Safety Factors	Grand Total
139.78	191.45	53.01	25	480.3

Sahand Mina Engineering Co. Ltd.



Freezer  
Abbaspour

**Product Technical Specification**

**Abbaspour**

<b>Description</b>	<b>Specification</b>
Company Name	Abbaspour
Product Name	Domestic Refrigerator
Product Model	6 Door Freezer
Product Application	Domestic
Operating Temperature	43 C
Climatic Condition	Tropical
Product Overall Dimension WxLxH mm	1900*750*850
Freezer Compartment Overall Dimension and Wall Thickness	50-70 mm
Product Shape, Double Doors, Upright, Chest, etc	6 Door
Product Net Volume	1200 liter
Product Inside Temperature C	-25 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Flow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	-25 C
Refrigerator Inside Temperature	N/A
Evaporating Temperature	-32 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	50 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	2000Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling Capacity Watt	550 Watts
Compressor Model Number	¾ G
Compressor Manufacturer	danfoss
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled



Condenser Dimension, Length, Inside Tube Diameter,	Four Rows Tube Coil and Fins 37*34 cm
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Wire and Tube
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Cylindrical
Dryer Material, Weight and Size	Sylycajen 100 Gr.
Capillary Tube Diameter and Length	0.32 mm dim. 3000 mm length



# Sahand Mina Engineering Co. Ltd.

## Product Load Calculation

### Sard Va Garm Iran

Product to be loaded	Product Mass Load Kg	Product Specific heat Above Freezing Point J/Kg. K	Product Specific heat Below Freezing Point J/Kg. K	Latent Heat of Fusion J/Kg.	Product Initial Temp C	Product Final Temp. C	Temp. Diff.	$Q_1$ $m \cdot C_1 \cdot \Delta T$	$Q_2$ $m \cdot C_2 \cdot \Delta T$	$Q_3$ M . h
ICE	15	4180	1950	333000	25	-28	43	18.14	9.53	57.81

$$Q_1 = (15 \times 25 \times 4180) / 86400 = 18.14, Q_2 = (15 \times 28 \times 1950) / 86400 = 9.53, Q_3 = (15 \times 333000) / 86400 = 57.81$$

$$Total = Q_1 + Q_2 + Q_3 = 85.48 \text{ Watts}$$


### Miscellanies Heat Load

Air Change = V . N . H V = Refrigerator Internal Volume N = Number of Air Change per Day H = Heat removed from cubic meter of air = 75000 jul/sec.	Gasket U . A . $\Delta T$ U = 0.07 L = 4.24 Mt. $\Delta T$ mean = 60	Electrometer	Florescent Lamp	Total
(0.384 x 30 x 75000) / 86400 = 10	17.81	16	N/A	43.81

### Total refrigeration Load

Heal Leaks Through Walls	Product Load	Miscellanies Load	Safety Factors	Grand Total
98.66	85.48	43.81	20	273.54

# Sahand Mina Engineering Co. Ltd.



Refrigerator and Freezer  
Sard Va Garm Iran

**Product Technical Specification****Sard Va Garm Iran**

<b>Description</b>	<b>Specification</b>
Company Name	Sard Va Garm Iran
Product Name	Chest Freezer
Product Model	4 Doors
Product Application	Domestic and Commercial
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	85*70*130
Freezer Compartment Overall Dimension and Wall Thickness	50 mm
Refrigerator Compartment Overall Dimension and Wall Thickness	N/A
Product Shape, Double Doors, Upright, Chest, etc	4 Doors
Freezer Internal Net Volume	384 Liters
Refrigerator Net Volume	N/A
Product Net Volume	384 Liters
Product Inside Temperature C	-28 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Fellow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	-28 C
Refrigerator Inside Temperature	N/A
Evaporating Temperature	-32 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	50 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	850Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity	275-360 Watts

Watt	
Compressor input Power, Watt	1/3-1/2 hp
Compressor Model Number	
Compressor Manufacturer	Danfoss Germany
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	30 Rows Tube Coil and Fins Length 35 cm; Diameter 11cm
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Tubes
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Cylindrical
Dryer Material, Weight and Size	20 gr; Silicone.
Capillary Tube Diameter and Length	0.45 mm dim. 3200 mm length



# Sahand Mina Engineering Co. Ltd.

## Product Load Calculation

### Sardin Tous

Product to be loaded	Product Mass Load Kg.	Product Specific heat Above Freezing Point J/Kg. K	Product Specific heat Below Freezing Point J/Kg. K	Latent Heat of Fusion J/Kg.	Product Initial Temp C	Product Final Temp. C	Temp. Diff.	$Q_1$ $m C_1 \Delta T$	$Q_2$ $m . C_2 . \Delta T$	$Q_3$ M . h
ICE	15	4180	1950	333000	25	-28	43	18.14	953	57.81

$$Q_1 = (15 \times 25 \times 4180) / 86400 = 18.14, Q_2 = (15 \times 28 \times 1950) / 86400 = 9.53, Q_3 = (15 \times 333000) / 86400 = 57.81$$

$$Total = Q_1 + Q_2 + Q_3 = 85.48 \text{ Watts}$$

### Miscellaneous Heat Load


Air Change = $V \cdot N \cdot H$ V = Refrigerator Internal Volume N = Number of Air Change per Day H = Heat removed from cubic meter of air = 75000 jul/sec.	Gasket U . A . $\Delta T$ U = 0.07 L = 5 Mt. $\Delta T$ mean = 60	Electrometer	Florescent Lamp	Total
$(0.3 \times 30 \times 75000) / 86400 = 7.8$	21	16	N/A	44.8

### Total refrigeration Load

Heat Leaks Through Walls	Product Load	Miscellanies Load	Safety Factors	Grand Total
59.65	85.48	44.8	20	227.92



Sahand Mina Engineering Co. Ltd.



Refrigerator and Freezer  
Sardin Tous

**Product Technical Specification**  
**Sardin Tous**

<b>Description</b>	<b>Specification</b>
Company Name	Sardin Tous
Product Name	Chest Freezer
Product Model	2 Doors
Product Application	Commercial & Domestic
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	112x82x65
Freezer Compartment Overall Dimension and Wall Thickness	70 mm
Refrigerator Compartment Overall Dimension and Wall Thickness	N/A
Product Shape, Double Doors, Upright, Chest, etc	Chest Freezer
Freezer Internal Net Volume	300 Liters
Refrigerator Net Volume	N/A
Product Net Volume	300 Liters
Product Inside Temperature C	-25 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Fellow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	-25 C
Refrigerator Inside Temperature	N/A
Evaporating Temperature	-32 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	70 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	400Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling System Static, Oil Cooled, Fan Cooled	Fan Cooled
Compressor Cooling Capacity	250 Watts

Watt	
Compressor Manufacturer	Danfoss Germany
Compressor Mounting Place Top, Bottom, Front, Back	Bottom
Condenser Type, Static, Fan Cooled	Fan Cooled
Condenser Dimension, Length, Inside Tube Diameter,	30 Rows Tube Coil and Fins Length 35 cm; Diameter 11cm
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Tubes
Evaporator Dimension, Length, Surface Area, Inside Tube Diameter	
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Cylindrical
Dryer Material, Weight and Size	20 Gr.
Capillary Tube Diameter and Length	0.36 mm dim. 28000 mm length



# Sahand Mina Engineering Co. Ltd.

## Product Load Calculation Booran Saz Karaj (Koohsar)

Product to be loaded	Product Mass Load Kg.	Product Specific heat Above Freezing Point J/Kg. K	Product Specific heat Below Freezing Point J/Kg. K	Latent Heat of Fusion J/Kg.	Product Initial Temp C	Product Final Temp. C	Product Temp. Diff.	$Q_1$ $m \cdot C_1 \cdot \Delta T$	$Q_2$ $m \cdot C_2 \cdot \Delta T$	$Q_3$ M. h
ICE	10	4180	1950	333000	25	-18	43	12.1	4.06	38.54

$$Q_1 = (10 \times 25 \times 4180) / 86400 = 12.1, \quad Q_2 = (10 \times 18 \times 1950) / 86400 = 4.06, \quad Q_3 = (10 \times 333000) / 86400 = 38.54$$

$$Total = Q_1 + Q_2 + Q_3 = 54.7 \text{ Watts}$$


### Miscellanies Heat Load

Air Change = V . N . H V = Refrigerator Internal Volume N = Number of Air Change per Day H = Heat removed from cubic meter of air = 75000 jul/sec.	Gasket U. A. $\Delta T$ U=0.07 L=4.34 Mt. $\Delta T$ mean=45	Electrometer	Florescent Lamp	Total
(0.415x30x75000)/86400 = 10.81	13.67	N/A	N/A	24.48

### Total refrigeration Load

Heal Leaks Through Walls	Product Load	Miscellanies Load	Safety Factors	Grand Total
49.56	54.7	24.48	25	160.92

# Sahand Mina Engineering Co. Ltd.



Refrigerator and Freezer  
Booran saz Karaj (Koohsar)

<b><i>Product Technical Specification</i></b>	
<b><i>Booran Saz Karaj (Koohsar)</i></b>	
<b>Description</b>	<b>Specification</b>
Company Name	Booran Saz Karaj (Koohsar)
Product Name	Domestic Refrigerator
Product Model	40/60
Product Application	Domestic
Operating Temperature	32 C
Climatic Condition	Normal
Product Overall Dimension WxLxH mm	1940*510*640
Freezer Compartment Overall Dimension and Wall Thickness	80 mm
Product Shape, Double Doors, Upright, Chest, etc	Double Door
Freezer Internal Net Volume	185 Liter
Refrigerator Net Volume	230 Liter
Product Net Volume	630 liter
Product Inside Temperature C	-25 C
Water Storage Tank Capacity, Water Cooler	N/A
Type of Water Storage Tank Cylinder, Cubic, etc.	N/A
Water Fellow per hour for water cooler	N/A
Water Storage Tank Dimension	N/A
Water Outlet Temperature	N/A
Water Inlet Temperature	N/A
Freezer Inside Temperature	-25 C
Refrigerator Inside Temperature	+2/+8 C
Evaporating Temperature	-32 C
Foam Insulation Thickness mm Side Walls, Top, Bottom, Door, Back Panel	40 mm
Type of PU Foam	R11 Pu Foam
Foam Density, Kg/Cu. Mt.	40 Kg/Cu. Mt.
Foam Mixture, Percentage Pol% + R11% + Isocyanate%	37% + 13% + 50%
Refrigerant Type	R12
Refrigerant Charge Weight Gr.	260Gr.
Type of Compressor, Hermetic, Semi Hermetic, Open	Hermetic
Compressor Cooling Capacity Watt	175 Watts
Compressor Model Number	20 G
Compressor Manufacturer	Matsoshita
Compressor Mounting Place Top, Bottom, Front, Back	Bottom

Condenser Type, Static, Fan Cooled	Static Cooled
Condenser Dimension, Length, Inside Tube Diameter,	Four Rows Tube Coil and Fins 0.8 mm
Condenser Material, Aluminum, Copper, Copper Coated, etc,	Copper
Condenser mounting Place, Back Wall, Top, Bottom	Bottom
Evaporator Type, Fin and Tube, Roll Bond, Wire and Tube, etc.	Wire and Tube
Evaporator Material, Aluminum, Copper, Copper Coated, etc,	Copper
Dryer Type,	Cylindrical
Dryer Material, Weight and Size	Silicon jell 100 Gr.
Capillary Tube Diameter and Length	0.32 mm dim. 3200 mm length



# BORNA

## Setting


Test Date	Nov 18-02
Test Type	Cycling
Hot Room Temp.	32
Hot Room Hum.	50
File Name	M\FR-18\18-004

## Product Specification


Product Type	Ref. & freezer
Compressor Type	Danfoss-1/4 HP
Refrigerant	R134a-225 gr
Cappil. Length	0.036 in - 340 Cm
Evap. Volume	90 CC - 19 m
Condensor Length	12 PASS-4 TUBE-12 m
Thermostat Type	DANFOSS-Short

## Test Result

Total Test Time(h:m)	04:04
Working Time(h:m)	04:04
Working Percentage	100.0%
Energy Cons. (KWh)	0.7247
Av. En. Cons. (KWh/Day)	4.277
No. of Thermostat	0
No. of Over Load	0



Nov 18-02



# Sard va Garm Iran

## Setting


Test Date	Oct 19-02
Test Type	Pulldown-Run
Hot Room Temp.	43
Hot Room Hum.	30
File Name	M\R-12\R12-011

## Product Specification


Product Type	Chest freezer
Compressor Type	NATIONAL-12G
Refrigerant	R134-140 gr
Capill. Length	0.031 in - 300 Cm
Evap. Volume	Roilband
Condensor Length	9 PASS-2 TUBE-9 m
Thermostat Type	D-short

## Test Result

Total Test Time(h:m)	22:40
Working Time(h:m)	22:40
Working Percentage	100.0%
Energy Cons. (KWh)	3.138
Av. En. Cons. (KWh/Day)	3.323
No. of Thermostat	0
No. of Over Load	0



Oct 19-02



# Booran Saz Karaj

## Setting


Test Date	Nov 28-02
Test Type	Cycling
Hot Room Temp.	32
Hot Room Hum.	50
File Name	OM\FR-16\16-30

## Product Specification


Product Type	Ref. & freezer
Compressor Type	NATIONAL-20G
Refrigerant	R134-250 gr
Cappil. Length	0.036 in - 340 Cm
Evap. Volume	110 CC - 11.5 m
Condansor Length	12 PASS-4 TUBE-12 m
Thermostat Type	DANFOSS-3.7

## Test Result

Total Test Time (h:m)	23:59
Working Time (h:m)	13:15
Working Percentage	55.3%
Energy Cons. (KWh)	2.681
Av. En. Cons. (KWh/Day)	2.683
No. of Thermostat	0
No. of Over Load	72



Nov 28-02



# ABBASPOUR

## Setting


Test Date	Oct 17-02
Test Type	Pull down - Run
Hot Room Temp.	32
Hot Room Hum.	60
File Name	OM\FR-16\16-39

## Product Specification


Product Type	Freezer
Compressor Type	Danfoss - 1/4 HP
Refrigerant	R134a - 215 gr
Cappil. Length	0.036 in - 360 Cm
Evap. Volume	110 CC-11.5 m-Ac
Condensor Length	12 PASS-4 TUBE-12 m
Thermostat Type	Danfoss-Short

## Test Result

Total Test Time(h:m)	21:19
Working Time(h:m)	21:19
Working Percentage	100.0%
Energy Cons. (KWh)	3.380
Av. En. Cons. (KWh/Day)	3.805
No. of Thermostat	0
No. of Over Load	0



Oct 17-02



# ARIZ

## Setting


Test Date	Oct 12-02
Test Type	Cycling
Hot Room Temp.	32
Hot Room Hum.	50
File Name	M\FR-18\18-006

## Product Specification


Product Type	RF 4060
Compressor Type	Danfoss-1/4 HP
Refrigerant	R134a-225 gr
Cappil. Length	0.036 in - 340 Cm
Evap. Volume	90 CC - 19 m
Condensor Length	12 PASS-4 TUBE-12 m
Thermostat Type	DANFOSS-Short

## Test Result

Total Test Time (h:m)	02:37
Working Time (h:m)	01:12
Working Percentage	46.2%
Energy Cons. (KWh)	0.3016
Av. En. Cons. (KWh/Day)	2.766
No. of Thermostat	0
No. of Over Load	10



Oct 12-02



# SARDIN TOUS

## Setting


Test Date	Oct 28-02
Test Type	Cycling
Hot Room Temp.	32
Hot Room Num.	50
File Name	M\FR-18\18-006

## Product Specification

Product Type	Chest freezer
Compressor Type	Danfoss-1/4 HP
Refrigerant	R134a-225 gr
Cappil. Length	0.036 in - 340 Cm
Evap. Volume	90 CC - 19 m
Condenser Length	12 PASS-4 TUBE-12 m
Thermostat Type	DANFOSS-Short

## Test Result

Total Test Time(h:m)	02:36
Working Time(h:m)	01:12
Working Percentage	46.5%
Energy Cons. (KWh)	0.3009
Av. En. Cons. (KWh/Day)	2.778
No. of Thermostat	0
No. of Over Load	10



Oct 28-02

