



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

2/2!!



AZMAYESH INDUSTRIAL FACTORIES CO.

PROJECT NO. MP/IRA/94/403

UNIDO, s CONTRACT NO. 94/097



FINAL REPORT



PREPARED BY: A. BAHMANI . N. IMANI

EDITED AND APPROVED BY: UNIDO


September 1995

TABLE OF CONTENTS

CHAPTER	Page
1 - Introduction	1
1 - 1 Project background in AZMAYESH Co.	2
2 - Synopsis	3
3 - Activities	5
4 - Tasks	8
4 - 1 Tasks analysis	9
5 - Prototype evaluation and analysis	13
5 - 1 EPA, Refrigerator analysis.	14
5 - 2 Ariston's methods of heat load calculation.	17
5 - 3 ASHRAE's methods of heat load calculation.	19
5 - 4 Conclusions, for selecting heat load calculation.	20
5 - 5 Prototypes performance evaluation.	21
5 - 6 Performance analysis	24
5 - 7 Performance comparison charts for different models	25 - 28
5 - 8 Opimizing test results.	29
6 - Conclusions	30
7 - Recommendations	31
8 - Bibliography and references	34
9 - Attachments	35

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995

INTRODUCTION

We are pleased to forward you our Final report regarding the execution of contract No. 94/097 which has been nominated as the first phase of CFC Phase Out project in AZMAYESH Co., as a part of project No. MP/IRA/94/403 in Iran.

AZMAYESH Co., under supreme supervision of UNIDO and UNDP in Tehran began the execution of this contract on first of Nov. 1994. Nevertheless we have been involved in this project directly or indirectly since 1992 by using reduced CFC gas as blowing agent in our insulation material, also we were the first refrigerator manufacture in Iran, that signed a contract with LIEBHERR of Germany to manufacture, no frost refrigerators and freezers, using Ozone friendly HFC R134a refrigerant.

AZMAYESH Co.'s main consideration is to achieve this programme timely and in the best and fastest possible way. As a leading manufacture in Iran we are proud that we could conduct the first international symposium of application of Ozone Friendly Gases in Iran, with collaboration of some German manufacturers such as BAYER and LEIBHERR, in October 1994. In this symposium more than 150 experts from Iranian local manufacturers as well as Iran Environmental Department and some universities were taking part.

This report contains following subjects.

- 1 - Project back ground in AZMAYESH Co.;
- 2 - Synopsis;
- 3 - Activities;
- 4 - Tasks
- 5 - Prototypes evaluation and analysis;
- 6 - Conclusion;
- 7 - Recommendations;
- 8 - Bibliography and References;
- 9 - Attachments;

(1)

PROJECT BACKGROUND IN AZMAYESH CO.

AZMAYESH Industrial Factories Co. As a leading home appliance manufacturer in Iran was established in 1959, the main activities of AZMAYESH Co. In Marvdasht plant is producing eight models of refrigerators and freezers, as well as washing machine and vacuum cleaner. The older factory is located near Tehran and produces convector heaters and water coolers as well as water heaters.

The total production rate of refrigerators and freezers are estimated to be more than 250,000 units per year at maximum capacity. More than 1200 people are working in Marvdasht plant and 600 production personnel are working in refrigerator production department. Laboratory department is taking care of testing of performance criteria of our refrigerators and freezers, as well as material acceptance tests.


The total annual ODP consumption rate, are estimated 159 MT (33 MT of CFC-12 and 126 MT of CFC-11). 3 MT of CFC-12 are considered for our service stations. Approximately more than 2,000,000 refrigerator and freezer units have been manufactured by AZMAYESH Co., and are still in service in Iran. The average service lives of our refrigerator units are 15 years. More than 180 authorized service agents are repairing our refrigerator units and give services to our customers in Iran. Refrigerator components such as Compressor Unit, Thermostat and driers are imported.

The existing high pressure foaming machines are three, one is used for refrigerators and the other for freezers, the smaller one is used for doors. The wet parts of our foaming machines are made of ELASTOGRAN and dry parts are made of PERROS. More than eighty sets of vacuum pumps are LEYBOLD model D2A.

Our charging equipment and leak detectors are old and should be replaced with new equipments.

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995

AZMAYESH INDUSTRIAL FACTORIES CO.

SYNOPSIS

The project No. MP/IRA/94/403 has been nominated to Islamic Republic of Iran for the Multilateral Fund for the implementation of The Montreal Protocol Financing.

AZMAYESH Industrial Factories Company, under UNIDO's contract No. 94/097 has executed, the design, calculation and drafting for model redefinition prototyping, testing prototypes for functionality and performance of five models of refrigerators and ref. freezers; i.e., to redesign the cooling units of all models so that they could run on the new ozone friendly refrigerant R134a instead of the ODP active CFC-12.

Under this contract AZMAYESH Co. has prepared a study of following subjects.

- A) Dimensional specifications;
 - Type and insulation thickness;
 - Refrigerator unit component details;
 - Working performance;
 - Energy consumption;
- B) Selection of HFC 134a compatible component;
- C) Redesigning of the complete refrigeration circuit;
- D) Specifying necessary changes in the refrigeration system;
- E) Preparation of trial equipment;
- F) Testing of prototypes for functionality and performance;
- G) Evaluation of test results;

Two progress reports were prepared in order to comply with the contract's requirements, the reports discuss following subjects:

1- First Progress Report


- 1 - 1 Method of Refrigeration Load Calculation.
- 1 - 2 Method of Product Load Calculation.
- 1 - 3 Refrigeration System Condition
- 1 - 4 Equipment Selection
- 1 - 5 Refrigeration Unit Governing Relations and Equations.
- 1 - 6 Refrigerator Model AR06 Load Calculation and Equipment Selection.
- 1 - 7 Refrigerator Model AR08 Load Calculation and Equipment Selection.
- 1 - 8 Refrigerator Model AR10 Load Calculation and Equipment Selection.
- 1 - 9 Refrigerator Model AR12 Load Calculation and Equipment Selection.
- 1 - 10 Refrigerator Model ARF2 Load Calculation and Equipment Selection.

2 - Second Progress Report

- 2 - 1 Products Specifications.
- 2 - 2 Working Performance Characteristics.
- 2 - 3 Determination of Constant " C "
- 2 - 4 Selection of R134a Compatible Components.
- 2 - 5 Evaluation of Prototypes.
- 2 - 6 Temperature Test Procedure.
- 2 - 7 Energy Consumption.
- 2 - 8 Optimization Method
- 2 - 9 Preperation of Trial Equipment.

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995

ACTIVITIES

Following activities were accomplished during execution of the contract since Nov. 1994 as well as other activities regarding project No. MP/TRA/94/403.

- 1 - Corresponding with UNIDO in Vienna and UNDP in Tehran concerning execution of the contract with respect to the contract requirements.
- 2 - Coordination with Marvdasht Plant in order to identify models, which are going to be modified and collect necessary information in this regard.
- 3 - Deliberation of required equipments for modifying the first prototype in Marvdasht plant.
- 4 - Corresponding with UNIDO and UNDP office in Tehran in order to give them the requested information regarding number of jigs and fixtures existed in Marvdasht plant. for the purpose of accomplishing required modifications.
- 5 - Preparing Marvdasht plant's layout plan for the purpose of preparing Term of Reference of modification and purchasing foaming machines.
- 6 - Corresponding with UNDP office in Tehran, regarding supplying necessary equipments such as vacuum pumps and a leak detector and also refrigerant chargers. required for execution of the contract.
- 7 - Making three more prototypes (AR08, AR10 & AR12) in our service center in Tehran as well as twenty prototypes made in Marvdasht plant, for the purpose of research and development.
- 8 - Shipping one of prototype Model AR08 to dkk- FORON research center in Germany with close cooperation and coordination with UNDP office in Tehran and UNIDO, in order to test the functionality and performance of the prototype.

(5)

9 - Sending two prototypes Model AR12 and AR10 to Sharif Industrial University of Tehran's research center, to check the performance of each prototype.

10 - Review and study of performance characteristics and specifications of more than thirty four-different kinds of compressors from different manufacturers, such as DANFOSS, ZANUSSI, NECCHI, GOLDSTAR, MATSUSHITA, ASPERA & TECOMSEH. In order to select the most suitable compressor fitted to our refrigeration system, table one of the second progress report shows the model and type of each compressor.

11 - Modifying water drain tray under evaporator compartment, in order to keep evaporator temperature constant and steady.

12 - Determination of a suitable amount of R134a refrigerant charge for each model.

13 - Determination of correct length of capillary tube.

14 - Selecting Drier type XI-9 and XII-7 which have the higher potential of absorbing humidity in a refrigeration cycle.

15 - Ordering 1500 units of R134a compressors, as well as driers and R134a refrigerant for production of 1500 refrigerator units for field test programme.

16 - Designing new test sheet for recording prototype performance data.

17 - Preparing two progress reports as follows;

1 - Redesign, calculation and modification of models AR06, AR08, AR10, AR12 and ARF2.

2 - Component selection, prototype testing and evaluation of performance of five models.

AZMAYESH INDUSTRIAL FACTORIES CO.

18 - Coordinating and corresponding with, Ministry of Commerce, Ministry of Foreign Affairs, Bureau of Customs, Bank Markazi of IR IRAN, in order to get Authorization for release of five sets of chargers and leak detectors, for ARJ, AZMAYESH, BAHMAN, IRAN POUYA and PARS. on behalf of UNIDO and UNDP.

19 - Coordinating and corresponding with ARJ, BAHMAN, IRAN POUYA and PARS APPLIANCES Co., in order to deliver four sets of charger and leak detector as well as spare parts. These equipments were purchased by UNIDO, from A'GRAMKOW, under Multilateral Fund Financing Programme, through project No. MP/TRA/94/403.

20 - Performing more than ten site surveys, in Marvdasht plant, in order to follow up all project activities in Marvdasht, and coordinate with authorities.


21 - Participating in an academic seminar and practical laboratory course of research and design of new refrigeration technology for phasing out CFC's and minimizing ODP impact. Held at dkk- FORON research center at Scharfenstein Germany on behalf of UNIDO, from 27th Feb. 1995 till 17th March 1995.

22- Visiting Liebherr and Foron Manufacturing facilities in Germany. in order to see their new technologies in this regard.

(7)

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995

TASKS

For the execution of the said contract, the following tasks have been accomplished.

1 - Preparation of the first progress report, including

1 - 1- Refrigeration Load Calculations:

In this section all necessary information has been gathered to calculate heat loads.

The following items have been considered to determine heat loads.

- 1 - 1 - 1 Heat gain by conduction through walls.
- 1 - 1 - 2 Determination of Coefficient of heat transmission.
- 1 - 1 - 3 Determination of temperature difference between Ambient and Freezer and Refrigerator Compartments.
- 1 - 1 - 4 Determination of thermal conductivity of, foam, carbon steel and ABS plastic.
- 1 - 1 - 5 Determination of product load calculations governing rules and equations.
- 1 - 1 - 6 Determination of product, latent heat, freezing point and specific heat.

1 - 2 Refrigeration System Condition:

The following subjects were considered to be discussed as important tasks in the first progress report. In this section all information, required for Determination of refrigeration system conditions, such as inlet and outlet temperature and pressure have been discussed.

1 - 2 - 1 Compressor working condition.

(8)

- 1 - 3 - 2 Condenser working condition.
- 1 - 2 - 3 Capillary tube working condition.
- 1 - 2 - 4 Evaporator working condition.
- 1 - 2 - 5 C.O.P., Compressor coefficient of performance.

1 - 3 Equipment Selection:

In this section the method of refrigeration system components selection, has been discussed. The desired compressor operating time and also minor changes in the amount of refrigerant charge and possibility of increasing capillary tube were explained.

A comparison table of existing R12 and R134a compressors was prepared to show the differences of compressors cooling capacity.

1 - 4 Refrigeration Unit Governing Rules and Equations:

All governing rules and equations necessary to calculate and determine the capacities of refrigeration system were brought in this section.

1 - 5 In sections I through X, the methods of refrigeration load calculation and equipment selection for five Models of AR06, AR08, AR10, AR12 and AR12 have been discussed.

ANALYSIS

The first progress report has been prepared mainly to discuss theoretical issues of choosing new R134a refrigerant. In this report ASHRAE handbook of fundamentals of refrigeration was used to calculate heat load and etc., nevertheless there are many other methods in the other references, which are similar, with a slight difference. We have to take into our consideration the point that since our Model Refrigerators are already existed and we do not have to design a new refrigerator unit, it is not necessary to consider all details for heat load calculations.

AZMAYESH INDUSTRIAL FACTORIES CO.

For example heat leaks through cabinet edges and door gasket and door openings could be neglected, because we already add ten percent of total heat loss to this figure.

For determination of product load calculation. there are two ideas in this regard;

a) To consider maximum product capacity of refrigerator and freezer units with respect to the actual internal volume of the unit. And calculate all heat gains from products either in refrigerator or freezer compartments.

b) To consider and calculate, the Kcal/hrs require to make least three Kg ice in the freezer compartment.

ASHRAE standard has selected the first method above. and we have chosen this method respectively.

2 - Second progress report

In order to prepare the second progress report the following tasks were achieved.

2 - 1 Making twenty-three prototypes, for the purpose of functionality and performance test run, as follow; .

2 -1-1 Model AR06	Four units
2 -1-2 Model AR08	Five units
2 -1-3 Model AR10	Five units
2 -1-4 Model AR12	Five units
2 -1-5 Model ARF2	Five units

2 - 2 Designing a new test sheet in accordance with ISO standard requirement, for the purpose of recording test data.

AZMAYESH INDUSTRIAL FACTORIES CO.

2 - 3 Preparing non CFC refrigeration trial production compressor selection form. for comparing different compressors technical specifications in comparison with our cooling capacity requirements.

2 - 4 Testing following compressor models on our prototypes:

2-4-1 ASPERA	MODEL. BP 1048 Z 22
2-4-2 ASPERA	MODEL. BP 1111 Z
2-4-3 ASPERA	MODEL. B 1116 Z
2-4-4 ASPERA	MODEL. B 1118 Z
2-4-5 GOLDSTAR	MODEL. NR 58 LAEG
2-4-6 GOLDSTAR	MODEL. NR 62 LAEG
2-4-7 GOLDSTAR	MODEL. V75 LAEG
2-4-8 DANFOSS	MODEL. FR 8.5 G
2-4-9 TECAMSEH	MODEL. AE 360 KS 561

2 - 5 Testing following R12 compressors to compare with R134a compressors:

2-5-1 ZANUSSI	MODEL. G45AW
2-5-2 MATSUSHITA	MODEL. FN51Q11G
2-5-3 MATSUSHITA	MODEL. FN77G18G

2 -6 Testing models AR12. ARF2. AR08. prototypes under 18. 32 and 43 degree centigrade ambient temperature test condition.

2 -7 Testing Models AR06 and AR10, prototypes under 43 degree centigrade ambient temperatures.

2 - 8 Testing four prototypes model AR12. under following conditions:

2 -8 -1 Under 18, 32 and 43 degree centigrade ambient temperature condition, with ten percent refrigerant charges reduced and the same capillary tube length as R12 system.


2 - 8 - 2 Under 43 degrees ambient temperature condition. with ten percent

AZMAYESH INDUSTRIAL FACTORIES CO.

- increase in capillary tube length and the same refrigerant charge as R12 system.
- 2 - 8 - 3 Under 43 degree centigrade temperature conditions, with the same refrigerant charge and capillary tube length as R12 system.
- 2 - 9 Comparing R12 system performance with R134 system performance.
- 2 - 10 Preparing product specifications.
- 2 - 11 Preparing working performance characteristics.
- 2 - 12 Preparing method of determination of constant "C."
- 2 - 13 Selection of R134a compatible components.
- 2 - 14 Performing evaluation of prototypes' actual performance.
- 2 - 15 Preparing temperature test procedure.
- 2 - 16 Preparing method of determination of energy consumption.
- 2 - 17 Preparing method of refrigeration system optimization.
- 2 - 18 Preparation of trial test equipments.
- 2 - 19 Editing two-progress report for accuracy and completeness.
- 2 - 20 Reviewing all available documents regarding changing refrigerant R12 into R134a, such as technical specification of different refrigerators from other manufacturers.
- 2 - 21 Collecting all necessary information from different sources, such as the department of environmental of USA.

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995

PROTOTYPES EVALUATION AND ANALYSIS

In preparation of the first progress report, we have chosen an appropriate method for our refrigeration load calculation. To respond our design and configuration requirements, choosing an appropriate method of refrigeration load calculation is the aim of selecting compatible components. The method of refrigeration load calculation for a new design refrigerator could be completely different, in comparison with an existing in production refrigerators, because, in this case, we are not looking for the new nature of each refrigerator component or parts. In contemporary with designing new refrigerator model, we have to consider many parameters, such as heat leaks from outside through, wedge, corners, door gasket, door infiltration, door openings, heat radiation dissipated from condenser and compressor shell and etc.

A number of heat load parameters for cabinet loads in addition to the wall conduction loads could be considered. These include: electric defrost, penetrations, heaters and controls, fan heat, refrigerant line heat, in-wall evaporator, in-mullion evaporator, and in-wall condenser.

The total values shown for the cabinet section are the hourly average loads which must be removed by refrigeration system.

For the purpose of determination of energy consumption, two cooling capacities should be considered: 1) evaporator load, and 2) net capacity. Normally these two quantities are the same. If a cold-plate evaporator is used, however, the total evaporator load will be higher than the net capacity due to the heat going directly to the back of the evaporator through the insulation.

In our case, which the main consideration is selecting compatible components with existing refrigeration components, the method of refrigeration load calculation is different from the refrigeration load calculation of the new design products.

In this chapter we are going to discuss three different methods of refrigeration load calculations, from following sources;

- 1) EPA Refrigerator Analysis programme (ERA).
- 2) Ariston Co.'s methods of refrigeration load calculation.
- 3) ASHRAE standards of refrigeration load calculation.

EPA (Environmental Protection Agency) Refrigerator Analysis

For this method, following data are required for cabinet loads:

- 1) Cabinet Type and Dimension, as follows;

a) Cabinet height is measured from the bottom to top of the cabinet, not the floor.

b) Depth includes the cabinet door. This dimension measures the distance from the outside (front) surface of doors to the back of the cabinet

c) Width of the gasket and the door edge thickness. The effects of door thickness on the internal volume are taken into account.

d) Wedge dimensions, the cabinet wedge is the section of the cabinet near the door. In all cabinet types, except the chest freezer, the thickness of the insulation is reduced near the door to accommodate the door geometry.

- 2) Refrigerated volume;

ERA considers calculation of internal volume of the cabinet compartment based on the input data for the cabinet dimensions. The calculated volume is used in the simulation of the contribution to the cabinet loads from door openings.

Normally, the compressor will be located in a space at the near, bottom of the cabinet, where it is cooled by air blown over the condenser or by natural

convection. This space requirement will reduce the food storage volume of the cabinet located above, and will also affect the net external surface area available for heat exchange with the room.

3) Freezer and Fresh Food Cabinets;

The wall and door thickness and also insulation resistivity for each wall element and door are required to calculate the sum of thermal resistivities. The net resistance of each cabinet element is determined by the resistivity and thickness.

The specified thickness of wall containing a sandwich of a foam and vacuum insulation panel should be the total thickness (neglecting the thickness of the liner). When a composite insulation system is used, an average resistivity for the wall should be specified. The general case assumes a vacuum insulation panel located between inner and outer foam panels and surrounded foam along all four edges.

4) Mullion

The mullion is the wall between the fresh food and freezer sections of the refrigerator. Typically the resistivity of the mullion insulation is less than that of the foam walls since a removable insulation is often installed in this area. The resistivity is normally half that of the walls.

5) Air and Cabinet Temperature

The room air and cabinet temperatures establish the heat loads of each compartment on the refrigeration system. For DOE closed door test simulation a room air temperature of 32.2 C is ordinary specified, along with a freezer temperature of -15 C and fresh food cabinet temperature of 3.3 C. Temperatures must also be specified for under cabinet (where the compressor is normally located) and for "air entering the condenser."

6) Door Opening Schedule

The schedule of door opening is defined here to establish the net sensible and latent heat inputs to the cabinet during the hour. The controlling parameters are: the room relative humidity, the number of times each door is opened during the hour, and the average duration of each opening.

Parameters controlling the sensible and latent loads are: room temperature, cabinet temperature, room relative humidity, number of openings/hour, average duration of each door opening, and type of defrosting (manual or automatic). The typical schedule for door openings might be;

Fresh food door	Opening/hr.	2.5
	Duration (sec)	20
Freezer door	Opening/hr.	1
	Duration (sec)	15

7) Gasket Heat Leak

The gasket areas around the cabinet doors are sources of heat due to conduction loads from the room air along the cabinet and door flanges, and through the gasket itself. Correct estimates of the heat leaks must take into consideration the geometry and materials used in the wall panels and doors.

All gasket heat leaks are expressed in units of conductance per length of the gasket. The net leak is determined by the programme from the total door perimeter and from the outside-inside air temperature difference.

8) Others such as: defrost and control's energy use, electrical anti-sweat heat, refrigerant line anti-sweat heat, and penetration heat input.

**Method of Heat Load Calculation by Ariston Home Appliance
Manufacturing Company of Italy**

In this method, the whole refrigerator circuit is designed in such manners to face the possible leakage deriving from working under stand by conditions, with an ambient temperature of 43 degree centigrade, granting at the same time the freezing at least 3 kg/24hrs. Of water at temperature of 48 C or 5 kg/24hrs of water at 32 C.

Determination of total heat loads;

- 1) In conservation at 43 C of outside temperature.
- 2) In freezing at 32 C of outside temperature.
- 3) Measuring all the thermal loss surfaces and thickness thereof.
- 4) Calculate the (t) revelant to the single surfaces at following conditions;
43 C outside temperature, except 60 C compressor shell area and 55 C Condenser side.
0 C refrigerator medium temp.
- 23 C freezer air temp.
- 26 C evaporator temp.
- 5) Determination of thermal loss for following areas;
- Refrigerator door.
- Crisper support area.
- Crisper back area.
- Crisper side area.
- Compressor upper area.
- Refrigerator side areas.
- Drops retainer.
- Back panel rear areas.
- Refrigerator gasket.
- Freezer side areas.
- Freezer gasket.

- 6) Determination of thermal conductivity for following materials.
- Expanded polyurethane.
 - Magnetic gasket

Note. In order to make calculation easier, select the average thickness of sloping surfaces, assuming that the whole insulation thickness is of one single material in polyurethane, expanded polystrol PVC.

The total thermal loss in Kcal/hr. Are those necessary to face all dispersions at 43 C . Then, the heat in Kcal/hr. obtained at temperature of 32 C are to be found and must be then added to those necessary to freeze 3 kg of water in 24 hrs. In order to obtain functionality relation of the compressor at 43 C, we divide total thermal loss at 32 C by total thermal loss at 43 C ambient temperature.

**Method of Heat Load Calculation Established by
ASHRAE Standard**

1) Heat gain by conduction, in Kcal/hr. Through;

- Refrigerator side areas.
- Refrigerator gaskets.
- Refrigerator door.
- Crisper side areas.
- Freezer side areas.
- Mullion area, positive to freezer compartment.
- Back panel

2) Determination of thermal conductivity of following materials;

- Cabinet carbon steel.
- Polyurithane of foam.
- Door and freezer gasket.
- Inner liner plastic
- Air, between mullion and evaporator.

3) The heat resistance of coefficient factor, with regard to average thickness of each substance.

4) Determination of product heat load as follows;

- heat removed from products above freezing point in fresh food compartment.

Note: The amount of product weight kept in fresh food compartment depends upon. Internal volume and different products selected by the manufacturer.

- Heat removed from products from initial temperature to freezing point in Freezer compartment.
- Heat removed from freezing point to final temperature below freezing point in Freezer compartment.
- Heat removal to freeze products (latent heat), in freezer compartment.

Note: The amount of product weight kept in Freezer compartment depends upon. Internal volume and different products selected by the manufacturer.

5) Calculation of total heat gain through refrigerator, evaporator, and heat removal per hour form product.

Note: The amount of heat removal from product are in 24 hrs. daily, in order to obtain total heat removal per hour we divide it by desired Compressor operating time in 24 hrs.

6) To determine the grand total of the heat load, we add ten percent of the total heat gain. This ten percent additional load is for door openings, infiltrations, and wedge and edge thermal loss.

Conclusion

The three above calculation methods were reviewed and studied, due to the Azmayesh Prtotypes Natures and since our models have been already designed by SILTAL Co. of Italy, we preferred to choose ASHRAE's method of heat load calculation. Specially when our selected test conditions for our prototypes are ASHRAE standards.

Prototypes Performance Evaluations

1) With respect to the contract requirements, we made four prototype units for each model, for the purpose of functionality and performance tests of prototypes. Following prototypes were made and more than thirty performance and life tests were accomplished.

- | | |
|--------------|------------|
| - Model AR06 | Four units |
| - Model AR08 | Five units |
| - Model AR10 | Five units |
| - Model AR12 | Five units |
| - Model ARF2 | Four units |

2) Testing more than nine different kinds of R134a compressor samples from different specifications and manufacturers, as follows:

- | | |
|------------|----------------------|
| - Aspera | Model, BP 1048 Z 22 |
| - Aspera | Model, BP 1111 Z |
| - Aspera | Model, B 1116 Z |
| - Aspera | Model, B1118 Z |
| - Goldstar | Model, NR 58 LEAG |
| - Goldstar | Model, NR 62 LEAG |
| - Goldstar | Model, V75 LEAG |
| - Danfoss | Model, FR 8.5 G |
| - Tecamseh | Model, AE 360 KS 561 |

3) Planning for testing following R134a compressor samples, in addition to above-mentioned compressor samples.

- | | |
|-----------|---------------|
| - Zanussi | Model, GL40AA |
| - Zanussi | Model, GL45AA |
| - Zanussi | Model, GL50AA |

- Zanussi	Model. GL60AA
- Zanussi	Model. GL80AA
- Matsushita	Model. S48C10KAX0
- Matsushita	Model. S48C13KAX5
- Matsushita	Model. QA57C13RAX5
- Matsushita	Model. QA77C18RAX5
- Matsushita	Model. QA91C20rAX
- Necchi	Model. ESC511
- Necchi	Model. ESC8H
- Necchi	Model. ESC9H

4) Selecting following R12 test samples to compare with R134a compressor performance test results.

- Zanussi	Model. G45Aw
- Matsushita	Model. FN51Q11G
- Matsushita	Model. FN77G18G

5) Following prototype samples were tested 18, 32, and 43 degree centigrade ambient temperature.

- AR12
- ARF2
- AR08

6) In order to optimize refrigerant charge weight and capillary tube length, prototype sample model AR12 was tested at following test conditions.

- At 18, 32, and 43 C ambient temperature with 10 percent refrigerant charge reduced and the same capillary tube length as R12 refrigeration system.
- At 43 C ambient temperature, with 10 percent increase in capillary tube length, and the same refrigerant charge weight as R12 refrigeration system.
- At 43 C ambient temperature, with the same refrigerant charge and capillary tube as R12 refrigeration system.

(22)

7) Preparation of compressor comparison charts in order to compare different R134a compressor specifications in relation with our refrigerator and freezers specifications.

8) Selecting the most suitable R134a compressor with respect to our cooling capacity requirements and COP of the compressor.

9) Analyzing R134a compressors power input. in order to determine minimum power consumption rates, with respect to our cooling capacity requirement.

10) Applying ISO 8187: 1991(E), first edition no. 1991-03-01, for testing our prototype samples.

Analysis

1) Table 1 through 4 compare the performance of R12 and R134a compressors for refrigerator and ref-freezers models. AR08, AR10, AR12, and ARF2. The main point for us to approve the R134a compressor performance is the freezer (evaporator) air temperature, in accordance with ISO 8187 the acceptable freezer air temperature for two star refrigerator is -12 C and for three star ref-freezer is -18 C or less. Please note that the freezer air temperatures for different models are as follows which are acceptable in accordance with ISO 8187.

- Model AR06	Freezer Air Temp. **
- Model AR08	Freezer Air Temp. = -20
- Model AR10	Freezer Air Temp. = -20
- Model AR12	Freezer Air Temp. = -20
- Model ARF2	Freezer Air Temp. = -15

** The refrigeration system for refrigerator models AR06 and AR08 are the same.

2) Table 5 shows prototype model AR12 performance at different conditions as follows;

Mode(I): Test condition at 43 C ambient temp. with 10% decrease in refrigerant charge weight, without capillary tube length change.

Mode(II): Test condition at 43 ambient temp. with 10% decrease in refrigerant charge weight. and 10% increase in capillary tube length.

Mode(III): Test condition at 43 C ambient temp. with no change in refrigerant charge weight and capillary tube length.

(24)

**R12 and R134a Refrigerator and Ref-Freezer Performance
Comparison Chart Model AR08**

Description	R12 Model	R134 Model
Compressor Model	Zanussi, G45AW	Aspera, BP1048Z22
Ambient Temperature	+ 43 C	+ 43 C
Refrigerant Charge	110 Gr.	100 Gr.
Air Freezer Mean Temp.	- 13 C	- 20 C
Refrigerator Mean Temp.	+ 5 C	+ 3 C
Crisper Mean Temp.	+ 10 C	+ 6 C
Compressor Shell Temp.	+ 65 C	+ 75
Condensor Inlet Temp.	+ 65 C	+ 65
Condenser Outlet Temp.	+ 51 C	+ 50
Suction Temp.	+ 45 C	+ 45
Compressor Running %	52 %	65 %
Cooling Capacity	108 Watts	108 Watts
Power Consumption Rate	1.3 Kw/24 Hrs.	1.25 Kw/24 Hrs.

Table (1)

(25)

**R12 and R134a Refrigerator and Ref-Freezer Performance
Comparison Chart Model AR10**

Description	R12 Model	R134a Model
Compressor Model	Matsushita, FN51Q11G	Aspera, BP1111Z
Ambient Temperature	+ 43 C	+ 43 C
Refrigerant Charge	140 Gr.	125 Gr.
Air Freezer Mean Temp.	- 12 C	- 13 C
Refrigerator Mean Temp.	+ 2.5C	+ 6 C
Crisper Mean Temp.	+ 6 C	+ 7 C
Compressor Shell Temp.	+ 58 C	+ 86
Condensor Inlet Temp.	+ 48 C	+ 77
Condenser Outlet Temp.	+ 38 C	+ 50
Suction Temp.	+ 32 C	+ 45
Compressor Running %	35 %	56 %
Cooling Capacity	125 Watts	125 Watts
Power Consumption Rate	1.85Kw/24 Hrs.	1.9 Kw/24 Hrs.

Table (2)

(26)

R12 and R134a Refrigerator and Ref-Freezer Performance Comparison Chart Model AR12

Description	R12 Model	R134a Model
Compressor Model	Matsushita, FN51Q11G	Danfoss, FR8.5G
Ambient Temperature	+ 43 C	+ 43 C
Refrigerant Charge	150 Gr.	130 Gr
Air Freezer Mean Temp.	- 12 C	- 20 C
Refrigerator Mean Temp.	+ 5 C	+ 5 C
Crisper Mean Temp.	+ 7 C	+ 12 C
Compressor Shell Temp.	+ 64 C	+ 85
Condensor Inlet Temp.	+ 50 C	+ 72
Condenser Outlet Temp.	+ 40 C	+ 55
Suction Temp.	+ 33 C	+ 44
Compressor Running %	37 %	68 %
Cooling Capacity	158 Watts	158 Watts
Power Consumption Rate	2.25 Kw/24 Hrs.	2.10 Kw/24 Hrs.

Table (3)

R12 and R134a Refrigerator and Ref-Freezer Performance Comparison Chart Model ARF2

Description	R12 Model	R134a Model
Compressor Model	Matsushita, FN77G18	Aspera, B1118 Z
Ambient Temperature	+ 43 C	+ 43 C
Refrigerant Charge	220 Gr.	180 Gr.
Air Freezer Mean Temp.	- 24 C	- 15 C
Refrigerator Mean Temp.	+ 4.3 C	+ 2 C
Crisper Mean Temp.	+ 7 C	+ 7 C
Compressor Shell Temp.	+ 59 C	+ 85
Condensor Inlet Temp.	+ 55 C	+ 90
Condenser Outlet Temp.	+ 42 C	+ 50
Suction Temp.	+ 33 C	+ 45
Compressor Running %	53 %	74 %
Cooling Capacity	204 Watts	204 Watts
Power Consumption Rate	3 Kw/24 Hrs.	2.75 Kw/24 Hrs.

Table (4)


**Refrigerator Model AR12, R134a Optimizing
Test Results**

Description	Mode I	Mode II	Mode III
Ambient Temp.	43 C	43 C	43 C
Refrigerant Charge	150	135 Gr.	130 Gr.
Capillary Tube Length	No Increase	10% Increase	No Increase
Freezer air Temp.	- 15 C	- 24 C	-20 C
Refrigerator Air Temp.	+ 7 C	+ 6 C	+ 5 C
Crisper Temp.	+ 10 C	+ 13 C	+ 12 C
Compressor Shell	+ 80 C	+ 80 C	+ 85 C
Condenser Inlet Temp.	+ 70 C	+ 75 C	+ 72 C
Condenser Outlet Temp.	+ 50 C	+ 55 C	+ 55 C
Suction Temp.	+ 44 C	+ 48 C	+ 44 C
Compressor Running %	64 %	61 %	68 %
Condenser Change	No Change	No Change	No Change

Table (5)

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995


Conclusion

With regard to the test results of different prototype performance tests, we found out that there is no need to change our capillary tube length and also condenser surfaces, we can produce the above five models of the refrigerator and ref-freezers by only decreasing 10% of refrigerant charge weight as of R12 refrigerant and in order to have better air temperature distribution in the fresh food compartment we have to modify our mullion design, which is located under the evaporator compartment in the shape of the water drain tray.

For five Prototypes samples the performance life test runs are being achieved since last three months, and we observed no major problem in this regard. We hope that we could continue these life tests for three more months. Meanwhile, our production for the field test and trial test of more than 1500 units from five models will start as soon as refrigerant charger from A'GRAMKOW will be installed and commissioned by A'GRAMKOW in mid September.

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995

Recommendations

AZMAYESH Industrial Factories Co. Is proud that could achieve the execution of UNIDO's contract No. 94/097, timely and in a good manner. We will be glad if we could have the opportunity to give our experience to other manufacturers in Iran and abroad in this regard, because AZMAYESH Co. Was the first home appliance manufacturer in Iran, which could finish with this contract sooner, and could provide all contracts' requirements in accordance with UNIDO's plans and programmes.

1) During the time of contract, we found out that, there are many different methods of calculation for redefinition and redesign of the prototypes, that could be used in different manners, but through our experience and high production rate of refrigerator and ref-freezer in Marvdasht plant, we found out that most of these methods are suitable for designing new products, and do not fit our requirements. Therefore we decided to choose ASHRAE's method of heat load calculation and components selection, for following reasons;

- More reliable elements and parameters applied.
- Real figures and data used for determination of cooling capacity.
- More information, regarding type of materials and products are provided.
- There is a very accurate method of calculating heat gain by fresh food and frozen food in refrigerator and freezer compartments.
- All equations and rules regarding calculation of the evaporator, condenser and capillary tube are defined and stated clearly.
- All test conditions used by compressor manufacturers, are ASHRAE

standards, which it could be helpful during compressor section with regard to tests' requirements.

With respect to above listed reasons we recommend, that ASHRAE method of calculation for determination of heat load for redefinition of prototypes be used by other groups of the refrigerator manufacturer.

2) Since there are numerous kinds of R134a compressors in the market, and usually all compressor manufacturers believe that their design fit to the refrigerator manufacture's requirements, and it could not be proved unless performing condition tests at different ambient temperature, we recommend;

All redefined and redesigned refrigerator prototypes made by refrigerator manufacturers, be tested at least with three different R134a compressor samples, from different manufacturers. In order to find out the real capability of the new refrigeration system with new conditions.

3) Since redesigning, calculation, modification, and performance test of each prototype, needs a lot of activities and tasks to be performed and varieties of compressor test should be accomplished, at different ambient tests, therefore the time for executing the contract are not enough, we recommend;

The period of executing the contract should be increased, with respect to the number of prototypes and models to be redesigned and close coordination with contactor prior to signing the contract.

4) To get a better result from prototypes performance tests, and in order to get more test figures for the purpose of energy consumption and working performance, assessments we recommend;

At least one prototype from each model should be continuous run tested at 18, 32, and 43 degree centigrade ambient temperature.

(32)

AZMAYESH INDUSTRIAL FACTORIES CO.

5) Due to the time and man-hours required to execute such a contract, it seems that, the contract fee for these activities are not enough and should be reconsidered and evaluated again, because the sum of US \$ 46.500 for redesigning, making, and testing five models including twenty prototypes. does not cover expenses spent. for accomplishment of contracts' requirements. We recommend:

A change to the contract is necessary, and the contract fee for redesigning, prototyping, testing, and modifying for each model should be increased as follows;

**Model, Redesign, Prototype Testing,
Contract Fee Change Recommendation**


Description	Contract Fee	Recommended Fee
Design. calculation. & draft per model	US \$ 1.300	US \$ 2.000
Prototyping. per model	US \$ 1.000	US \$ 3.000
Prototype testing, per model	US \$ 1.000	US \$ 2.000

AZMAYESH Industrial Factories Co. would like to give its sincere appreciation to those people. which helped us sincerely in execution of this contract.

We would like to give our special tanks to Dr.Malayeri, Mr. Nowotny from UNIDO, Mrs. Latrech UNIDO's contract officer, Mr. I. Banafsheh UNDP programme manager from UNDP office in Tehran, Ministry of Industry, and Department of Environmental. for their kind and keen cooperation and coordination with AZMAYESH Co., in this regard.

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097




DATE: 27 August 1995

Bibliography and References

- 1 - ASHRAE Fundamentals of Refrigeration Handbook Edition 1977.
- 2 - ASHRAE Handbook of Refrigeration. Edition. 1986.
- 3 - ASHRAE Handbook Fundamental for Refrigeration and Air Conditioning, Edition 1986.
- 4 - Modern Refrigeration and Air Conditioning. By Goodheart- willcox Co. Inc., Edition 1968
- 5 - ISO standards, 8187 and 7371.
- 6 - Mechanical Handbooks.
- 7 - Heat Transfer by J.P.HOLMAN
- 8 - CFC-134a Pressure- Entholpy Diagram.
- 9 - Carrier Refrigeration and air conditioning Handbook.
- 10 - Ariston's Co. Calculation of heat load balancing
- 11 - DuPont, HFC 134a properties, uses, storage, and handling.
- 12 - Suva, refrigerant HFC-134a, thermodynamic properties.
- 13 - Goldstar's reciprocating compressor division, R134a
- 14 - Electrolux. R134a refrigerant application guide lines

**AZMAYESH INDUSTRIAL FACTORIES
COMPANY**

UNIDO'S CONTRACT NO. 94/097



DATE: 27 August 1995

Attachments

- 1 - First progress report dated February 1995
- 2 - Second Progress Report date May 1995
- 3 - Ariston's Co. Calculation of heat load balancing
- 4 - DuPont, HFC 134a properties, uses, storage, and handling.
- 5 - Suva, refrigerant HFC-134a, thermodynamic properties.
- 6 - Goldstar's reciprocating compressor division, R134a
- 7 - Electrolux, R134a refrigerant application guide lines

CALCULATION OF BALANCING - REFRIGERATOR MODEL TMG 300

The whole refrigerating circuit is to be designed in such a way as to face the possible leakages deriving from working under stand-by conditions, with an ambient temperature of 43°C, according to ISO standards, granting at the same time the freezing of at least 3 Kg/24h at temperature of 48°C.

The design of refrigerating circuit foresees a quite considerable number of strictly connected variables, in which the quantity of refrigerating units necessary in both sections of the refrigerator is controlled by the thermostat placed in the lower area, inside which temperature changes with more frequency than inside the freezer section. The evaporator of freezer section is to be powerful enough to face the possible leakages of chiller, heat box and refrigerator at a 43°C, but it should not keep the temperature above 0°C at an ambient temperature of 18°C during freezing phase.

The above mentioned variables are to be added to t' , K KS and capillary's capacity factors, which will be calculated according to production experience. However, as the mathematical results are usually far from practice, it will be necessary to prepare more than one prototype to obtain satisfactory results.

A. DETERMINATION OF COMPRESSOR'S POWER

- 1) In conservation at 43°C of outside temperature
- 2) In freezing at 32°C of outside temperature

a) Measure all the thermal loss surfaces and thickness thereof

b) calculate the t' relevant to the single surfaces

43°C outside temperature
(except 58°C compressor area
55°C condenser side)

0°C refrigerator medium temperature
-23°C freezer air temperature
-26°C evaporator temperature

c) Apply the formula hereunder for each surface :

$$P = \frac{l}{s} \times K \times S \quad t'$$

Whereby :

P = power in Kcal/h per each single surface

s = thickness in m. of the single surfaces

k = Kcal/h x m x °C - coefficient of transmission of insulating material adopted

k = Kcal. $\frac{1}{\text{h.m.c.}}$

h = hours

m = length in m. of test specimen

°C = temperature displacement between the two sides of test specimen

s = surface in m² of area to be considered

t' = temperature displacement between the two sides of dispersant surfaces

NOTE : in order to make calculation easier, select the average thickness of sloping surface, assuming that the whole insulation thickness is of one single material in polyurethane, expanded polystirol PVC.

K will be

Expanded polyurethane : density 20 to 30 kg/m³
k=0,023 to 0,025 (with 50% R11)

Magnetic gasket : ARISTON Type
k=0,07

Expanded polystyrene : Density 30 to 35 kg/m³
k=0,019 to 0,07

Chiller lower area : $\frac{1}{0,042} \times 0,027 \times (0,297 \times 0,547)$
x 43 = 4,716 Kcal/h

Compressor back area : $\frac{1}{0,055} \times 0,027 \times (0,235 \times 0,545)$
x 60 = 3,773 Kcal/h

Compressor upper area: $\frac{1}{0,052} \times 0,027 \times (0,160 \times 0,245)$
x 60 x 28 = 1,222 Kcal/h

Chiller side area : $\frac{1}{0,041} \times 0,027 \times (0,308 \times 0,236)$
x 2 x 43 = 4,117 Kcal/h

Refrigerator side area : $\frac{1}{0,042} \times 0,027 \times \frac{(0,460 \times 0,804)}{2}$
x 2 x 43 = 20,447 Kcal/h

$$\begin{aligned} \text{Freezer back area} & : \frac{1}{0,035} \times 0,027 \times (0,49 \times 0,241) \\ \times 81 & = 3,690 \text{ Kcal/h} \end{aligned}$$

$$\begin{aligned} \text{Liner inlet area} & : \frac{1}{0,035} \times 0,027 \times (1,4 \times 0,576) \\ 43 & = 26,750 \text{ Kcal/h} \end{aligned}$$

$$\begin{aligned} \text{Gasket area:} & \frac{1}{0,17} \times 0,027 \times 0,019 [(1,4 + 0,576) \times 2] (0,074 \times 0,358) \\ 43 & = 13,295 \text{ Kcal/h} \end{aligned}$$

TOTAL

105,764 Kcal/h

These 105,764 Kcal/h. are those necessary to face all dispersions at 43°C. Now Kcal./h. obtained at a temperature of 32 °C are to be found and must be then added to those necessary to freeze 3 Kg.

Considering : 53°C compressor cell area
53°C condenser area

4,716	x	32/43	=	3,510	Kcal/h
3,773	x	58/60	=	3,648	Kcal/h
1,222	x	58/60	=	1,182	Kcal/h
4,117	x	32/43	=	3,064	Kcal/h
20,447	x	32/43	=	15,217	Kcal/h
0,120	x	32/43	=	0,090	Kcal/h
0,734	x	32/43	=	0,547	Kcal/h
1,510	x	32/43	=	1,124	Kcal/h
3,268	x	53/55	=	3,150	Kcal/h
1,634	x	53/55	=	1,575	Kcal/h
10,896	x	79/81	=	10,627	Kcal/h
0,569	x	53/55	=	0,549	Kcal/h
0,289	x	53/55	=	0,274	Kcal/h
1,199	x	32/43	=	0,893	Kcal/h
4,708	x	32/43	=	3,504	Kcal/h
2,827	x	32/43	=	2,104	Kcal/h
3,690	x	79/81	=	3,599	Kcal/h
26,750	x	32/43	=	19,907	Kcal/h
13,295	x	32/43	=	9,894	Kcal/h
			=	84,458	Kcal/h

$$\begin{aligned}
& \text{Refrigerator side area : } \frac{1}{0,044} \times 0,027 \times \frac{(0,126 \times 0,36)}{2} \\
& \times 2 \times 43 = 0,120 \text{ Kcal/h} \\
& \text{Refrigerator side area : } \frac{1}{0,041} \times 0,027 \times (0,332 \times 0,039) \\
& \times 2 \times 43 = 0,734 \text{ Kcal/h} \\
& \text{Refrigerator side area : } \frac{1}{0,0405} \times 0,027 \times (0,325 \times 0,080) \\
& \times 2 \times 43 = 1,510 \text{ Kcal/h} \\
& \text{Drops retainer : } \frac{1}{0,0435} \times 0,027 \times (0,517 \times 0,183) \\
& 55 = 3,268 \text{ Kcal/h} \\
& \text{Back panel rear area : } \frac{1}{0,055} \times 0,027 \times (0,117 \times 0,517) \\
& 55 = 1,634 \text{ Kcal/h} \\
& \text{Chiller back area : } \frac{1}{0,055} \times 0,027 \times (0,530 \times 0,517) \\
& \times 81 = 10,896 \text{ Kcal/h} \\
& \text{Back area without evap: } \frac{1}{0,055} \times 0,027 \times (0,041 \times 0,541) \\
& \times 55 = 0,569 \text{ Kcal/h} \\
& \text{Back area with evap. : } \frac{1}{0,092} \times 0,027 \times (0,33 \times 0,541) \\
& \times 55 = 0,289 \text{ Kcal/h} \\
& \text{Liner upper area : } \frac{1}{0,004} \times 0,27 + 0,025 \times (0,78 \times 0,55) \\
& \times 43 = 1,199 \text{ Kcal/h} \\
& \text{Freezer side area : } \frac{1}{0,017} \times 0,27 \times (0,367 \times 0,241) \\
& \times 69 = 4,708 \text{ Kcal/h} \\
& \text{Freezer upper area: } \frac{1}{0,115} \times \frac{[(0,027 \times 0,069) + (0,025 \times 0,046)]}{0,115} \\
& \times (0,367 \times 0,49) \times 69 = 2,827 \\
& \times 81 = 3,690 \text{ Kcal/h}
\end{aligned}$$

The chosen compressor will be V 62JEG which delivers 89,5 Kcal/h with and with an evaporation temperature of - 30 °C.

In this way you can establish the functionality relation of the compressor at 43 °C

$$\frac{84,458 \text{ Kcal/h} \times 100}{89,5 \text{ Kcal/h}} = 94,5 \%$$

The formula to applicate to determine the power necessary to freeze 3 kg in 24 h is the following :

$$P = [(G \times C \times t_1) + (G \times C_1) + (G \times C_2 \times t_2)] \frac{1}{24}$$

P : Input power in Kcal/h

G : Weight to be freezing in Kg

C : Heating power in Kcal

t1 : difference between external temperature and 0°C

C1 : Latent heat in Kcal/Kg

t2 : Difference between 0°C and - 18°C

1/24: As the freezing last for 24 hours, it will be necessary to divide by 24 to obtain the hour/power

Note : C and C1 change following the material in case of testing packing

$$C = 0,77 \text{ Kcal}$$

$$C_1 = 60 \text{ Kcal/Kg}$$

$$P [(3 \times 0,77 \times 32) + (3 \times 60) + (3 \times 0,77 \times 18)] \frac{1}{24}$$

$$= (73,92 + 180 + 41,58) \frac{1}{24} = 12,313 \text{ Kcal/h}$$

$$= 295,5 \times \frac{1}{24}$$

Additioning these 13,579 Kcal/h to the 51,03 Kcal/h due to dispersion, we obtain 64,612 Kcal/h which represent the compressor power necessary in freezing phase, being always under those necessary to face the dispersions St 38°C.

B. DETERMINATION OF CONDENSER'S POWER

The condenser is to be up to exchange the Kcal/h required to condensate the quantity of freon necessary to attain the prefixed temperatures.

The calculation formula is the following :

$$KS = \frac{\text{Kcal/h provided by compressor} \times 1,25}{t^{\circ}}$$

Whereby :

KS = coefficient of trasmission in Kcal/h. This
°C

coefficient is indicated by the condenser's manufacturer, and changes according to type material, technology and surface

t° in °C = Displacement between outlet temperature of freon and ambient temperature

1,25 = Displacement in entalphies between condensation and evaporator phases, keeping into account the overheating value (Kollier)

For condenser too the worst operating conditions must be determined:

Preservation at 43°C $\frac{84,458 \text{ kcal/h}}{56-43} \times 1,25 = 8,798 \text{ kcal/h/}^{\circ}\text{C}$

Freezing at 32°C $\frac{96,770 \text{ kcal/h}}{53-32} \times 1,25 = 5,760 \text{ kcal/h/}^{\circ}\text{C}$

The chosen condenser, built with Bentler pipe diam. 4,7 with wires diam. 1,4 distanced of 6,35 and width 578 allows following KS:

W	H	KS
578	812	8,40
578	914	9,30
578	1016	10,30
578	1118	11,25
578	1219	12,20

This condenser should be 914 high.
It should work also at 48°C
That's why we choose: 1016 min.

C. DETERMINATION OF CAPILLARY'S CAPACITY

As regards this particular component, it is recommended to rely on the experience acquired during tests, and this because the capacity of capillary depends on length, internal diameter, glazing of surface and on the type of mixture (liquid-gas) of freon passing through it. Therefore the allowances on all these elements could by themselves effect sensibly the theoretical results.

Assuming a condensation temperature of 55 °C the compressor would deliver 2,6 kg/h of R 12.

Going back to the Molier diagram for R 12 freon, the following specific volumes would be attained at an evaporation temperature of - 30 °C and an absolute pressure of 1,025 kg/cm² :

- liquid : 0,6728 l/kg
- vapour : 0,1633 m³/kg

Assuming an outlet of R 12 under form of vapor only, the capacity freon in l/min. can be calculated as follows :

$$P_c = \frac{P_f \times P_{sv} \times 1000}{60}$$

P_c : Capillary capacity in l/min

P_f : freon q.ty produced by compressor in Kg/h

P_{sv} : steam specific gravity q.ty in m³/kg

1000 : transformation from m³ to l.

60 : transformation from hours to minutes.

$$P_c = \frac{2,6 \times 0,1633 \times 1000}{60} = 7,076 \text{ l/min}$$

Comparing R 12 in AIR capillary you can apply following formula :

$$V_a = 2,35 \cdot (P_2 - 1) \cdot \emptyset \cdot l^{-0,5}$$

V_a : capillary capacity (with air passing) in l/min

P : condensation pressure in Kg/cm²

\emptyset : capillary internal diameter

l : length of capillary

$$7,076 = 2,35 \cdot (13,862^2 - 1) \cdot 0,71^{2,5} \cdot l^{-0,5}$$

$$7,076 = 2,35 \cdot 191,32 \cdot 0,424 \cdot l^{-0,5}$$

$$l^{-0,5} = \frac{7,076}{2,35 \cdot 13,33 \cdot 0,424} = \frac{7,076}{13,780} = 0,5135$$

$$l = 3,79 \text{ m}$$

The theoretical length of the capillary examined therefore corresponds to 4 m but due to our experience it should be 3 or 4 meters. In any case this value should be confirmed by adequate laboratory tests.

As per compressor and condenser, you must check if the higher power to be exchanged is at preservation 43°C or at freezing 25°C ambient temperature.

Concerning the freezer evaporators:

Refrig./freezer separation area	: $\frac{1}{0,071} \times 0,027 \times (0,111 \times 0,542) \times 26 =$	= 0,595 Kcal/h
Refrig./freezer	: $\frac{1}{0,071} \times 0,027 \times (0,255 \times 0,546) \times 26 =$	= 1,778 Kcal/h
freezer side area :		4,708 Kcal/h
freezer upper area :		2,827 Kcal/h
freezer back area :		3,690 Kcal/h
freezer gasket area :	$1 \times 0,07 \times 0,007$	1,667 Kcal/h
freezer door area :		1,335 Kcal/h

TOTAL at 43°C preservation		10,61 Kcal/h

Taking into account that at 25°C there are:
 58°C in compressor area
 53°C in condenser area

Dispersions will change as follows:

Refrig./freezer separation area:		= 0,595 Kcal/h
Refrig./freezer separation area:		= 1,778 Kcal/h
freezer side area:	$4,708 \times 32/43$	= 3,504 Kcal/h
freezer upper area:	$2,827 \times 32/43$	= 2,104 Kcal/h
freezer back area:	$3,690 \times 79/81$	= 3,599 Kcal/h

D) DETERMINATION OF EVAPORATOR

The evaporating surface is to be up to deliver the Kcal/h leaked by the refrigerating system. The calculation formula is the following :

$$P = K \times S \times t'$$

Whereby :

P : power to be exchanged by the evaporator in Kcal/h

K : coefficient of transmission of the evaporator, changing according to the type of material employed and to the constructive technology, in Kcal/m²/°C

S : surface of evaporator, in m²

t' : displacement of temperature between evaporation temperature and air to be cooled

K is much variable for many factors but principally it depends on the thickness of the back part of the cell and on the flatness (in the refrigerator). The thickness is inversely proportional to the thermic conductivity.

K = 8,5 for an evaporator made up by aluminium pipe dia. 8, thk. 1, coupled with a steel plate thk. 0,4.

K = 6,5 for an evaporator made up by aluminium pipe dia. 8, thk 1, coupled with a steel plate thickness 0,4 and with one of ABS from 1 to 1,5.

freezer gasket area: = 1,677 Kcal/h
 freezer door area: = 1,335 Kcal/h

TOTAL at freezing dispersions -----
 14,592 Kcal/h

To these 14,592 Kcal/h must be added 12,313 Kcal/h of freezing of 3 Kg. Total will be 26,905 Kcal/h, quantity to be exchanged by the evaporator.

Freezer evaporator surface will be:
 $26,905 = 8,5 \times 5 \times (30,83)$

$$S = \frac{26,905}{89,5} = 0,452 \text{ m}^2$$

For constructive reasons the freezer evaporator has depth 322 mm and development 1419 that is 0,456 m².

As far as refrigerator evaporator is concerned the Kcal/h dispersed from freezer will be subtracted from dispersions at 43 °C conservation phase.

Refrig/freezer separation area: = -0,595 Kcal/h
 Refrig/freezer separation area: = -1,778 Kcal/h
 freezer gasket area: = -1,677 Kcal/h
 freezer door area: = -1,335 Kcal/h
 crisper support area: = 4,716 Kcal/h
 crisper back area: = 3,773 Kcal/h
 compressor upper area: = 1,222 Kcal/h
 crisper side area: = 4,117 Kcal/h
 refrigerator side area: = 20,447 Kcal/h

refrigerator side area:	=	0,120	Kcal/h
refrigerator side area:	=	0,734	Kcal/h
refrigerator side area:	=	1,510	Kcal/h
refrigerator drops retainer area:	=	3,268	Kcal/h
back panel rear area:	=	1,634	Kcal/h
back panel rear area:	=	10,896	Kcal/h
back panel rear area:	=	0,569	Kcal/h
back panel rear area:	=	0,289	Kcal/h
refrigerator gasket area:	=	13,295	Kcal/h
	TOTAL	=	61,205 Kcal/h

By applying the formula $P = K \times S \times \tau'$
 we have $61,205 = 3,5 \times S \times (30-0) = 3,5 \times S \times 30$

$$S = \frac{61,205}{105} = 0,582 \text{ m}^2$$

Always for constructive reasons our evaporator is 495 mm x 525 mm equal to 0,259 m², that is insufficient.


Factor K should be therefore increased favouring transmission between evaporator and coil, by means of some pieces of adhesive aluminium.



DuPont HFC-134a

Properties, Uses, Storage and Handling

- SUVA 134a refrigerant
- SUVA' *Cold-MP* refrigerant
- SUVA' *Trans A/C* refrigerant
- FORMACEL' Z-4 foam expansion agent
- DYMEL' 134a aerosol propellant
- DYMEL' 134a/P aerosol propellant



INTRODUCTION

HFC-134a—AN ENVIRONMENTALLY ACCEPTABLE ALTERNATIVE

HFC-134a does not contain chlorine; therefore, it has an ozone depletion potential (ODP) of zero. Listed below are all generic and DuPont trade names:

Hydrofluorocarbon-134a

HFC-134a

HFA-134a

SUVA[®] 134a

SUVA[®] Trans A/C (automotive market)

SUVA[®] Cold MP (stationary refrigeration/air conditioning market)

FORMACEL[®] Z-4 (foam blowing agent market)

DYMEL[®] 134a /P (aerosol pharmaceutical market)

DYMEL[®] 134a (general aerosol market)

The chemical properties of HFC-134a are listed below.

HFC-134a

Chemical Name 1,1,1, 2-tetrafluoroethane

Molecular Formula CH_2F_2

CAS Registry Number 811-97-2

Molecular Weight 102.0




BACKGROUND

HFC-134a has been introduced by DuPont as a replacement for chlorofluorocarbons (CFCs) in many applications. CFCs, which were developed over 60 years ago, have many unique properties. They are low in toxicity, nonflammable, noncorrosive and compatible with other materials. In addition, they offer the thermodynamic and physical properties that make them ideal for a variety of uses. CFCs are used as refrigerants; as blowing agents in the manufacture of insulation, packaging and cushioning foams; as cleaning agents for metal and electronic components; and in many other applications.

However, the stability of these compounds, coupled with their chlorine content, has linked them to depletion of the earth's protective ozone layer. As a result, DuPont plans to phase out production of CFCs and introduce environmentally acceptable alternatives, such as hydrofluorocarbon (HFC) 134a.

Figure 1. Infrared Spectrum of HFC-134a Vapor at 400 mm Hg Pressure (53.3 kPa) in a 10-cm Cell.



USES

HFC-134a can be used in many applications that currently use dichlorodifluoromethane (CFC-12). These include refrigeration, polymer foam blowing and aerosol products. However, equipment design changes are sometimes required to optimize the performance of HFC-134a in these applications.

The thermodynamic and physical properties of HFC-134a, coupled with its low toxicity, make it a very efficient and safe replacement refrigerant for CFC-12 in many segments of the refrigeration industry, most notably in automotive air conditioning, appliances, small stationary equipment, medium-temperature supermarket cases and industrial and commercial chillers. Table 1 provides a comparison of the theoretical performance of CFC-12 and HFC-134a at medium-temperature conditions.

TABLE 1
Theoretical Cycle Comparison of CFC-12
and HFC-134a*

	CFC-12	HFC-134a
Capacity (as % CFC-12)	100	99.7
Coefficient of Performance (COP)	3.55	3.43
Compressor		
Exit Temperature, °C (°F)	86.8 (188.2)	83.1 (181.5)
Exit Pressure, kPa (psia)	1349 (195.6)	1473 (213.7)
Compression Ratio	4.1	4.7

* Temperatures were as follows: Condenser, 54.4°C (130.0°F); Evaporator, 1.7°C (35.0°F); Compressor Suction, 26.7°C (80.0°F); Expansion Device, 51.7°C (125.0°F).

As a blowing agent in polymer foams, HFC-134a can be used to replace CFC-12 in many thermoplastic foam applications. Recent developments, however, are also providing new technology that uses HFC-134a as a replacement for CFC-12 in thermoset foams. HFC-134a features properties that are advantageous for high value-in-use products and meets the requirements of safety/environmental issues. HFC-134a is nonflammable, has negligible photochemical reactivity and low vapor thermal conductivity.

HFC-134a is also being developed for use in pharmaceutical inhalers because of its low toxicity and nonflammability. Other aerosol applications may use HFC-134a where these properties are critical. See DuPont DYMEL[®] Bulletin ATB-30 (H-44691) for additional information on aerosol applications of HFC-134a.

PHYSICAL PROPERTIES

Physical properties of HFC-134a are given in Table 2 and Figures 2 to 8. Additional physical property data may be found in other DuPont publications. Bulletin ART-1 (H-43855-1) contains viscosity, thermal conductivity and heat capacity data for saturated liquid and vapor in addition to heat capacity data and heat capacity ratios for both saturated and superheated vapors. Thermodynamic tables in English and SI units are available in Bulletins T-134a-ENG (H-47751) and T-134a-SI (H-47752). Liquid and vapor densities are included in the thermodynamic tables.


TABLE 2
Physical Properties of HFC-134a

Physical Properties	Units	HFC-134a
Chemical Name	—	Ethane, 1,1,1,2-Tetrafluoro
Chemical Formula	—	CH ₂ FCF ₃
Molecular Weight	—	102.03
Boiling Point at 1 atm (101.3 kPa or 1.013 bar)	°C	-26.1
	°F	-14.9
Freezing Point	°C	-103.0
	°F	-153.9
Critical Temperature	°C	101.1
	°F	213.9
Critical Pressure	kPa	4060
	lb/in. ² abs	588.9
Critical Volume	m ³ /kg	1.94 x 10 ⁻³
	ft ³ /lb	0.0311
Critical Density	kg/m ³	515.3
	lb/ft ³	32.17
Density (Liquid) at 25°C (77°F)	kg/m ³	1206
	lb/ft ³	75.28
Density (Saturated Vapor) at Boiling Point	kg/m ³	5.26
	lb/ft ³	0.328
Heat Capacity (Liquid) at 25°C (77°F)	kJ/kg-K	1.44
	or Btu/(lb) (°F)	0.340
Heat Capacity (Vapor) at Constant Pressure at 25°C (77°F) and 1 atm (101.3 kPa or 1.013 bar)	kJ/kg-K	0.852
	or Btu/(lb) (°F)	0.204
Vapor Pressure at 25°C (77°F)	kPa	666.1
	bar	6.661
	psia	96.61
Heat of Vaporization at Boiling Point	kJ/kg	217.1
	Btu/lb	93.4
Thermal Conductivity at 25°C (77°F) Liquid	W/m-K	0.0824
	Btu/hr-ft ² °F	0.0478
Vapor at 1 atm (101.3 kPa or 1.013 bar)	W/m-K	0.0145
	Btu/hr-ft ² °F	0.00836
Viscosity at 25°C (77°F) Liquid	mPa-S (cP)	0.202
	mPa-S (cP)	0.012
Solubility of HFC-134a in Water at 25°C (77°F) and 1 atm (101.3 kPa or 1.013 bar)	wt %	0.15
	wt %	0.11
Solubility of Water in HFC-134a at 25°C (77°F)	wt %	0.11
	wt %	0.11
Flammability Limits in Air at 1 atm (101.3 kPa or 1.013 bar)	vol %	None
Autoignition Temperature	°C	770
	°F	1418
Ozone Depletion Potential	—	0
Halocarbon Global Warming Potential (HGWP) (For CFC-11, HGWP = 1)	—	0.28
	—	0.28
Global Warming Potential (GWP) (100 yr. ITH. For CO ₂ , GWP = 1)	—	1200
	—	1200
TSCA Inventory Status	—	Reported/Included
Toxicity AEL ^(a) (8- and 12-hr TWA)	ppm (v/v)	1,000

^(a) AEL (Acceptable Exposure Limit) is an airborne exposure limit established by DuPont scientists for substances to ensure the safe handling and use of that substance.

Note: kPa is absolute pressure.

Figure 2. Solubility of Water in HFC-134a.



CHEMICAL/THERMAL STABILITY

THERMAL DECOMPOSITION

HFC-134a vapors will decompose when exposed to high temperatures from flames or electric resistance heaters. Decomposition may produce toxic and irritating compounds, such as hydrogen fluoride. The pungent odors released will irritate the nose and throat and generally force people to evacuate the area. Therefore, it is important to prevent decomposition by avoiding exposure to high temperatures.

STABILITY WITH METALS AND REFRIGERATION LUBRICANTS

Stability tests for refrigerants with metals are typically performed in the presence of refrigeration oils. The results of sealed tube stability tests are available for CFC-12/mineral oil combinations, which have shown long-term stability in contact with copper, steel and aluminum in actual refrigeration systems. Polyalkylene glycol (PAG) and polyol ester (POE) lubricants will most likely be used with HFC-134a. Sealed tube tests were, therefore, run to determine the relative long-term stability of HFC-134a/metals in the presence of these lubricants.

The method followed was generally the same as ASHRAE 97 with several minor modifications. A 3-mL volume of refrigerant/lubricant solution was heated in the presence of copper, steel and aluminum strips in an oven for 14 days at 175°C (347°F). Both the neat lubricant and a mixture of lubricant and refrigerant (50/50 volume ratio) were tested. Visual ratings were obtained on both the liquid solutions and the metal coupons after the designated exposure time. The visual ratings ranged from 0 to 5, with 0 being the best and 5 being the worst.

After the visual ratings were obtained, sample tubes were opened and the lubricant and refrigerant (if present) were analyzed. The lubricant was typically checked for halide content and viscosity, while the refrigerant was examined for the presence of decomposition products. Table 3 summarizes typical data for both HFC-134a and CFC-12. Visual ratings are listed for the neat lubricant, the lubricant/refrigerant solution and the three metals that were present in the lubricant/refrigerant solutions. Viscosity was determined on the unused lubricant, the tested neat lubricant and the lubricant tested in the presence of refrigerant. A percent change was calculated for the two tested lubricants. The decomposition products listed are HFC-143a (the predominant decomposition product for HFC-134a) and fluoride ion. Both species are typically measured in the low parts per million (ppm) range.

As the CFC-12/mineral oil combinations have been proven in actual service, these tests indicate that HFC-134a/PAG and HFC-134a/POE solutions have acceptable chemical stability. In several other tests, results have confirmed that the HFC-134a molecule is as chemically stable as CFC-12.

Figure 3 Pressure vs Temperature (English Units).




Figure 4. Pressure vs. Temperature (SI Units).




Figure 5. Vapor Thermal Conductivity of HFC-134a at Atmospheric Pressure (English Units).




Figure 6. Vapor Thermal Conductivity of HFC-134a at Atmospheric Pressure (SI Units).




TABLE 3
Stability of HFC-134a with Metals and Lubricating Oils

Oil	Mineral Oil	Mineral Oil	UCON RO-W-6602 ^(a)	Mobil EAL Arctic 32 ^(b)	Castrol Icematic SW 100 ^(b)
Oil Viscosity, cSt at 40°C (104°F)	30.7	125	134	29.4	108.8
Refrigerant	R-12	R-12	HFC-134a	HFC-134a	HFC-134a
Ratings					
Neat Oil	—	—	0	0	0
Oil/Refrigerant	4	4	0	0	0
Copper	2	2	0	0	0
Iron	3	3	0	0	0
Aluminum	2	2	0	0	0
Viscosity Change					
% Change Neat	ND	ND	<1	-3.1	4.3
% Change with Refrigerant	ND	ND	-12.7	-36.2	-27.1
Decomposition Analysis					
HFC-143a, ppm	ND	ND	<7	<3	<0.3
Fluoride, ppm	ND	420	<0.7	—	<7

^(a) Polyalkylene glycol lubricant.

^(b) Polyol ester lubricant.

ND = Not determined.

Stability Ratings: 0 to 5

0 = Best

3 = Failed

5 = Coked

COMPATIBILITY WITH FOAM CHEMICALS

As with other alternative blowing agents, the stability of HFC-134a in foam chemicals (B-side systems) is being studied. The first tests evaluated HFC-134a stability in a sucrose-amine polyether polyol with either an amine catalyst, a potassium catalyst, a tin catalyst or an amine catalyst neutralized with an organic acid. The initial tests, which included analysis of the volatile components, showed no degradation of HFC-134a in any of the systems, even at elevated temperatures. The results are summarized in Table 4.

TABLE 4
Stability of HFC-134a with Foam Chemicals

Catalyst	Degradation, %
Amine	<0.001
Potassium	<0.001
Tin	<0.001
Neutralized Amine	<0.001

Test Conditions

Six weeks at 60°C (140°F).

25% (wt.) HFC-134a

Two parts catalyst per 100 parts polyol by weight.

One part water per 100 parts polyol by weight.

Type 1010 steel test coupon.

COMPATIBILITY CONCERNS IF HFC-134a AND CFC-12 ARE MIXED

HFC-134a and CFC-12 are chemically compatible with each other; this means that they do NOT react with each other and form other compounds. However, when the two materials are mixed together, they form what is known as an "azeotrope." An azeotrope is a mixture of two components that acts like a single compound, but has physical and chemical properties different than either of the two components. An example of this is FREON® 502, which is an azeotrope of HCFC-22 and CFC-115. When HFC-134a and CFC-12 are mixed in certain concentrations, they form a high-pressure (low boiling) azeotrope. This means that the vapor pressure of the azeotrope is higher than that of either of the two components by themselves. At 109 psia (752 kPa absolute) the azeotrope contains 46 weight percent HFC-134a. In general, compressor discharge pressures will be undesirably high if refrigeration equipment is operated with a mixture of HFC-134a and CFC-12.

Another characteristic of an azeotrope is that it is very difficult to separate the components once they are mixed together. Therefore, a mixture of HFC-134a and CFC-12 cannot be separated in an on-site recycle machine or in the typical facilities of an off-site reclaimer. Mixtures of HFC-134a and CFC-12 will usually have to be disposed of by incineration.

Figure 7. Pressure-Enthalpy Diagram for HFC-134a (English Units).

15-672
216 222





Figure 8. Pressure-Enthalpy Diagram for HFC-134a (SI Units).



MATERIALS COMPATIBILITY

Because HFC-134a is used in many applications, it is important to review materials of construction for compatibility when designing new equipment, retrofitting existing equipment or preparing storage and handling facilities.

PLASTICS

Customary industry screening tests, in which twenty-three typical plastic materials were exposed to liquid HFC-134a in sealed glass tubes at room temperature, are summarized in *Table 5*. Observations of weight gain and physical change were used to separate materials meriting further laboratory and/or field testing from materials which appeared unacceptable. The majority of the materials tested merit further evaluation.

Since the performance of plastic materials is affected by polymer variations, compounding agents, fillers, and molding processes, verifying compatibility using actual fabricated parts under end-use conditions is advised.

ELASTOMERS

Compatibility results for HFC-134a and CFC-12 are compared for 11 typical elastomers in *Tables 6* through *17*. It should be recognized, however, that effects on specific elastomers depend on the nature of the polymer, the compounding formulation used and the curing or vulcanizing conditions. Actual samples should be tested under end-use conditions before specifying elastomers for critical components.

Recommendations, based on the detailed data in *Tables 7* through *17*, are given in *Table 6*. Data on "temporary" elastomer swell and hardness changes were used as the prime determinants of compatibility. The subsequent "final" data were used as a guide to indicate if the seals in a refrigeration system should be replaced after equipment tear down.

Most polymeric materials used in refrigeration equipment are exposed to a mixture of refrigerant and refrigeration oil. Data on the compatibility of elastomers and motor materials with HFC-134a in combination with mineral oils and a PAG lubricant are available in *Bulletins ARTD-18* (H-26845) and *ARTD-30* (H-32123). Data for nylon and for graphite-filled TEFLON fluorocarbon resin are included in *ARTD-30*. Additional data are being developed by equipment manufacturers.

HOSE PERMEATION

Elastomeric hoses are used in mobile air conditioning systems and for transferring HFC-134a in other applications. The permeation rates of HFC-134a and CFC-12 through several automotive A/C hoses were measured as a guide to hose selection.

TABLE 5
Plastics Compatibility of HFC-134a

Test Conditions: Plastic specimens exposed to liquid HFC-134a (no lubricant) in sealed glass tubes for two weeks at room temperature.

Chemical Type	Trade Name
<i>Plastic materials meriting further testing</i>	
ABS	KRALASTIC*
Acetal	DELIRIN*
Epoxy	
Fluorocarbons	
PTFE	TEFLON*
ETFE	TEFZEL*
PVDF	
Ionomer	SURLYN*
Polyamide	
6/6 Nylon	ZYTEL*
Polyarylate	ARYLON*
Polycarbonate	TUFFAK*
Polyester:	
PBT	VALOX*
FET	RYNITE*
Polyetherimide	ULTEM*
Polyethylene-HD	ALATHON*
Polyphenylene Oxide	NORYL*
Polyphenylene Sulfide	RYTON*
Polypropylene	
Polystyrene	STYRON*
Polysulfone	POLYSUFONE*
Polyvinyl Chloride	
PVC	
CPVC	
<i>Plastic materials exhibiting unacceptable change</i>	
Acrylic	LUCITE*
Cellulosic	ETHOCEL*

TABLE 6
Elastomer Compatibility of HFC-134a

	Ratings					
	CFC-12			HFC-134a		
	25°C (77°F)	80°C (176°F)	141°C (285°F)	25°C (77°F)	80°C (176°F)	141°C (295°F)
ADIPRENE L	1	5		2	5	
Buna N	1*	0*	2*	1	0*	1
Buna S	3	4		3	2	
Butyl Rubber	2	4		0	3	
HYPALON® 48	1	0	0	1*	0	0
Natural Rubber	4	5		0	2	
Neoprene W	0*	1*		0	2	
NORDEL® Elastomer	2*	2*		1	1	
Silicone	5	5		2	2	
THIOLKOL® FA	1	1		1*	0	
VITON® A	5	5		5	5	

*Recommend elastomer replacement after equipment teardown.

HYPALON®, NORDEL® and VITON® are DuPont registered trademarks.

ADIPRENE® is a Uniroyal registered trademark.

THIOLKOL® FA is a Morton Thiokol registered trademark.

Codes: 0 = No change

1 = Acceptable change.

2 = Borderline change.

3 = Slightly unacceptable change

4 = Moderately unacceptable change

5 = Severely unacceptable change

The studies were run at 80°C (176°F) with an initial 87.5 volume percent liquid loading of HFC-134a in 76-cm (30-in.) lengths of 15.9-mm (5.8-in.) inside diameter automotive air conditioning hose. Hose construction and permeation rates are summarized in *Table 18*. Based on these tests, hoses lined with nylon, as well as those made of HYPALON® 48, appear to be suitable for use with HFC-134a. Note, however, that these rate measurements provide a comparison of the various hoses at a single temperature and should not be used as an indication of actual permeation losses from an operating system.

DESICCANTS

Dryers filled with desiccant are typically used in refrigeration systems and bulk storage facilities. A common molecular sieve desiccant used with CFC-12, UOP's (formerly Union Carbide Molecular Sieve) 4A-XH-5, is not compatible with HFC-134a; however, UOP has developed other molecular sieve desiccants, such as XH-7 and XH-9, which perform well in HFC-134a service. In addition, several other manufacturers offer loose-fill and molded-core desiccants that are compatible with HFC-134a and lubricants. Be sure to indicate your specific HFC-134a application when ordering a dryer or desiccant.

REFRIGERATION LUBRICANTS

Most compressors require a lubricant to protect internal moving parts. The compressor manufacturer usually recommends the type of lubricant and viscosity that should be used to ensure proper operation and equipment durability. Recommendations are based on several criteria, such as lubricity, compatibility with materials of construction, thermal stability and refrigerant/

oil miscibility. To ensure efficient operation and long equipment life, it is important to follow the manufacturer's recommendations.

Current lubricants used with CFC-12 are fully miscible over the range of expected operating conditions, easing the problem of getting the lubricant to flow back to the compressor. Refrigeration systems using CFC-12 take advantage of this full miscibility when considering lubricant return. Refrigerants such as HFC-134a, with little or no chlorine, may exhibit less solubility with many existing mineral oil or alkylbenzene lubricants.

The search for lubricants for use with HFC-134a started with commercially available products. *Table 19* shows solubilities of various refrigerant/lubricant combinations. Current naphthenic, paraffinic and alkylbenzene lubricants have very poor solubility with HFC-134a. PAGs with low viscosity show good solubility but, as viscosity increases, they become less soluble. Ester lubricants, of which there are many types, generally show good solubility with HFC-134a. When compared to PAGs, ester lubricants are more compatible with hermetic motor components and are less sensitive to mineral oil and CFC-12 remaining in a refrigeration system.

Although HFC-134a and CFC-12 are chemically compatible with each other, such is not the case with CFC-12 and PAG lubricants. Specifically, the chlorine contained in CFC-12 or other chlorinated compounds can react with the PAG and cause lubricant degradation. CFC-11, which is often used as a cleaning or flushing agent, is also incompatible with PAGs. At contaminant levels of 1 percent CFC-11 or 2 to 10 percent residual mineral oil (saturated with CFC-12), the stability of the system is affected enough to cause possible degradation. Lubricant degradation can result in poor lubrication and premature failure. In addition, sludge will be formed that can plug orifice tubes and other small openings.

TABLE 7
Compatibility of Refrigerants with ADIPRENE[®] L

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final).

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	1.8	5.5	2.1	5.0
Final	0.3	0.1	^(a)	-0.5
Weight Change (%)				
Temporary	8.5	20	5.2	20
Final	1.2	0.3	^(a)	-0.5
Shore A Hardness				
Original	60	61	60	63
Temporary, Δ SH	-2	-4	^(a)	-28
Final, Δ SH	0	1	—	-19
Elasticity Rating				
Temporary	0	0	5 ^(a)	4 ^(a)
Final	0	0	5 ^(a)	5 ^(c)
Visual Rating				
Liquid	0	0	0	0
Polymer				
Temporary	0	0	0	1 ^(a)
Final	0	0	5 ^(a)	2 ^(a)

• Sample disintegrated
 ° More elastic

^(a) Broke when stretched
^(b) Sticky

TABLE 8
Compatibility of Refrigerants with Buna N

Test Conditions: 27 days immersion of the polymer at 25°C (77°F), 80°C (176°F) and 141°C (285°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final).

	CFC-12			HFC-134a		
	25°C (77°F)	80°C (176°F)	141°C (285°F)	25°C (77°F)	80°C (176°F)	141°C (285°F)
Length Change (%) (±0.5)						
Temporary	2	1	2	2	2	3
Final	0	-1	0	0	0	0
Weight Change (%) (±0.5)						
Temporary	7	6	8	8	8	8
Final	0	-1	2	0	0	0
Shore A Hardness						
Original	77	76	72	77	74	75
Temporary, Δ SH	-6	-1	9	-5	-1	-3
Final, Δ SH	7	9	14	5	7	4
Elasticity Rating						
Temporary	0	1	1 ^(a)	0	1	1
Final	0	0	0	0	0	0
Visual Rating						
Liquid	0	0	0	0	0	0
Polymer						
Temporary	0	1	1 ^(b)	0	0	0
Final	0	1	1 ^(b)	0	0	0

^(a) More elastic
^(b) Surface dulled

TABLE 9
Compatibility of Refrigerants with Buna S

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final).

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	-0.1	1.1	0.7	0.8
Final	-2.5	<0.1	-2.6	0.3
Weight Change (%)				
Temporary	2.8	1.9	2.9	2.5
Final	-6.2	-0.1	-6.2	-0.1
Shore A Hardness				
Original	85	84	83	81
Temporary, Δ SH	-12	-12	-16	-9
Final, Δ SH	8	-2	-9	-2
Elasticity Rating				
Temporary	0	0	0	1 ^(a)
Final	3 ^(b)	1 ^(b)	3 ^(c)	0
Visual Rating				
Liquid	0	0	0	0
Polymer				
Temporary	0	0	0	0
Final	0	0	0	0

* More elastic
 † Less elastic

TABLE 10
Compatibility of Refrigerants with Butyl Rubber

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final)

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	6.3	7.2	7.6	1.3
Final	-1.2	0	-0.8	0.4
Weight Change (%)				
Temporary	34	2.0	36	3.7
Final	-2.6	-0.1	-1.2	0.6
Shore A Hardness				
Original	54	54	57	58
Temporary, Δ SH	-8	-1	-14	-4
Final, Δ SH	-1	-2	-10	-3
Elasticity Rating				
Temporary	1 ^(a)	1 ^(a)	3 ^(a)	0
Final	0	0	2 ^(a)	0
Visual Rating				
Liquid	0	0	3 ^(a)	0
Polymer				
Temporary	0	0	3 ^(a)	4 ^(c)
Final	0	0	1 ^(a)	2 ^(a)

* More elastic
 † White solids in liquid

^(a) White deposit on elastomer
^(b) White film on elastomer

TABLE 11
Compatibility of Refrigerants with HYPALON 48

Test Conditions: 27 days immersion of the polymer at 25°C (77°F), 80°C (176°F) and 141°C (285°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final).

	CFC-12			HFC-134a		
	25°C (77°F)	80°C (176°F)	141°C (285°F)	25°C (77°F)	80°C (176°F)	141°C (285°F)
Length Change (%) (±0.5)						
Temporary	1	0	1	0	0	1
Final		0	0	0	0	0
Weight Change (%) (±0.5)						
Temporary	7	5	9	0	1	2
Final	2	1	4	0	0	1
Shore A Hardness						
Original	79	81	81	76	82	82
Temporary, Δ SH	-4	0	0	3	1	1
Final, Δ SH	4	2	2	8	1	4
Elasticity Rating						
Temporary	0	0	0	0	0	0
Final	0	0	0	0	0	0
Visual Rating						
Liquid	0	0	0	0	0	0
Polymer						
Temporary	0	1	1 ^{1a}	0	0	0
Final	0	1	1 ^{1a}	0	0	0

^{1a} Surface dulled

TABLE 12
Compatibility of Refrigerants with Natural Rubber

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final).

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	14	1.3	14	2.0
Final	-1.1	-0.3	-0.8	0.4
Weight Change (%)				
Temporary	51	4.5	55	5.8
Final	-2.6	-0.5	-2.6	-0.6
Shore A Hardness				
Original	55	56	56	57
Temporary, Δ SH	-9	-1	-17	-8
Final, Δ SH	-5	-4	-8	-4
Elasticity Rating				
Temporary	0	0	1 ^{1a)}	1 ^{1a)}
Final	0	0	2 ^{1a)}	0
Visual Rating				
Liquid	0	0	0	0
Polymer				
Temporary	0	0	0	0
Final	0	0	0	0

^{1a)} More elastic

TABLE 13
Compatibility of Refrigerants with Neoprene W

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final)

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	0.2	0.7	0.9	1.4
Final	-7.6	-0.5	-7.3	-0.3
Weight Change (%)				
Temporary	6.6	2.3	6.8	2.9
Final	-12	-0.6	-13	-1.8
Shore A Hardness				
Original	73	73	73	72
Temporary, Δ SH	-1	0	-5	-7
Final, Δ SH	-10	0	5	-5
Elasticity Rating				
Temporary	2 ^(a)	0	1 ^(b)	0
Final	2 ^(a)	0	2 ^(b)	0
Visual Rating				
Liquid	1 ^(c)	0	1 ^(a)	0
Polymer				
Temporary	0	0	1 ^(a)	0
Final	0	0	0	0

* Less elastic

^(b) Hazy

† More elastic

^(c) White film

‡ Clear, yellow

TABLE 14
Compatibility of Refrigerants with NORDEL[®] Elastomer

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final).

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	-0.6	0.5	-0.4	0.7
Final	-8.2	-0.2	-8.4	0.4
Weight Change (%)				
Temporary	5.5	2.8	6.1	4.4
Final	-22	<0.1	-22	-0.2
Shore A Hardness				
Original	66	66	65	63
Temporary, Δ SH	-4	-3	0	-6
Final, Δ SH	19	-4	20	0
Elasticity Rating				
Temporary	2 ^(a)	0	2 ^(b)	1 ^(b)
Final	2 ^(a)	0	2 ^(b)	0
Visual Rating				
Liquid	0	0	0	1 ^(a)
Polymer				
Temporary	0	0	0	0
Final	0	0	1 ^(c)	0

* Less elastic

^(b) White film

† More elastic

^(c) Hazy

TABLE 15
Compatibility of Refrigerants with Silicone

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final)

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	41	6.1	44	5.5
Final	-0.1	0.1	-0.2	-0.2
Weight Change (%)				
Temporary	173	20	187	20.3
Final	0.7	-0.1	-0.7	-0.3
Shore A Hardness				
Original	60	61	60	58
Temporary, Δ SH	-13	-8	-15	-6
Final, Δ SH	-7	-4	-7	-2
Elasticity Rating				
Temporary	0	1 ^(a)	1 ^(a)	0
Final	0	0	0	0
Visual Rating				
Liquid	0	0	0	0
Polymer	5 ^(b)	0	4 ^(b)	0
Temporary	0	0	0	0
Final	0	0	0	0

- (a) Less elastic
- (b) Swollen

TABLE 16
Compatibility of Refrigerants with THIOKOL FA

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final)

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	1.3	0.8	1.4	-0.2
Final	-0.5	-0.2	-0.5	-0.9
Weight Change (%)				
Temporary	1.9	1.0	3.7	1.9
Final	-0.2	-0.1	-0.8	-0.8
Shore A Hardness				
Original	70	69	74	74
Temporary, Δ SH	-6	-4	-6	0
Final, Δ SH	-5	-6	-1	0
Elasticity Rating				
Temporary	1 ^(a)	1 ^(a)	0	1 ^(b)
Final	0	0	1 ^(a)	2 ^(a)
Visual Rating				
Liquid	0	0	0	0
Polymer	0	0	0	0
Temporary	0	0	0	0
Final	0	0	0	0

- (a) Less elastic
- (b) More elastic

TABLE 17
Compatibility of Refrigerants with VITON A

Test Conditions: 27 days immersion of the polymer at 25°C (77°F) and 80°C (176°F) in liquid (temporary) plus two weeks drying in air at about 25°C (77°F) (final)

	25°C (77°F)		80°C (176°F)	
	CFC-12	HFC-134a	CFC-12	HFC-134a
Length Change (%)				
Temporary	5.5	13	4.9	12
Final	0.7	-0.1	1.2	0.3
Weight Change (%)				
Temporary	19	48	20	49
Final	1.8	0.7	2.5	1.2
Shore A Hardness				
Original	74	74	73	73
Temporary, Δ SH	-19	-30	-23	-31
Final, Δ SH	-7	-8	-10	-6
Elasticity Rating				
Temporary	2 ^m	2 ^m	3 ^e	3 ^m
Final	0	0	0	0
Visual Rating				
Liquid	0	0	0	0
Polymer				
Temporary	0	1 ^k	0	0
Final	0	1 ^m	0	5 ^e

- * Less elastic
- † More elastic
- ‡ Very slightly tacky

- ^m Oil, sheen
- ^k Puffed mounds—5% of surface

TABLE 18
HFC-134a Permeation Through Elastomeric Hoses

	Permeation Rate, gm/cm-yr (lb/ft-yr)			
	Nylon	HYPALON® 48	Nitrile #1	Nitrile #2
CFC-12	4.5 (0.3)	14.9 (1.0)	22.3 (1.5)	28.3 (1.9)
HFC-134a	3.0 (0.2)	3.0 (0.2)	26.8 (1.8)	40.2 (2.7)
Hose Construction:				
Inner Liner	Nylon	HYPALON® 48	Nitrile (NBR)	
Second Layer	—	Rayon	Rayon	
Reinforcement	Nylon	2 Braids	2 Braids	
Outer Cover	Chlorobutyl	EPDM	EPDM	

TABLE 19
Solubilities of HFC-134a in Lubricants

Temperature Range: -50°C to 93°C (-58°F to 199°F)

Oil Type	Percent Refrigerant in Mixture		
	30%	60%	90%
500 SUS Naphthenic	2 phase	2 phase	2 phase
500 SUS Paraffinic	2 phase	2 phase	2 phase
125 SUS Dialkylbenzene	2 phase	2 phase	2 phase
300 SUS Alkylbenzene	2 phase	2 phase	2 phase
165 SUS PAG	-50 to >93 ^(a)	-50 to >93	-50 to +73
525 SUS PAG	-50 to >93	-40 to +35	-23 to -7
100 SUS Ester	-40 to >93	-35 to >93	-35 to >93
150 SUS Ester	-50 to >93	-50 to >93	-50 to >93
300 SUS Ester	-50 to >93	-50 to >93	-50 to >93
500 SUS Ester	-40 to >93	-35 to >93	-35 to >93

^a One phase in this temperature range. °C



INHALATION TOXICITY

HFC-134a poses no acute or chronic hazard when it is handled in accordance with DuPont recommendations and when exposures are maintained at or below the DuPont Acceptable Exposure Limit (AEL) of 1,000 ppm (8- and 12-hour Time-Weighted Average or TWA).

An AEL is an airborne exposure limit established by DuPont scientists that specifies time-weighted average (TWA) airborne concentrations to which nearly all workers may be repeatedly exposed without adverse effects. The AEL for HFC-134a has the same value as the Threshold Limit Values (TLVs) established for CFC-12 and HCFC-22. TLVs are established by the American Conference of Governmental and Industrial Hygienists (ACGIH).

However, inhaling high concentrations of HFC-134a vapor may cause temporary central nervous system depression with narcosis, lethargy and anesthetic effects. Other effects that may occur include dizziness, a feeling of intoxication and a loss of coordination. Continued breathing of high concentrations of HFC-134a vapors may produce cardiac irregularities (cardiac sensitization), unconsciousness and, with gross over-exposure, death. Intentional misuse or deliberate inhalation of HFC-134a may cause death without warning. This practice is *extremely dangerous*.

If you experience *any* of the initial symptoms, move to fresh air and seek medical attention.

CARDIAC SENSITIZATION

If vapors are inhaled at a concentration of 75,000 ppm, which is well above the AEL, the heart may become sensitized to adrenaline, leading to cardiac irregularities and, possibly, to cardiac arrest. The likelihood of these cardiac problems increases if you are under physical or emotional stress.

Medical attention must be given immediately if exposed to high concentrations of HFC-134a. Do not treat with adrenaline (epinephrine) or similar drugs. These drugs may increase the risk of cardiac arrhythmias and cardiac arrest. If the person is having difficulty breathing, administer oxygen. If breathing has stopped, give artificial respiration.

SPILLS OR LEAKS

If a large release of vapor occurs, such as from a large spill or leak, the vapors may concentrate near the floor or low spots and displace the oxygen available for breathing, causing suffocation.

Evacuate everyone until the area has been ventilated. Use blowers or fans to circulate the air at floor level. Do not reenter the affected area unless you are equipped with a self-contained breathing apparatus or unless an area monitor indicates that the concentration of HFC-134a vapors in the area is below the AEL.

Always use self-contained breathing apparatus or an airline mask when entering tanks or other areas where vapors might exist. Use the buddy system and a lifeline. Refer to the Material Safety Data Sheet (MSDS) for HFC-134a for more information.

HFC-134a vapors have a slightly sweet odor that can be difficult to detect. Therefore, frequent leak checks and the installation of permanent area monitors may be necessary in enclosed spaces. Refer to ASHRAE Standards 15 and 34 for refrigeration machinery rooms.

To ensure safety when working with HFC-134a in enclosed areas:

1. Route relief and purge vent piping (if present) outdoors, away from air intakes.
2. Make certain the area is well ventilated, using auxiliary ventilation, if necessary, to move vapors.
3. Make sure the area is clear of vapors prior to beginning work.
4. Install air monitoring equipment to detect leaks. (Monitors are discussed in the next section, Monitors and Leak Detection.)

SKIN AND EYE CONTACT

At room temperature, HFC-134a vapors have little or no effect on the skin or eyes. However, in liquid form, HFC-134a can freeze skin or eyes on contact, causing frostbite. Following contact, soak the exposed area in luke-warm water, not cold or hot. If medical treatment cannot begin immediately, apply a light coat of a nonmedicated ointment, such as petroleum jelly. If the exposed area is in a location where the presence of the ointment would be awkward, such as on the eye, apply a light bandage. In all cases of frostbite, seek medical attention as soon as possible.

Always wear protective clothing when there is a risk of exposure to liquid HFC-134a. Where splashing is possible, always wear eye protection and a face shield.

COMBUSTIBILITY OF HFC-134a

HFC-134a is *nonflammable* at ambient temperatures and atmospheric pressure. However, tests have shown HFC-134a to be combustible at pressures as low as 5.5 psig (139.3 kPa absolute) at 177°C (350°F) when mixed with air at concentrations generally greater than 60 volume % air. At lower temperatures, higher pressures are required for combustibility (HCFC-22 is also combustible at pressures above atmospheric in the presence of high air concentrations.) Test results and calculations have shown:


- At ambient temperature, all concentrations of HFC-134a in air are nonflammable at pressures below 15 psig (205 kPa absolute).
- Combustible mixtures of air and HFC-134a will not form when liquid HFC-134a is pumped into a closed vessel if the initial air pressure in the vessel is limited to one atmosphere absolute and the final pressure is limited to 300 psig (2,170 kPa absolute). If the initial air pressure is greater than one atmosphere, combustible mixtures may form as the tank is filled.

Based on the above information, the following operating practices are recommended:

- **Leak Testing**
 - Equipment should **never** be leak tested with a pressurized mixture of HFC-134a and air. HFC-134a may be safely pressured with dry nitrogen.
- **Bulk Delivery and Storage**
 - Tanks should normally be evacuated at the start of filling, and should never be filled while under positive air pressure. Tank pressure should never be allowed to exceed 300 psig (2,170 kPa) when filling with HFC-134a. Relief devices on either the tanks or the HFC-134a supply system usually prevent this.
 - Tank pressures should be monitored routinely.
 - Air lines should never be connected to storage tanks.
- **Filling and Charging Operations**
 - Before evacuating cylinders or refrigeration equipment, any remaining refrigerant should be removed by a recovery system.
 - Vacuum pump discharge lines should be free of restrictions that could increase discharge pressures above 15 psig (205 kPa) and result in the formation of combustible mixtures.
 - Cylinders or refrigeration equipment should normally be evacuated at the start of filling, and should never be filled while under positive air pressure.
 - Final pressures should not exceed 300 psig (2,170 kPa).
 - Filled cylinders should periodically be analyzed for air (nonabsorbable gas or NAG).

• Refrigerant Recovery Systems

Efficient recovery of refrigerant from equipment or containers requires evacuation at the end of the recovery cycle. Suction lines to a recovery compressor should be periodically checked for leaks to prevent compressing air into the recovery cylinder during evacuation. In addition, the recovery cylinder pressure should be monitored, and evacuation stopped in the event of a rapid pressure rise indicating the presence of noncondensable air. The recovery cylinder contents should then be analyzed for NAG, and the recovery system leak checked if air is present. Do not continue to evacuate a refrigeration system that has a major leak.



Service personnel have used leak detection equipment for years when servicing equipment. Leak detectors exist not only for pinpointing specific leaks, but also for monitoring an entire room on a continual basis. There are several reasons for leak pinpointing or area monitoring, including: conservation of HFCs, protection of valuable equipment, reduction of fugitive emissions and protection of employees.

Leak detectors can be placed into two broad categories: leak pinpointers and area monitors. Before purchasing a monitor or pinpointer, several instrumental criteria should be considered, including sensitivity, detection limits and selectivity.

TYPES OF DETECTORS

Using selectivity as a criterion, leak detectors can be placed into one of three categories: nonselective, halogen-selective or compound-specific. In general, as the specificity of the monitor increases, so does the complexity and cost. Another method used to find leaks is to add fluorescent dyes to the system.

A detailed discussion of leak detection, along with a list of manufacturers of leak detection equipment, is given in Bulletin ARTD-27 (H-31753-2).

NONSELECTIVE DETECTORS

Nonselective detectors are those that will detect any type of emission or vapor present, regardless of its chemical composition. These detectors are typically quite simple to use, very rugged, inexpensive and almost always portable. However, their inability to be calibrated, long-term drift, lack of selectivity and lack of sensitivity limit their use for area monitoring.

Some nonselective detectors designed for use with CFC-12 may have a much lower sensitivity when used with HFC-134a. However, newly designed detectors with good HFC-134a sensitivity are now available. Be sure to consult with the manufacturer before selecting or using a nonselective detector with HFC-134a.

HALOGEN-SELECTIVE DETECTORS

Halogen-selective detectors use a specialized sensor that allows the monitor to detect compounds containing fluorine, chlorine, bromine and iodine without interference from other species. The major advantage of such a detector is a reduction in the number of "nuisance alarms"—false alarms caused by the presence of some compound in the area other than the target compound.

These detectors are typically easy to use, feature higher sensitivity than the nonselective detectors (detection limits are typically <5 ppm when used as an area monitor and <0.05 oz/yr (<1.4 gm/yr) when used as a leak pinpointer), and are very durable. In addition, due to the partial specificity of the detector, these instruments can be calibrated easily.

COMPOUND-SPECIFIC DETECTORS

The most complex detectors, which are also the most expensive, are compound-specific detectors. These units are typically capable of detecting the presence of a single compound without interference from other compounds.

FLUORESCENT DYES

Fluorescent dyes have been used in refrigeration systems for several years. These dyes, invisible under ordinary lighting, but visible under ultraviolet (UV) light, are used to pinpoint leaks in systems. The dyes are typically placed into the refrigeration lubricant when the system is serviced. Leaks are detected by using a UV light to search for dye that has escaped from the system.

Recent innovations in dye technology have allowed fluorescent dyes to be used with HFC-134a. However, before adding dyes to a system, the compatibility of the specific dye with the lubricant and refrigerant should be tested.

DuPont has formed a partnership with Spectronics Corporation to supply refrigerant mixed with fluorescent additives and to assist in developing additives that are compatible with new alternative refrigerants. For additional information, contact DuPont.

STORAGE AND HANDLING

SHIPPING CONTAINERS IN THE U.S.

HFC-134a is a liquefied compressed gas. According to the U.S. Department of Transportation (DOT), a non-flammable compressed gas is defined as a nonflammable material having an absolute pressure greater than 40 psi at 21°C (70°F) and/or an absolute pressure greater than 104 psi at 54°C (130°F).

The appropriate DOT designations are as follows:

Proper shipping name: Refrigerant Gas, N.O.S. (Tetrafluoroethane)

Hazard class: Nonflammable Gas

UN/NA No.: UN 1078

A list of the different types of containers that can be used to ship HFC-134a in the United States, along with their water capacities, dimensions, DOT specifications and the net weights of HFC-134a, are provided in *Table 20*. All pressure relief devices used on the containers must be in compliance with the corresponding Compressed Gas Association (CGA) Standards for compressed gas cylinders, cargo and portable tanks.

The 30-lb and 123-lb cylinders designed for refrigerant applications are a light blue color with labels that bear the name of the product in light blue. The color designation is "Light Blue (Sky)," PMS 2975.

The 30-lb cylinder, known as a "Dispose A Can" (D.A.C.) fits into a box that measures 10 in. x 10 in. x 17 in. Dispose A Can is DuPont's registered trade name for this type of single-use container. When used to ship SUVA® Cold-MP for the stationary refrigeration market, these 30-lb cylinders have the same outlet fittings as cylinders of CFC-12. However, when used for SUVA® Trans A/C for the automotive industry, these cylinders have a CGA-167 valve outlet. This fitting was specified by the Society of Automotive Engineers (SAE) to avoid mixing CFC-12 and HFC-134a when servicing mobile air conditioning systems. Additional unique fittings used with HFC-134a in automotive service applications are discussed in Bulletin ART-12 (H-45948).

The 123-lb cylinders are equipped with a nonrefillable liquid vapor CGA-660 valve. With this two-way valve, HFC-134a can be removed from the cylinder as either a vapor or as a liquid, without inverting the cylinder. The vapor handwheel is located on the top. The liquid wheel is on the side of the valve and attached to a dip tube extending to the bottom of the cylinder. Each is clearly identified as vapor or liquid.

The 4,400-gal cylinder is known as an ISO tank. The dimensions referenced in *Table 20* represent the frame in which the container is shipped. The tank itself has the same length of 20 ft and an outside diameter of approximately 86 in. ISO tanks are used for export shipments of HFC-134a from the United States.


The general construction of a one-ton returnable container is shown in *Figure 9*. Notice that one end of the container is fitted with two valves. When the container is turned so that the valves are lined up vertically, the top valve will discharge vapor and the bottom valve will discharge liquid. The valves are protected by a dome cover.

TABLE 20
Specifications of Shipping Containers for HFC-134a

Water Capacity	Dimensions	DOT Specification	Net Weight (lb) HFC-134a
30 lb Dispose A Can**	10" x 10" x 17" (box)	39	30
123 lb	55" H x 10" OD	4BA300	125
1,682 lb	82" L x 30" OD	110A500W	1,750
5,000 gal	Tank Truck	MC-330 or -331	40,000
4,400 gal ISO	8' x 8.5' x 20' (frame)	51	30,865
170,000 lb	Tank Rail Car	114A340W	—

**Dispose A Can® is a registered trademark of the DuPont Company

Figure 9 One-Ton Returnable Container.



Ton containers are equipped with two fusible plugs in each end. The fusible metal in the plugs is designed to start melting at 69 C (157 F) and completely melt at 74 C (165 F). Containers should never be heated to temperatures higher than 52 C (125 F). One spring-loaded pressure relief valve is also located in each end of the ton container.

BULK STORAGE SYSTEMS

DuPont sells storage systems, at cost, to its HFC-134a customers. The systems are prefabricated, tested and ready to install on site. The units are designed to optimize economy, efficiency and safety in the storage and dispensing of HFC-134a. The delivered systems include all components, such as storage tanks, pumps, piping, valves, motors and gauges, as an integrated unit. All systems are equipped with the DuPont F. E. E. D. (Fluorochemical Emission Elimination Delivery) system to prevent emissions during deliveries, and with dual pumps to provide an installed spare. The units are skid-mounted and require only placement on a concrete pad and connection to electrical and process systems.

A typical bulk storage system is shown in Figure 10.

Your DuPont Marketing Representative can arrange for guidance on site selection, purchase, installation, start-up and maintenance.

CONVERTING BULK STORAGE TANKS FROM CFC-12 TO HFC-134a

Before switching from CFC-12 to HFC-134a, the existing storage equipment must be checked to verify that it is adequate. Storage tanks built to the specifications of the American Society of Mechanical Engineers (ASME) Pressure Vessel Code are required to have a metal nameplate indicating each tank's maximum allowable working pressure (MAWP). This rating must be 185 psig

(1377 kPa absolute) or higher for HFC-134a service. In most cases, existing storage tanks that have been properly designed to contain CFC-12 will have an adequate pressure rating for HFC-134a. The set pressure of the relief devices on the top of the tanks must also be verified and changed, if necessary.

We recommend that storage tanks be **completely** emptied of all CFC-12 liquid and vapor before introducing HFC-134a. In general, converting a storage tank from CFC-12 to HFC-134a requires:

1. Removing CFC-12 from the storage tank, lines and equipment
2. Evacuating the storage tank to 25 inches of mercury vacuum (16.7 kPa absolute pressure) and purging with compressed dry nitrogen gas
3. Making necessary repairs to the tank after initial evacuation and purging
4. Repeating step 2 until CFC-12 and moisture analyses are within acceptable limits
5. Refilling system with HFC-134a

The above is a simplified outline of what is actually a lengthy procedure. Your DuPont Marketing Representative can assist in obtaining the equipment, instrumentation and technical assistance to safely and effectively make the conversion.

MATERIAL COMPATIBILITY CONCERNS

Most metal components suitable for use with CFC-12 are also compatible with HFC-134a, including standard types of carbon steel, aluminum and copper. Some elastomeric or nonmetallic components suitable for CFC-12 may not be adequate. Therefore, all elastomeric or nonmetallic components throughout the system must be identified and their compatibility with HFC-134a verified. See Materials Compatibility section. For complete reliability, any component that cannot be properly identified should be replaced.

in a fluorocarbon storage system, elastomers are most commonly found in:


- Packing and seats of manual valves
- Pressure-relief device seats
- Flange and manway gaskets
- Mechanical pump seals
- Wet-end pump gaskets and O-rings
- Filter O-rings
- Sight-flow indicator gaskets
- Back-pressure regulator diaphragms and O-rings

HANDLING PRECAUTIONS FOR HFC-134a SHIPPING CONTAINERS

The following rules for handling HFC-134a containers are strongly recommended:

- Use personal protective equipment, such as side shield glasses, gloves and safety shoes when handling HFC-134a containers.
- Avoid skin contact with liquid HFC-134a, since it may cause frostbite.
- Never heat a container to a temperature higher than 52°C (125°F).
- Never apply direct flame or live steam to a container or valve.
- Never refill disposable cylinders with anything. The shipment of refilled disposable cylinders is prohibited by DOT regulations.
- Never refill returnable cylinders without DuPont consent. DOT regulations forbid transportation of returnable cylinders refilled without DuPont's authorization.
- Never use a lifting magnet or sling (rope or chain) when handling containers. A crane may be used when a safe cradle or platform is used to hold the container.

Figure 10. Typical Bulk Storage System.



- Never use containers as rollers, supports or for any purpose other than to carry HFC-134a
- Protect containers from any object that will result in a cut or other abrasion in the surface of the metal
- Never tamper with the safety devices in the valves or containers
- Never attempt to repair or alter containers or valves.
- Never force connections that do not fit. Make sure the threads on the regulators or other auxiliary equipment are the same as those on the container valve outlets.
- Keep valves tightly closed and valve caps and hoods in place when the containers are not in use.
- Store containers under a roof to protect them from weather extremes.
- Use a vapor recovery system to collect HFC-134a vapors from lines after unloading.

RECOVERY, RECLAMATION, RECYCLE AND DISPOSAL

Responsible use of HFC-134a requires that the product be recovered for reuse or disposal whenever possible. DuPont purchases used refrigerants for reclamation through its distributor networks in the United States, Canada and Europe. In the United States, used HFC-134a is accepted as part of this program. Recovery and reuse of HFC-134a makes sense from an environmental and economic standpoint. In addition, the U.S. Clean Air Act will prohibit known venting of HFC-134a in late 1995 during the maintenance, servicing or disposal of refrigeration equipment.

RECOVERY

Recovery refers to the removal of HFC-134a from equipment and collection in an appropriate external container. As defined by the Air Conditioning and Refrigeration Institute (ARI), a U.S. organization, recovery does not

involve processing or analytical testing. HFC-134a may be recovered from refrigeration equipment using permanent on-site equipment or one of the portable recovery devices now on the market. The portable devices contain a small compressor and an air cooled condenser, and may be used for vapor or liquid recovery. At the end of the recovery cycle, the system is evacuated to remove vapors. In the United States, the Environmental Protection Agency (EPA) sets standards for recovery equipment. Before purchasing a specific recovery unit, check with the manufacturer to be sure that it contains elastomeric seals and a compressor oil compatible with HFC-134a.

RECLAMATION

Reclamation refers to the reprocessing of used HFC-134a to new product specifications. Quality of reclaimed product is verified by chemical analysis. In the United States, HFC-134a is included in DuPont's refrigerant reclamation program. Contact DuPont or one of its authorized distributors for further information.

Reclamation offers advantages over on-site refrigerant recycling procedures because these systems cannot guarantee complete removal of contaminants. Putting refrigerants that do not meet new product specifications back into expensive equipment may cause damage.

RECYCLE

Refrigerant recycle refers to the reduction of used refrigerant contaminants using devices that reduce oil, water, acidity and particulates. Recycle is usually a field or shop procedure with no analytical testing of refrigerant. HFC-134a may be recycled using one of the devices now on the market. In the United States, the EPA sets standards for these devices. Recycle is becoming the accepted practice in the U.S. mobile air conditioning service industry. Consult with the manufacturer before specifying a recycle device for HFC-134a.

DISPOSAL

Disposal refers to the destruction of used HFC-134a. Disposal may be necessary when HFC-134a has become badly contaminated with other products and no longer meets the acceptance specifications of DuPont or other reclaimers. Although DuPont does not presently accept severely contaminated refrigerants for disposal, licensed waste disposal firms are available. Be sure to check the qualifications of any firm before sending them used HFC-134a.

**DuPont Chemicals
Fluorochemicals Customer Service Center
Wilmington, DE 19898**

**For sales information:
1-800-441-9442
In Delaware (302) 774-2099**

**For technical information:
1-800-582-5606
In Delaware (302) 999-3129**

Europe

DuPont de Nemours
International S.A.
2 Chemin du Pavillon
P.O. Box 50
CH-1218 Le Grand-Saconnex
Geneva, Switzerland
41-22-717-5111

Canada

DuPont Canada, Inc
P.O. Box 2200, Streetsville
Mississauga, Ontario
L5M 2H3
(416) 821-3300

Mexico

DuPont, S.A. de C.V.
Homerio 205
Col. Chapultepec Morales
C.P. 11570 Mexico, D.F.
52-5-250-8000

South America

DuPont do Brasil S.A.
Alameda Itapicuru, 506
São Paulo, Brazil
55 11 421-8509

DuPont Argentina S.A.
Casilla Correo 1888
Correo Central
1000 Buenos Aires, Argentina
54-1-311-8167

Pacific

DuPont Australia
P.O. Box 930
North Sydney, NSW 2050
Australia
61-2-923-6165

Japan

Mitsui DuPont Fluoro-
chemicals Company, Ltd.
Mitsui Seimei Building
2-3, 1-Chome Ohtemachi
Chiyoda Ku, Tokyo 100 Japan.
81-3-3216-8451

Asia

DuPont Taiwan
P.O. Box 81-777
Taipei, Taiwan
886 2-514-4400

DuPont Asia Pacific Limited
P.O. Box TST 98851
Tsim Sha Tsui
Kowloon, Hong Kong
852-734-5345

DuPont Thailand
P.O. Box 2398
Bangkok 10501, Thailand
66-2-238-4361

DuPont China Ltd.
Room 1704, Union Bldg
100 Yanan Rd. East
Shanghai, PR China 200 002
Phone 86-21-328-3738
Telex 33448 DCLSH CN
Fax: 86-21-320-2304

DuPont Far East Inc
P.O. Box 12396
50776 Kuala Lumpur,
Malaysia
Phone 60-3-232-3522
Telex (784) 30391 DUFE M
Fax 60-3-238-7250

DuPont Korea Ltd.
C.P.O. Box 5972
Seoul, Korea
82-2-721-5114

DuPont Singapore Pte. Ltd.
1 Maritime Square #07 01
World Trade Centre
Singapore 0409
65-273-2244

DuPont Far East, Philippines
5th Floor, Solid Bank Bldg
777 Paseo de Roxas
Makati, Metro Manila
Philippines
63-2-818-9911

DuPont Far East Inc
7A Murray's Gate Road
Alwarpet
Madras, 600 018 India
91-44-454-029

DuPont Far East Inc.—
Pakistan
9 Khayaban-E-Shaheen
Defence Phase 5
Karachi, Pakistan
92-21-533-350

DuPont Far East Inc.
P.O. Box 2553/Jkt
Jakarta 10001
Indonesia
62-21-517-800





Goldstar Company

RECIPROCATING COMPRESSOR DIVISION

VS / NR / V – Series
L B P
220 – 240V / 50Hz

R134a

GoldStar

PARTS LIST OF GOLDSTAR COMPRESSOR

TO : GOLDSTAR COMP. EXPORT SECTION

FAX : 82-2-787-3074

FROM :

◆ CUSTOMER : _____
◆ COMP. MODEL : _____
◆ SPEC. NO. : _____

DATE : _____

DRAWN	APPROVED

- * RATED VOLTAGE :
- * LIST OF ACCESSORY PARTS



	DWG. NO.	PART NO.	Q'TY	SPECIFICATION
ELECTRICAL PARTS				
OVERLOAD PROTECTOR				
P T C				
PTC COVER				
MOUNTING PARTS				
SEAT RUBBER				
BOLT				
PIECE MOUNTING				
PLAIN WASHER				
SPRING WASHER				
NUT				

• CUSTOMER'S MEMO •

CUSTOMER'S DECISION
Decision : YES . NO
Signature :

• Please return one copy of this page on your approval.

NR - Series



* TUBE SPECIFICATION

	Suction & Process Tube (T 0.7)	Discharge Tube (T 1.0)
O.D./ I.D (mm) COPPER	8.0 / 6.6 8.0 / 6.1	6.95/ 4.95



* MOUNTING FITCH

TYPE	X	Y
FLAT	106	184
	70	170

MODEL	H	H1
NR45/52	173	65
NR58/62	177	69

TITLE	COMP. APPEARANCE
DWG. NO.	APR - F142

NR – Series



*** TUBE SPECIFICATION**

	Suction & Process Tube (T 0.7)	Discharge Tube (T 1.0)
O.D/ I.D	8.0 / 6.6	6.95 / 4.95
(■)	8.0 / 6.1	
COPPER		

*** MOUNTING PITCH**

TYPE	X	Y
FLAT	106	184
	70	170

MODEL	H	H1
NR45/52	173	65
NR58/62	177	69

TITLE	COMP. APPEARANCE
DWG. NO.	APR – F152

R134a, 50Hz/LBP Application

Series	Model	Displ. e- ment cc	Motor Type	Compressor Cooling	Refrigerant Control	Oil Charge cc	Weight kg(lb)	"ASHRAE" Performance												"CECOMAF" Performance				
								Capacity						Power consumption						Capacity				
								Evaporating temp. (°C)						Evaporating temp. (°C)						Evaporating temp. (°C)				
								-30	-25	23.3	-20	-15	-10	-30	-25	23.3	-20	-15	-10	-30	-25	-20	-15	-10
kcal/h	kcal/h	kcal/h	kcal/h	kcal/h	kcal/h	w	w	w	w	w	w	kcal/h	kcal/h	kcal/h	kcal/h	kcal/h								
VS	VS24L	2.42	RSIR	N	C	200	4.8 (10.6)	-	39	43	54	73	94	-	76	78	83	92	100	-	31	43	59	76
	VS28L	2.84	RSIR	N	C	200	5.8 (12.8)	-	48	55	67	92	120	-	78	80	86	95	104	-	39	54	75	97
	VS36L	3.58	RSIR	N	C	200	5.8 (12.8)	-	67	72	88	115	146	-	89	93	100	112	125	-	54	72	93	119
NR	NR45L	4.50	RSIR	N	C	210	8.5 (18.7)	59	84	93	114	146	189	87	100	104	114	126	143	49	67	90	117	149
	NR52L	5.20	RSIR	N	C	210	8.5 (18.7)	75	101	113	135	173	220	98	112	119	128	146	164	61	82	108	140	179
	NR62L	6.22	RSIR	N	C	210	8.8 (19.4)	87	122	134	163	209	267	108	128	132	148	167	190	69	99	131	166	215
V	V75L	7.46	RSIR	F, O	C	390	10.2 (22.5)	110	152	167	204	262	334	127	150	157	172	193	224	87	123	162	212	269

- 1) Performance data were obtained under 230V/50Hz running condition.
- 2) The High Efficiency models "RSCR" can be also available with permanent run capacitor
- 3) Refrigerant Control : C (Capillary tube)
- 4) Voltage range : 187V~264V

Notes

- 1) Capacity Conversion
 $1 \text{ kcal/h} = 3.97 \text{ Btu/h}$
 $1 \text{ kcal/h} = 1.16 \text{ Watt}$
- 2) $E.E.R(\text{Btu/Wh}) = \frac{\text{Capacity (kcal/h)} \times 3.97}{\text{Motor input(Watt)}}$
- 3) RSIR = Resistance Start Induction Run
RSCR = Resistance Start Capacitor Run



Compressor Cooling Test Conditions

	ASHRAE	CECOMAF
N = Natural Convection	Condensing temperature 54.4 °C (130 °F)	55 °C (131 °F)
O = Oil Cooling	Gas superheated to 37.2 °C (90 °F)	32 °C (90 °F)
F = Fan Cooling	Liquid subcooled to 32.2 °C (90 °F)	55 °C (131 °F)
	Ambient temperature 32.2 °C (90 °F)	32 °C (90 °F)

TITLE	PERFORMANCE DATA
DWG. NO.	PER--HF5A

• OLP (TEXAS INSTRUMENT)

• PTC Starter



ex) 4TM 330 KFB YY-52


- External Terminations (Male Quick Connects)
- Denotes Contact Capacity
- Designate Disc. Operating Temp. and Tolerance
- Three digit Heater Code
- Basic Name of Thermal Motor Protector

ex) P 6R8 M C

- Starting type
- Tolerance of the resistance ($\pm 20\%$)
- Normal resistance (6.8 ohms)
- PTC Starter


		VS24LAEG	VS28LAEG	VS36LAEG	NR45LAEG	NR52LAEG	NR62LAEG	V75LAEG
O	TYPE (Part No)	4TM117SFB (3C003010)	4TM149NFB (3C00301A)	4TM149NFB (3C00301A)	4TM166RFB (3C0030111)	4TM232NFB (3C00301G)	4TM205RFB (3C00404L)	4TM276LFB (3C00301F)
	OPEN TEMP. (°C)	135 $\begin{smallmatrix} +10 \\ -5 \end{smallmatrix}$	120 $\begin{smallmatrix} +10 \\ -5 \end{smallmatrix}$	120 $\begin{smallmatrix} +10 \\ -5 \end{smallmatrix}$	130 $\begin{smallmatrix} +10 \\ -5 \end{smallmatrix}$	120 $\begin{smallmatrix} +10 \\ -5 \end{smallmatrix}$	130 $\begin{smallmatrix} +10 \\ -5 \end{smallmatrix}$	110 $\begin{smallmatrix} +10 \\ -5 \end{smallmatrix}$
	CLOSE TEMP. (°C)	61 \pm 9	61 \pm 9	61 \pm 9	61 \pm 9	61 \pm 9	61 \pm 9	61 \pm 9
L	ULTIMATE TRIP CURRENT(A)	0.8~1.2	0.95~1.2	0.95~1.2	1.1~1.44	1.57~1.90	1.6~2.0	1.62~2.0
	P	CURRENT(A)	3.5	4.3	4.3	4.92	7.47	6.46
SHORT TIME		FIRST TRIP TIME(SEC)	10 \pm 5	10 \pm 5	10 \pm 5	10 \pm 5	10 \pm 5	10 \pm 5
RECOVERY TIME(SEC)		MIN. 50	MIN. 50	MIN. 50	MIN. 50	MIN. 50	MIN. 50	MIN. 50
P	TYPE (Part No)	P220MC (2C00146A)	P220MC (2C00146A)	P220MC (2C00146A)	P220MC (2C00146A)	P330MC (2C00146C)	P330MC (2C00146C)	P470MC (2C00146U)
	T	RESISTANCE AT 25 °C (Ω)	22 \pm 20%	22 \pm 20%	22 \pm 20%	22 \pm 20%	33 \pm 20%	33 \pm 20%
C	Max. VOLTAGE(Vrms)	300	300	300	300	355	355	400
	Max. CURRENT(Arms)	7	7	7	7	6	6	5

TITLE	ELECTRICAL PARTS
DWG. NO.	ELE - 1510




TITLE	EXPLODED VIEW
DWG. NO.	EXP-WCT1

*** BOLT TYPE**



	P / NO	φ	H
RUBBER GROMMET	3C00434A	φ 9	10
	4022C-0101A	φ 8	10.5
	4022C-0102A	φ 11	9.5
	3C00181A	φ 8.3	16
	3C00413A	φ 8.3	22
	3C00181B	φ 8.3	22
	3C00181C	φ 8.3	28

*** SNAP-ON TYPE**



1) BOLT TYPE ASSEMBLY

CHECK	RUBBER GROMMET	BOLT (M6*P1)	PIECE MOUNTING	PLAIN WASHER (O.D 25)	SPRING WASHER	NUT (M6*P1)
()	3C00434A	1BHD0603906	3C00286D	4040C-0101A	1WSD0600030	NHC303UD
()	4022C-0101A					
()	4022C-0102A	1BHD0603906	3C00286F	4040C-0101A	1WSD0600030	NHC3030D
()	3C00181A	1BHD0604306	3C00286E	4040C-0101A	1WSD0600030	NHC3030D
()	3C00413A	1BHD0604806	3C00286A	4040C-0101A	1WSD0600030	NHC3030D
()	3C00181B					
()	3C00181C	1BHD0605106	3C00286B	4040C-0101A	1WSD0600030	NHC3030D

2) SNAP-ON TYPE ASSEMBLY

CHECK	RUBBER GROMMET	STUD	STOPPER
()	3C00413A	3C00388A	4J02686A
()	3C00181B		
()	3C00434A	3C00388B	4J02686A
()	4022C-0101A		

* Checked(V) Item will be supplied

TITLE	MOUNTING ACCESSORY
DWG. NO.	ACC-0001

SUVA[®]
Refrigerant
HFC-134a

(1,1,1,2-TETRAFLUOROETHANE)



* SUVA is Du Pont's registered trademark for its alternative refrigerants
Only Du Pont makes SUVA environmentally acceptable refrigerants

Thermodynamic
Properties
of

SUVA[®]
Refrigerant
HFC-134a

(1,1,2-TETRAFLUOROETHANE)

PROPRIÉTÉS THERMODYNAMIQUES DU FLUIDE FRIGORIGÈNE HFC-134a
THERMODYNAMISCHE EIGENSCHAFTEN DES KÄLTEMITTELS FKW-134a
PROPRIETÀ TERMODINAMICHE DEL REFRIGERANTE HFC-134a
PROPIEDADES TERMODINAMICAS DEL REFRIGERANTE HFC-134a
THERMODYNAMISKE EGENSKAPER FOR HFC-134a KJØLEVÆSKE



* SUVA is Du Pont's registered trademark for its alternative refrigerants
Only Du Pont makes SUVA environmentally acceptable refrigerants

TABLE I: SATURATION PROPERTIES SUVA HFC - 134a

TEMP t °C	PRESS p bar	DENSITY		ENTHALPY			ENTROPY		SPEC. HEAT CAP.		TENS σ N/m	TEMP t °C
		ρ ^l kg/m ³	ρ ^v	h ^l	h ^l -h ^v	h ^v	s ^l	s ^v	c _p ^l	c _p ^v		
		liquid	vapour	liquid	latent	vapour	liquid	vapour	liquid	vapour		
-92	0.008	1577.8	0.044	79.4	259.4	337.2	0.451	1.941	1.153	0.604	0.0274	-92
-93	0.007	1575.0	0.046	79.5	257.6	336.4	0.458	1.935	1.152	0.603	0.0272	-93
-97	0.003	1572.8	0.054	80.7	253.0	333.0	0.465	1.931	1.151	0.604	0.0270	-97
-96	0.009	1569.5	0.059	81.3	251.7	333.5	0.471	1.926	1.151	0.603	0.0269	-96
-95	0.010	1566.9	0.065	83.0	251.1	340.1	0.478	1.921	1.151	0.603	0.0267	-95
-94	0.010	1564.1	0.072	84.2	256.5	340.7	0.484	1.916	1.151	0.605	0.0265	-94
-93	0.012	1561.3	0.079	85.3	256.0	341.3	0.491	1.912	1.151	0.608	0.0263	-93
-92	0.013	1558.6	0.086	86.5	255.4	341.9	0.497	1.907	1.152	0.610	0.0262	-92
-91	0.014	1555.8	0.094	87.6	254.9	342.5	0.503	1.903	1.152	0.612	0.0260	-91
-90	0.015	1553.1	0.103	88.8	254.3	343.1	0.510	1.896	1.153	0.614	0.0258	-90
-89	0.017	1550.4	0.112	89.9	253.8	343.7	0.516	1.894	1.153	0.617	0.0257	-89
-88	0.018	1547.6	0.122	91.1	253.2	344.3	0.522	1.890	1.154	0.619	0.0255	-88
-87	0.020	1544.9	0.133	92.3	252.7	344.9	0.528	1.886	1.155	0.621	0.0253	-87
-86	0.022	1542.1	0.145	93.4	252.1	345.5	0.534	1.892	1.156	0.624	0.0251	-86
-85	0.024	1539.4	0.158	94.6	251.6	346.2	0.541	1.878	1.157	0.626	0.0250	-85
-84	0.026	1535.7	0.171	95.7	251.0	346.8	0.547	1.874	1.158	0.628	0.0248	-84
-83	0.029	1533.9	0.185	96.9	250.5	347.4	0.553	1.870	1.159	0.630	0.0246	-83
-82	0.031	1531.2	0.201	98.0	249.9	348.0	0.559	1.867	1.161	0.633	0.0245	-82
-81	0.034	1528.5	0.217	99.2	249.4	348.6	0.565	1.863	1.162	0.635	0.0243	-81
-80	0.037	1525.7	0.235	100.4	248.8	349.2	0.571	1.859	1.164	0.637	0.0241	-80
-79	0.040	1522.0	0.253	101.5	248.3	349.8	0.577	1.856	1.166	0.640	0.0240	-79
-78	0.043	1520.2	0.273	102.7	247.7	350.4	0.583	1.853	1.167	0.642	0.0238	-78
-77	0.047	1517.5	0.295	103.9	247.2	351.1	0.589	1.849	1.168	0.645	0.0236	-77
-76	0.051	1514.8	0.317	105.0	246.6	351.7	0.595	1.846	1.170	0.647	0.0235	-76
-75	0.055	1512.0	0.341	106.2	246.1	352.3	0.601	1.843	1.172	0.649	0.0233	-75
-74	0.059	1509.3	0.367	107.4	245.5	352.9	0.607	1.840	1.173	0.651	0.0231	-74
-73	0.064	1506.5	0.394	108.6	245.0	353.5	0.613	1.837	1.174	0.653	0.0229	-73
-72	0.069	1503.8	0.421	109.7	244.4	354.2	0.619	1.834	1.175	0.655	0.0227	-72
-71	0.074	1501.0	0.451	110.9	243.9	354.8	0.625	1.831	1.176	0.657	0.0225	-71
-70	0.080	1498.3	0.485	112.1	243.3	355.4	0.630	1.828	1.177	0.659	0.0225	-70
-69	0.086	1495.5	0.520	113.3	242.8	356.0	0.636	1.825	1.178	0.664	0.0223	-69
-68	0.092	1492.8	0.556	114.5	242.2	356.6	0.642	1.822	1.178	0.667	0.0221	-68
-67	0.099	1490.0	0.594	115.6	241.6	357.3	0.648	1.820	1.179	0.669	0.0220	-67
-66	0.106	1487.3	0.634	116.6	241.1	357.9	0.653	1.817	1.179	0.672	0.0218	-66
-65	0.114	1484.5	0.677	118.0	240.5	358.5	0.659	1.814	1.180	0.674	0.0216	-65
-64	0.122	1481.8	0.722	119.2	239.9	359.2	0.665	1.812	1.182	0.677	0.0215	-64
-63	0.130	1479.0	0.769	120.4	239.4	359.8	0.670	1.810	1.184	0.679	0.0213	-63
-62	0.139	1476.3	0.819	121.6	238.8	360.4	0.676	1.807	1.185	0.682	0.0212	-62
-61	0.149	1473.5	0.871	122.8	238.2	361.0	0.682	1.805	1.187	0.684	0.0210	-61
-60	0.159	1470.7	0.926	124.0	237.7	361.7	0.687	1.802	1.200	0.687	0.0208	-60
-59	0.170	1468.0	0.984	125.2	237.1	362.3	0.693	1.800	1.202	0.690	0.0207	-59
-58	0.181	1465.2	1.044	126.4	236.5	362.9	0.699	1.798	1.204	0.692	0.0205	-58
-57	0.193	1462.4	1.108	127.6	236.0	363.6	0.704	1.796	1.206	0.695	0.0204	-57
-56	0.205	1459.6	1.175	128.8	235.4	364.2	0.710	1.794	1.208	0.698	0.0202	-56
-55	0.218	1456.9	1.245	130.0	234.8	364.8	0.715	1.792	1.210	0.701	0.0200	-55
-54	0.232	1454.1	1.318	131.2	234.2	365.4	0.721	1.790	1.212	0.703	0.0199	-54
-53	0.246	1451.3	1.395	132.4	233.6	366.1	0.726	1.788	1.214	0.706	0.0197	-53
-52	0.261	1448.5	1.476	133.7	233.1	366.7	0.732	1.786	1.216	0.709	0.0196	-52
-51	0.277	1445.7	1.560	134.9	232.5	367.3	0.737	1.784	1.218	0.712	0.0194	-51
-50	0.294	1442.9	1.648	136.1	231.9	368.0	0.743	1.782	1.220	0.714	0.0192	-50

SYMBOLS AND UNITS

Texte en français

TABLERAU I SUVA FLUIDE FRIGORIGÈNE HFC-134a - PROPRIÉTÉS DE SATURATION

TEMP t	PRESS p	MASSE VOLUME ρ' ρ"	ENTHALPIE h' h ^o -h' h"	ENTROPIE s' s"	CAPACITÉ SPECIF cp' cp"	TENS σ	TEMP t
°C	bar	kg/m ³	kJ/kg		kJ/(kg·K)		°C
		liquide vapeur	liquide latente vapeur	liquide vapeur	liquide vapeur		

Deutscher Text

TABELLE I SUVA KÄLTEMITTEL FKW-134a - SÄTTIGUNGSEIGENSCHAFTEN

TEMP t	DRUCK p	DICHTE ρ' ρ"	ENTHALPIE h' h ^o -h' h"	ENTROPIE s' s"	SPEZ WARMEKAP cp' cp"	SPANN σ	TEMP t
°C	bar	kg/m ³	kJ/kg		kJ/(kg·K)		°C
		flüssig dampf	flüssig latent dampf	flüssig dampf	flüssig dampf		

Texto en español

CUADRO I PROPIEDADES DE SATURACION DEL SUVA FLUIDO FRIGORIFICO HFC-134a

TEMP t	PRESION p	MASA VOLUMET ρ' ρ"	ENTHALPIA h' h ^o -h' h"	ENTROPIA s' s"	CALOR ESPECIF cp' cp"	TENS σ	TEMP t
°C	bar	kg/m ³	kJ/kg		kJ/(kg·K)		°C
		liquido vapor	liquido latente vapor	liquido vapor	liquido vapor		

Testo in italiano

TABELLA I PROPRIETÀ DI SATURAZIONE DEL SUVA FLUIDO FRIGORIGENO HFC-134a

TEMP t	PRESS p	VOLUME MASSICO ρ' ρ"	ENTHALPIA h' h ^o -h' h"	ENTROPIA s' s"	CALORE SPECIF cp' cp"	TENS σ	TEMP t
°C	bar	kg/m ³	kJ/kg		kJ/(kg·K)		°C
		liquido vapore	liquido latente vapore	liquido vapore	liquido vapore		

Norsk tekst

TABELL I EGENSKAPER VED METNINGSPUNKT FOR SUVA REFRIGERANT HFC-134a

TEMP t	TRYKK p	TETTHET ρ' ρ"	ENTHALPY h' h ^o -h' h"	ENTROPY s' s"	SPEIF VARMEKAP cp' cp"	SPENN σ	TEMP t
°C	bar	kg/m ³	kJ/kg		kJ/(kg·K)		°C
		vaeske damp	vaeske latent damp	vaeske damp	vaeske damp		

TABLE I: SATURATION PROPERTIES SUVA HFC - 134a

TEMP t	PRESS p	DENSITY		ENTHALPY			ENTROPY		SPEC. HEAT CAP.		TENS	TEMP t
		ρ^l	ρ^v	h^l	$h^l - h^v$	h^v	s^l	s^v	cp^l	cp^v	σ	
		kg/m ³	kg/m ³	kJ/kg	kJ/kg	kJ/kg	kJ/kg·K	kJ/kg·K	kJ/kg·K	kJ/kg·K	N/m	
1	3.04	1230.1	14.946	201.3	198.0	399.4	1.005	1.727	1.344	0.853	0.0116	1
2	3.15	1233.7	15.472	202.7	197.3	400.0	1.013	1.727	1.347	0.857	0.0115	2
3	3.26	1237.4	16.013	204.0	196.5	400.5	1.015	1.726	1.350	0.902	0.0113	3
4	3.38	1241.1	16.539	205.4	195.7	401.1	1.022	1.726	1.353	0.915	0.0112	4
5	3.50	1244.7	17.140	206.8	194.9	401.7	1.024	1.725	1.357	0.917	0.0110	5
6	3.62	1273.4	17.725	208.1	194.2	402.3	1.029	1.725	1.360	0.915	0.0109	6
7	3.75	1270.0	18.329	209.5	193.4	402.8	1.034	1.724	1.363	0.920	0.0107	7
8	3.88	1266.5	18.948	210.8	192.6	403.4	1.039	1.724	1.366	0.925	0.0106	8
9	4.01	1263.2	19.583	212.2	191.8	404.0	1.044	1.723	1.370	0.929	0.0105	9
10	4.15	1259.8	20.236	213.6	190.9	404.5	1.049	1.723	1.373	0.934	0.0103	10
11	4.29	1256.3	20.906	215.0	190.1	405.1	1.053	1.722	1.377	0.939	0.0102	11
12	4.43	1252.9	21.594	216.4	189.3	405.6	1.058	1.722	1.380	0.944	0.0100	12
13	4.58	1249.4	22.301	217.7	188.5	406.2	1.063	1.722	1.384	0.949	0.0099	13
14	4.73	1245.9	23.025	219.1	187.6	406.8	1.068	1.721	1.387	0.954	0.0098	14
15	4.89	1242.3	23.770	220.5	186.8	407.3	1.073	1.721	1.391	0.960	0.0096	15
16	5.05	1238.8	24.533	221.9	185.9	407.8	1.077	1.720	1.395	0.965	0.0095	16
17	5.21	1235.2	25.317	223.3	185.1	408.4	1.082	1.720	1.399	0.970	0.0094	17
18	5.38	1231.5	25.121	224.7	184.2	408.9	1.087	1.720	1.402	0.975	0.0092	18
19	5.55	1227.8	25.945	226.1	183.3	409.5	1.092	1.719	1.405	0.981	0.0091	19
20	5.72	1224.4	27.791	227.5	182.5	410.0	1.096	1.719	1.410	0.987	0.0089	20
21	5.90	1220.7	28.659	228.9	181.6	410.5	1.101	1.719	1.414	0.992	0.0088	21
22	6.08	1217.0	29.549	230.4	180.7	411.0	1.105	1.718	1.418	0.998	0.0087	22
23	6.27	1213.3	30.462	231.8	179.8	411.6	1.111	1.718	1.423	1.004	0.0085	23
24	6.46	1209.6	31.399	233.2	178.9	412.1	1.116	1.718	1.427	1.010	0.0084	24
25	6.66	1205.9	32.359	234.6	178.0	412.6	1.120	1.717	1.431	1.015	0.0083	25
26	6.86	1202.1	33.344	236.1	177.0	413.1	1.125	1.717	1.435	1.022	0.0081	26
27	7.07	1198.0	34.354	237.5	176.1	413.6	1.130	1.717	1.440	1.028	0.0080	27
28	7.28	1194.4	35.389	238.9	175.2	414.1	1.135	1.716	1.445	1.035	0.0079	28
29	7.49	1190.5	36.451	240.4	174.2	414.5	1.139	1.716	1.449	1.041	0.0077	29
30	7.71	1186.7	37.540	241.8	173.3	415.1	1.144	1.716	1.454	1.048	0.0076	30
31	7.93	1182.8	38.657	243.3	172.3	415.6	1.149	1.715	1.459	1.055	0.0075	31
32	8.16	1178.8	39.802	244.8	171.3	416.1	1.153	1.715	1.464	1.062	0.0073	32
33	8.40	1174.9	40.975	246.2	170.3	416.6	1.158	1.715	1.469	1.069	0.0072	33
34	8.64	1170.8	42.179	247.7	169.3	417.0	1.163	1.714	1.474	1.075	0.0071	34
35	8.88	1156.8	43.413	249.2	168.3	417.5	1.168	1.714	1.479	1.084	0.0069	35
36	9.13	1162.7	44.679	250.6	167.3	418.0	1.172	1.714	1.485	1.091	0.0068	36
37	9.38	1158.6	45.977	252.1	166.3	418.4	1.177	1.713	1.490	1.099	0.0067	37
38	9.64	1154.5	47.308	253.6	165.3	418.9	1.182	1.713	1.496	1.107	0.0065	38
39	9.91	1150.3	48.672	255.1	164.2	419.3	1.186	1.713	1.501	1.115	0.0064	39
40	10.18	1146.1	50.072	256.6	163.2	419.8	1.191	1.712	1.507	1.123	0.0063	40
41	10.45	1141.9	51.508	258.1	162.1	420.2	1.196	1.712	1.513	1.132	0.0062	41
42	10.73	1137.6	52.980	259.6	161.0	420.6	1.201	1.712	1.520	1.140	0.0060	42
43	11.02	1133.2	54.490	261.1	159.9	421.1	1.205	1.711	1.526	1.149	0.0059	43
44	11.31	1128.9	56.040	262.7	158.8	421.5	1.210	1.711	1.533	1.159	0.0058	44
45	11.61	1124.5	57.630	264.2	157.7	421.9	1.215	1.711	1.539	1.168	0.0057	45
46	11.91	1120.0	59.261	265.7	156.6	422.3	1.220	1.710	1.546	1.178	0.0055	46
47	12.22	1115.6	60.934	267.3	155.4	422.7	1.224	1.710	1.553	1.188	0.0054	47
48	12.54	1111.0	62.652	268.8	154.3	423.1	1.229	1.709	1.561	1.198	0.0053	48
49	12.86	1106.4	64.415	270.4	153.1	423.5	1.234	1.709	1.568	1.209	0.0052	49
50	13.19	1101.8	66.225	271.9	151.9	423.8	1.238	1.709	1.576	1.220	0.0050	50

	English	Français	Deutsch	Español	Italiano	Norsk
t	temperature	température	Temperatur	temperatura	temperatura	temperatur
ρ	density	masse volumique	Dichte	masa volumetrica	densità	tetthet
h	enthalpy	enthalpie	Enthalpie	entalpía	entalpia	enthalpy
s	entropy	entropie	Entropie	entropía	entropia	entropy
cp	specific capacity	capacité calorifique	spez. Wärmekapazität	cap. específica	calore specifico	spesifikk varmekap.
c	speed of sound	vitesse du son	Schallgeschwindigkeit	velocidad del sonido	velocità del suono	lydets hastighet

Texten français

TABLEAU II SUVA FLUIDE FRIGORIGÈNE HFC-134a-VAPEUR SURCHAUFFÉE

													température de saturation entre parenthèses		
(t) °C	(ρ) kg/m ³	(h) kJ/kg	(s) kJ/(kg·K)	(cp) kJ/(kg·K)	(c) km/s							(p) h	(cp) c	(t)	
t	ρ	h	s	cp	c	p	h	s	cp	c	p	h	cp	c	t

Deutscher Text

TABELLE II SUVA KÄLTEMITTEL FKW-134a - ÜBERHITZTER DAMPF

													Sättigungstemperatur in Klammern		
(t) °C	(ρ) kg/m ³	(h) kJ/kg	(s) kJ/(kg·K)	(cp) kJ/(kg·K)	(c) km/s							(p) h	(cp) c	(t)	
t	ρ	h	s	cp	c	p	h	s	cp	c	p	h	cp	c	t

Texto en español

CUADRO II SUVA FLUIDO FRIGORIFICO HFC-134a-VAPOR RECALENTADO

													temperatura de saturación entre paréntesis		
(t) °C	(ρ) kg/m ³	(h) kJ/kg	(s) kJ/(kg·K)	(cp) kJ/(kg·K)	(c) km/s							(p) h	(cp) c	(t)	
t	ρ	h	s	cp	c	p	h	s	cp	c	p	h	cp	c	t

Testo in italiano

TABELLA II SUVA FLUIDO FRIGORIGENO HFC-134a-VAPORE SURRISCALDATO

													temperatura d'equilibrio tra parentesi		
(t) °C	(ρ) kg/m ³	(h) kJ/kg	(s) kJ/(kg·K)	(cp) kJ/(kg·K)	(c) km/s							(p) h	(cp) c	(t)	
t	ρ	h	s	cp	c	p	h	s	cp	c	p	h	cp	c	t

Norsk tekst

TABELL II SUVA REFRIGERANT HFC-134a-OVERHETET DAMP

													metningstemperatur i parentesi		
(t) °C	(ρ) kg/m ³	(h) kJ/kg	(s) kJ/(kg·K)	(cp) kJ/(kg·K)	(c) km/s							(p) h	(cp) c	(t)	
t	ρ	h	s	cp	c	p	h	s	cp	c	p	h	cp	c	t

TABLE I: SATURATION PROPERTIES SUVA HFC - 134a

TEMP	PRESS	DENSITY		ENTHALPY			ENTROPY		SPEC. HEAT CAP.		TENS	TEMP				
		t	p	ρ^l	ρ^v	h^l	$h^v - h^l$	h^v	s^l	s^v			cp^l	cp^v	σ	t
		°C	bar	kg/m ³		kJ/kg			kJ/kg-K				kJ/kg-K		N/m	°C
		liquid	vapour	liquid	latent	vapour	liquid	vapour	liquid	vapour			liquid	vapour		
51	13.52	1037.1	69.084	273.5	150.7	424.2	1.213	1.709	1.584	1.232	0.0043	51				
52	13.87	1052.4	69.992	275.1	149.5	424.6	1.248	1.706	1.592	1.243	0.0048	52				
53	14.21	1067.8	71.952	276.6	148.3	424.9	1.253	1.707	1.601	1.256	0.0047	53				
54	14.57	1083.5	73.965	278.2	147.0	425.3	1.257	1.707	1.607	1.268	0.0045	54				
55	14.93	1099.5	76.035	279.8	145.8	425.6	1.262	1.705	1.611	1.282	0.0044	55				
56	15.29	1072.9	78.162	281.4	144.5	425.9	1.267	1.706	1.628	1.295	0.0043	56				
57	15.67	1067.9	80.348	283.0	143.2	426.2	1.272	1.706	1.638	1.310	0.0042	57				
58	16.05	1062.3	82.596	284.6	141.9	426.5	1.277	1.705	1.648	1.325	0.0041	58				
59	16.43	1057.7	84.908	286.3	140.5	426.8	1.281	1.704	1.659	1.340	0.0039	59				
60	16.83	1052.5	87.287	287.9	139.2	427.1	1.286	1.704	1.670	1.356	0.0038	60				
61	17.23	1047.2	89.735	289.5	137.8	427.4	1.291	1.703	1.681	1.373	0.0037	61				
62	17.64	1041.8	92.255	291.2	136.4	427.6	1.296	1.703	1.693	1.391	0.0036	62				
63	18.05	1036.4	94.851	292.9	135.0	427.9	1.301	1.702	1.706	1.410	0.0035	63				
64	18.47	1030.9	97.526	294.5	133.6	428.1	1.305	1.702	1.719	1.429	0.0034	64				
65	18.91	1025.3	100.283	296.2	132.1	428.3	1.310	1.701	1.732	1.450	0.0032	65				
66	19.34	1019.6	103.125	297.9	130.6	428.5	1.315	1.700	1.747	1.471	0.0031	66				
67	19.79	1013.8	106.058	299.6	129.1	428.7	1.320	1.700	1.762	1.494	0.0030	67				
68	20.24	1008.0	109.095	301.3	127.5	428.8	1.325	1.699	1.778	1.519	0.0029	68				
69	20.70	1002.1	112.212	303.0	126.0	429.0	1.330	1.698	1.794	1.544	0.0028	69				
70	21.17	996.3	115.442	304.8	124.4	429.1	1.335	1.697	1.812	1.572	0.0027	70				
71	21.65	989.7	118.783	306.5	122.7	429.2	1.340	1.695	1.830	1.601	0.0026	71				
72	22.14	983.4	122.239	308.3	121.1	429.3	1.345	1.695	1.850	1.632	0.0025	72				
73	22.63	977.0	125.818	310.1	119.4	429.4	1.350	1.695	1.871	1.665	0.0024	73				
74	23.13	970.4	129.527	311.8	117.6	429.5	1.355	1.694	1.894	1.701	0.0023	74				
75	23.64	963.7	133.373	313.7	115.8	429.5	1.360	1.692	1.918	1.739	0.0022	75				
76	24.16	956.9	137.365	315.5	114.0	429.5	1.365	1.691	1.943	1.781	0.0021	76				
77	24.69	949.9	141.514	317.3	112.2	429.5	1.370	1.691	1.971	1.825	0.0020	77				
78	25.23	942.7	145.830	319.2	110.3	429.4	1.375	1.690	2.001	1.875	0.0019	78				
79	25.77	935.4	150.324	321.0	108.3	429.3	1.380	1.689	2.033	1.925	0.0018	79				
80	26.32	927.9	155.010	322.9	106.3	429.2	1.385	1.688	2.068	1.986	0.0016	80				
81	26.89	920.1	159.904	324.9	104.2	429.1	1.391	1.685	2.106	2.051	0.0015	81				
82	27.47	912.1	165.021	326.8	102.1	428.9	1.396	1.683	2.148	2.122	0.0015	82				
83	28.05	903.9	170.383	328.8	99.9	428.7	1.401	1.682	2.195	2.201	0.0014	83				
84	28.65	895.5	176.010	330.7	97.7	428.4	1.407	1.680	2.246	2.290	0.0013	84				
85	29.25	886.7	181.929	332.8	95.3	428.1	1.412	1.678	2.304	2.390	0.0012	85				
86	29.87	877.6	188.169	334.8	92.9	427.7	1.418	1.676	2.369	2.503	0.0011	86				
87	30.49	868.2	194.766	336.9	90.4	427.3	1.423	1.674	2.443	2.633	0.0010	87				
88	31.13	858.4	201.761	339.0	87.7	426.8	1.429	1.672	2.528	2.784	0.0009	88				
89	31.77	848.1	209.206	341.2	85.0	426.2	1.435	1.669	2.627	2.959	0.0008	89				
90	32.43	837.3	217.162	343.4	82.1	425.5	1.441	1.667	2.744	3.167	0.0007	90				
91	33.10	826.0	225.705	345.7	79.1	424.8	1.447	1.664	2.884	3.418	0.0006	91				
92	33.78	814.0	234.936	348.0	75.9	423.9	1.453	1.661	3.055	3.724	0.0006	92				
93	34.47	801.1	244.978	350.4	72.5	422.9	1.459	1.657	3.269	4.108	0.0005	93				
94	35.18	787.4	256.005	353.0	68.9	421.8	1.466	1.653	3.546	4.602	0.0004	94				
95	35.89	772.3	268.255	355.6	64.9	420.5	1.473	1.649	3.917	5.261	0.0003	95				
96	36.63	755.8	282.079	358.4	60.5	418.9	1.480	1.644	4.442	6.184	0.0003	96				
97	37.37	737.1	298.029	361.3	55.7	417.0	1.488	1.638	5.241	7.566	0.0002	97				
98	38.13	715.4	317.065	364.6	50.0	414.6	1.496	1.631	6.600	9.867	0.0001	98				
99	38.91	688.5	341.133	368.4	43.2	411.5	1.506	1.622	9.392	14.406	0.0001	99				
100	39.70	651.4	375.503	373.2	33.8	407.0	1.519	1.609	18.008	27.554	0.0000	100				

TABLE I: SATURATION PROPERTIES SUVA HFC - 134a

TEMP t	PRESS p	DENSITY		ENTHALPY			ENTROPY		SPEC. HEAT CAP.		TENS σ	TEMP t
		ρ ^l	ρ ^v	h ^l	h ^v -h ^l	h ^v	s ^l	s ^v	cp ^l	cp ^v		
°C	bar	kg/m ³		kJ/kg			kJ/kg-K		kJ/kg-K		N/m	°C
		liquid	vapour	liquid	latent	vapour	liquid	vapour	liquid	vapour		
-49	0.31	1440.1	1.740	137.3	231.3	368.6	0.749	1.780	1.222	0.717	0.0191	-49
-48	0.33	1437.3	1.835	138.5	230.7	369.2	0.754	1.776	1.224	0.720	0.0189	-48
-47	0.35	1434.5	1.935	139.8	230.1	369.9	0.759	1.777	1.226	0.723	0.0188	-47
-46	0.37	1431.6	2.040	141.0	229.5	370.5	0.765	1.775	1.228	0.726	0.0186	-46
-45	0.39	1428.9	2.149	142.2	228.9	371.1	0.770	1.773	1.230	0.729	0.0185	-45
-44	0.41	1426.0	2.263	143.5	228.3	371.8	0.775	1.772	1.232	0.732	0.0183	-44
-43	0.44	1423.2	2.382	144.7	227.7	372.4	0.781	1.770	1.234	0.735	0.0182	-43
-42	0.46	1420.3	2.505	145.9	227.1	373.0	0.786	1.769	1.237	0.736	0.0180	-42
-41	0.49	1417.5	2.633	147.2	226.5	373.7	0.791	1.767	1.239	0.741	0.0178	-41
-40	0.51	1414.6	2.767	148.4	225.9	374.3	0.797	1.766	1.241	0.744	0.0177	-40
-39	0.54	1411.8	2.906	149.6	225.3	374.9	0.802	1.764	1.243	0.747	0.0175	-39
-38	0.57	1408.9	3.050	150.9	224.7	375.5	0.807	1.763	1.245	0.750	0.0174	-38
-37	0.60	1406.0	3.200	152.1	224.0	376.2	0.813	1.761	1.247	0.753	0.0172	-37
-36	0.63	1403.1	3.356	153.4	223.4	376.8	0.818	1.760	1.250	0.755	0.0171	-36
-35	0.66	1400.2	3.518	154.6	222.8	377.4	0.823	1.759	1.252	0.759	0.0169	-35
-34	0.69	1397.4	3.686	155.9	222.2	378.1	0.828	1.757	1.254	0.762	0.0168	-34
-33	0.73	1394.5	3.861	157.1	221.5	378.7	0.834	1.756	1.256	0.766	0.0166	-33
-32	0.77	1391.5	4.042	158.4	220.9	379.2	0.839	1.755	1.259	0.769	0.0165	-32
-31	0.80	1388.6	4.229	159.7	220.3	379.9	0.844	1.754	1.261	0.772	0.0163	-31
-30	0.84	1385.7	4.424	160.9	219.6	380.5	0.849	1.753	1.263	0.775	0.0162	-30
-29	0.88	1382.8	4.625	162.2	219.0	381.2	0.854	1.751	1.265	0.779	0.0160	-29
-28	0.93	1379.8	4.833	163.5	218.3	381.8	0.860	1.750	1.268	0.782	0.0159	-28
-27	0.97	1376.9	5.049	164.7	217.7	382.4	0.865	1.749	1.270	0.785	0.0157	-27
-26	1.02	1373.9	5.273	166.0	217.1	383.1	0.870	1.748	1.272	0.789	0.0156	-26
-25	1.06	1371.0	5.504	167.3	216.4	383.7	0.875	1.747	1.275	0.792	0.0154	-25
-24	1.11	1368.0	5.743	168.5	215.7	384.3	0.880	1.745	1.277	0.796	0.0153	-24
-23	1.16	1365.0	5.991	169.8	215.1	384.9	0.885	1.745	1.279	0.799	0.0151	-23
-22	1.22	1362.0	6.247	171.1	214.4	385.5	0.890	1.744	1.282	0.803	0.0150	-22
-21	1.27	1359.0	6.511	172.4	213.7	386.2	0.895	1.743	1.284	0.807	0.0148	-21
-20	1.33	1355.0	6.784	173.7	213.1	386.8	0.901	1.742	1.287	0.810	0.0147	-20
-19	1.39	1353.0	7.066	175.0	212.4	387.4	0.905	1.741	1.289	0.813	0.0145	-19
-18	1.45	1349.9	7.357	176.3	211.7	388.0	0.911	1.740	1.292	0.817	0.0144	-18
-17	1.51	1346.9	7.653	177.6	211.0	388.6	0.916	1.740	1.294	0.821	0.0142	-17
-16	1.57	1343.8	7.968	178.9	210.4	389.2	0.921	1.739	1.297	0.824	0.0141	-16
-15	1.64	1340.8	8.288	180.2	209.7	389.8	0.926	1.738	1.299	0.828	0.0139	-15
-14	1.71	1337.7	8.618	181.5	209.0	390.4	0.931	1.737	1.302	0.832	0.0138	-14
-13	1.78	1334.6	8.958	182.8	208.3	391.1	0.936	1.736	1.305	0.836	0.0136	-13
-12	1.85	1331.5	9.309	184.1	207.6	391.7	0.941	1.736	1.307	0.839	0.0135	-12
-11	1.93	1328.4	9.671	185.4	206.9	392.3	0.946	1.735	1.310	0.843	0.0133	-11
-10	2.01	1325.3	10.044	186.7	206.2	392.9	0.951	1.734	1.313	0.847	0.0132	-10
-9	2.09	1322.1	10.428	188.0	205.4	393.5	0.956	1.733	1.315	0.851	0.0130	-9
-8	2.17	1319.0	10.823	189.3	204.7	394.1	0.961	1.733	1.318	0.855	0.0129	-8
-7	2.26	1315.8	11.231	190.7	204.0	394.7	0.966	1.732	1.321	0.859	0.0127	-7
-6	2.34	1312.6	11.650	192.0	203.3	395.3	0.971	1.731	1.324	0.863	0.0126	-6
-5	2.43	1309.4	12.082	193.3	202.5	395.9	0.976	1.731	1.326	0.867	0.0125	-5
-4	2.53	1306.2	12.526	194.6	201.8	396.4	0.980	1.730	1.329	0.871	0.0123	-4
-3	2.62	1303.0	12.983	196.0	201.1	397.0	0.985	1.730	1.332	0.875	0.0122	-3
-2	2.72	1299.8	13.454	197.3	200.3	397.6	0.990	1.729	1.335	0.880	0.0120	-2
-1	2.82	1296.5	13.937	198.7	199.6	398.2	0.995	1.728	1.338	0.884	0.0119	-1
0	2.93	1293.3	14.435	200.0	198.8	398.8	1.000	1.728	1.341	0.888	0.0117	0

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	[p] in kg/m ²					[ρ] in kg/m ³					[c _p] in J/(kg·K)					t
	p	h	s	cp	c	ρ	h	s	cp	c	ρ	h	s	cp	c	
	ps=0.060 bar (ts=70°C)					ps=0.066 bar (ts=69°C)					ps=0.092 bar (ts=68°C)					
70	0.436	355.4	1.828	0.692	136.9	0.503	359.7	1.838	0.671	138.4	0.549	369.7	1.832	0.672	138.3	-7.0
65	0.474	358.7	1.844	0.671	138.4	0.497	362.1	1.854	0.683	140.0	0.525	362.0	1.848	0.687	139.9	-6.0
60	0.502	362.1	1.860	0.650	140.0	0.491	364.5	1.870	0.695	141.6	0.502	364.5	1.854	0.690	141.5	-5.0
55	0.531	365.5	1.876	0.629	141.5	0.484	366.9	1.886	0.707	143.2	0.487	366.9	1.860	0.693	143.0	-5.7
50	0.561	369.0	1.892	0.608	143.0	0.478	369.3	1.902	0.719	144.8	0.480	369.3	1.876	0.696	143.0	
45	0.591	372.5	1.908	0.587	144.5	0.472	371.7	1.918	0.731	146.4	0.483	371.7	1.892	0.699	144.5	-4.5
40	0.621	376.0	1.924	0.566	146.0	0.466	374.1	1.934	0.743	148.0	0.485	374.1	1.908	0.702	146.0	-4.0
35	0.651	379.5	1.940	0.545	147.5	0.460	376.5	1.950	0.755	149.6	0.487	376.5	1.924	0.705	147.5	-3.5
30	0.681	383.0	1.956	0.524	149.0	0.454	378.9	1.966	0.767	151.2	0.489	378.9	1.940	0.708	149.0	-3.0
25	0.711	386.5	1.972	0.503	150.5	0.448	381.3	1.982	0.779	152.8	0.491	381.3	1.956	0.711	150.5	-2.5
20	0.741	390.0	1.988	0.482	152.0	0.442	383.7	1.998	0.791	154.4	0.493	383.7	1.972	0.714	152.0	
15	0.771	393.5	2.004	0.461	153.5	0.436	386.1	2.014	0.803	156.0	0.495	386.1	1.988	0.717	153.5	-1.5
10	0.801	397.0	2.020	0.440	155.0	0.430	388.5	2.030	0.815	157.6	0.497	388.5	2.004	0.720	155.0	-1.0
5	0.831	400.5	2.036	0.419	156.5	0.424	390.9	2.046	0.827	159.2	0.499	390.9	2.020	0.723	156.5	-0.5
0	0.861	404.0	2.052	0.398	158.0	0.418	393.3	2.062	0.839	160.8	0.501	393.3	2.036	0.726	158.0	0
5	0.891	407.5	2.068	0.377	159.5	0.412	395.7	2.078	0.851	162.4	0.503	395.7	2.052	0.729	159.5	0.5
10	0.921	411.0	2.084	0.356	161.0	0.406	398.1	2.094	0.863	164.0	0.505	398.1	2.068	0.732	161.0	1.0
15	0.951	414.5	2.100	0.335	162.5	0.400	400.5	2.110	0.875	165.6	0.507	400.5	2.084	0.735	162.5	1.5
20	0.981	418.0	2.116	0.314	164.0	0.394	402.9	2.126	0.887	167.2	0.509	402.9	2.100	0.738	164.0	2.0
25	1.011	421.5	2.132	0.293	165.5	0.388	405.3	2.142	0.899	168.8	0.511	405.3	2.116	0.741	165.5	2.5
30	1.041	425.0	2.148	0.272	167.0	0.382	407.7	2.158	0.911	170.4	0.513	407.7	2.132	0.744	167.0	3.0
35	1.071	428.5	2.164	0.251	168.5	0.376	410.1	2.174	0.923	172.0	0.515	410.1	2.148	0.747	168.5	3.5
40	1.101	432.0	2.180	0.230	170.0	0.370	412.5	2.190	0.935	173.6	0.517	412.5	2.164	0.750	170.0	4.0
45	1.131	435.5	2.196	0.209	171.5	0.364	414.9	2.206	0.947	175.2	0.519	414.9	2.180	0.753	171.5	4.5
50	1.161	439.0	2.212	0.188	173.0	0.358	417.3	2.222	0.959	176.8	0.521	417.3	2.196	0.756	173.0	5.0
55	1.191	442.5	2.228	0.167	174.5	0.352	419.7	2.238	0.971	178.4	0.523	419.7	2.212	0.759	174.5	5.5
60	1.221	446.0	2.244	0.146	176.0	0.346	422.1	2.254	0.983	180.0	0.525	422.1	2.228	0.762	176.0	6.0
	ps=0.099 bar (ts=67°C)					ps=0.126 bar (ts=66°C)					ps=0.144 bar (ts=65°C)					
65	0.585	356.6	1.825	0.673	139.3	0.631	358.6	1.820	0.673	138.2	0.677	358.6	1.815	0.670	139.2	-6.5
60	0.574	362.0	1.842	0.652	139.9	0.625	362.0	1.835	0.692	139.9	0.650	361.9	1.831	0.683	139.6	-6.0
55	0.560	365.4	1.858	0.631	141.4	0.621	365.4	1.852	0.691	141.4	0.645	365.4	1.847	0.692	141.3	-5.5
50	0.547	368.9	1.874	0.610	142.9	0.617	368.9	1.869	0.701	142.9	0.621	368.9	1.862	0.701	142.9	-5.1
45	0.535	372.4	1.890	0.589	144.5	0.574	372.4	1.884	0.709	144.4	0.616	372.4	1.876	0.701	144.4	-4.6
40	0.522	376.0	1.905	0.568	145.9	0.552	376.0	1.899	0.718	145.9	0.602	376.0	1.891	0.709	145.9	-4.0
35	0.510	379.5	1.920	0.547	147.4	0.550	379.5	1.914	0.727	147.4	0.586	379.5	1.905	0.709	147.3	-3.5
30	0.501	383.0	1.936	0.526	148.9	0.558	383.0	1.930	0.736	148.9	0.577	383.0	1.904	0.707	148.8	-3.0
25	0.491	387.0	1.951	0.505	150.3	0.557	386.9	1.945	0.745	150.3	0.567	386.9	1.909	0.706	150.2	-2.5
20	0.481	390.7	1.965	0.484	151.7	0.516	390.7	1.960	0.754	151.7	0.554	390.7	1.954	0.705	151.7	-2.0
15	0.472	394.5	1.980	0.463	153.1	0.505	394.5	1.975	0.763	153.1	0.543	394.5	1.969	0.704	153.1	-1.5
10	0.463	398.3	1.995	0.442	154.5	0.496	398.3	1.989	0.772	154.5	0.532	398.3	1.984	0.703	154.5	-1.0
5	0.454	402.2	2.010	0.421	155.9	0.487	402.2	2.004	0.781	155.9	0.522	402.2	1.998	0.702	155.8	-0.5
0	0.445	406.0	2.024	0.400	157.2	0.478	406.0	2.018	0.790	157.2	0.512	406.0	2.013	0.701	157.2	0
5	0.437	410.0	2.038	0.379	158.6	0.469	410.0	2.033	0.799	158.6	0.503	410.0	2.027	0.699	158.5	0.5
10	0.430	414.1	2.052	0.358	159.9	0.461	414.1	2.047	0.808	159.9	0.494	414.1	2.042	0.698	159.9	1.0
15	0.422	418.2	2.066	0.337	161.2	0.453	418.2	2.061	0.817	161.2	0.483	418.2	2.057	0.697	161.2	1.5
20	0.415	422.3	2.080	0.316	162.5	0.445	422.3	2.075	0.826	162.5	0.477	422.3	2.072	0.696	162.5	2.0
25	0.408	426.5	2.094	0.295	163.9	0.438	426.5	2.089	0.835	163.9	0.469	426.5	2.064	0.695	163.9	2.5
30	0.401	430.7	2.108	0.274	165.2	0.430	430.6	2.104	0.843	165.2	0.461	430.6	2.099	0.694	165.2	3.0
35	0.395	434.9	2.122	0.253	166.4	0.423	434.9	2.117	0.852	166.4	0.454	434.9	2.112	0.693	166.4	3.5
40	0.388	439.2	2.136	0.232	167.7	0.416	439.2	2.131	0.861	167.7	0.446	439.2	2.106	0.692	167.7	4.0
45	0.382	443.5	2.150	0.211	169.0	0.410	443.5	2.145	0.869	169.0	0.439	443.5	2.109	0.691	169.0	4.5
50	0.376	447.9	2.164	0.190	170.2	0.404	447.9	2.158	0.878	170.2	0.433	447.8	2.103	0.690	170.2	5.0
55	0.370	452.3	2.178	0.169	171.4	0.397	452.3	2.172	0.885	171.4	0.426	452.3	2.106	0.689	171.4	5.5
	ps=0.122 bar (ts=64°C)					ps=0.136 bar (ts=63°C)					ps=0.139 bar (ts=62°C)					
60	0.708	361.9	1.825	0.584	139.7	0.758	361.8	1.815	0.684	139.6	0.811	361.8	1.814	0.685	139.6	-6.0
55	0.691	365.3	1.841	0.563	141.3	0.740	365.3	1.835	0.693	141.2	0.791	365.2	1.820	0.694	141.1	-5.5
50	0.675	368.8	1.857	0.542	142.8	0.722	368.8	1.851	0.702	142.7	0.773	368.7	1.845	0.703	142.7	-5.0
45	0.660	372.3	1.872	0.521	144.3	0.706	372.3	1.867	0.711	144.3	0.755	372.2	1.851	0.711	144.2	-4.5
40	0.645	375.9	1.888	0.500	145.8	0.691	375.9	1.882	0.720	145.9	0.739	375.8	1.877	0.720	145.7	-4.0
35	0.631	379.5	1.903	0.479	147.3	0.676	379.5	1.897	0.729	147.3	0.723	379.5	1.892	0.729	147.2	-3.5
30	0.618	383.2	1.918	0.458	148.8	0.661	383.1	1.913	0.737	148.7	0.707	383.1	1.907	0.738	148.7	-3.0
25	0.605	386.9	1.933	0.437	150.2	0.646	386.9	1.928	0.746	150.2	0.691	386.8	1.922	0.747	150.1	-2.5
20	0.593	390.5	1.948	0.416	151.6	0.635	390.6	1.943	0.755	151.6	0.679	390.6	1.937	0.756	151.5	-2.0
15	0.581	394.4	1.963	0.395	153.0	0.622	394.4	1.958	0.764	153.0	0.665	394.4	1.952	0.765	153.0	-1.5
10	0.570	398.3	1.978	0.374	154.4	0.610	398.3	1.972	0.773	154.4	0.65					

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	[bar]					[kg/m ³]					[kJ/kg]					i
	p	h	s	cp	c	ρ	h	s	cp	c	ρ	h	s	cp	c	
	ps=0.261 bar (ts=52°C)					ps=0.277 bar (ts=51°C)					ps=0.294 bar (ts=50°C)					
-50	1.462	368.1	1.792	0.712	141.9	1.552	369.1	1.787	0.713	141.8	1.648	369.3	1.782	0.714	141.7	-50
-45	1.427	371.7	1.808	0.720	143.5	1.516	371.6	1.813	0.721	143.4	1.609	371.7	1.798	0.722	143.3	-45
-40	1.395	375.3	1.824	0.728	145.1	1.481	375.3	1.839	0.729	145.0	1.572	375.2	1.814	0.730	144.9	-40
-35	1.364	379.0	1.839	0.736	146.6	1.446	378.9	1.864	0.737	146.5	1.507	378.9	1.829	0.735	146.4	-35
-30	1.334	382.7	1.855	0.744	148.1	1.411	382.6	1.889	0.745	148.0	1.504	382.7	1.844	0.745	147.9	-30
-25	1.307	386.4	1.870	0.752	149.6	1.377	386.4	1.915	0.753	149.5	1.470	386.3	1.859	0.754	149.4	-25
-20	1.282	390.2	1.885	0.760	151.0	1.343	390.2	1.941	0.761	151.0	1.472	390.1	1.873	0.762	150.9	-20
-15	1.258	394.0	1.900	0.768	152.5	1.310	394.0	1.967	0.770	152.4	1.474	393.9	1.887	0.770	152.4	-15
-10	1.229	397.9	1.915	0.776	153.9	1.278	397.9	1.993	0.778	153.9	1.476	397.8	1.901	0.775	153.5	-10
-5	1.206	401.6	1.929	0.783	155.3	1.246	401.6	1.974	0.787	155.3	1.478	401.7	1.915	0.785	155.2	-5
0	1.183	405.6	1.944	0.795	156.7	1.215	405.7	1.934	0.795	156.7	1.480	405.7	1.934	0.796	156.6	0
5	1.161	409.5	1.958	0.803	158.1	1.184	409.7	1.954	0.804	158.0	1.482	409.7	1.949	0.804	158.0	5
10	1.140	413.8	1.973	0.812	159.4	1.153	413.8	1.975	0.812	159.4	1.484	413.7	1.963	0.813	159.4	10
15	1.120	417.9	1.987	0.820	160.8	1.123	417.8	1.997	0.821	160.8	1.486	417.8	1.977	0.821	160.7	15
20	1.100	422.0	2.001	0.829	162.1	1.093	422.0	1.970	0.829	162.1	1.488	421.9	1.990	0.830	162.0	20
25	1.082	426.2	2.015	0.838	163.5	1.063	426.1	2.011	0.838	163.4	1.489	426.1	2.006	0.838	163.4	25
30	1.063	430.4	2.029	0.846	164.8	1.033	430.2	2.025	0.846	164.7	1.491	430.3	2.020	0.847	164.7	30
35	1.045	434.6	2.043	0.854	166.1	1.003	434.6	2.032	0.855	166.0	1.492	434.5	2.034	0.855	166.0	35
40	1.029	438.9	2.057	0.863	167.3	0.973	438.9	2.052	0.863	167.3	1.493	438.9	2.047	0.863	167.3	40
45	1.012	443.3	2.071	0.871	168.6	0.943	443.2	2.066	0.871	168.6	1.494	443.2	2.061	0.872	168.6	45
50	0.997	447.6	2.085	0.880	169.9	0.913	447.6	2.080	0.880	169.8	1.495	447.6	2.075	0.880	169.8	50
55	0.981	452.1	2.098	0.888	171.1	0.883	452.0	2.093	0.888	171.1	1.496	452.0	2.088	0.888	171.1	55
60	0.966	456.5	2.112	0.896	172.4	0.853	456.5	2.107	0.896	172.3	1.497	456.5	2.102	0.897	172.3	60
65	0.952	461.0	2.125	0.904	173.6	0.823	461.0	2.120	0.905	173.6	1.497	461.0	2.115	0.905	173.6	65
70	0.935	465.6	2.139	0.913	174.8	0.793	465.6	2.132	0.913	174.8	1.498	465.6	2.129	0.913	174.8	70
	ps=0.312 bar (ts=49°C)					ps=0.330 bar (ts=48°C)					ps=0.349 bar (ts=47°C)					
-45	1.707	371.5	1.793	0.723	143.2	1.809	371.4	1.788	0.725	143.1	1.917	371.3	1.783	0.725	143.0	-45
-40	1.657	375.1	1.809	0.731	144.6	1.753	375.0	1.804	0.732	144.7	1.873	375.0	1.799	0.733	144.6	-40
-35	1.610	378.8	1.824	0.739	146.0	1.708	378.7	1.819	0.740	145.2	1.831	378.7	1.814	0.741	146.1	-35
-30	1.595	382.5	1.840	0.747	147.2	1.691	382.4	1.835	0.748	147.3	1.791	382.4	1.830	0.749	147.7	-30
-25	1.561	386.3	1.855	0.755	148.3	1.654	386.2	1.851	0.750	148.2	1.751	386.1	1.841	0.751	149.0	-25
-20	1.524	390.1	1.870	0.763	149.3	1.617	390.1	1.865	0.754	150.1	1.710	390.1	1.851	0.754	150.7	-20
-15	1.492	393.9	1.885	0.771	150.3	1.581	393.9	1.880	0.772	150.2	1.669	393.8	1.870	0.770	152.1	-15
-10	1.460	397.8	1.900	0.779	151.7	1.545	397.7	1.895	0.780	151.7	1.648	397.7	1.880	0.781	153.6	-10
-5	1.439	401.7	1.915	0.788	153.1	1.508	401.6	1.910	0.789	153.1	1.615	401.6	1.900	0.789	155.0	-5
0	1.412	405.5	1.929	0.796	154.5	1.492	405.5	1.925	0.797	155.5	1.580	405.5	1.921	0.797	155.4	0
5	1.385	409.6	1.944	0.805	157.9	1.463	409.6	1.939	0.805	157.9	1.555	409.6	1.934	0.805	157.8	5
10	1.361	413.7	1.958	0.813	159.3	1.442	413.7	1.953	0.814	159.2	1.527	413.6	1.949	0.814	159.2	10
15	1.337	417.8	1.972	0.822	160.7	1.416	417.7	1.968	0.822	160.6	1.499	417.7	1.963	0.822	160.5	15
20	1.313	421.9	1.987	0.830	162.0	1.391	421.9	1.982	0.830	161.9	1.473	421.8	1.977	0.831	161.9	20
25	1.291	426.1	2.001	0.838	163.3	1.367	426.0	1.995	0.839	163.3	1.448	426.0	1.991	0.839	163.2	25
30	1.269	430.3	2.015	0.847	164.6	1.344	430.3	2.010	0.847	164.5	1.423	430.3	2.006	0.848	164.6	30
35	1.248	434.5	2.029	0.855	165.9	1.322	434.5	2.024	0.855	165.9	1.401	434.4	2.020	0.855	165.9	35
40	1.227	438.8	2.043	0.864	167.2	1.300	438.8	2.036	0.864	167.2	1.377	438.8	2.035	0.864	167.1	40
45	1.203	443.2	2.058	0.872	168.5	1.279	443.2	2.052	0.872	168.5	1.355	443.1	2.041	0.872	168.4	45
50	1.189	447.5	2.072	0.880	169.8	1.258	447.5	2.067	0.880	169.8	1.333	447.5	2.047	0.880	169.8	50
55	1.173	452.0	2.084	0.889	171.0	1.241	452.0	2.079	0.889	171.0	1.313	452.0	2.051	0.889	171.0	55
60	1.153	456.4	2.097	0.897	172.3	1.221	456.4	2.092	0.897	172.3	1.293	456.4	2.055	0.897	172.3	60
65	1.135	460.9	2.111	0.905	173.6	1.200	460.9	2.106	0.905	173.5	1.273	460.9	2.059	0.905	173.4	65
70	1.119	465.5	2.124	0.913	174.7	1.185	465.5	2.119	0.913	174.7	1.254	465.4	2.114	0.913	174.7	70
75	1.102	470.1	2.137	0.921	176.0	1.169	470.1	2.132	0.921	175.9	1.235	470.0	2.128	0.921	175.9	75
	ps=0.370 bar (ts=46°C)					ps=0.391 bar (ts=45°C)					ps=0.413 bar (ts=44°C)					
-45	2.031	371.2	1.778	0.727	142.8	2.150	371.1	1.773	0.729	142.7	2.221	371.0	1.784	0.737	144.2	-45
-40	1.983	374.9	1.794	0.735	144.4	2.099	374.8	1.789	0.736	144.3	2.170	374.7	1.800	0.744	145.8	-40
-35	1.939	378.6	1.810	0.742	146.0	2.051	378.5	1.805	0.743	145.9	2.120	378.4	1.816	0.752	147.4	-35
-30	1.896	382.3	1.825	0.750	147.6	2.005	382.2	1.820	0.751	147.5	2.122	382.1	1.816	0.752	147.4	-30
-25	1.855	386.1	1.840	0.757	149.1	1.962	386.0	1.836	0.758	149.0	2.076	385.9	1.831	0.759	148.9	-25
-20	1.817	389.9	1.856	0.765	150.6	1.922	389.8	1.851	0.766	150.5	2.032	389.7	1.846	0.767	150.4	-20
-15	1.779	393.7	1.871	0.773	152.1	1.882	393.7	1.866	0.774	152.0	1.991	393.6	1.861	0.775	151.9	-15
-10	1.744	397.6	1.886	0.781	153.5	1.845	397.6	1.881	0.782	153.4	1.951	397.5	1.876	0.783	153.3	-10
-5	1.710	401.5	1.900	0.790	154.9	1.809	401.5	1.896	0.790	154.9	1.910	401.4	1.891	0.791	154.8	-5
0	1.677	405.5	1.915	0.798	156.4	1.774	405.5	1.910	0.799	156.3	1.876	405.4	1.906	0.799	156.2	0
5	1.646	409.5	1.930	0.806	157.7	1.741	409.5	1.925	0.807	157.7	1.841	409.4	1.920	0.807	157.6	5
10	1.616	413.6	1.944	0.815	159.1	1.709	413.5	1.939	0.815	159.1	1.807	413.5	1.935	0.815	159.0	10
15	1.587	417.7	1.958	0.823	160.5	1.679	417.6	1.954	0.823	160.4	1.774	417.6	1.949	0.824	160.4	15
20	1.559															

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

Pressure		Temperature		Density		Enthalpy		Entropy		Specific Heat		Sound Speed		Saturation temperature in brackets																																																																																																																																																																																																																																																																																																																																																																																																																													
t	p	h	s	ρ	h	s	cp	c	ρ	h	s	cp	c	t																																																																																																																																																																																																																																																																																																																																																																																																																													
<table border="1"> <thead> <tr> <th colspan="4">ps=0.436 bar (ts=43°C)</th> <th colspan="4">ps=0.460 bar (ts=42°C)</th> <th colspan="4">ps=0.485 bar (ts=41°C)</th> </tr> </thead> <tbody> <tr><td>-40</td><td>2.348</td><td>374.5</td><td>1.780</td><td>0.739</td><td>144.1</td><td>2.481</td><td>374.5</td><td>1.775</td><td>0.740</td><td>143.9</td><td>2.621</td><td>374.4</td><td>1.770</td><td>0.742</td><td>143.8</td></tr> <tr><td>-35</td><td>2.234</td><td>379.3</td><td>1.795</td><td>0.746</td><td>145.7</td><td>2.424</td><td>379.2</td><td>1.791</td><td>0.747</td><td>145.5</td><td>2.560</td><td>378.1</td><td>1.786</td><td>0.749</td><td>145.4</td></tr> <tr><td>-30</td><td>2.143</td><td>382.7</td><td>1.811</td><td>0.753</td><td>147.2</td><td>2.370</td><td>380.0</td><td>1.806</td><td>0.754</td><td>147.1</td><td>2.502</td><td>381.9</td><td>1.802</td><td>0.755</td><td>147.0</td></tr> <tr><td>-25</td><td>2.094</td><td>385.9</td><td>1.826</td><td>0.759</td><td>148.8</td><td>2.315</td><td>385.5</td><td>1.822</td><td>0.762</td><td>148.7</td><td>2.449</td><td>385.7</td><td>1.817</td><td>0.763</td><td>148.5</td></tr> <tr><td>-20</td><td>2.148</td><td>389.7</td><td>1.842</td><td>0.768</td><td>150.3</td><td>2.259</td><td>385.6</td><td>1.837</td><td>0.769</td><td>150.2</td><td>2.396</td><td>389.5</td><td>1.832</td><td>0.770</td><td>150.1</td></tr> <tr><td>-15</td><td>2.154</td><td>393.3</td><td>1.857</td><td>0.776</td><td>151.8</td><td>2.222</td><td>393.5</td><td>1.852</td><td>0.777</td><td>151.7</td><td>2.346</td><td>393.4</td><td>1.848</td><td>0.773</td><td>151.6</td></tr> <tr><td>-10</td><td>2.251</td><td>397.5</td><td>1.872</td><td>0.784</td><td>153.3</td><td>2.177</td><td>397.4</td><td>1.867</td><td>0.785</td><td>153.2</td><td>2.299</td><td>397.3</td><td>1.863</td><td>0.776</td><td>153.1</td></tr> <tr><td>-5</td><td>2.327</td><td>401.2</td><td>1.896</td><td>0.792</td><td>154.7</td><td>2.132</td><td>401.3</td><td>1.882</td><td>0.792</td><td>154.6</td><td>2.255</td><td>401.2</td><td>1.877</td><td>0.779</td><td>154.5</td></tr> <tr><td>0</td><td>2.392</td><td>405.3</td><td>1.921</td><td>0.800</td><td>156.1</td><td>2.088</td><td>405.3</td><td>1.897</td><td>0.801</td><td>156.0</td><td>2.209</td><td>405.2</td><td>1.892</td><td>0.782</td><td>156.0</td></tr> <tr><td>5</td><td>2.455</td><td>409.4</td><td>1.916</td><td>0.807</td><td>157.5</td><td>2.054</td><td>409.3</td><td>1.911</td><td>0.809</td><td>157.5</td><td>2.168</td><td>409.3</td><td>1.907</td><td>0.784</td><td>157.4</td></tr> <tr><td>10</td><td>1.929</td><td>413.4</td><td>1.930</td><td>0.816</td><td>158.9</td><td>2.016</td><td>413.4</td><td>1.925</td><td>0.817</td><td>158.9</td><td>2.127</td><td>413.3</td><td>1.921</td><td>0.787</td><td>158.5</td></tr> <tr><td>15</td><td>1.875</td><td>417.5</td><td>1.945</td><td>0.824</td><td>160.3</td><td>1.979</td><td>417.5</td><td>1.940</td><td>0.825</td><td>160.2</td><td>2.083</td><td>417.4</td><td>1.936</td><td>0.825</td><td>160.2</td></tr> <tr><td>20</td><td>1.851</td><td>421.7</td><td>1.953</td><td>0.833</td><td>161.7</td><td>1.944</td><td>421.6</td><td>1.954</td><td>0.833</td><td>161.6</td><td>2.052</td><td>421.6</td><td>1.950</td><td>0.834</td><td>161.5</td></tr> <tr><td>25</td><td>1.813</td><td>425.9</td><td>1.973</td><td>0.841</td><td>163.0</td><td>1.910</td><td>425.8</td><td>1.968</td><td>0.841</td><td>162.9</td><td>2.015</td><td>425.8</td><td>1.964</td><td>0.840</td><td>162.9</td></tr> <tr><td>30</td><td>1.773</td><td>430.1</td><td>1.987</td><td>0.849</td><td>164.0</td><td>1.878</td><td>430.0</td><td>1.983</td><td>0.849</td><td>164.0</td><td>1.982</td><td>430.0</td><td>1.978</td><td>0.850</td><td>164.0</td></tr> <tr><td>35</td><td>1.749</td><td>434.3</td><td>2.001</td><td>0.857</td><td>165.7</td><td>1.847</td><td>434.3</td><td>1.997</td><td>0.858</td><td>165.6</td><td>1.949</td><td>434.3</td><td>1.992</td><td>0.853</td><td>165.5</td></tr> <tr><td>40</td><td>1.723</td><td>438.5</td><td>2.015</td><td>0.865</td><td>167.0</td><td>1.816</td><td>438.5</td><td>2.010</td><td>0.866</td><td>166.9</td><td>1.917</td><td>438.6</td><td>2.006</td><td>0.866</td><td>166.9</td></tr> <tr><td>45</td><td>1.693</td><td>442.0</td><td>2.029</td><td>0.874</td><td>168.3</td><td>1.787</td><td>442.0</td><td>2.024</td><td>0.874</td><td>168.2</td><td>1.886</td><td>442.9</td><td>2.020</td><td>0.874</td><td>168.1</td></tr> <tr><td>50</td><td>1.656</td><td>447.4</td><td>2.042</td><td>0.882</td><td>169.5</td><td>1.759</td><td>447.3</td><td>2.038</td><td>0.882</td><td>169.5</td><td>1.855</td><td>447.3</td><td>2.033</td><td>0.882</td><td>169.4</td></tr> <tr><td>55</td><td>1.640</td><td>451.8</td><td>2.056</td><td>0.890</td><td>170.8</td><td>1.731</td><td>451.8</td><td>2.051</td><td>0.890</td><td>170.8</td><td>1.827</td><td>451.7</td><td>2.047</td><td>0.890</td><td>170.7</td></tr> <tr><td>60</td><td>1.615</td><td>456.3</td><td>2.069</td><td>0.898</td><td>172.1</td><td>1.704</td><td>456.3</td><td>2.065</td><td>0.898</td><td>172.0</td><td>1.798</td><td>456.2</td><td>2.061</td><td>0.899</td><td>172.0</td></tr> <tr><td>65</td><td>1.590</td><td>460.8</td><td>2.083</td><td>0.906</td><td>173.3</td><td>1.679</td><td>460.8</td><td>2.078</td><td>0.906</td><td>173.3</td><td>1.771</td><td>460.7</td><td>2.074</td><td>0.907</td><td>173.2</td></tr> <tr><td>70</td><td>1.567</td><td>465.3</td><td>2.096</td><td>0.914</td><td>174.5</td><td>1.654</td><td>465.3</td><td>2.092</td><td>0.914</td><td>174.5</td><td>1.745</td><td>465.3</td><td>2.087</td><td>0.915</td><td>174.5</td></tr> <tr><td>75</td><td>1.544</td><td>469.9</td><td>2.110</td><td>0.922</td><td>175.8</td><td>1.630</td><td>469.9</td><td>2.105</td><td>0.922</td><td>175.7</td><td>1.719</td><td>469.9</td><td>2.101</td><td>0.923</td><td>175.7</td></tr> <tr><td>80</td><td>1.521</td><td>474.5</td><td>2.123</td><td>0.930</td><td>177.0</td><td>1.605</td><td>474.5</td><td>2.118</td><td>0.930</td><td>176.9</td><td>1.694</td><td>474.5</td><td>2.114</td><td>0.931</td><td>176.9</td></tr> </tbody> </table>																ps=0.436 bar (ts=43°C)				ps=0.460 bar (ts=42°C)				ps=0.485 bar (ts=41°C)				-40	2.348	374.5	1.780	0.739	144.1	2.481	374.5	1.775	0.740	143.9	2.621	374.4	1.770	0.742	143.8	-35	2.234	379.3	1.795	0.746	145.7	2.424	379.2	1.791	0.747	145.5	2.560	378.1	1.786	0.749	145.4	-30	2.143	382.7	1.811	0.753	147.2	2.370	380.0	1.806	0.754	147.1	2.502	381.9	1.802	0.755	147.0	-25	2.094	385.9	1.826	0.759	148.8	2.315	385.5	1.822	0.762	148.7	2.449	385.7	1.817	0.763	148.5	-20	2.148	389.7	1.842	0.768	150.3	2.259	385.6	1.837	0.769	150.2	2.396	389.5	1.832	0.770	150.1	-15	2.154	393.3	1.857	0.776	151.8	2.222	393.5	1.852	0.777	151.7	2.346	393.4	1.848	0.773	151.6	-10	2.251	397.5	1.872	0.784	153.3	2.177	397.4	1.867	0.785	153.2	2.299	397.3	1.863	0.776	153.1	-5	2.327	401.2	1.896	0.792	154.7	2.132	401.3	1.882	0.792	154.6	2.255	401.2	1.877	0.779	154.5	0	2.392	405.3	1.921	0.800	156.1	2.088	405.3	1.897	0.801	156.0	2.209	405.2	1.892	0.782	156.0	5	2.455	409.4	1.916	0.807	157.5	2.054	409.3	1.911	0.809	157.5	2.168	409.3	1.907	0.784	157.4	10	1.929	413.4	1.930	0.816	158.9	2.016	413.4	1.925	0.817	158.9	2.127	413.3	1.921	0.787	158.5	15	1.875	417.5	1.945	0.824	160.3	1.979	417.5	1.940	0.825	160.2	2.083	417.4	1.936	0.825	160.2	20	1.851	421.7	1.953	0.833	161.7	1.944	421.6	1.954	0.833	161.6	2.052	421.6	1.950	0.834	161.5	25	1.813	425.9	1.973	0.841	163.0	1.910	425.8	1.968	0.841	162.9	2.015	425.8	1.964	0.840	162.9	30	1.773	430.1	1.987	0.849	164.0	1.878	430.0	1.983	0.849	164.0	1.982	430.0	1.978	0.850	164.0	35	1.749	434.3	2.001	0.857	165.7	1.847	434.3	1.997	0.858	165.6	1.949	434.3	1.992	0.853	165.5	40	1.723	438.5	2.015	0.865	167.0	1.816	438.5	2.010	0.866	166.9	1.917	438.6	2.006	0.866	166.9	45	1.693	442.0	2.029	0.874	168.3	1.787	442.0	2.024	0.874	168.2	1.886	442.9	2.020	0.874	168.1	50	1.656	447.4	2.042	0.882	169.5	1.759	447.3	2.038	0.882	169.5	1.855	447.3	2.033	0.882	169.4	55	1.640	451.8	2.056	0.890	170.8	1.731	451.8	2.051	0.890	170.8	1.827	451.7	2.047	0.890	170.7	60	1.615	456.3	2.069	0.898	172.1	1.704	456.3	2.065	0.898	172.0	1.798	456.2	2.061	0.899	172.0	65	1.590	460.8	2.083	0.906	173.3	1.679	460.8	2.078	0.906	173.3	1.771	460.7	2.074	0.907	173.2	70	1.567	465.3	2.096	0.914	174.5	1.654	465.3	2.092	0.914	174.5	1.745	465.3	2.087	0.915	174.5	75	1.544	469.9	2.110	0.922	175.8	1.630	469.9	2.105	0.922	175.7	1.719	469.9	2.101	0.923	175.7	80	1.521	474.5	2.123	0.930	177.0	1.605	474.5	2.118	0.930	176.9	1.694	474.5	2.114	0.931	176.9
ps=0.436 bar (ts=43°C)				ps=0.460 bar (ts=42°C)				ps=0.485 bar (ts=41°C)																																																																																																																																																																																																																																																																																																																																																																																																																																			
-40	2.348	374.5	1.780	0.739	144.1	2.481	374.5	1.775	0.740	143.9	2.621	374.4	1.770	0.742	143.8																																																																																																																																																																																																																																																																																																																																																																																																																												
-35	2.234	379.3	1.795	0.746	145.7	2.424	379.2	1.791	0.747	145.5	2.560	378.1	1.786	0.749	145.4																																																																																																																																																																																																																																																																																																																																																																																																																												
-30	2.143	382.7	1.811	0.753	147.2	2.370	380.0	1.806	0.754	147.1	2.502	381.9	1.802	0.755	147.0																																																																																																																																																																																																																																																																																																																																																																																																																												
-25	2.094	385.9	1.826	0.759	148.8	2.315	385.5	1.822	0.762	148.7	2.449	385.7	1.817	0.763	148.5																																																																																																																																																																																																																																																																																																																																																																																																																												
-20	2.148	389.7	1.842	0.768	150.3	2.259	385.6	1.837	0.769	150.2	2.396	389.5	1.832	0.770	150.1																																																																																																																																																																																																																																																																																																																																																																																																																												
-15	2.154	393.3	1.857	0.776	151.8	2.222	393.5	1.852	0.777	151.7	2.346	393.4	1.848	0.773	151.6																																																																																																																																																																																																																																																																																																																																																																																																																												
-10	2.251	397.5	1.872	0.784	153.3	2.177	397.4	1.867	0.785	153.2	2.299	397.3	1.863	0.776	153.1																																																																																																																																																																																																																																																																																																																																																																																																																												
-5	2.327	401.2	1.896	0.792	154.7	2.132	401.3	1.882	0.792	154.6	2.255	401.2	1.877	0.779	154.5																																																																																																																																																																																																																																																																																																																																																																																																																												
0	2.392	405.3	1.921	0.800	156.1	2.088	405.3	1.897	0.801	156.0	2.209	405.2	1.892	0.782	156.0																																																																																																																																																																																																																																																																																																																																																																																																																												
5	2.455	409.4	1.916	0.807	157.5	2.054	409.3	1.911	0.809	157.5	2.168	409.3	1.907	0.784	157.4																																																																																																																																																																																																																																																																																																																																																																																																																												
10	1.929	413.4	1.930	0.816	158.9	2.016	413.4	1.925	0.817	158.9	2.127	413.3	1.921	0.787	158.5																																																																																																																																																																																																																																																																																																																																																																																																																												
15	1.875	417.5	1.945	0.824	160.3	1.979	417.5	1.940	0.825	160.2	2.083	417.4	1.936	0.825	160.2																																																																																																																																																																																																																																																																																																																																																																																																																												
20	1.851	421.7	1.953	0.833	161.7	1.944	421.6	1.954	0.833	161.6	2.052	421.6	1.950	0.834	161.5																																																																																																																																																																																																																																																																																																																																																																																																																												
25	1.813	425.9	1.973	0.841	163.0	1.910	425.8	1.968	0.841	162.9	2.015	425.8	1.964	0.840	162.9																																																																																																																																																																																																																																																																																																																																																																																																																												
30	1.773	430.1	1.987	0.849	164.0	1.878	430.0	1.983	0.849	164.0	1.982	430.0	1.978	0.850	164.0																																																																																																																																																																																																																																																																																																																																																																																																																												
35	1.749	434.3	2.001	0.857	165.7	1.847	434.3	1.997	0.858	165.6	1.949	434.3	1.992	0.853	165.5																																																																																																																																																																																																																																																																																																																																																																																																																												
40	1.723	438.5	2.015	0.865	167.0	1.816	438.5	2.010	0.866	166.9	1.917	438.6	2.006	0.866	166.9																																																																																																																																																																																																																																																																																																																																																																																																																												
45	1.693	442.0	2.029	0.874	168.3	1.787	442.0	2.024	0.874	168.2	1.886	442.9	2.020	0.874	168.1																																																																																																																																																																																																																																																																																																																																																																																																																												
50	1.656	447.4	2.042	0.882	169.5	1.759	447.3	2.038	0.882	169.5	1.855	447.3	2.033	0.882	169.4																																																																																																																																																																																																																																																																																																																																																																																																																												
55	1.640	451.8	2.056	0.890	170.8	1.731	451.8	2.051	0.890	170.8	1.827	451.7	2.047	0.890	170.7																																																																																																																																																																																																																																																																																																																																																																																																																												
60	1.615	456.3	2.069	0.898	172.1	1.704	456.3	2.065	0.898	172.0	1.798	456.2	2.061	0.899	172.0																																																																																																																																																																																																																																																																																																																																																																																																																												
65	1.590	460.8	2.083	0.906	173.3	1.679	460.8	2.078	0.906	173.3	1.771	460.7	2.074	0.907	173.2																																																																																																																																																																																																																																																																																																																																																																																																																												
70	1.567	465.3	2.096	0.914	174.5	1.654	465.3	2.092	0.914	174.5	1.745	465.3	2.087	0.915	174.5																																																																																																																																																																																																																																																																																																																																																																																																																												
75	1.544	469.9	2.110	0.922	175.8	1.630	469.9	2.105	0.922	175.7	1.719	469.9	2.101	0.923	175.7																																																																																																																																																																																																																																																																																																																																																																																																																												
80	1.521	474.5	2.123	0.930	177.0	1.605	474.5	2.118	0.930	176.9	1.694	474.5	2.114	0.931	176.9																																																																																																																																																																																																																																																																																																																																																																																																																												
<table border="1"> <thead> <tr> <th colspan="4">ps=0.511 bar (ts=40°C)</th> <th colspan="4">ps=0.539 bar (ts=39°C)</th> <th colspan="4">ps=0.567 bar (ts=38°C)</th> </tr> </thead> <tbody> <tr><td>-40</td><td>2.757</td><td>374.3</td><td>1.766</td><td>0.744</td><td>143.5</td><td>2.651</td><td>374.3</td><td>1.767</td><td>0.752</td><td>143.7</td><td>3.007</td><td>374.3</td><td>1.770</td><td>0.752</td><td>143.7</td></tr> <tr><td>-35</td><td>2.702</td><td>379.5</td><td>1.781</td><td>0.750</td><td>145.3</td><td>2.605</td><td>379.5</td><td>1.782</td><td>0.759</td><td>145.7</td><td>2.938</td><td>381.5</td><td>1.785</td><td>0.753</td><td>145.6</td></tr> <tr><td>-30</td><td>2.641</td><td>384.8</td><td>1.797</td><td>0.757</td><td>146.9</td><td>2.560</td><td>384.7</td><td>1.797</td><td>0.765</td><td>146.9</td><td>2.873</td><td>385.4</td><td>1.800</td><td>0.757</td><td>146.2</td></tr> <tr><td>-25</td><td>2.583</td><td>389.5</td><td>1.813</td><td>0.764</td><td>148.4</td><td>2.515</td><td>389.5</td><td>1.812</td><td>0.771</td><td>148.5</td><td>2.811</td><td>389.3</td><td>1.815</td><td>0.759</td><td>148.7</td></tr> <tr><td>-20</td><td>2.528</td><td>393.4</td><td>1.828</td><td>0.771</td><td>150.0</td><td>2.469</td><td>393.3</td><td>1.827</td><td>0.777</td><td>149.9</td><td>2.811</td><td>393.3</td><td>1.819</td><td>0.764</td><td>149.7</td></tr> <tr><td>-15</td><td>2.478</td><td>397.3</td><td>1.843</td><td>0.779</td><td>151.5</td><td>2.424</td><td>397.2</td><td>1.842</td><td>0.783</td><td>151.4</td><td>2.750</td><td>397.2</td><td>1.834</td><td>0.769</td><td>151.1</td></tr> <tr><td>-10</td><td>2.425</td><td>401.2</td><td>1.858</td><td>0.786</td><td>153.0</td><td>2.379</td><td>401.1</td><td>1.857</td><td>0.789</td><td>153.9</td><td>2.690</td><td>401.1</td><td>1.849</td><td>0.774</td><td>152.9</td></tr> <tr><td>-5</td><td>2.377</td><td>405.1</td><td>1.873</td><td>0.794</td><td>154.4</td><td>2.334</td><td>405.0</td><td>1.872</td><td>0.795</td><td>154.0</td><td>2.640</td><td>405.0</td><td>1.864</td><td>0.779</td><td>154.0</td></tr> <tr><td>0</td><td>2.331</td><td>409.0</td><td>1.889</td><td>0.802</td><td>155.9</td><td>2.289</td><td>408.9</td><td>1.887</td><td>0.801</td><td>155.8</td><td>2.590</td><td>408.9</td><td>1.879</td><td>0.784</td><td>155.0</td></tr> <tr><td>5</td><td>2.287</td><td>409.0</td><td>1.922</td><td>0.810</td><td>157.3</td><td>2.244</td><td>409.0</td><td>1.922</td><td>0.811</td><td>157.2</td><td>2.547</td><td>409.0</td><td>1.893</td><td>0.810</td><td>157.0</td></tr> <tr><td>10</td><td>2.245</td><td>413.3</td><td>1.917</td><td>0.818</td><td>158.7</td><td>2.200</td><td>413.2</td><td>1.912</td><td>0.819</td><td>158.6</td><td>2.494</td><td>413.1</td><td>1.908</td><td>0.819</td><td>158.5</td></tr> <tr><td>15</td><td>2.204</td><td>417.4</td><td>1.931</td><td>0.826</td><td>160.1</td><td>2.155</td><td>417.3</td><td>1.927</td><td>0.827</td><td>160.0</td><td>2.448</td><td>417.3</td><td>1.922</td><td>0.827</td><td>159.9</td></tr> <tr><td>20</td><td>2.164</td><td>421.5</td><td>1.945</td><td>0.834</td><td>161.5</td><td>2.110</td><td>421.5</td><td>1.941</td><td>0.835</td><td>161.4</td><td>2.404</td><td>421.4</td><td>1.937</td><td>0.835</td><td>161.3</td></tr> <tr><td>25</td><td>2.127</td><td>425.7</td><td>1.960</td><td>0.842</td><td>162.8</td><td>2.065</td><td>425.7</td><td>1.955</td><td>0.843</td><td>162.7</td><td>2.362</td><td>425.6</td><td>1.951</td><td>0.843</td><td>162.7</td></tr> <tr><td>30</td><td>2.090</td><td>429.9</td><td>1.974</td><td>0.850</td><td>164.2</td><td>2.020</td><td>429.9</td><td>1.969</td><td>0.851</td><td>164.1</td><td>2.322</td><td>429.8</td><td>1.965</td><td>0.851</td><td>164.0</td></tr> <tr><td>35</td><td>2.055</td><td>434.2</td><td>1.988</td><td>0.858</td><td>165.5</td><td>1.975</td><td>434.2</td><td>1.983</td><td>0.859</td><td>165.4</td><td>2.283</td><td>434.1</td><td>1.979</td><td>0.859</td><td>165.4</td></tr> <tr><td>40</td><td>2.021</td><td>438.5</td><td>2.002</td><td>0.867</td><td>166.8</td><td>1.930</td><td>438.5</td><td>1.997</td><td>0.867</td><td>166.7</td><td>2.245</td><td>438.4</td><td>1.993</td><td>0.867</td><td>166.7</td></tr> <tr><td>45</td><td>1.989</td><td>442.8</td><td>2.015</td><td>0.875</td><td>168.1</td><td>1.885</td><td>442.8</td><td>2.011</td><td>0.875</td><td>168.0</td><td>2.209</td><td>442.8</td><td>2.007</td><td>0.875</td><td>168.0</td></tr> <tr><td>50</td><td>1.957</td><td>447.0</td><td>2.029</td><td>0.883</td><td>169.4</td><td>1.840</td><td>447.0</td><td>2.025</td><td>0.883</td><td>169.3</td><td>2.173</td><td>447.0</td><td>2.020</td><td>0.883</td><td>169.3</td></tr> <tr><td>55</td><td>1.925</td><td>451.2</td><td>2.043</td><td>0.891</td><td>170.7</td><td>1.795</td><td>451.2</td><td>2.038</td><td>0.891</td><td>170.5</td><td>2.139</td><td>451.2</td><td>2.034</td><td>0.891</td><td>170.5</td></tr> <tr><td>60</td><td>1.893</td><td>455.4</td><td>2.056</td><td>0.899</td><td>172.0</td><td>1.750</td><td>455.4</td><td>2.052</td><td>0.899</td><td>171.9</td><td>2.105</td><td>455.4</td><td>2.049</td><td>0.899</td><td>171.9</td></tr> <tr><td>65</td><td>1.861</td><td>459.6</td><td>2.070</td><td>0.907</td><td>173.2</td><td>1.705</td><td>459.6</td><td>2.065</td><td>0.907</td><td>173.1</td><td>2.074</td><td>459.6</td><td>2.061</td><td>0.907</td><td>173.1</td></tr> <tr><td>70</td><td>1.840</td><td>463.8</td><td>2.083</td><td>0.915</td><td>174.4</td><td>1.660</td><td>463.8</td><td>2.079</td><td>0.915</td><td>174.4</td><td>2.043</td><td>463.8</td><td>2.074</td><td>0.916</td><td>174.4</td></tr> <tr><td>75</td><td>1.813</td><td>469.9</td><td>2.096</td><td>0.923</td><td>175.5</td><td>1.615</td><td>469.9</td><td>2.092</td><td>0.923</td><td>175.5</td><td>2.013</td><td>469.9</td><td>2.088</td><td>0.923</td><td>175.5</td></tr> <tr><td>80</td><td>1.787</td><td>474.5</td><td>2.110</td><td>0.931</td><td>176.9</td><td>1.570</td><td>474.4</td><td>2.105</td><td>0.931</td><td>176.8</td><td>1.984</td><td>474.4</td><td>2.101</td><td>0.931</td><td>176.8</td></tr> </tbody> </table>																ps=0.511 bar (ts=40°C)				ps=0.539 bar (ts=39°C)				ps=0.567 bar (ts=38°C)				-40	2.757	374.3	1.766	0.744	143.5	2.651	374.3	1.767	0.752	143.7	3.007	374.3	1.770	0.752	143.7	-35	2.702	379.5	1.781	0.750	145.3	2.605	379.5	1.782	0.759	145.7	2.938	381.5	1.785	0.753	145.6	-30	2.641	384.8	1.797	0.757	146.9	2.560	384.7	1.797	0.765	146.9	2.873	385.4	1.800	0.757	146.2	-25	2.583	389.5	1.813	0.764	148.4	2.515	389.5	1.812	0.771	148.5	2.811	389.3	1.815	0.759	148.7	-20	2.528	393.4	1.828	0.771	150.0	2.469	393.3	1.827	0.777	149.9	2.811	393.3	1.819	0.764	149.7	-15	2.478	397.3	1.843	0.779	151.5	2.424	397.2	1.842	0.783	151.4	2.750	397.2	1.834	0.769	151.1	-10	2.425	401.2	1.858	0.786	153.0	2.379	401.1	1.857	0.789	153.9	2.690	401.1	1.849	0.774	152.9	-5	2.377	405.1	1.873	0.794	154.4	2.334	405.0	1.872	0.795	154.0	2.640	405.0	1.864	0.779	154.0	0	2.331	409.0	1.889	0.802	155.9	2.289	408.9	1.887	0.801	155.8	2.590	408.9	1.879	0.784	155.0	5	2.287	409.0	1.922	0.810	157.3	2.244	409.0	1.922	0.811	157.2	2.547	409.0	1.893	0.810	157.0	10	2.245	413.3	1.917	0.818	158.7	2.200	413.2	1.912	0.819	158.6	2.494	413.1	1.908	0.819	158.5	15	2.204	417.4	1.931	0.826	160.1	2.155	417.3	1.927	0.827	160.0	2.448	417.3	1.922	0.827	159.9	20	2.164	421.5	1.945	0.834	161.5	2.110	421.5	1.941	0.835	161.4	2.404	421.4	1.937	0.835	161.3	25	2.127	425.7	1.960	0.842	162.8	2.065	425.7	1.955	0.843	162.7	2.362	425.6	1.951	0.843	162.7	30	2.090	429.9	1.974	0.850	164.2	2.020	429.9	1.969	0.851	164.1	2.322	429.8	1.965	0.851	164.0	35	2.055	434.2	1.988	0.858	165.5	1.975	434.2	1.983	0.859	165.4	2.283	434.1	1.979	0.859	165.4	40	2.021	438.5	2.002	0.867	166.8	1.930	438.5	1.997	0.867	166.7	2.245	438.4	1.993	0.867	166.7	45	1.989	442.8	2.015	0.875	168.1	1.885	442.8	2.011	0.875	168.0	2.209	442.8	2.007	0.875	168.0	50	1.957	447.0	2.029	0.883	169.4	1.840	447.0	2.025	0.883	169.3	2.173	447.0	2.020	0.883	169.3	55	1.925	451.2	2.043	0.891	170.7	1.795	451.2	2.038	0.891	170.5	2.139	451.2	2.034	0.891	170.5	60	1.893	455.4	2.056	0.899	172.0	1.750	455.4	2.052	0.899	171.9	2.105	455.4	2.049	0.899	171.9	65	1.861	459.6	2.070	0.907	173.2	1.705	459.6	2.065	0.907	173.1	2.074	459.6	2.061	0.907	173.1	70	1.840	463.8	2.083	0.915	174.4	1.660	463.8	2.079	0.915	174.4	2.043	463.8	2.074	0.916	174.4	75	1.813	469.9	2.096	0.923	175.5	1.615	469.9	2.092	0.923	175.5	2.013	469.9	2.088	0.923	175.5	80	1.787	474.5	2.110	0.931	176.9	1.570	474.4	2.105	0.931	176.8	1.984	474.4	2.101	0.931	176.8
ps=0.511 bar (ts=40°C)				ps=0.539 bar (ts=39°C)				ps=0.567 bar (ts=38°C)																																																																																																																																																																																																																																																																																																																																																																																																																																			
-40	2.757	374.3	1.766	0.744	143.5	2.651	374.3	1.767	0.752	143.7	3.007	374.3	1.770	0.752	143.7																																																																																																																																																																																																																																																																																																																																																																																																																												
-35	2.702	379.5	1.781	0.750	145.3	2.605	379.5	1.782	0.759	145.7	2.938	381.5	1.785	0.753	145.6																																																																																																																																																																																																																																																																																																																																																																																																																												
-30	2.641	384.8	1.797	0.757	146.9	2.560	384.7	1.797	0.765	146.9	2.873	385.4	1.800	0.757	146.2																																																																																																																																																																																																																																																																																																																																																																																																																												
-25	2.583	389.5	1.813	0.764	148.4	2.515	389.5	1.812	0.771	148.5	2.811	389.3	1.815	0.759	148.7																																																																																																																																																																																																																																																																																																																																																																																																																												
-20	2.528	393.4	1.828	0.771	150.0	2.469	393.3	1.827	0.777	149.9	2.811	393.3	1.819	0.764	149.7																																																																																																																																																																																																																																																																																																																																																																																																																												
-15	2.478	397.3	1.843	0.779	151.5	2.424	397.2	1.842	0.783	151.4	2.750	397.2	1.834	0.769	151.1																																																																																																																																																																																																																																																																																																																																																																																																																												
-10	2.425	401.2	1.858	0.786	153.0	2.379	401.1	1.857	0.789	153.9	2.690	401.1	1.849	0.774	152.9																																																																																																																																																																																																																																																																																																																																																																																																																												
-5	2.377	405.1	1.873	0.794	154.4	2.334	405.0	1.872	0.795	154.0	2.640	405.0	1.864	0.779	154.0																																																																																																																																																																																																																																																																																																																																																																																																																												
0	2.331	409.0	1.889	0.802	155.9	2.289	408.9	1.887	0.801	155.8	2.590	408.9	1.879	0.784	155.0																																																																																																																																																																																																																																																																																																																																																																																																																												
5	2.287	409.0	1.922	0.810	157.3	2.244	409.0	1.922	0.811	157.2	2.547	409.0	1.893	0.810	157.0																																																																																																																																																																																																																																																																																																																																																																																																																												
10	2.245	413.3	1.917	0.818	158.7	2.200	413.2	1.912	0.819	158.6	2.494	413.1	1.908	0.819	158.5																																																																																																																																																																																																																																																																																																																																																																																																																												
15	2.204	417.4	1.931	0.826	160.1	2.155	417.3	1.927	0.827	160.0	2.448	417.3	1.922	0.827	159.9																																																																																																																																																																																																																																																																																																																																																																																																																												
20	2.164	421.5	1.945	0.834	161.5	2.110	421.5	1.941	0.835	161.4	2.404	421.4	1.937	0.835	161.3																																																																																																																																																																																																																																																																																																																																																																																																																												
25	2.127	425.7	1.960	0.842	162.8	2.065	425.7	1.955	0.843	162.7	2.362	425.6	1.951	0.843	162.7																																																																																																																																																																																																																																																																																																																																																																																																																												
30	2.090	429.9	1.974	0.850	164.2	2.020	429.9	1.969	0.851	164.1	2.322	429.8	1.965	0.851	164.0																																																																																																																																																																																																																																																																																																																																																																																																																												
35	2.055	434.2	1.988	0.858	165.5	1.975	434.2	1.983	0.859	165.4	2.283	434.1	1.979	0.859	165.4																																																																																																																																																																																																																																																																																																																																																																																																																												
40	2.021	438.5	2.002	0.867	166.8	1.930	438.5	1.997	0.867	166.7	2.245	438.4	1.993	0.867	166.7																																																																																																																																																																																																																																																																																																																																																																																																																												
45	1.989	442.8	2.015	0.875	168.1	1.885	442.8	2.011	0.875	168.0	2.209	442.8	2.007	0.875	168.0																																																																																																																																																																																																																																																																																																																																																																																																																												
50	1.957	447.0	2.029	0.883	169.4	1.840	447.0	2.025	0.883	169.3	2.173	447.0	2.020	0.883	169.3																																																																																																																																																																																																																																																																																																																																																																																																																												
55	1.925	451.2	2.043	0.891	170.7	1.795	451.2	2.038	0.891	170.5	2.139	451.2	2.034	0.891	170.5																																																																																																																																																																																																																																																																																																																																																																																																																												
60	1.893	455.4	2.056	0.899	172.0	1.750	455.4	2.052	0.899	171.9	2.105	455.4	2.049	0.899	171.9																																																																																																																																																																																																																																																																																																																																																																																																																												
65	1.861	459.6	2.070	0.907	173.2	1.705	459.6	2.065	0.907	173.1	2.074	459.6	2.061	0.907	173.1																																																																																																																																																																																																																																																																																																																																																																																																																												
70	1.840	463.8	2.083	0.915	174.4	1.660	463.8	2.079	0.915	174.4	2.043	463.8	2.074	0.916	174.4																																																																																																																																																																																																																																																																																																																																																																																																																												
75	1.813	469.9	2.096	0.923	175.5	1.615	469.9	2.092	0.923	175.5	2.013	469.9	2.088	0.923	175.5																																																																																																																																																																																																																																																																																																																																																																																																																												
80	1.787	474.5	2.110	0.931	176.9	1.570	474.4	2.105	0.931	176.8	1.984	474.4	2.101	0.931	176.8																																																																																																																																																																																																																																																																																																																																																																																																																												
<table border="1"> <thead> <tr> <th colspan="4">ps=0.597 bar (ts=37°C)</th> <th colspan="4">ps=0.628 bar (ts=36°C)</th> <th colspan="4">ps=0.661 bar (ts=35°C)</th> </tr> </thead> <tbody> <tr><td>-35</td><td>3.170</td><td>377.7</td><td>1.768</td><td>0.755</td><td>144.8</td><td>3.340</td><td>377.6</td><td>1.763</td><td>0.757</td><td>144.6</td><td>3.518</td><td>377.4</td><td>1.759</td><td>0.752</td><td>144.5</td></tr> <tr><td>-30</td><td>3.037</td><td>381.5</td><td>1.783</td><td>0.762</td><td>146.4</td><td>3.263</td><td>381.4</td><td>1.779</td><td>0.763</td><td>145.3</td><td>3.437</td><td>381.2</td><td>1.774</td><td>0.765</td><td>146.1</td></tr> <tr><td>-25</td><td>3.028</td><td>385.3</td><td>1.799</td><td>0.768</td><td>148.0</td><td>3.190</td><td>385.2</td><td>1.795</td><td>0.770</td><td>147.9</td><td>3.359</td><td>385.1</td><td>1.790</td><td>0.771</td><td>147.7</td></tr> <tr><td>-20</td><td>2.952</td><td>389.2</td><td>1.814</td><td>0.775</td><td>149.5</td><td>3.120</td><td>389.1</td><td>1.810</td><td>0.777</td><td>149.5</td><td>3.286</td><td>389.0</td><td>1.806</td><td>0.779</td><td>149.3</td></tr> <tr><td>-15</td><td>2.900</td><td>393.1</td><td>1.830</td><td>0.782</td><td>151.1</td><td>3.054</td><td>393.0</td><td>1.825</td><td>0.783</td><td>151.0</td><td>3.216</td><td>392.9</td><td>1.821</td><td>0.785</td><td>150.9</td></tr> <tr><td>-10</td><td>2.840</td><td>397.0</td><td>1.845</td><td>0.790</td><td>152.6</td><td>2.991</td><td>396.9</td><td>1.840</td><td>0.791</td><td>152.5</td><td>3.149</td><td>396.8</td><td>1.836</td><td>0.792</td><td>152.4</td></tr> <tr><td>-5</td><td>2.783</td><td>400.9</td><td>1.860</td><td>0.797</td><td>154.1</td><td>2.931</td><td>400.9</td><td>1.855</td><td>0.798</td><td>154.0</td><td>3.085</td><td>400.8</td><td>1.851</td><td>0.799</td><td>153.9</td></tr> <tr><td>0</td><td>2.729</td><td>405.0</td><td>1.874</td><td>0.805</td><td>155.5</td><td>2.874</td><td>404.9</td><td>1.870</td><td>0.806</td><td>155.5</td><td>3.025</td><td>404.8</td><td>1.866</td><td>0.807</td><td>155.4</td></tr> <tr><td>5</td><td>2.677</td><td>409.0</td><td>1.889</td><td>0.812</td><td>157.0</td><td>2.819</td><td>408.9</td><td>1.885</td><td>0.813</td><td>156.9</td><td>2.966</td><td>408.8</td><td>1.880</td><td>0.814</td><td>156.9</td></tr> <tr><td>10</td><td>2.627</td><td>413.1</td><td>1.904</td><td>0.820</td><td>158.4</td><td>2.766</td><td>413.0</td><td>1.899</td><td>0.821</td><td>158.4</td><td>2.911</td><td>412.9</td><td>1.895</td><td>0.822</td><td>158.3</td></tr> <tr><td>15</td><td>2.579</td><td>417.2</td><td>1.918</td><td>0.828</td><td>159.8</td><td>2.715</td><td>417.1</td><td>1.914</td><td>0.829</td><td>159.8</td><td>2.857</td><td>417.1</td><td>1.909</td><td>0.829</td><td>159.7</td></tr> <tr><td>20</td><td>2.533</td><td>421.4</td><td>1.932</td><td>0.836</td><td>161.2</td><td>2.665</td><td>421.3</td><td>1.928</td><td>0.837</td><td>161.1</td><td>2.805</td><td>421.2</td><td>1.924</td><td>0.837</td><td>161.1</td></tr> <tr><td>25</td><td>2.488</td><td>425.6</td><td>1.947</td><td>0.844</td><td>162.6</td><td>2.619</td><td>425.5</td><td>1.942</td><td>0.844</td><td>162.5</td><td>2.756</td><td>425.4</td><td>1.938</td><td>0.845</td><td>162.4</td></tr> <tr><td>30</td><td>2.445</td><td>429.8</td><td>1.961</td><td>0.852</td><td>163.9</td><td>2.574</td><td>429.7</td><td>1.956</td><td>0.852</td><td>163.9</td><td>2.708</td><td>429.7</td><td>1.952</td><td>0.853</td><td>163.8</td></tr> <tr><td>35</td><td>2.404</td><td>434.1</td><td>1.975</td><td>0.860</td><td>165.3</td><td>2.530</td><td>434.0</td><td>1.970</td><td>0.860</td><td>165.2</td><td>2.662</td><td>434.0</td><td>1.966</td><td>0.861</td><td>165.1</td></tr> <tr><td>40</td><td>2.364</td><td>438.4</td><td>1.989</td><td>0.868</td><td>166.6</td><td>2.488</td><td>438.3</td><td>1.984</td><td>0.868</td><td>166.5</td><td>2.618</td><td>438.3</td><td>1.980</td><td>0.869</td><td>166.5</td></tr> <tr><td>45</td><td>2.325</td><td>442.8</td><td>2.002</td><td>0.876</td><td>167.9</td><td>2.448</td><td>442.7</td><td>1.998</td><td>0.876</td><td>167.8</td><td>2.575</td><td>442.7</td><td>1.994</td><td>0.877</td><td>167.8</td></tr> <tr><td>50</td><td>2.298</td><td>447.1</td><td>2.016</td><td>0.884</td><td>169.2</td><td>2.409</td><td>447.1</td><td>2.012</td><td>0.884</td><td>169.1</td><td>2.534</td><td>447.1</td><td>2.008</td><td>0.885</td><td>169.1</td></tr> <tr><td>55</td><td>2.252</td><td>451.5</td><td>2.030</td><td>0.892</td><td>170.5</td><td>2.371</td><td>451.5</td><td>2.026</td><td>0.892</td><td>170.4</td><td>2.494</td><td>451.5</td><td>2.021</td><td>0.893</td><td>170.4</td></tr> <tr><td>60</td><td>2.218</td><td>456.1</td><td>2.043</td><td>0.900</td><td>171.8</td><td>2.334</td><td>456.0</td><td>2.039</td><td>0.900</td><td>171.7</td><td>2.455</td><td>456.0</td><td>2.035</td><td>0.901</td><td>171.6</td></tr> <tr><td>65</td><td>2.184</td><td>460.6</td><td>2.057</td><td>0.908</td><td>173.0</td><td>2.298</td><td>460.5</td><td>2.053</td><td>0.908</td><td>173.0</td><td>2.418</td><td>460.5</td><td>2.048</td><td>0.909</td><td>172.9</td></tr> <tr><td>70</td><td>2.151</td><td>465.1</td><td>2.070</td><td>0.916</td><td>174.3</td><td>2.254</td><td>465.1</td><td>2.066</td><td>0.916</td><td>174.2</td><td>2.382</td><td>465.1</td><td>2.062</td><td>0.916</td><td>174.2</td></tr> <tr><td>75</td><td>2.120</td><td>469.7</td><td>2.083</td><td>0.924</td><td>175.5</td><td>2.230</td><td>469.7</td><td>2.079</td></tr></tbody></table>																ps=0.597 bar (ts=37°C)				ps=0.628 bar (ts=36°C)				ps=0.661 bar (ts=35°C)				-35	3.170	377.7	1.768	0.755	144.8	3.340	377.6	1.763	0.757	144.6	3.518	377.4	1.759	0.752	144.5	-30	3.037	381.5	1.783	0.762	146.4	3.263	381.4	1.779	0.763	145.3	3.437	381.2	1.774	0.765	146.1	-25	3.028	385.3	1.799	0.768	148.0	3.190	385.2	1.795	0.770	147.9	3.359	385.1	1.790	0.771	147.7	-20	2.952	389.2	1.814	0.775	149.5	3.120	389.1	1.810	0.777	149.5	3.286	389.0	1.806	0.779	149.3	-15	2.900	393.1	1.830	0.782	151.1	3.054	393.0	1.825	0.783	151.0	3.216	392.9	1.821	0.785	150.9	-10	2.840	397.0	1.845	0.790	152.6	2.991	396.9	1.840	0.791	152.5	3.149	396.8	1.836	0.792	152.4	-5	2.783	400.9	1.860	0.797	154.1	2.931	400.9	1.855	0.798	154.0	3.085	400.8	1.851	0.799	153.9	0	2.729	405.0	1.874	0.805	155.5	2.874	404.9	1.870	0.806	155.5	3.025	404.8	1.866	0.807	155.4	5	2.677	409.0	1.889	0.812	157.0	2.819	408.9	1.885	0.813	156.9	2.966	408.8	1.880	0.814	156.9	10	2.627	413.1	1.904	0.820	158.4	2.766	413.0	1.899	0.821	158.4	2.911	412.9	1.895	0.822	158.3	15	2.579	417.2	1.918	0.828	159.8	2.715	417.1	1.914	0.829	159.8	2.857	417.1	1.909	0.829	159.7	20	2.533	421.4	1.932	0.836	161.2	2.665	421.3	1.928	0.837	161.1	2.805	421.2	1.924	0.837	161.1	25	2.488	425.6	1.947	0.844	162.6	2.619	425.5	1.942	0.844	162.5	2.756	425.4	1.938	0.845	162.4	30	2.445	429.8	1.961	0.852	163.9	2.574	429.7	1.956	0.852	163.9	2.708	429.7	1.952	0.853	163.8	35	2.404	434.1	1.975	0.860	165.3	2.530	434.0	1.970	0.860	165.2	2.662	434.0	1.966	0.861	165.1	40	2.364	438.4	1.989	0.868	166.6	2.488	438.3	1.984	0.868	166.5	2.618	438.3	1.980	0.869	166.5	45	2.325	442.8	2.002	0.876	167.9	2.448	442.7	1.998	0.876	167.8	2.575	442.7	1.994	0.877	167.8	50	2.298	447.1	2.016	0.884	169.2	2.409	447.1	2.012	0.884	169.1	2.534	447.1	2.008	0.885	169.1	55	2.252	451.5	2.030	0.892	170.5	2.371	451.5	2.026	0.892	170.4	2.494	451.5	2.021	0.893	170.4	60	2.218	456.1	2.043	0.900	171.8	2.334	456.0	2.039	0.900	171.7	2.455	456.0	2.035	0.901	171.6	65	2.184	460.6	2.057	0.908	173.0	2.298	460.5	2.053	0.908	173.0	2.418	460.5	2.048	0.909	172.9	70	2.151	465.1	2.070	0.916	174.3	2.254	465.1	2.066	0.916	174.2	2.382	465.1	2.062	0.916	174.2	75	2.120	469.7	2.083	0.924	175.5	2.230	469.7	2.079																																							
ps=0.597 bar (ts=37°C)				ps=0.628 bar (ts=36°C)				ps=0.661 bar (ts=35°C)																																																																																																																																																																																																																																																																																																																																																																																																																																			
-35	3.170	377.7	1.768	0.755	144.8	3.340	377.6	1.763	0.757	144.6	3.518	377.4	1.759	0.752	144.5																																																																																																																																																																																																																																																																																																																																																																																																																												
-30	3.037	381.5	1.783	0.762	146.4	3.263	381.4	1.779	0.763	145.3	3.437	381.2	1.774	0.765	146.1																																																																																																																																																																																																																																																																																																																																																																																																																												
-25	3.028	385.3	1.799	0.768	148.0	3.190	385.2	1.795	0.770	147.9	3.359	385.1	1.790	0.771	147.7																																																																																																																																																																																																																																																																																																																																																																																																																												
-20	2.952	389.2	1.814	0.775	149.5	3.120	389.1	1.810	0.777	149.5	3.286	389.0	1.806	0.779	149.3																																																																																																																																																																																																																																																																																																																																																																																																																												
-15	2.900	393.1	1.830	0.782	151.1	3.054	393.0	1.825	0.783	151.0	3.216	392.9	1.821	0.785	150.9																																																																																																																																																																																																																																																																																																																																																																																																																												
-10	2.840	397.0	1.845	0.790	152.6	2.991	396.9	1.840	0.791	152.5	3.149	396.8	1.836	0.792	152.4																																																																																																																																																																																																																																																																																																																																																																																																																												
-5	2.783	400.9	1.860	0.797	154.1	2.931	400.9	1.855	0.798	154.0	3.085	400.8	1.851	0.799	153.9																																																																																																																																																																																																																																																																																																																																																																																																																												
0	2.729	405.0	1.874	0.805	155.5	2.874	404.9	1.870	0.806	155.5	3.025	404.8	1.866	0.807	155.4																																																																																																																																																																																																																																																																																																																																																																																																																												
5	2.677	409.0	1.889	0.812	157.0	2.819	408.9	1.885	0.813	156.9	2.966	408.8	1.880	0.814	156.9																																																																																																																																																																																																																																																																																																																																																																																																																												
10	2.627	413.1	1.904	0.820	158.4	2.766	413.0	1.899	0.821	158.4	2.911	412.9	1.895	0.822	158.3																																																																																																																																																																																																																																																																																																																																																																																																																												
15	2.579	417.2	1.918	0.828	159.8	2.715	417.1	1.914	0.829	159.8	2.857	417.1	1.909	0.829	159.7																																																																																																																																																																																																																																																																																																																																																																																																																												
20	2.533	421.4	1.932	0.836	161.2	2.665	421.3	1.928	0.837	161.1	2.805	421.2	1.924	0.837	161.1																																																																																																																																																																																																																																																																																																																																																																																																																												
25	2.488	425.6	1.947	0.844	162.6	2.619	425.5	1.942	0.844	162.5	2.756	425.4	1.938	0.845	162.4																																																																																																																																																																																																																																																																																																																																																																																																																												
30	2.445	429.8	1.961	0.852	163.9	2.574	429.7	1.956	0.852	163.9	2.708	429.7	1.952	0.853	163.8																																																																																																																																																																																																																																																																																																																																																																																																																												
35	2.404	434.1	1.975	0.860	165.3	2.530	434.0	1.970	0.860	165.2	2.662	434.0	1.966	0.861	165.1																																																																																																																																																																																																																																																																																																																																																																																																																												
40	2.364	438.4	1.989	0.868	166.6	2.488	438.3	1.984	0.868	166.5	2.618	438.3	1.980	0.869	166.5																																																																																																																																																																																																																																																																																																																																																																																																																												
45	2.325	442.8	2.002	0.876	167.9	2.448	442.7	1.998	0.876	167.8	2.575	442.7	1.994	0.877	167.8																																																																																																																																																																																																																																																																																																																																																																																																																												
50	2.298	447.1	2.016	0.884	169.2	2.409	447.1	2.012	0.884	169.1	2.534	447.1	2.008	0.885	169.1																																																																																																																																																																																																																																																																																																																																																																																																																												
55	2.252	451.5	2.030	0.892	170.5	2.371	451.5	2.026	0.892	170.4	2.494	451.5	2.021	0.893	170.4																																																																																																																																																																																																																																																																																																																																																																																																																												
60	2.218	456.1	2.043	0.900	171.8	2.334	456.0	2.039	0.900	171.7	2.455	456.0	2.035	0.901	171.6																																																																																																																																																																																																																																																																																																																																																																																																																												
65	2.184	460.6	2.057	0.908	173.0	2.298	460.5	2.053	0.908	173.0	2.418	460.5	2.048	0.909	172.9																																																																																																																																																																																																																																																																																																																																																																																																																												
70	2.151	465.1	2.070	0.916	174.3	2.254	465.1	2.066	0.916	174.2	2.382	465.1	2.062	0.916	174.2																																																																																																																																																																																																																																																																																																																																																																																																																												
75	2.120	469.7	2.083	0.924	175.5	2.230	469.7	2.079																																																																																																																																																																																																																																																																																																																																																																																																																																			

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	[p] = kg/m ²					[h] = kJ/kg					[s] = kJ / (kg·K)					[c] = m/s					Saturation temperature in brackets																				
	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	t																				
																						ps=0.694 bar (ts=34°C)					ps=0.729 bar (ts=33°C)					ps=0.766 bar (ts=32°C)									
-30	3.677	321.1	1.770	0.767	145.7	3.805	321.0	1.766	0.759	145.8	4.004	320.9	1.761	0.751	145.9	-30																									
-25	3.535	335.0	1.755	0.773	147.6	3.719	334.8	1.761	0.775	147.4	3.912	334.7	1.757	0.767	147.2	-25																									
-20	3.457	339.9	1.801	0.779	149.2	3.637	339.7	1.791	0.781	149.0	3.824	339.6	1.793	0.783	148.9	-20																									
-15	3.391	332.8	1.817	0.785	152.7	3.553	332.7	1.812	0.789	152.6	3.742	332.6	1.800	0.793	152.4	-15																									
-10	3.317	335.7	1.872	0.793	152.3	3.484	335.6	1.827	0.794	152.1	3.653	335.5	1.821	0.796	152.0	-10																									
-5	3.251	400.7	1.847	0.803	153.9	3.410	400.6	1.842	0.811	153.6	3.583	400.5	1.834	0.813	153.5	-5																									
0	3.182	404.7	1.852	0.808	155.0	3.345	404.6	1.871	0.819	155.1	3.517	404.5	1.871	0.815	155.0	0																									
5	3.121	408.4	1.870	0.815	155.0	3.281	408.3	1.872	0.816	156.6	3.448	408.6	1.867	0.817	156.6	5																									
10	3.061	412.7	1.931	0.823	152.0	3.218	412.8	1.897	0.823	155.6	3.383	412.7	1.891	0.824	157.9	10																									
15	3.005	417.0	1.955	0.830	159.6	3.159	416.9	1.921	0.831	159.5	3.320	416.8	1.937	0.832	159.4	15																									
20	2.951	421.2	1.920	0.838	161.0	3.102	421.1	1.915	0.839	162.9	3.259	421.0	1.911	0.839	162.8	20																									
25	2.898	425.4	1.924	0.845	162.3	3.047	425.3	1.930	0.846	162.2	3.202	425.2	1.925	0.847	162.2	25																									
30	2.843	429.5	1.948	0.854	163.7	2.994	429.6	1.944	0.854	163.5	3.146	429.5	1.940	0.855	163.5	30																									
35	2.789	433.9	1.962	0.864	165.7	2.943	433.9	1.958	0.862	165.0	3.092	433.6	1.954	0.863	164.9	35																									
40	2.733	438.2	1.976	0.869	166.4	2.893	438.2	1.972	0.870	166.3	3.040	438.1	1.969	0.873	166.2	40																									
45	2.708	442.6	1.990	0.877	167.7	2.846	442.6	1.995	0.878	167.6	2.990	442.5	1.982	0.879	167.5	45																									
50	2.654	447.0	2.004	0.885	169.0	2.800	447.0	1.999	0.886	168.9	2.942	446.9	1.995	0.885	168.9	50																									
55	2.622	451.5	2.017	0.893	170.3	2.755	451.4	2.013	0.894	170.2	2.895	451.4	2.009	0.894	170.2	55																									
60	2.581	455.9	2.031	0.901	171.6	2.713	455.9	2.027	0.901	171.5	2.850	455.8	2.023	0.902	171.5	60																									
65	2.542	460.5	2.044	0.909	172.8	2.671	460.4	2.040	0.909	172.8	2.806	460.4	2.036	0.910	172.7	65																									
70	2.504	465.0	2.058	0.917	174.1	2.631	465.0	2.054	0.917	174.0	2.764	464.9	2.049	0.917	174.0	70																									
75	2.467	469.6	2.071	0.925	175.3	2.592	469.6	2.067	0.925	175.3	2.723	469.5	2.063	0.925	175.2	75																									
80	2.431	474.3	2.084	0.932	176.5	2.554	474.2	2.082	0.933	176.5	2.683	474.2	2.076	0.933	176.5	80																									
85	2.395	479.0	2.097	0.940	177.8	2.518	478.9	2.093	0.940	177.8	2.645	478.9	2.089	0.940	177.7	85																									
90	2.362	483.7	2.110	0.948	179.0	2.482	483.6	2.106	0.948	179.0	2.607	483.6	2.102	0.948	178.9	90																									
																						ps=0.804 bar (ts=31°C)					ps=0.843 bar (ts=30°C)					ps=0.884 bar (ts=29°C)									
-30	4.259	375.7	1.757	0.773	145.4	4.423	380.6	1.753	0.775	145.2	-	-	-	-	-30																										
-25	4.112	384.6	1.773	0.779	147.1	4.320	384.5	1.768	0.781	145.9	4.538	384.3	1.764	0.783	146.1	-25																									
-20	4.019	388.5	1.788	0.784	148.7	4.223	388.4	1.794	0.786	148.5	4.435	388.2	1.781	0.788	148.3	-20																									
-15	3.932	392.4	1.904	0.791	150.3	4.130	392.3	1.799	0.792	150.1	4.357	392.2	1.795	0.794	149.9	-15																									
-10	3.843	396.4	1.819	0.797	151.8	4.043	396.3	1.815	0.799	151.7	4.244	396.2	1.810	0.800	151.5	-10																									
-5	3.770	403.4	1.834	0.804	153.4	3.959	400.3	1.830	0.805	153.2	4.156	400.2	1.825	0.807	153.1	-5																									
0	3.694	404.4	1.849	0.811	154.9	3.879	404.3	1.845	0.812	154.7	4.072	404.2	1.841	0.813	154.6	0																									
5	3.622	408.5	1.864	0.818	155.4	3.803	408.4	1.853	0.819	156.2	3.992	408.3	1.855	0.820	156.1	5																									
10	3.553	412.5	1.878	0.825	157.8	3.731	412.5	1.874	0.826	157.7	3.915	412.4	1.870	0.827	157.6	10																									
15	3.487	416.8	1.893	0.833	159.3	3.661	416.7	1.889	0.834	159.1	3.842	416.6	1.885	0.835	159.0	15																									
20	3.423	421.0	1.907	0.840	160.7	3.594	420.9	1.903	0.841	160.6	3.771	420.8	1.899	0.842	160.5	20																									
25	3.362	425.2	1.921	0.848	162.1	3.529	425.1	1.917	0.849	162.0	3.703	425.0	1.913	0.849	161.9	25																									
30	3.303	429.4	1.935	0.856	163.4	3.468	429.4	1.932	0.856	163.3	3.639	429.3	1.928	0.857	163.2	30																									
35	3.247	433.7	1.950	0.863	164.8	3.408	433.7	1.946	0.864	164.7	3.576	433.6	1.942	0.865	164.6	35																									
40	3.192	438.1	1.964	0.871	166.1	3.350	438.0	1.960	0.872	166.1	3.515	437.9	1.958	0.872	165.0	40																									
45	3.139	442.4	1.977	0.879	167.5	3.295	442.4	1.972	0.879	167.4	3.457	442.3	1.969	0.882	167.3	45																									
50	3.089	446.9	1.991	0.887	168.8	3.242	446.8	1.987	0.887	168.7	3.401	446.7	1.981	0.886	168.6	50																									
55	3.040	451.3	2.005	0.894	170.1	3.191	451.2	2.001	0.895	170.0	3.347	451.1	1.997	0.895	170.0	55																									
60	2.992	455.7	2.019	0.902	171.4	3.141	455.6	2.015	0.903	171.3	3.294	455.5	2.013	0.903	171.3	60																									
65	2.946	460.1	2.032	0.910	172.7	3.092	460.0	2.029	0.910	172.6	3.241	460.0	2.027	0.910	172.6	65																									
70	2.901	464.9	2.045	0.916	173.9	3.045	464.8	2.041	0.916	173.3	3.184	464.8	2.037	0.917	173.9	70																									
75	2.859	469.5	2.059	0.924	175.2	3.000	469.5	2.055	0.925	175.1	3.140	469.4	2.051	0.925	175.0	75																									
80	2.817	474.2	2.072	0.931	176.4	2.956	474.1	2.069	0.934	176.4	3.100	474.1	2.064	0.934	176.3	80																									
85	2.776	478.8	2.085	0.941	177.6	2.913	478.8	2.081	0.941	177.6	3.058	478.7	2.077	0.942	177.5	85																									
90	2.737	483.6	2.099	0.949	178.9	2.872	483.5	2.094	0.949	178.8	3.012	483.5	2.090	0.949	178.7	90																									
																						ps=0.926 bar (ts=28°C)					ps=0.970 bar (ts=27°C)					ps=1.02 bar (ts=25°C)									
-25	4.764	384.2	1.760	0.785	146.5	5.001	384.0	1.756	0.787	146.3	5.247	383.8	1.751	0.790	146.0	-25																									
-20	4.656	388.1	1.776	0.790	148.1	4.886	388.0	1.771	0.792	147.9	5.125	387.8	1.767	0.794	147.7	-20																									
-15	4.552	392.1	1.791	0.795	149.8	4.777	391.9	1.787	0.798	149.6	5.011	391.8	1.783	0.800	149.4	-15																									
-10	4.455	396.1	1.806	0.802	151.4	4.674	395.9	1.802	0.803	151.2	4.902	395.8	1.798	0.805	151.0	-10																									
-5	4.362	400.1	1.821	0.808	152.9	4.576	400.0	1.817	0.810	152.8	4.798	399.8	1.813	0.811	152.6	-5																									
0	4.273	404.1	1.836	0.815	154.5	4.482	404.0	1.832	0.816	154.3	4.700	403.9	1.828	0.817	154.1	0																									
5	4.188	408.2	1.851	0.821	156.0	4.393	408.1	1.847	0.823	155.8	4.606	408.0	1.843	0.824	155.7	5																									
10	4.106	412.4	1.866	0.828	157.4	4.308	412.3	1.862	0.830	157.3	4.516	412.2	1.858	0.831	157.2	10																									
15	4.030	416.5	1.881	0.836	158.9	4.227	416.4	1.877	0.837	158.8	4.430	416.3	1.873	0.838	158.6	15																									
20	3.956	420.7	1.895	0.843	160.3	4.148	420.6	1.891	0.844	160.2	4.348	420.5	1.887	0.845	160.1	20																									
25	3.885	424.9	1.909	0.8																																					

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	[p] = MPa					[v] = m³/kg					[c] = J/(kg·K)					t
	p	h	s	cp	c	v	h	s	cp	c	p	h	s	cp	c	
	ps=1.05 bar (ts=25°C)					ps=1.1 bar (ts=26°C)					ps=1.16 bar (ts=27°C)					
25	5.504	393.7	1.747	0.792	145.8	5.635	397.5	1.759	0.799	147.3	5.906	397.3	1.755	0.802	147.1	-25
20	5.375	397.7	1.763	0.797	147.5	5.507	397.5	1.774	0.804	149.0	5.770	397.3	1.770	0.826	148.9	-20
15	5.254	397.6	1.779	0.802	149.2	5.375	397.5	1.789	0.809	150.5	5.640	397.4	1.786	0.831	150.4	-15
10	5.139	397.7	1.794	0.807	150.9	5.254	397.6	1.804	0.815	152.2	5.520	397.4	1.801	0.836	150.3	-10
5	5.020	397.7	1.809	0.812	152.4	5.139	397.6	1.819	0.821	153.9	5.400	397.4	1.816	0.842	150.2	-5
0	4.907	407.9	1.824	0.817	154.0	5.020	407.7	1.834	0.827	155.4	5.285	407.7	1.831	0.848	150.1	0
5	4.792	407.9	1.839	0.822	155.5	4.907	407.7	1.849	0.833	156.9	5.170	407.8	1.846	0.854	150.0	5
10	4.677	412.1	1.854	0.827	157.1	4.792	411.9	1.864	0.839	158.3	5.055	411.8	1.853	0.860	149.9	10
15	4.562	416.2	1.869	0.832	158.2	4.677	417.0	1.879	0.845	159.4	4.940	416.2	1.869	0.866	149.8	15
20	4.447	420.4	1.884	0.837	159.3	4.562	420.3	1.894	0.851	160.5	4.825	420.2	1.884	0.872	149.7	20
25	4.332	424.7	1.899	0.842	160.4	4.447	424.6	1.909	0.857	161.6	4.710	424.5	1.899	0.878	149.6	25
30	4.217	429.0	1.914	0.847	161.5	4.332	428.9	1.924	0.863	162.7	4.595	428.8	1.914	0.884	149.5	30
35	4.102	433.3	1.929	0.852	162.6	4.217	433.2	1.939	0.869	163.8	4.480	433.1	1.929	0.890	149.4	35
40	4.000	437.6	1.944	0.857	163.6	4.102	437.5	1.954	0.875	164.9	4.365	437.5	1.944	0.896	149.3	40
45	4.172	442.0	1.959	0.862	164.5	4.000	442.0	1.969	0.883	166.0	4.250	441.9	1.959	0.902	149.2	45
50	4.103	446.5	1.974	0.867	165.3	4.172	446.4	1.984	0.891	167.1	4.135	446.3	1.974	0.908	149.1	50
55	4.037	450.9	1.989	0.872	166.1	4.037	450.9	1.999	0.899	168.2	4.020	450.8	1.989	0.915	149.0	55
60	3.973	455.4	1.995	0.877	167.0	4.037	455.4	2.005	0.906	169.3	3.905	455.3	1.995	0.922	148.9	60
65	3.911	460.0	2.008	0.883	167.8	4.037	460.0	2.011	0.913	170.4	3.790	460.0	2.008	0.929	148.8	65
70	3.852	464.6	2.022	0.889	168.5	4.037	464.6	2.018	0.921	171.4	3.675	464.5	2.018	0.937	148.7	70
75	3.793	469.2	2.035	0.895	169.2	3.973	469.2	2.025	0.929	172.4	3.560	469.1	2.025	0.944	148.6	75
80	3.738	473.9	2.049	0.901	170.0	3.912	473.8	2.032	0.936	173.4	3.445	473.7	2.032	0.951	148.5	80
85	3.683	478.6	2.062	0.907	170.7	3.855	478.5	2.039	0.944	174.4	3.330	478.4	2.039	0.958	148.4	85
90	3.629	483.3	2.075	0.913	171.5	3.800	483.2	2.046	0.951	175.4	3.215	483.1	2.046	0.965	148.3	90
95	3.580	488.1	2.088	0.919	172.2	3.745	488.0	2.053	0.959	176.4	3.100	488.0	2.053	0.972	148.2	95
	ps=1.22 bar (ts=27°C)					ps=1.27 bar (ts=28°C)					ps=1.33 bar (ts=29°C)					
20	5.187	387.1	1.750	0.804	146.9	5.479	397.2	1.745	0.807	146.6	5.764	397.3	1.740	0.810	146.3	-20
15	5.043	391.2	1.766	0.808	148.5	5.328	391.0	1.762	0.811	148.3	5.624	397.8	1.758	0.813	148.1	-15
10	5.008	395.2	1.782	0.813	150.0	5.185	395.1	1.778	0.815	150.0	5.474	394.3	1.774	0.817	149.9	-10
5	5.040	399.2	1.797	0.818	151.5	5.040	399.2	1.793	0.820	151.6	5.331	399.0	1.789	0.822	151.4	-5
0	5.059	403.4	1.812	0.824	153.0	5.022	403.3	1.809	0.826	153.3	5.195	403.1	1.804	0.828	153.1	0
5	5.040	407.5	1.827	0.830	154.5	5.021	407.4	1.823	0.831	154.8	5.058	407.3	1.819	0.835	154.6	5
10	5.012	411.7	1.842	0.835	156.0	5.005	411.6	1.838	0.836	156.4	4.921	411.5	1.834	0.839	156.2	10
15	5.028	415.9	1.857	0.840	157.5	5.074	415.8	1.853	0.844	157.9	4.786	415.7	1.849	0.843	157.1	15
20	5.027	420.1	1.871	0.845	159.0	5.043	420.0	1.868	0.851	159.4	4.651	420.0	1.864	0.848	157.3	20
25	5.031	424.4	1.885	0.850	160.5	5.057	424.3	1.883	0.857	160.8	4.516	424.2	1.878	0.853	157.5	25
30	5.039	428.7	1.900	0.856	162.0	5.070	428.6	1.898	0.864	162.3	4.381	428.5	1.892	0.858	162.1	30
35	4.950	433.0	1.914	0.870	163.5	5.176	432.9	1.910	0.871	163.7	4.246	432.8	1.907	0.872	163.6	35
40	4.864	437.4	1.929	0.875	165.0	5.087	437.3	1.925	0.878	165.1	4.111	437.2	1.921	0.879	165.0	40
45	4.782	441.8	1.942	0.885	166.5	5.051	441.7	1.939	0.885	166.5	3.976	441.6	1.935	0.886	166.4	45
50	4.703	446.2	1.955	0.892	168.0	4.917	446.2	1.952	0.893	167.9	3.841	446.1	1.949	0.894	167.7	50
55	4.671	450.7	1.970	0.898	169.5	4.877	450.7	1.965	0.900	169.3	3.706	450.6	1.962	0.901	169.1	55
60	4.552	455.2	1.984	0.907	171.0	4.761	455.2	1.981	0.905	170.5	3.571	455.1	1.977	0.902	170.9	60
65	4.451	459.8	1.997	0.914	172.5	4.651	459.7	1.997	0.910	171.5	3.436	459.6	1.993	0.907	171.7	65
70	4.370	464.4	2.010	0.921	174.0	4.540	464.3	2.013	0.915	172.5	3.301	464.2	2.009	0.912	171.9	70
75	4.347	469.0	2.024	0.927	175.5	4.430	468.9	2.029	0.920	173.4	3.166	468.8	2.025	0.917	172.1	75
80	4.301	473.7	2.037	0.933	177.0	4.319	473.6	2.044	0.927	174.3	3.031	473.5	2.041	0.922	172.3	80
85	4.213	478.4	2.051	0.940	178.5	4.210	478.3	2.060	0.945	175.2	2.896	478.2	2.047	0.927	172.5	85
90	4.158	483.1	2.064	0.947	179.9	4.147	483.0	2.076	0.952	176.1	2.761	482.9	2.053	0.932	172.7	90
95	4.093	487.9	2.077	0.954	181.3	4.085	487.8	2.093	0.960	177.0	2.626	487.7	2.069	0.937	172.9	95
100	4.042	492.7	2.090	0.961	182.7	4.025	492.7	2.096	0.967	180.7	2.491	492.6	2.085	0.942	180.6	100
	ps=1.39 bar (ts=29°C)					ps=1.45 bar (ts=30°C)					ps=1.51 bar (ts=31°C)					
15	5.931	390.6	1.754	0.816	147.8	7.251	390.5	1.750	0.819	147.5	7.583	390.3	1.746	0.822	147.3	-15
10	6.773	394.7	1.770	0.820	149.5	7.084	394.5	1.766	0.822	149.3	7.407	394.4	1.762	0.825	149.0	-10
5	6.623	399.8	1.785	0.824	151.2	6.925	399.7	1.781	0.827	151.0	7.240	399.5	1.777	0.829	150.7	-5
0	6.480	403.0	1.800	0.829	152.8	6.776	402.8	1.797	0.832	152.6	7.082	402.7	1.793	0.834	152.4	0
5	6.345	407.1	1.816	0.835	154.4	6.634	407.0	1.812	0.837	154.2	6.933	406.8	1.808	0.839	154.0	5
10	6.217	411.3	1.831	0.841	156.0	6.499	411.2	1.827	0.842	155.8	6.791	411.1	1.823	0.844	155.6	10
15	6.095	415.5	1.845	0.847	157.6	6.370	415.4	1.841	0.848	157.4	6.656	415.3	1.838	0.850	157.2	15
20	5.978	419.8	1.860	0.853	159.1	6.248	419.7	1.856	0.855	159.0	6.521	419.5	1.852	0.856	158.7	20
25	5.855	424.1	1.874	0.860	160.5	6.130	424.0	1.871	0.861	160.4	6.403	423.8	1.867	0.862	160.2	25
30	5.759	428.4	1.889	0.866	162.0	6.018	428.3	1.885	0.866	161.8	6.285	428.2	1.881	0.869	161.7	30
35	5.557	432.7	1.903	0.873	163.4	5.910	432.5	1.899	0.874	163.3	6.173	432.5	1.895	0.875	163.1	35
40	5.558	437.1	1.917	0.880	164.8	5.807	437.0	1.913	0.881	164.7	6.063	436.9	1.910	0.882	164.6	40
45	5.463	441.5	1.931	0.887	166.2	5.707	441.5	1.927	0.888	166.1	5.959	441.4	1.924	0.889	166.0	45
50	5.372	446														

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

[t] = °C	[p] = kg/cm ²	[h] = kcal/kg	[s] = kJ / (kg·K)	[cp] = kJ / (kg·K)	[c] = m/s	Saturation temperature in brackets											
t	p	h	s	cp	c	o	h	s	cp	c	p	h	s	cp	c	t	
	ps=1.57 bar (ts=10°C)					ps=1.64 bar (ts=15°C)					ps=1.71 bar (ts=14°C)						
-15	7.923	393.1	1.742	0.825	147.0	8.289	393.8	1.738	0.828	146.7							-15
-10	7.742	394.2	1.756	0.829	148.8	8.291	394.0	1.754	0.831	148.5	8.452	393.4	1.750	0.834	148.2		-10
-5	7.556	395.3	1.773	0.832	150.5	7.905	395.1	1.773	0.834	150.2	8.257	393.0	1.766	0.837	150.0		-5
0	7.400	402.5	1.789	0.836	152.2	7.731	402.3	1.785	0.833	151.9	8.073	402.1	1.781	0.841	151.7		0
5	7.263	409.7	1.804	0.841	153.8	7.565	406.5	1.800	0.843	153.6	7.893	406.4	1.796	0.845	153.4		5
10	7.094	410.5	1.819	0.845	155.4	7.423	410.9	1.815	0.848	155.2	7.722	410.5	1.811	0.850	155.0		10
15	6.952	418.1	1.834	0.852	157.0	7.259	415.0	1.830	0.853	156.8	7.577	414.3	1.826	0.855	156.6		15
20	6.816	419.4	1.849	0.857	158.5	7.116	419.3	1.845	0.859	158.3	7.427	419.1	1.841	0.861	158.1		20
25	6.687	425.7	1.863	0.864	160.0	6.987	423.6	1.859	0.865	159.9	7.285	423.5	1.856	0.867	159.7		25
30	6.563	429.1	1.878	0.870	161.5	6.851	427.9	1.874	0.871	161.4	7.148	427.8	1.870	0.873	161.2		30
35	6.444	432.4	1.892	0.877	163.0	6.726	432.3	1.888	0.878	162.8	7.018	432.2	1.885	0.879	162.7		35
40	6.331	435.3	1.905	0.883	164.4	6.607	435.7	1.902	0.884	164.3	6.893	436.5	1.899	0.886	164.1		40
45	6.221	441.3	1.920	0.890	165.8	6.492	441.1	1.916	0.891	165.7	6.773	441.0	1.913	0.892	165.5		45
50	6.116	445.7	1.934	0.897	167.2	6.382	445.5	1.930	0.898	167.1	6.657	445.5	1.927	0.899	167.0		50
55	6.015	450.2	1.948	0.904	168.6	6.276	450.1	1.944	0.905	168.5	6.545	450.0	1.941	0.906	168.3		55
60	5.917	454.8	1.962	0.911	170.0	6.173	454.7	1.958	0.912	169.8	6.440	454.5	1.954	0.913	169.7		60
65	5.822	459.3	1.975	0.918	171.3	6.075	459.2	1.972	0.919	171.2	6.336	459.2	1.968	0.920	171.1		65
70	5.732	463.9	1.989	0.926	172.6	5.980	463.9	1.985	0.926	172.5	6.236	463.8	1.982	0.927	172.4		70
75	5.643	468.6	2.002	0.933	173.9	5.888	468.5	1.999	0.934	173.8	6.140	468.4	1.995	0.934	173.7		75
80	5.558	473.3	2.016	0.940	175.2	5.798	473.2	2.012	0.941	175.1	6.047	473.1	2.008	0.941	175.0		80
85	5.476	478.0	2.029	0.947	176.5	5.713	477.9	2.025	0.948	176.4	5.957	477.8	2.022	0.949	176.3		85
90	5.395	482.7	2.042	0.955	177.8	5.629	482.7	2.038	0.955	177.7	5.869	482.6	2.035	0.956	177.6		90
95	5.313	487.5	2.055	0.962	179.0	5.548	487.5	2.052	0.963	178.9	5.785	487.4	2.048	0.963	178.8		95
100	5.244	492.4	2.068	0.969	180.3	5.470	492.3	2.065	0.970	180.2	5.703	492.2	2.061	0.970	180.1		100
105	5.171	497.2	2.081	0.977	181.5	5.394	497.2	2.078	0.977	181.4	5.623	497.1	2.074	0.978	181.3		105
	ps=1.78 bar (ts=11°C)					ps=1.85 bar (ts=12°C)					ps=1.93 bar (ts=11°C)						
-10	8.828	393.5	1.746	0.837	147.9	9.218	393.3	1.742	0.840	147.6	9.623	393.1	1.738	0.844	147.3		-10
-5	8.622	397.8	1.762	0.849	149.7	9.001	397.5	1.758	0.843	149.4	9.394	397.3	1.754	0.846	149.1		-5
0	8.428	402.0	1.777	0.843	151.4	8.795	401.8	1.773	0.846	151.1	9.178	401.6	1.770	0.848	150.9		0
5	8.245	406.2	1.792	0.847	153.1	8.583	406.0	1.789	0.850	152.9	8.975	405.8	1.785	0.852	152.6		5
10	8.071	410.4	1.808	0.852	154.8	8.421	410.3	1.804	0.854	154.5	8.783	410.1	1.800	0.856	154.3		10
15	7.905	414.7	1.823	0.857	156.4	8.247	414.5	1.819	0.859	156.1	8.601	414.4	1.815	0.861	155.9		15
20	7.749	419.0	1.837	0.862	157.9	8.083	418.8	1.834	0.864	157.7	8.428	418.7	1.830	0.866	157.5		20
25	7.600	423.3	1.852	0.868	159.5	7.925	423.2	1.848	0.870	159.3	8.264	423.0	1.845	0.871	159.1		25
30	7.457	427.7	1.867	0.874	161.0	7.776	427.5	1.863	0.876	160.9	8.105	427.4	1.859	0.877	160.6		30
35	7.320	432.1	1.881	0.880	162.5	7.633	431.9	1.877	0.882	162.3	7.955	431.8	1.874	0.883	162.1		35
40	7.190	436.5	1.895	0.887	164.0	7.495	436.4	1.892	0.888	163.8	7.812	436.2	1.889	0.889	163.6		40
45	7.063	440.9	1.909	0.893	165.4	7.364	440.8	1.906	0.894	165.2	7.674	440.7	1.902	0.896	165.1		45
50	6.942	445.4	1.923	0.900	166.8	7.237	445.3	1.920	0.901	166.7	7.541	445.2	1.916	0.902	166.5		50
55	6.825	449.9	1.937	0.907	168.2	7.114	449.8	1.934	0.908	168.1	7.414	449.7	1.930	0.909	167.9		55
60	6.714	454.5	1.951	0.914	169.6	6.998	454.4	1.947	0.915	169.4	7.292	454.3	1.934	0.916	169.3		60
65	6.606	459.1	1.965	0.921	170.9	6.884	459.0	1.961	0.922	170.8	7.174	458.9	1.958	0.922	170.7		65
70	6.502	463.7	1.978	0.928	172.3	6.775	463.6	1.975	0.929	172.2	7.060	463.5	1.971	0.929	172.0		70
75	6.400	468.3	1.991	0.935	173.6	6.671	468.3	1.989	0.930	173.5	6.950	468.2	1.985	0.936	173.4		75
80	6.302	473.0	2.005	0.942	174.9	6.571	473.0	2.011	0.942	174.1	6.845	472.9	1.991	0.943	174.1		80
85	6.209	477.0	2.018	0.949	176.2	6.477	477.7	2.015	0.945	175.1	6.741	477.6	2.011	0.949	176.1		85
90	6.119	481.5	2.031	0.956	177.5	6.378	482.5	2.028	0.957	177.4	6.641	481.4	2.026	0.959	177.3		90
95	6.029	487.3	2.045	0.964	178.9	6.283	487.3	2.041	0.964	178.7	6.544	487.2	2.039	0.965	178.5		95
100	5.944	492.2	2.059	0.971	180.3	6.193	492.1	2.054	0.971	179.9	6.451	492.0	2.051	0.972	179.3		100
105	5.862	497.0	2.071	0.978	181.2	6.107	497.0	2.067	0.978	181.2	6.360	496.9	2.054	0.979	181.1		105
110	5.781	501.9	2.083	0.985	182.5	6.023	501.9	2.080	0.986	182.4	6.273	501.8	2.077	0.986	182.3		110
	ps=2.01 bar (ts=10°C)					ps=2.09 bar (ts=9°C)					ps=2.17 bar (ts=8°C)						
-10	10.044	392.9	1.734	0.847	146.9						10.664	395.5	1.742	0.855	148.1		-10
-5	9.802	397.1	1.750	0.849	148.8	10.225	395.9	1.746	0.852	148.5	10.412	400.9	1.758	0.857	150.0		-5
0	9.575	401.4	1.766	0.851	150.5	9.985	401.1	1.762	0.854	150.3	10.175	405.2	1.774	0.860	151.7		0
5	9.361	405.6	1.781	0.855	152.3	9.761	405.4	1.778	0.857	152.0	9.951	409.5	1.789	0.863	153.5		5
10	9.159	409.9	1.797	0.858	154.0	9.548	409.7	1.793	0.861	153.8						10	
15	8.968	414.2	1.812	0.863	155.7	9.347	414.0	1.808	0.865	155.4	9.740	413.8	1.804	0.867	155.2		15
20	8.786	418.5	1.827	0.868	157.3	9.155	418.4	1.823	0.870	157.1	9.540	418.1	1.819	0.872	156.8		20
25	8.613	422.9	1.841	0.873	158.9	8.975	422.7	1.838	0.875	158.7	9.350	422.6	1.834	0.877	158.4		25
30	8.448	427.3	1.856	0.879	160.4	8.802	427.1	1.852	0.880	160.2	9.168	427.0	1.849	0.882	160.0		30
35	8.291	431.7	1.870	0.884	161.9	8.637	431.5	1.867	0.886	161.7	8.995	431.4	1.863	0.888	161.5		35
40	8.140	436.1	1.884	0.891	163.4	8.479	435.3	1.881	0.892	163.2	8.823	435.8	1.877	0.893	163.1		40
45	7.995	440.6	1.899	0.897	164.9	8.328	440.4	1.895	0.898	164.7	8.672	440.3					

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

[t] °C	[p] = kg/m ²	[h] = kJ/kg	[s] = kJ / (kg·K)	[cp] = kJ / (kg·K)	[c]	[p] = kg/m ²	[h] = kJ/kg	[s] = kJ / (kg·K)	[cp] = kJ / (kg·K)	[c]	[p] = kg/m ²	[h] = kJ/kg	[s] = kJ / (kg·K)	[cp] = kJ / (kg·K)	[c]	[p] = kg/m ²	[h] = kJ/kg	[s] = kJ / (kg·K)	[cp] = kJ / (kg·K)	[c]	[p] = kg/m ²	[h] = kJ/kg	[s] = kJ / (kg·K)	[cp] = kJ / (kg·K)	[c]	[p] = kg/m ²	[h] = kJ/kg	[s] = kJ / (kg·K)	[cp] = kJ / (kg·K)	[c]
	ps=2.26 bar (ts=7°C)					ps=2.34 bar (ts=8°C)					ps=2.43 bar (ts=5°C)																			
-5	11 110	136.4	1.739	0.859	147.8	11 592	136.1	1.735	0.863	147.4	12 081	135.9	1.731	0.867	147.0	-5														
0	10 853	137.7	1.754	0.851	149.6	11 311	137.4	1.751	0.864	149.3	11 786	137.2	1.747	0.858	148.9	0														
5	10 604	139.0	1.770	0.853	151.4	11 043	138.1	1.766	0.865	151.1	11 529	138.5	1.763	0.859	150.6	5														
10	10 363	140.3	1.785	0.856	153.2	10 782	138.9	1.782	0.865	152.9	11 269	138.9	1.779	0.862	152.6	10														
15	10 147	141.7	1.801	0.871	154.9	10 525	139.5	1.797	0.872	154.6	11 024	139.3	1.793	0.875	154.3	15														
20	9 937	143.0	1.816	0.874	156.6	10 289	140.8	1.812	0.876	156.3	10 792	140.5	1.809	0.879	156.0	20														
25	9 737	144.4	1.830	0.879	158.2	10 139	142.0	1.827	0.881	157.9	10 552	142.0	1.823	0.885	157.7	25														
30	9 547	145.8	1.845	0.894	159.8	9 995	143.5	1.842	0.885	159.5	10 333	143.5	1.839	0.887	159.3	30														
35	9 366	147.2	1.860	0.899	161.5	9 749	143.1	1.855	0.893	161.1	10 145	143.9	1.853	0.893	161.3	35														
40	9 191	148.7	1.874	0.895	162.9	9 557	143.5	1.871	0.896	162.6	9 954	143.4	1.857	0.895	162.4	40														
45	9 026	149.0	1.898	0.901	164.3	9 393	144.0	1.885	0.902	164.0	9 773	143.9	1.881	0.904	163.9	45														
50	8 868	149.7	1.902	0.907	165.8	9 229	144.6	1.899	0.908	165.6	9 522	144.4	1.895	0.910	165.4	50														
55	8 715	149.2	1.916	0.913	167.3	9 068	144.9	1.913	0.914	167.1	9 432	144.9	1.909	0.915	166.9	55														
60	8 559	149.8	1.930	0.919	168.7	8 916	145.7	1.927	0.921	168.5	9 273	145.6	1.923	0.922	168.3	60														
65	8 428	149.4	1.944	0.925	170.1	8 763	145.3	1.940	0.927	169.9	9 118	145.2	1.937	0.928	169.8	65														
70	8 291	149.1	1.958	0.933	171.5	8 626	146.0	1.954	0.934	171.3	8 970	145.9	1.951	0.935	171.2	70														
75	8 151	148.7	1.971	0.940	172.8	8 488	146.7	1.968	0.941	172.7	8 825	146.6	1.964	0.941	172.5	75														
80	8 034	147.5	1.984	0.946	174.2	8 357	147.4	1.981	0.947	174.0	8 689	147.3	1.978	0.948	173.9	80														
85	7 912	147.2	1.998	0.953	175.5	8 228	147.1	1.995	0.954	175.4	8 556	147.0	1.991	0.955	175.2	85														
90	7 794	148.0	2.011	0.960	176.8	8 105	148.9	2.008	0.961	176.7	8 427	148.8	2.005	0.962	176.5	90														
95	7 579	148.6	2.024	0.967	178.1	7 985	148.6	2.021	0.968	178.0	8 303	148.7	2.018	0.969	177.9	95														
100	7 568	149.1	2.037	0.974	179.4	7 871	149.5	2.034	0.975	179.3	8 182	149.5	2.031	0.975	179.1	100														
105	7 461	149.6	2.050	0.981	180.6	7 759	149.6	2.047	0.982	180.5	8 065	149.6	2.044	0.982	180.4	105														
110	7 357	150.1	2.063	0.988	181.9	7 650	150.4	2.060	0.989	181.8	7 953	150.3	2.057	0.989	181.7	110														
115	7 256	150.6	2.076	0.995	183.1	7 545	150.6	2.073	0.996	183.0	7 842	150.6	2.070	0.996	182.9	115														
	ps=2.53 bar (ts=4°C)					ps=2.62 bar (ts=3°C)					ps=2.72 bar (ts=2°C)																			
0	10 079	139.9	1.743	0.871	148.6	10 733	139.7	1.739	0.875	148.2	11 317	139.4	1.735	0.879	147.8	0														
5	11 987	140.3	1.759	0.873	150.5	12 481	140.4	1.755	0.876	150.1	12 594	140.8	1.751	0.882	149.7	5														
10	11 713	140.7	1.774	0.875	152.3	12 193	140.8	1.771	0.878	152.0	12 637	141.2	1.767	0.881	151.6	10														
15	11 455	141.0	1.790	0.877	154.0	11 922	141.8	1.796	0.880	153.7	12 426	142.6	1.783	0.883	153.4	15														
20	11 212	141.4	1.805	0.881	155.9	11 657	141.2	1.801	0.883	155.6	12 177	141.0	1.799	0.886	155.2	20														
25	10 981	142.9	1.820	0.885	157.4	11 425	142.7	1.816	0.887	157.2	11 862	142.6	1.813	0.890	156.9	25														
30	10 762	142.6	1.835	0.889	159.1	11 195	142.6	1.831	0.892	159.8	11 647	142.9	1.828	0.894	158.6	30														
35	10 554	143.0	1.849	0.894	160.7	10 977	143.6	1.846	0.896	160.4	11 434	143.3	1.843	0.898	160.0	35														
40	10 355	143.5	1.864	0.900	162.2	10 759	143.1	1.860	0.901	162.0	11 195	143.9	1.857	0.903	161.8	40														
45	10 165	143.7	1.878	0.905	163.7	10 570	143.6	1.874	0.907	163.5	10 988	143.4	1.871	0.905	163.3	45														
50	9 984	144.2	1.892	0.911	165.2	10 380	144.1	1.889	0.912	165.0	10 788	144.0	1.885	0.914	164.8	50														
55	9 808	144.9	1.906	0.917	166.7	10 198	144.7	1.903	0.918	166.6	10 597	144.6	1.899	0.920	166.3	55														
60	9 642	145.3	1.920	0.923	168.2	10 022	145.3	1.917	0.924	168.0	10 415	145.2	1.913	0.926	167.8	60														
65	9 481	145.9	1.934	0.929	169.6	9 854	145.8	1.930	0.931	169.4	10 240	145.8	1.927	0.932	169.2	65														
70	9 325	146.7	1.947	0.936	171.0	9 692	146.5	1.944	0.937	170.8	10 071	146.5	1.941	0.938	170.7	70														
75	9 176	147.4	1.961	0.942	172.4	9 537	146.3	1.959	0.943	172.2	9 929	146.0	1.954	0.944	172.0	75														
80	9 033	147.2	1.975	0.949	173.7	9 387	147.1	1.971	0.950	173.6	9 782	147.3	1.969	0.951	173.4	80														
85	8 894	147.9	1.989	0.956	175.1	9 244	147.6	1.985	0.957	174.9	9 627	147.6	1.981	0.957	174.8	85														
90	8 762	148.7	1.999	0.962	176.4	9 110	148.1	1.991	0.962	176.2	9 480	148.1	1.987	0.964	176.1	90														
95	8 630	148.6	2.014	0.969	177.7	8 986	148.0	2.007	0.967	177.6	9 344	148.4	2.005	0.971	177.5	95														
100	8 504	149.4	2.029	0.976	179.0	8 865	149.3	2.024	0.977	179.6	9 177	149.2	2.022	0.975	179.8	100														
105	8 382	149.3	2.041	0.983	180.3	8 708	149.6	2.037	0.984	180.2	9 044	149.6	2.034	0.984	180.1	105														
110	8 264	150.2	2.054	0.990	181.6	8 585	150.2	2.050	0.991	181.5	8 917	150.1	2.047	0.991	181.3	110														
115	8 150	150.6	2.066	0.997	182.8	8 466	150.6	2.063	0.997	182.7	8 792	150.6	2.060	0.999	182.6	115														
120	8 039	151.2	2.079	1.004	184.1	8 351	151.1	2.076	1.004	184.0	8 672	151.0	2.073	1.005	183.9	120														
	ps=2.82 bar (ts=1°C)					ps=2.93 bar (ts=0°C)					ps=3.04 bar (ts=1°C)																			
0	13 866	139.1	1.732	0.884	147.4	14 455	139.8	1.728	0.888	147.0	15 081	139.4	1.735	0.892	146.6	0														
5	13 525	140.5	1.748	0.884	149.4	14 375	140.2	1.744	0.889	149.0	14 643	140.0	1.740	0.897	148.6	5														
10	13 206	140.9	1.763	0.884	151.3	13 739	140.7	1.760	0.888	150.9	14 291	140.7	1.756	0.892	150.5	10														
15	12 906	141.4	1.779	0.886	153.1	13 424	141.1	1.775	0.885	152.8	13 959	141.9	1.772	0.893	152.4	15														
20	12 624	141.8	1.794	0.889	154.9	13 128	141.6	1.791	0.892	154.5	13 648	141.3	1.787	0.895	154.2	20														
25	12 358	142.3	1.809	0.892	156.6	12 848	142.0	1.806	0.895	156.3	13 354	142.8	1.802	0.897	156.0	25														
30	12 105	142.7	1.824	0.896	158.3	12 593	142.5	1.821	0.898	158.0	13 077	142.3	1.817	0.901	157.7	30														
35	11 865	143.0	1.839	0.900	159.9	12 332	143.0	1.835	0.902	159.6	12 814	142.8	1.832	0.905	159.4	35														
40	11 637	143.7	1.853	0.905	161.5	12 093	143.5	1.850	0.907	161.3	12 564	143.4	1.847	0.909	161.0	40														
45	11 419	143.3	1.868	0.910	163.1	11 854	143.9	1.864	0.912	162.8	12 325	143.9	1.861	0.914	162.6	45														
50	11 213	144.9	1.882	0.915	164.6	11 647	144.7	1.879	0.917	164.4	12 098	144.5	1.875	0.919	164.2	50														
55	11 013	144.4	1.896	0.921</																										

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

[t] °C		[p] = kg/m ²		[h] = kJ/kg		[s] = kJ/(kg·K)		[c _p] = kJ/(kg·K)		[c] J/m ³		Saturation temperature in brackets				
t	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	t
ps=4.29 bar (ts=11°C)																
15	20 452	426.8	1.735	0.936	142.1	17 245	426.5	1.732	0.947	147.6	22 055	426.1	1.729	0.957	147.7	15
20	19 844	413.5	1.702	0.933	150.2	17 599	413.2	1.748	0.939	149.7	21 473	412.9	1.744	0.943	149.3	20
25	19 462	418.2	1.707	0.931	152.7	17 792	417.9	1.764	0.936	151.8	20 945	417.5	1.760	0.941	151.2	25
30	19 212	422.5	1.703	0.931	154.2	17 719	422.2	1.779	0.937	153.8	20 448	422.2	1.776	0.939	151.4	30
35	19 022	427.5	1.700	0.932	156.7	17 676	427.2	1.795	0.938	156.7	19 980	426.3	1.791	0.942	151.3	35
40	18 882	432.7	1.693	0.934	159.9	17 659	431.3	1.810	0.937	159.5	19 540	431.6	1.807	0.944	151.2	40
45	18 777	436.8	1.688	0.936	162.7	17 456	435.6	1.825	0.939	159.3	19 131	436.3	1.821	0.946	151.0	45
50	18 745	441.5	1.683	0.940	164.4	18 094	441.3	1.837	0.942	161.1	18 745	441.0	1.834	0.948	150.7	50
55	18 725	445.2	1.687	0.942	163.7	17 742	445.0	1.854	0.945	162.9	18 379	445.0	1.851	0.949	150.5	55
60	18 823	450.9	1.671	0.947	164.7	17 425	450.7	1.868	0.949	164.4	18 023	450.5	1.865	0.951	164.1	60
65	18 495	455.7	1.665	0.952	166.3	17 083	455.5	1.892	0.953	166.0	17 589	455.3	1.873	0.955	166.7	65
70	18 202	460.5	1.699	0.956	167.3	16 782	460.3	1.905	0.958	167.6	17 372	460.1	1.893	0.960	167.3	70
75	18 323	465.3	1.913	0.951	169.4	17 485	465.1	1.970	0.953	169.2	17 056	464.9	1.907	0.966	166.3	75
80	18 653	470.1	1.927	0.957	170.9	18 207	469.9	1.924	0.969	170.7	16 775	469.7	1.921	0.971	170.4	80
85	18 333	474.9	1.941	0.972	172.4	18 927	474.8	1.938	0.972	172.2	16 495	474.6	1.935	0.975	171.9	85
90	18 147	479.8	1.954	0.978	173.8	18 677	479.6	1.951	0.979	173.6	16 227	479.5	1.949	0.980	173.4	90
95	18 998	484.7	1.968	0.984	175.3	18 429	484.5	1.965	0.985	175.1	15 968	484.4	1.962	0.986	174.8	95
100	18 676	489.6	1.981	0.989	176.7	18 190	489.5	1.978	0.991	176.5	15 718	489.3	1.975	0.992	176.3	100
105	18 453	494.6	1.994	0.989	178.1	18 959	494.4	1.991	0.997	177.9	15 476	494.3	1.988	0.998	177.7	105
110	18 238	499.6	2.007	1.002	179.4	18 734	499.4	2.004	1.003	179.2	15 246	499.3	2.001	1.004	179.1	110
115	18 031	504.6	2.020	1.008	180.8	18 519	504.5	2.017	1.009	180.6	15 019	504.3	2.014	1.010	180.4	115
120	18 830	509.7	2.033	1.014	182.1	18 312	509.5	2.030	1.015	181.9	14 804	509.4	2.027	1.015	181.8	120
125	18 537	514.7	2.045	1.020	183.4	18 105	514.6	2.043	1.021	183.2	14 591	514.5	2.042	1.022	183.1	125
130	18 447	519.9	2.059	1.027	184.7	18 914	519.7	2.056	1.027	184.5	14 390	519.6	2.053	1.028	184.4	130
135	18 266	525.0	2.072	1.033	186.0	18 723	524.9	2.059	1.034	185.9	14 195	524.8	2.066	1.035	185.7	135
ps=4.73 bar (ts=14°C)																
15	22 896	427.7	1.725	0.955	146.5	20 770	427.3	1.721	0.950	145.9	23 934	427.3	1.721	0.950	147.6	15
20	22 288	412.5	1.741	0.948	148.7	21 125	412.1	1.737	0.954	148.2	23 934	411.7	1.734	0.950	147.6	20
25	21 725	417.2	1.757	0.945	150.3	21 533	416.8	1.753	0.951	150.4	23 934	416.5	1.750	0.955	149.9	25
30	21 203	421.9	1.773	0.942	152.9	21 993	421.6	1.769	0.949	152.5	22 799	421.2	1.766	0.952	152.0	30
35	20 714	426.5	1.789	0.943	154.9	21 470	426.3	1.785	0.947	154.4	22 250	426.0	1.781	0.951	154.3	35
40	20 255	431.3	1.803	0.944	156.8	20 990	431.1	1.800	0.947	156.4	21 745	430.8	1.797	0.951	154.0	40
45	19 825	436.1	1.818	0.945	158.6	20 538	435.8	1.815	0.949	158.2	21 273	435.5	1.812	0.950	157.4	45
50	19 417	440.8	1.833	0.947	160.4	20 111	440.5	1.830	0.950	160.0	20 826	440.3	1.826	0.953	157.7	50
55	19 032	445.5	1.847	0.950	162.1	19 710	445.3	1.846	0.952	161.8	20 404	445.0	1.841	0.956	164.4	55
60	18 665	450.3	1.862	0.954	163.8	19 323	450.1	1.861	0.956	163.5	20 005	449.8	1.856	0.959	163.2	60
65	18 315	455.1	1.876	0.958	165.5	18 952	454.9	1.877	0.960	165.2	19 523	454.6	1.870	0.962	164.8	65
70	17 985	459.9	1.890	0.962	167.1	18 596	459.7	1.883	0.964	166.8	19 264	459.4	1.884	0.966	166.5	70
75	17 665	464.7	1.904	0.966	168.6	18 253	464.5	1.901	0.968	168.4	18 918	464.3	1.899	0.970	166.1	75
80	17 361	469.5	1.918	0.971	170.2	17 927	469.3	1.915	0.972	169.9	18 596	469.2	1.912	0.975	163.7	80
85	17 070	474.4	1.932	0.976	171.7	17 607	474.2	1.929	0.979	171.4	18 269	474.0	1.926	0.980	171.2	85
90	16 790	479.2	1.945	0.982	173.2	17 310	479.1	1.942	0.982	172.9	17 957	478.9	1.939	0.984	172.7	90
95	16 520	484.2	1.959	0.987	174.6	17 032	484.1	1.956	0.985	174.4	17 675	483.9	1.953	0.988	174.2	95
100	16 261	489.2	1.972	0.991	176.1	16 779	489.0	1.969	0.988	176.0	17 392	488.8	1.966	0.991	176.0	100
105	16 014	494.2	1.985	0.995	177.5	16 540	494.0	1.982	0.992	177.5	17 124	493.8	1.979	0.994	177.1	105
110	15 779	499.2	1.999	1.000	178.9	16 315	499.0	1.996	1.000	178.7	16 862	498.8	1.992	1.000	177.5	110
115	15 557	504.2	2.012	1.001	180.2	16 105	504.1	2.009	1.012	180.1	16 612	503.9	2.005	1.005	179.3	115
120	15 342	509.2	2.024	1.017	181.6	15 903	509.1	2.022	1.018	181.4	16 370	509.0	2.019	1.019	181.2	120
125	15 293	514.4	2.037	1.023	182.9	15 677	514.2	2.035	1.024	182.8	16 134	514.1	2.032	1.025	182.5	125
130	14 862	519.6	2.050	1.029	184.2	15 368	519.4	2.047	1.030	184.1	15 907	519.2	2.044	1.031	183.9	130
135	14 679	524.7	2.063	1.035	185.5	15 176	524.5	2.060	1.036	185.4	15 687	524.4	2.057	1.037	185.2	135
ps=5.21 bar (ts=17°C)																
20	24 893	411.3	1.730	0.966	147.1	25 474	410.9	1.726	0.972	146.5	26 790	410.4	1.723	0.979	145.2	20
25	24 233	416.1	1.745	0.971	149.3	25 128	415.7	1.743	0.965	148.8	25 054	415.3	1.739	0.972	148.2	25
30	23 623	420.9	1.761	0.977	151.5	24 486	420.5	1.759	0.962	151.0	25 377	420.2	1.755	0.947	150.4	30
35	23 057	425.7	1.778	0.955	153.5	23 890	425.3	1.774	0.950	153.1	24 750	425.0	1.771	0.964	152.6	35
40	22 527	430.5	1.793	0.955	155.5	23 334	430.1	1.790	0.958	155.1	24 165	429.8	1.787	0.962	154.6	40
45	22 031	435.2	1.808	0.955	157.4	22 813	434.9	1.805	0.959	157.0	23 620	434.6	1.802	0.962	156.5	45
50	21 564	440.0	1.823	0.956	159.3	22 324	439.7	1.820	0.959	158.9	23 108	439.4	1.817	0.963	158.5	50
55	21 123	444.8	1.838	0.958	161.1	21 862	444.5	1.835	0.961	160.7	22 625	444.3	1.832	0.964	160.3	55
60	20 703	449.5	1.852	0.961	162.8	21 427	449.3	1.849	0.964	162.5	22 168	449.1	1.845	0.965	162.1	60
65	20 302	454.4	1.867	0.964	164.5	21 013	454.2	1.864	0.967	164.2	21 735	453.9	1.861	0.969	162.9	65
70	19 930	459.2	1.881	0.968	166.2	20 617	459.0	1.878	0.970	165.9	21 325	458.8	1.875	0.972	165.6	70
75	19 570	464.1	1.895	0.972	167.8	20 241	463.9	1.892	0.974	167.5	20 933	463.5	1.889	0.975	167.2	75
80	19 225	469.0	1.909	0.977	169.4											

TABLE II. SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	t
[t] = °C [p] = kg/m ² [h] = kJ/kg [s] = kJ/(kg·K) [cp] = kJ/(kg·K) [c] = m/s Saturation temperature in brackets																
ps=7.49 bar (ts=29°C)																
33	36 220	415.7	1.719	1.038	144.0	37 542	415.1	1.716	1.048	143.2	-	-	-	-	-	33
35	35 142	420.8	1.730	1.026	145.7	36 398	420.3	1.733	1.034	145.9	37 698	419.9	1.729	1.043	145.2	35
40	34 161	425.9	1.753	1.017	149.1	35 351	425.5	1.749	1.024	148.5	36 601	425.0	1.746	1.031	147.8	40
45	32 252	431.0	1.769	1.010	151.5	34 473	430.5	1.765	1.016	150.9	35 620	430.1	1.762	1.022	150.3	45
50	32 432	435.0	1.784	1.007	153.7	33 633	435.5	1.781	1.011	153.2	34 652	435.0	1.779	1.016	152.6	50
55	31 650	441.0	1.800	1.002	155.9	32 829	440.7	1.797	1.007	155.4	33 822	440.3	1.793	1.012	154.8	55
60	30 941	446.0	1.815	1.000	157.9	32 073	445.7	1.812	1.015	157.4	33 038	445.3	1.801	1.010	156.9	60
65	30 257	451.0	1.831	1.000	159.9	31 358	450.7	1.827	1.024	159.5	32 292	450.4	1.824	1.028	159.0	65
70	29 629	456.0	1.844	1.000	161.8	30 679	455.7	1.841	1.004	161.4	31 631	455.4	1.829	1.007	161.0	70
75	29 033	459.1	1.859	1.002	163.7	29 981	456.7	1.856	1.005	163.3	30 950	460.4	1.851	1.028	162.9	75
80	28 468	466.1	1.873	1.004	165.5	29 355	465.9	1.870	1.006	165.1	30 332	465.5	1.857	1.009	164.7	80
85	27 927	471.1	1.887	1.006	167.2	28 825	470.3	1.884	1.009	166.9	29 742	470.5	1.862	1.011	166.5	85
90	27 417	476.1	1.901	1.009	168.9	28 292	475.9	1.893	1.012	168.5	29 193	475.6	1.895	1.014	168.2	90
95	26 925	481.2	1.915	1.013	170.6	27 768	480.9	1.912	1.015	170.3	28 661	480.7	1.903	1.017	169.9	95
100	26 459	485.3	1.929	1.016	172.2	27 252	485.0	1.925	1.019	171.9	28 162	485.8	1.920	1.021	171.6	100
105	26 015	491.3	1.942	1.021	173.8	26 836	491.1	1.940	1.023	173.5	27 690	490.9	1.937	1.024	173.2	105
110	25 586	496.5	1.956	1.025	175.4	26 331	496.2	1.953	1.027	175.1	27 215	495.0	1.950	1.029	174.8	110
115	25 176	501.6	1.969	1.030	176.9	25 855	501.4	1.966	1.031	176.6	26 774	501.2	1.964	1.033	176.4	115
120	24 782	506.8	1.982	1.035	178.4	25 555	506.6	1.980	1.036	178.1	26 344	506.3	1.977	1.038	177.9	120
125	24 399	511.9	1.995	1.040	179.9	25 161	511.7	1.993	1.041	179.6	25 938	511.5	1.990	1.042	179.4	125
130	24 032	517.2	2.008	1.045	181.3	24 782	517.0	2.006	1.046	181.1	25 542	516.8	2.003	1.047	180.8	130
135	23 681	522.4	2.021	1.050	182.7	24 415	522.2	2.019	1.051	182.5	25 165	522.0	2.016	1.053	182.3	135
140	23 337	527.7	2.034	1.056	184.1	24 060	527.5	2.032	1.057	183.9	24 799	527.3	2.029	1.058	183.7	140
145	23 009	532.9	2.047	1.061	185.5	23 720	532.8	2.044	1.062	185.3	24 442	532.5	2.042	1.063	185.1	145
150	22 689	538.3	2.060	1.067	186.9	23 388	538.1	2.057	1.068	186.7	24 099	537.9	2.054	1.069	186.5	150
ps=8.16 bar (ts=32°C)																
35	39 044	419.3	1.725	1.032	144.4	40 445	418.7	1.721	1.062	143.6	41 950	418.1	1.718	1.072	142.8	35
40	37 953	424.5	1.742	1.039	147.1	39 213	424.0	1.738	1.047	146.4	40 532	423.4	1.735	1.055	145.6	40
45	36 825	429.6	1.758	1.029	149.6	38 095	429.2	1.755	1.036	148.9	39 411	423.7	1.751	1.044	148.3	45
50	35 657	434.8	1.774	1.022	152.0	37 073	434.3	1.771	1.028	151.4	38 333	433.9	1.769	1.039	150.7	50
55	34 563	439.9	1.790	1.017	154.3	36 134	439.5	1.787	1.023	153.7	37 344	439.0	1.783	1.028	153.1	55
60	34 132	444.9	1.805	1.014	155.4	35 253	444.6	1.802	1.019	155.9	36 428	444.2	1.799	1.024	155.3	60
65	33 356	450.0	1.820	1.012	158.5	34 451	449.5	1.817	1.016	159.0	35 577	449.2	1.814	1.021	157.5	65
70	32 630	455.1	1.835	1.011	160.5	33 694	454.7	1.832	1.015	160.0	34 779	454.4	1.829	1.019	159.5	70
75	31 951	460.1	1.850	1.011	162.4	32 977	459.9	1.847	1.015	162.3	34 025	459.5	1.844	1.019	161.5	75
80	31 307	465.2	1.864	1.012	164.3	32 305	464.9	1.861	1.016	163.9	33 331	464.6	1.858	1.019	163.5	80
85	30 692	470.2	1.879	1.014	166.1	31 669	470.0	1.876	1.017	165.7	32 684	469.7	1.873	1.020	165.3	85
90	30 114	475.3	1.893	1.017	167.9	31 069	475.0	1.890	1.019	167.5	32 043	474.8	1.867	1.022	167.1	90
95	29 565	480.4	1.907	1.019	169.6	30 495	480.1	1.904	1.022	169.2	31 444	479.9	1.901	1.024	168.9	95
100	29 037	485.5	1.920	1.023	171.3	29 945	485.3	1.918	1.025	170.9	30 875	485.0	1.915	1.027	170.6	100
105	28 539	490.6	1.934	1.026	172.9	29 425	490.4	1.931	1.028	172.6	30 335	490.1	1.929	1.031	172.3	105
110	28 058	495.8	1.948	1.030	174.5	28 925	495.5	1.945	1.032	174.2	29 816	495.0	1.942	1.034	173.9	110
115	27 591	500.9	1.961	1.035	176.1	28 449	500.7	1.958	1.036	175.8	29 320	500.5	1.950	1.036	175.5	115
120	27 156	506.1	1.974	1.039	177.6	27 992	505.9	1.971	1.041	177.3	28 842	505.7	1.963	1.039	177.3	120
125	26 735	511.3	1.987	1.044	179.1	27 547	511.1	1.985	1.045	179.0	28 385	510.9	1.982	1.042	179.6	125
130	26 325	516.5	2.000	1.049	180.6	27 122	516.4	1.998	1.050	180.5	27 945	516.0	1.990	1.046	180.1	130
135	25 930	521.8	2.013	1.054	182.0	26 719	521.6	2.011	1.055	181.8	27 523	521.4	2.002	1.051	181.5	135
140	25 547	527.1	2.026	1.059	183.5	26 325	526.9	2.024	1.056	183.2	27 117	526.7	2.005	1.052	183.0	140
145	25 184	532.4	2.039	1.064	184.9	25 946	532.2	2.036	1.066	184.7	26 723	532.0	2.034	1.057	184.4	145
150	24 829	537.8	2.052	1.070	186.3	25 579	537.5	2.049	1.071	186.1	26 344	537.4	2.046	1.072	185.8	150
155	24 485	543.1	2.064	1.075	187.6	25 219	542.9	2.062	1.075	187.4	25 977	542.8	2.059	1.077	187.2	155
ps=8.88 bar (ts=35°C)																
35	43 413	417.5	1.714	1.084	141.9	-	-	-	-	-	45 053	421.7	1.724	1.086	143.2	35
40	42 024	422.9	1.731	1.065	144.8	43 510	422.3	1.727	1.078	144.0	43 646	427.1	1.741	1.069	146.0	40
45	40 773	428.2	1.748	1.052	147.5	42 184	427.6	1.744	1.060	146.8	42 375	432.4	1.757	1.057	148.7	45
50	39 635	433.4	1.764	1.042	150.1	40 982	432.9	1.761	1.049	149.4	41 216	437.7	1.774	1.047	151.2	50
55	38 593	438.6	1.780	1.034	152.5	39 883	438.1	1.777	1.041	151.8	40 169	442.9	1.789	1.040	153.6	55
60	37 631	443.7	1.796	1.029	154.8	38 872	443.3	1.793	1.035	154.2	39 169	448.1	1.805	1.035	155.8	60
65	36 738	448.9	1.811	1.025	156.9	37 935	448.5	1.808	1.030	156.4	38 253	453.2	1.820	1.032	158.0	65
70	35 907	454.0	1.826	1.023	159.0	37 052	453.5	1.823	1.028	158.5	37 397	458.4	1.835	1.030	160.1	70
75	35 126	459.1	1.841	1.022	161.1	36 249	458.8	1.838	1.026	160.6	36 595	463.5	1.850	1.030	162.1	75
80	34 391	464.2	1.855	1.022	163.0	35 479	463.9	1.853	1.026	162.6	35 842	468.6	1.864	1.031	164.1	80
85	33 701	469.3	1.870	1.023	164.9	34 756	469.0	1.867	1.026	164.5	35 144	473.8	1.878	1.031	165.9	85
90	33 044	474.5	1.884	1.025	166.7	34 077	474.2	1.881	1.026	166.3	34 457	479.0	1.892	1.032	167.7	90
95	32 423	479.6	1.898	1.027	168.5	33 425	479.3	1.895	1.030	168.1	33 818	484.2	1.906	1.035	169.5	95
100	31 829	484.7	1.912	1.030	170.2	32 811	484.5	1.909	1.032	169.9	33 209	489.3	1.920	1.037	171.2	100
105	31 265	489.9	1.926	1.033	171.9	32 225	489.6	1.923	1.035	171.6	32 623	494.5	1.934	1.041	172.9	105
110	30 726	495.1	1.939	1.036	173.6	31 663	494.8	1.937	1.038	173.2	32 069	499.8	1.947	1.044	174.5	110
115	30 210	500.2	1.953	1.040	175.2	31 132	500.0	1.950	1.042	174.9	31 538	505.0	1.961	1.048	176.2	115
120	29 718	505.5	1.966	1.044	176.8	30 616	505.2	1.963	1.046	176.5	31 030	510.2	1.974	1.052	177.7	120
125	29 246	510.7	1.979	1.049	178.3	30 124	510.5	1.977	1.							

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	[t]=20					[t]=30					[t]=40					t
	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	
	ps=7.49 bar (ts=29°C)					ps=7.71 bar (ts=30°C)					ps=7.93 bar (ts=31°C)					
30	36.223	415.7	1.719	1.028	144.0	37.540	415.1	1.716	1.048	143.2						30
35	35.142	422.8	1.716	1.025	145.7	36.399	422.1	1.733	1.034	145.9	37.637	419.8	1.729	1.043	145.2	35
40	34.161	429.9	1.753	1.017	149.1	35.351	429.5	1.749	1.024	148.0	36.501	425.0	1.746	1.031	147.9	40
45	33.202	437.0	1.759	1.010	151.5	34.413	433.6	1.765	1.016	150.9	35.502	433.1	1.762	1.022	150.3	45
50	32.432	443.0	1.784	1.005	153.7	33.539	435.6	1.781	1.011	153.2	34.652	435.2	1.778	1.016	152.6	50
55	31.802	449.0	1.811	1.000	155.9	32.723	440.7	1.797	1.007	155.4	33.829	440.3	1.793	1.012	154.8	55
60	30.947	455.0	1.819	1.000	157.9	31.975	445.7	1.812	1.003	157.4	33.052	445.3	1.809	1.009	156.9	60
65	30.207	451.0	1.830	1.000	159.9	31.255	450.7	1.827	1.004	159.4	32.298	450.4	1.824	1.009	159.0	65
70	29.529	456.0	1.844	1.000	161.8	30.572	455.7	1.841	1.004	161.4	31.601	455.4	1.838	1.007	161.0	70
75	29.033	461.1	1.853	1.000	163.7	29.921	460.7	1.856	1.000	163.3	30.950	460.4	1.853	1.000	162.9	75
80	28.459	466.1	1.873	1.004	165.5	29.355	465.8	1.870	1.000	165.1	30.332	465.5	1.867	1.009	164.7	80
85	27.907	471.1	1.887	1.005	167.2	28.824	470.9	1.874	1.000	166.9	29.748	470.5	1.882	1.011	166.5	85
90	27.417	476.1	1.901	1.009	168.9	28.321	475.9	1.893	1.012	168.2	29.193	475.6	1.896	1.014	168.2	90
95	26.925	481.2	1.915	1.013	170.6	27.855	480.0	1.912	1.015	170.3	28.661	480.7	1.909	1.017	169.9	95
100	26.459	486.3	1.929	1.016	172.2	27.322	484.1	1.926	1.019	171.9	28.162	485.8	1.923	1.021	171.6	100
105	26.016	491.3	1.942	1.021	173.8	26.836	491.1	1.940	1.023	173.5	27.690	490.9	1.937	1.024	173.2	105
110	25.586	496.5	1.956	1.025	175.4	26.391	496.2	1.953	1.027	175.1	27.215	496.0	1.950	1.029	174.8	110
115	25.176	501.6	1.969	1.030	176.9	25.965	501.4	1.966	1.031	176.6	26.774	501.2	1.964	1.033	174.4	115
120	24.782	506.8	1.982	1.035	178.4	25.555	506.5	1.980	1.036	178.1	26.344	506.3	1.977	1.038	177.9	120
125	24.399	511.9	1.995	1.040	179.9	25.161	511.7	1.993	1.041	179.6	25.938	511.5	1.990	1.042	179.4	125
130	24.032	517.2	2.008	1.045	181.3	24.782	517.0	2.006	1.046	181.1	25.543	516.8	2.003	1.047	180.8	130
135	23.681	522.4	2.021	1.050	182.7	24.415	522.2	2.019	1.051	182.5	25.165	522.0	2.016	1.053	182.3	135
140	23.337	527.7	2.034	1.056	184.1	24.060	527.5	2.032	1.057	183.9	24.798	527.3	2.029	1.058	183.7	140
145	23.009	532.9	2.047	1.061	185.5	23.720	532.8	2.044	1.062	185.3	24.442	532.6	2.042	1.063	185.1	145
150	22.589	538.3	2.063	1.067	186.9	23.388	538.1	2.057	1.066	186.7	24.093	537.9	2.054	1.069	186.5	150
	ps=8.16 bar (ts=32°C)					ps=8.40 bar (ts=33°C)					ps=8.64 bar (ts=34°C)					
35	39.044	419.3	1.725	1.052	144.4	40.445	418.7	1.721	1.052	143.6	41.900	418.1	1.718	1.072	142.8	35
40	37.883	425.5	1.742	1.039	147.1	39.213	424.0	1.738	1.047	146.4	40.592	423.4	1.735	1.056	145.6	40
45	36.825	429.5	1.758	1.029	149.6	38.096	429.2	1.755	1.036	148.9	39.411	428.7	1.751	1.044	148.3	45
50	35.857	434.8	1.774	1.022	152.0	37.075	434.3	1.771	1.028	151.4	38.333	433.9	1.768	1.035	150.7	50
55	34.963	439.9	1.790	1.017	154.3	36.134	439.5	1.787	1.023	153.7	37.344	439.0	1.783	1.028	153.1	55
60	34.132	444.9	1.805	1.014	156.4	35.263	444.6	1.802	1.019	155.9	36.429	444.2	1.799	1.024	155.3	60
65	33.358	450.0	1.820	1.012	158.5	34.451	449.6	1.817	1.015	158.0	35.577	449.3	1.814	1.021	157.5	65
70	32.533	455.1	1.835	1.011	160.5	33.694	454.7	1.832	1.015	160.0	34.779	454.4	1.829	1.019	159.5	70
75	31.651	460.1	1.850	1.011	162.4	32.977	459.8	1.847	1.015	162.0	34.035	459.5	1.844	1.019	161.5	75
80	31.307	465.2	1.864	1.012	164.3	32.305	464.9	1.861	1.015	163.3	33.331	464.6	1.858	1.019	163.5	80
85	30.692	470.3	1.879	1.014	166.1	31.669	470.0	1.876	1.017	165.7	32.668	469.7	1.873	1.020	165.3	85
90	30.114	475.3	1.893	1.017	167.9	31.069	475.0	1.890	1.019	167.5	32.043	474.8	1.887	1.022	167.1	90
95	29.565	480.4	1.907	1.019	169.6	30.495	480.1	1.904	1.022	169.2	31.444	479.9	1.901	1.024	168.9	95
100	29.037	485.5	1.920	1.023	171.3	29.946	485.3	1.918	1.025	170.9	30.875	485.0	1.915	1.027	170.6	100
105	28.539	490.6	1.934	1.026	172.9	29.425	490.4	1.931	1.028	172.6	30.335	490.1	1.928	1.031	172.3	105
110	28.058	495.8	1.948	1.030	174.5	28.925	495.5	1.945	1.032	174.2	29.815	495.2	1.942	1.034	173.9	110
115	27.537	500.9	1.961	1.032	176.1	28.449	500.7	1.951	1.035	175.9	29.320	500.5	1.955	1.036	175.5	115
120	27.156	506.1	1.974	1.039	177.5	27.992	505.3	1.971	1.041	177.0	28.843	505.7	1.969	1.043	177.0	120
125	26.735	511.3	1.987	1.044	179.1	27.547	511.1	1.985	1.048	178.0	28.385	510.9	1.981	1.047	178.5	125
130	26.325	516.4	2.000	1.049	180.6	27.125	516.4	1.998	1.055	180.3	27.945	516.2	1.995	1.052	180.1	130
135	25.933	521.8	2.013	1.054	182.0	26.719	521.5	2.011	1.055	181.8	27.523	521.4	2.008	1.057	181.6	135
140	25.547	527.1	2.026	1.059	183.5	26.329	526.9	2.024	1.060	183.2	27.117	526.7	2.021	1.062	183.0	140
145	25.184	532.4	2.039	1.064	184.9	25.946	532.2	2.036	1.066	184.7	26.725	532.0	2.034	1.067	184.4	145
150	24.829	537.8	2.052	1.070	186.3	25.579	537.6	2.049	1.071	186.1	26.344	537.4	2.046	1.072	185.9	150
155	24.485	543.1	2.064	1.075	187.6	25.219	542.9	2.062	1.076	187.4	25.977	542.8	2.059	1.077	187.2	155
	ps=9.88 bar (ts=35°C)					ps=9.13 bar (ts=36°C)					ps=9.38 bar (ts=37°C)					
35	43.413	417.5	1.714	1.054	141.9						45.053	421.7	1.724	1.086	143.2	35
40	42.024	422.9	1.731	1.065	144.8	43.510	422.3	1.727	1.076	144.0	43.546	427.1	1.741	1.069	146.0	40
45	40.773	428.2	1.748	1.052	147.5	42.184	427.5	1.744	1.060	146.8	42.375	432.4	1.757	1.057	148.7	45
50	39.635	433.4	1.764	1.042	150.1	40.982	432.9	1.761	1.049	149.4	41.216	437.7	1.774	1.047	151.2	50
55	38.593	438.6	1.780	1.034	152.5	39.883	438.1	1.777	1.041	151.8					55	
60	37.631	443.7	1.796	1.029	154.8	38.872	443.3	1.790	1.035	154.2	40.152	448.9	1.789	1.040	153.6	60
65	36.738	448.9	1.811	1.025	156.9	37.935	448.5	1.808	1.030	156.4	39.169	448.1	1.805	1.035	155.8	65
70	35.907	454.0	1.826	1.023	159.0	37.062	453.6	1.823	1.028	158.5	38.253	453.2	1.820	1.032	158.0	70
75	35.126	459.1	1.841	1.022	161.1	36.249	458.8	1.838	1.026	160.6	37.397	458.4	1.835	1.030	160.1	75
80	34.397	464.2	1.855	1.022	163.0	35.479	463.9	1.853	1.026	162.6	36.595	463.5	1.850	1.030	162.1	80
85	33.701	469.3	1.870	1.023	164.9	34.756	469.0	1.867	1.026	164.5	35.844	468.7	1.864	1.030	164.0	85
90	33.044	474.5	1.884	1.025	166.7	34.077	474.2	1.881	1.028	166.3	35.131	473.8	1.878	1.031	165.9	90
95	32.423	479.6	1.893	1.027	168.5	33										

TABLE II: SUPERHEATED VAPOUR PROPERTIES - SUVA HFC - 134a

t	[p] = bar					[h] = kJ/kg					[s] = kJ/kgK					[c _p] = J/kgK					[v] = m ³ /kg					Saturation temperature in brackets																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	t	t	t	t	t																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
															ps=12.22 bar (ts=47°C)					ps=12.54 bar (ts=48°C)					ps=12.86 bar (ts=49°C)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																	
50	59.541	426.2	1.727	1.167	142.0	61.655	425.5	1.717	1.193	138.9	63.692	424.7	1.710	1.201	137.8	70	51.050	454.1	1.604	1.023	154.3	52.658	453.6	1.601	1.090	153.6	54.322	452.1	1.736	1.027	152.9	75	49.775	454.5	1.819	1.076	156.7	52.658	453.0	1.816	1.092	156.3	52.916	452.8	1.813	1.095	156.6	80	48.602	454.9	1.834	1.072	158.9	52.658	454.4	1.831	1.077	158.3	51.623	454.2	1.829	1.082	157.7	85	47.478	470.2	1.849	1.062	161.3	48.375	453.8	1.846	1.073	160.6	50.422	453.4	1.843	1.078	160.3	90	46.456	475.6	1.864	1.057	163.2	47.652	475.2	1.861	1.071	162.7	49.237	474.9	1.858	1.075	162.0	95	45.500	480.9	1.878	1.056	166.2	46.571	480.5	1.875	1.070	164.7	48.043	480.1	1.873	1.073	164.1	100	44.597	485.2	1.892	1.052	169.2	45.501	485.9	1.892	1.059	166.7	47.022	485.5	1.891	1.073	166.2	105	43.733	491.6	1.905	1.047	172.9	44.503	491.2	1.904	1.070	168.6	46.015	490.9	1.901	1.073	168.2	110	42.910	496.9	1.920	1.038	177.9	43.521	496.5	1.918	1.071	170.5	44.932	496.2	1.915	1.074	170.1	115	42.136	502.2	1.934	1.030	182.7	42.347	501.9	1.931	1.073	172.3	44.597	501.5	1.929	1.075	171.9	120	41.394	507.5	1.947	1.023	192.4	42.552	507.3	1.945	1.075	174.1	43.792	507.0	1.942	1.078	173.7	125	40.692	513.0	1.951	1.016	197.1	41.847	512.7	1.958	1.078	175.8	43.035	512.4	1.956	1.080	175.4	130	40.012	518.4	1.974	1.009	197.8	41.145	518.1	1.972	1.081	177.4	42.300	517.8	1.969	1.083	177.1	135	39.364	523.8	1.987	1.002	199.4	40.473	523.5	1.985	1.084	179.1	41.605	523.2	1.982	1.086	178.8	140	38.739	529.2	2.000	1.005	181.0	39.825	528.9	1.999	1.088	180.7	40.941	528.7	1.995	1.090	180.4	145	38.145	534.6	2.013	1.030	182.6	39.208	534.4	2.011	1.092	182.3	40.301	534.1	2.008	1.094	182.0	150	37.567	540.1	2.026	1.035	184.1	38.614	539.8	2.024	1.096	183.8	39.684	539.6	2.021	1.098	183.5	155	37.013	545.6	2.039	1.099	185.6	38.044	545.3	2.036	1.101	185.3	39.056	545.1	2.034	1.102	185.0	160	36.482	551.1	2.051	1.104	187.1	37.483	551.0	2.049	1.105	185.8	38.520	550.8	2.047	1.106	186.5	165	35.961	556.6	2.064	1.108	188.6	36.958	556.4	2.062	1.110	185.3	37.974	556.2	2.059	1.111	188.0	170	66.225	423.8	1.709	1.220	136.6	68.262	423.3	1.719	1.216	138.0	70	63.657	429.5	1.727	1.192	143.3	65.927	429.1	1.723	1.199	139.2	65.639	434.2	1.737	1.181	141.6	60	61.419	435.7	1.745	1.154	143.6	63.515	435.0	1.741	1.167	142.6	63.453	442.1	1.755	1.155	144.8	65	59.436	441.4	1.762	1.123	149.6	61.426	441.8	1.758	1.144	145.8	61.454	448.9	1.771	1.136	147.9	70	57.656	447.0	1.778	1.107	149.5	59.521	446.4	1.775	1.126	148.7	59.654	451.4	1.789	1.121	150.7	75	56.041	452.6	1.794	1.104	152.2	57.817	452.0	1.791	1.112	151.4	58.015	457.0	1.804	1.109	153.3	80	54.562	458.1	1.810	1.095	154.7	56.256	457.6	1.807	1.102	154.0	56.522	462.5	1.819	1.104	155.2	85	53.199	463.5	1.825	1.088	157.1	54.822	463.0	1.822	1.094	155.5	55.126	468.0	1.834	1.094	158.2	90	51.944	468.9	1.840	1.083	159.4	53.529	463.5	1.827	1.089	158.8	53.843	473.5	1.849	1.089	160.5	95	50.773	474.4	1.855	1.080	161.6	52.279	473.9	1.852	1.084	161.1	53.843	473.5	1.849	1.089	160.5	100	49.667	479.7	1.870	1.078	163.7	51.133	473.3	1.867	1.082	163.2	52.659	478.9	1.864	1.086	162.7	105	48.635	485.1	1.884	1.076	165.8	50.055	484.7	1.881	1.080	165.3	51.517	484.4	1.878	1.084	164.8	110	47.658	490.5	1.899	1.075	167.7	49.045	490.1	1.895	1.080	167.3	50.462	489.8	1.893	1.083	166.8	115	46.737	495.3	1.912	1.077	169.6	48.028	495.0	1.903	1.080	169.2	49.473	495.2	1.907	1.083	169.3	120	45.870	501.3	1.926	1.078	171.5	47.174	500.9	1.923	1.081	171.1	48.517	500.6	1.921	1.084	170.6	125	45.042	506.7	1.940	1.080	173.3	45.315	500.4	1.937	1.085	172.9	47.507	506.0	1.934	1.086	172.3	130	44.253	512.1	1.952	1.082	175.3	43.958	511.7	1.950	1.089	174.7	46.778	511.5	1.948	1.087	174.0	135	43.495	517.5	1.966	1.085	177.1	42.714	517.2	1.961	1.091	176.4	45.950	510.9	1.941	1.090	175.2	140	42.769	522.9	1.980	1.088	179.4	41.654	522.7	1.977	1.090	177.1	45.190	520.4	1.974	1.092	177.7	145	42.082	529.4	1.993	1.090	182.7	40.240	528.7	1.990	1.094	179.7	44.440	520.3	1.960	1.090	179.4	150	41.418	534.9	2.006	1.096	181.7	42.555	533.6	2.003	1.097	181.3	43.730	523.3	2.007	1.099	181.0	155	40.777	539.3	2.019	1.099	183.2	41.522	539.1	2.016	1.101	182.9	43.050	538.8	2.014	1.103	182.6	160	40.168	544.8	2.031	1.104	184.9	41.269	544.6	2.029	1.105	184.5	42.394	544.3	2.026	1.107	184.2	165	39.575	550.4	2.044	1.108	186.3	40.660	550.1	2.042	1.109	185.0	41.762	549.9	2.039	1.111	185.7	170	39.004	555.9	2.057	1.112	188.6	40.087	555.7	2.054	1.114	187.5	41.152	555.5	2.052	1.115	187.2	175	70.727	427.4	1.715	1.235	136.8	73.314	426.5	1.711	1.258	135.6	76.035	425.6	1.706	1.282	134.3	60	67.976	431.1	1.733	1.197	140.5	70.353	432.7	1.729	1.214	139.4	72.839	431.9	1.725	1.232	138.2	65	65.580	439.4	1.751	1.158	143.9	67.792	438.7	1.747	1.181	142.9	70.095	437.2	1.744	1.196	141.9	70	63.457	445.2	1.768	1.146	147.0	65.536	444.5	1.764	1.157	145.1	67.694	443.8	1.761	1.169	145.2	75	61.554	450.9	1.784	1.129	149.9	63.520	450.3	1.781	1.139	149.1	65.557	449.6	1.778	1.149	148.2	80	59.832	456.5	1.800	1.117	152.6	61.705	455.9	1.797	1.125	151.8	63.635	455.3	1.794	1.133	151.1	85	58.252	462.0	1.816	1.107	155.1	60.040	461.5	1.813	1.114	154.4	61.883	461.0	1.810	1.121	153.7	90	56.795	467.5	1.831	1.100	157.6	58.505	467.1	1.829	1.105	156.9	60.292	466.6	1.825	1.112	156.3	95	55.453	473.0	1.846	1.095	159.9	57.101	472.6	1.843	1.100	159.3	58.604	472.1	1.840	1.106	158.7	100	54.195	478.5	1.861	1.091	162.1	55.791	478.1	1.858	1.096	161.5	57.436	477.6	1.855	1.101	161.0	105	53.016	483.9	1.876	1.089	164.3	54.553	483.5	1.873	1.093	163.7	56.156	483.1	1.870	1.097	163.2	110	51.923	489.4	1.890	1.087	166.3	53.414	489.0	1.887	1.091	165.8	54.953	488.6	1.884	1.095	165.3	115	50.875	494.8	1.904	1.087	168.3	52.329	494.4	1.901	1.090	167.8	53.828	484.1	1.898	1.094	167.3	120	49.900	500.3	1.913	1.087	170.2	51.313	499.9	1.915	1.091	169.7	52.766	499.5	1.912	1.094	169.3	125	48.970	505.7	1.932	1.088	172.1	50.345	505.3	1.929	1.091	171.8	51.751	505.0	1.928	1.094	171.2	130	48.080	511.1	1.945	1.090	173.9	49.423	510.8	1.943	1.093	173.5	50.798	510.5	1.940	1.096	173.1	135	47.237	516.6	1.959	1.092	175.6	48.549	516.3	1.955	1.095	175.3	49.892	516.0	1.953	1.097	174.9	140	46.440	522.1	1.972	1.095	177.4	47.721	521.8	1.969	1.097	177.0	49.025	521.4	1.967	1.100	176.6	145	45.667	527.5	1.985	1.099	179.1	46.916	527.2	1.983	1.100	178.7	48.205	526.9	1.980	1.102	178.3	150	44.925	533.0	1.998	1.101	180.7	46.159	532.8	1.996	1.103	180.4	47.408	532.5	1.993	1.105	180.0	155	44.222	538.6	2.011	1.105	182.3	45.425	538.3	2.009	1.107	182.0	46.651	538.0	2.006	1.109	181.7	160	43.542	544.1	2.024	1.109	183.9	44.722	543.8	2.022	1.110	183.6	45.924	543.6	2.019	1.112	183.3	165	42.894	549.6	2.037	1.113	185.4	44.042	549.4	2.034	1.114	185.1	45.221	549.1	2.032	1.116	184.9	170	42.261	555.2	2.049	1.117	187.0	43.394	555.0	2.047	1.118	186.7	44.550	554.7	2.045	1.120	186.4	175	41.652	560.8	2.062	1.121	188.4	42.789	560.6	2.060	1.123	186.2	43.900	560.3	2.057	1.124	187.9

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	[p]=0.68 bar (ts=38°C)					[p]=0.91 bar (ts=39°C)					[p]=1.08 bar (ts=40°C)					t
	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	
40	46.659	421.1	1.720	1.098	142.3	48.330	420.4	1.716	1.110	141.4	50.072	419.8	1.712	1.123	143.4	40
45	45.164	426.5	1.737	1.079	145.2	46.739	425.9	1.734	1.073	144.4	48.376	425.3	1.730	1.120	143.5	45
50	43.818	431.9	1.754	1.065	147.9	45.313	431.3	1.750	1.074	147.2	46.863	430.8	1.747	1.083	146.4	50
55	42.535	437.2	1.770	1.054	150.5	44.021	436.7	1.767	1.062	149.8	45.437	436.2	1.763	1.070	149.1	55
60	41.475	442.4	1.786	1.047	152.9	42.847	442.0	1.783	1.053	152.3	44.252	441.5	1.779	1.060	151.6	60
65	40.440	447.6	1.802	1.041	155.3	41.755	447.2	1.798	1.047	154.7	43.110	446.9	1.795	1.050	154.0	65
70	39.460	452.8	1.817	1.037	157.5	40.745	452.4	1.814	1.042	156.9	42.054	452.0	1.811	1.047	156.3	70
75	38.585	458.0	1.832	1.033	159.5	39.815	457.6	1.829	1.039	159.1	41.077	457.2	1.826	1.044	158.5	75
80	37.750	463.2	1.847	1.030	161.5	38.950	462.8	1.844	1.037	161.1	40.159	462.8	1.841	1.042	160.6	80
85	36.965	468.4	1.861	1.028	163.5	38.115	468.0	1.858	1.037	163.1	39.297	467.7	1.855	1.041	162.6	85
90	36.225	473.5	1.875	1.034	165.5	37.339	473.2	1.873	1.037	165.0	38.491	472.9	1.870	1.041	164.5	90
95	35.521	478.7	1.890	1.035	167.3	36.610	478.4	1.887	1.038	166.9	37.723	478.1	1.894	1.041	166.5	95
100	34.850	483.9	1.904	1.037	169.1	35.914	483.6	1.901	1.040	168.7	37.000	483.3	1.898	1.043	168.3	100
105	34.217	489.1	1.917	1.040	170.9	35.256	488.8	1.915	1.040	170.5	36.319	488.5	1.912	1.045	170.1	105
110	33.615	494.3	1.931	1.043	172.6	34.623	494.0	1.929	1.045	172.2	35.662	493.7	1.926	1.047	171.8	110
115	33.037	499.5	1.945	1.046	174.2	34.022	499.2	1.942	1.048	173.9	35.037	499.0	1.939	1.050	173.5	115
120	32.483	504.7	1.958	1.050	175.8	33.451	504.5	1.955	1.052	175.5	34.443	504.2	1.953	1.054	175.2	120
125	31.952	510.0	1.971	1.054	177.4	32.901	509.8	1.969	1.056	177.1	33.873	509.5	1.966	1.058	176.8	125
130	31.444	515.3	1.984	1.058	179.0	32.374	515.0	1.982	1.060	178.7	33.326	514.8	1.979	1.062	178.4	130
135	30.956	520.6	1.998	1.063	180.5	31.866	520.4	1.995	1.064	180.2	32.803	520.1	1.992	1.066	180.0	135
140	30.483	525.9	2.011	1.067	182.0	31.382	525.7	2.008	1.069	181.7	32.295	525.5	2.005	1.070	181.5	140
145	30.030	531.3	2.023	1.072	183.5	30.913	531.0	2.021	1.073	183.2	31.811	530.8	2.018	1.075	183.0	145
150	29.593	536.6	2.036	1.077	184.9	30.460	536.4	2.034	1.078	184.7	31.343	536.2	2.031	1.080	184.4	150
155	29.171	542.0	2.049	1.082	186.4	30.023	541.8	2.046	1.083	186.1	30.893	541.6	2.044	1.085	185.9	155
160	28.765	547.4	2.061	1.087	187.8	29.591	547.3	2.059	1.088	187.5	30.452	547.1	2.056	1.090	187.3	160
45	50.077	424.7	1.726	1.112	142.6	51.848	424.0	1.722	1.124	141.7	53.532	423.4	1.718	1.138	142.7	45
50	49.470	430.2	1.743	1.092	145.6	50.138	429.6	1.740	1.103	144.7	51.871	429.0	1.735	1.114	143.9	50
55	47.024	435.6	1.760	1.078	148.3	48.606	435.1	1.756	1.087	147.6	50.246	434.5	1.751	1.096	145.8	55
60	45.711	441.0	1.775	1.067	150.9	47.219	440.5	1.773	1.074	150.2	48.780	439.9	1.769	1.082	149.5	60
65	44.509	446.3	1.792	1.059	153.4	45.953	445.8	1.789	1.065	152.7	47.445	445.3	1.785	1.072	152.1	65
70	43.400	451.6	1.807	1.053	155.7	44.788	451.1	1.804	1.058	155.1	46.220	450.7	1.801	1.064	154.5	70
75	42.371	456.9	1.823	1.049	158.0	43.705	456.4	1.820	1.054	157.4	45.090	455.3	1.815	1.059	156.8	75
80	41.411	462.1	1.838	1.046	160.1	42.707	461.7	1.835	1.050	159.6	44.020	460.3	1.832	1.055	159.0	80
85	40.519	467.3	1.852	1.045	162.1	41.762	466.9	1.849	1.049	161.7	43.050	465.5	1.846	1.053	161.1	85
90	39.671	472.5	1.867	1.044	164.1	40.884	472.2	1.864	1.048	163.7	42.136	470.8	1.861	1.052	163.2	90
95	38.878	477.7	1.881	1.045	166.1	40.056	477.4	1.878	1.048	165.6	41.268	477.1	1.875	1.051	165.2	95
100	38.124	483.0	1.895	1.046	167.9	39.271	482.6	1.892	1.049	167.5	40.449	482.3	1.890	1.052	167.1	100
105	37.403	488.2	1.909	1.048	169.7	38.529	487.9	1.906	1.050	169.3	39.676	487.6	1.904	1.053	168.9	105
110	36.724	493.4	1.923	1.050	171.5	37.817	493.1	1.920	1.052	171.1	38.942	492.8	1.917	1.055	170.7	110
115	36.076	498.7	1.935	1.053	173.2	37.146	498.4	1.934	1.055	172.8	38.233	498.1	1.931	1.059	172.5	115
120	35.459	504.0	1.950	1.056	174.9	36.505	503.7	1.947	1.058	174.5	37.575	503.4	1.945	1.060	174.2	120
125	34.869	509.3	1.963	1.060	176.5	35.888	509.0	1.961	1.060	176.2	36.935	509.1	1.958	1.064	175.8	125
130	34.303	514.6	1.977	1.063	178.1	35.302	514.3	1.974	1.063	177.8	36.328	514.1	1.971	1.067	177.5	130
135	33.755	519.9	1.991	1.067	179.7	34.740	519.6	1.987	1.066	179.4	35.740	519.4	1.988	1.071	179.1	135
140	33.233	525.2	2.005	1.072	181.2	34.199	525.0	2.000	1.070	180.9	35.177	524.6	1.995	1.075	180.6	140
145	32.743	530.6	2.016	1.076	182.7	33.679	530.4	2.013	1.075	182.4	34.639	530.1	2.011	1.079	182.2	145
150	32.249	536.0	2.028	1.081	184.2	33.170	535.8	2.026	1.080	183.9	34.123	535.0	2.023	1.084	183.7	150
155	31.780	541.4	2.041	1.086	185.6	32.685	541.2	2.039	1.087	185.4	33.619	541.0	2.035	1.089	185.1	155
160	31.327	546.9	2.054	1.091	187.0	32.221	546.7	2.051	1.092	186.8	33.139	546.4	2.049	1.093	186.6	160
165	30.890	552.3	2.066	1.095	188.5	31.772	552.1	2.064	1.097	188.3	32.670	551.9	2.061	1.098	188.0	165
45	55.617	422.6	1.715	1.152	139.7	57.629	421.9	1.711	1.168	138.6	59.503	422.0	1.725	1.152	141.0	45
50	53.672	428.3	1.732	1.126	142.9	55.550	427.7	1.728	1.139	142.0	57.547	432.7	1.742	1.129	144.2	50
55	51.946	433.9	1.749	1.106	145.9	53.713	433.3	1.746	1.116	145.1	55.804	438.2	1.759	1.109	147.1	55
60	50.395	439.4	1.766	1.091	148.7	52.070	438.8	1.763	1.100	148.0	54.232	443.8	1.775	1.095	149.9	60
65	48.987	444.8	1.782	1.079	151.4	50.583	444.3	1.779	1.087	150.6	52.801	449.2	1.791	1.084	152.5	65
70	47.697	450.2	1.798	1.071	153.8	49.225	449.7	1.795	1.077	153.2	51.499	454.6	1.807	1.077	154.9	70
75	46.514	455.5	1.813	1.065	156.2	47.980	455.1	1.810	1.070	155.6	50.283	460.0	1.822	1.071	157.3	75
80	45.404	460.9	1.829	1.060	158.5	46.827	460.4	1.825	1.065	157.9	49.148	465.3	1.837	1.067	159.5	80
85	44.383	466.1	1.843	1.057	160.8	45.749	465.7	1.840	1.062	160.1	48.093	470.6	1.852	1.064	161.6	85
90	43.422	471.4	1.858	1.056	162.7	44.741	471.0	1.855	1.060	162.2	47.099	475.9	1.867	1.063	163.7	90
95	42.512	476.7	1.872	1.055	164.7	43.798	476.3	1.870	1.059	164.2	46.116	481.2	1.881	1.062	165.7	95
100	41.661	482.0	1.887	1.055	166.6	42.914	481.6	1.884	1.059	166.2	45.191	486.5	1.895	1.062	167.6	100
105	40.856	487.2	1.901	1.056	168.5	42.066	486.9	1.898	1.059	168.1	44.316	491.9	1.909	1.064	169.5	105
110	40.090	492.5	1.915	1.058	170.3	41.259	492.2	1.912	1.061	169.9	43.488	497.2	1.923	1.065	171.3	110
115	39.364	497.8	1.928	1.060	172.1	40.520	497.5	1.926	1.063	171.7	42.699	502.5	1.937	1.068	173.1	115
120	38.669	503.1	1.942	1.063	173.8	39.801	502.8	1.939	1.065	173.4	41.949	507.9	1.950	1.070	174.8	120
125	38.013	508.5	1.955	1.066	175.5	39.114	508.2	1.953	1.068	175.1	41.239	513.2	1.963	1.073	176.5	125
130	37.380	513.8	1.969	1.069	177.1	38.458	513.5	1.966	1.071	176.8	40.559	518.6	1.977	1.077	178.1	130
135	36.771	519.1	1.982	1.072	178.8	37.825	518.9	1.979	1.075	178.4	39.903	524.0	1.989	1.081	179.7	135
140	36.185	524.5	1.995	1.077	180.3	37.224	524.3	1.992	1.079	180.0	39.278	529.4	1.999			

TABLE II: SUPERHEATED VAPOUR PROPERTIES - SUVA HFC - 134a

t	[p] = kg/m ²					[ρ] = kg/m ³					[c _p] = MJ/(kg·K)					[α] = mm ² /s					Saturation temperature in brackets									
	p	h	s	cp	c	ρ	h	s	cp	c	α	h	s	cp	c	α	h	s	cp	c	t									
	ps=15.29 bar (ts=58°C)										ps=15.67 bar (ts=57°C)										ps=16.05 bar (ts=56°C)									
50	75.443	433.3	1.721	1.252	133.1	79.177	432.1	1.717	1.274	135.8	81.051	429.1	1.713	1.298	134.5						60									
55	72.499	431.3	1.743	1.212	140.5	75.009	435.3	1.736	1.229	133.7	77.631	435.5	1.732	1.247	138.6						65									
60	69.950	443.1	1.757	1.182	144.3	72.000	442.4	1.754	1.195	143.2	74.693	441.5	1.750	1.210	142.2						70									
65	67.624	445.0	1.770	1.154	147.3	69.459	449.7	1.771	1.164	146.4	72.122	447.5	1.767	1.181	144.5						75									
70	65.634	446.7	1.782	1.128	150.3	67.206	456.1	1.787	1.132	149.4	69.951	455.1	1.784	1.148	146.6						80									
75	63.792	448.2	1.807	1.103	153.0	65.254	459.8	1.803	1.107	152.0	67.801	459.0	1.802	1.124	151.5						85									
80	62.110	449.3	1.822	1.119	155.3	63.973	459.5	1.819	1.106	154.9	65.929	463.9	1.816	1.133	154.2						90									
85	60.620	450.1	1.837	1.119	157.0	62.565	471.1	1.834	1.119	157.4	64.231	470.6	1.831	1.124	156.7						95									
90	59.123	450.7	1.852	1.101	158.4	61.859	476.7	1.849	1.111	159.8	62.643	476.2	1.846	1.107	159.1						100									
95	57.765	450.7	1.867	1.102	161.6	59.467	482.2	1.864	1.107	162.0	61.166	481.0	1.861	1.112	161.4						105									
100	56.531	459.2	1.881	1.099	161.7	58.155	487.7	1.879	1.104	164.2	59.807	481	1.876	1.108	163.7						110									
105	55.253	459.7	1.896	1.094	161.8	56.929	493.3	1.893	1.102	166.3	58.546	492.9	1.893	1.105	165.8						115									
110	54.250	459.1	1.910	1.097	161.8	55.781	498.8	1.907	1.101	168.3	57.343	499.4	1.904	1.105	167.9						120									
115	53.204	503.6	1.924	1.096	170.8	54.681	504.3	1.921	1.101	170.3	56.211	503.9	1.919	1.104	169.9						125									
120	52.212	510.1	1.937	1.099	172.6	53.607	509.8	1.935	1.102	172.2	55.141	509.4	1.932	1.105	171.5						130									
125	51.267	515.6	1.951	1.103	174.5	52.672	515.3	1.948	1.103	174.1	54.125	514.9	1.946	1.105	173.6						135									
130	50.368	521.1	1.964	1.102	176.2	51.751	520.8	1.962	1.105	175.9	53.157	520.5	1.959	1.107	175.5						140									
135	49.517	526.6	1.978	1.103	178.0	50.830	526.3	1.975	1.107	177.6	52.235	526.0	1.972	1.109	177.2						145									
140	48.689	532.2	1.991	1.107	179.7	50.009	531.9	1.988	1.110	179.3	51.360	531.6	1.986	1.112	179.0						150									
145	47.908	537.7	2.004	1.111	181.3	49.197	537.4	2.001	1.113	181.0	50.517	537.1	1.999	1.115	180.7						155									
150	47.158	543.3	2.017	1.114	183.0	48.416	543.0	2.014	1.116	182.6	49.705	542.7	2.012	1.113	182.3						160									
155	46.432	548.9	2.029	1.118	184.5	47.674	548.6	2.027	1.120	184.2	49.035	548.3	2.025	1.121	183.9						165									
160	45.737	554.5	2.042	1.122	186.1	46.955	554.2	2.040	1.123	185.8	48.389	553.9	2.037	1.125	185.5						170									
165	45.065	560.1	2.055	1.126	187.5	46.250	559.8	2.052	1.127	187.4	47.747	559.5	2.053	1.123	187.1						175									
170	44.425	565.7	2.067	1.130	189.1	45.535	565.5	2.065	1.131	189.9	45.784	565.2	2.063	1.133	188.6						180									
	ps=16.43 bar (ts=59°C)										ps=16.83 bar (ts=60°C)										ps=17.23 bar (ts=61°C)									
50	84.082	428.1	1.728	1.326	133.1	87.285	427.1	1.704	1.356	131.7											60									
55	80.340	434.6	1.729	1.258	137.4	83.253	433.7	1.724	1.290	136.1	86.297	431.7	1.719	1.316	134.8						65									
60	77.233	440.8	1.746	1.225	141.1	79.877	440.0	1.742	1.244	140.0	82.643	439.2	1.738	1.262	138.8						70									
65	74.456	446.9	1.764	1.194	144.5	76.953	446.2	1.762	1.209	143.5	79.513	446.4	1.757	1.224	142.5						75									
70	72.075	452.8	1.780	1.170	147.7	74.381	452.1	1.777	1.184	146.8	76.775	451.4	1.773	1.196	145.9						80									
75	69.911	458.6	1.797	1.153	150.6	72.087	458.0	1.793	1.164	149.8	74.342	457.3	1.790	1.175	149.0						85									
80	67.943	464.4	1.813	1.141	153.4	70.010	463.8	1.810	1.150	152.6	72.158	463.2	1.806	1.159	151.9						90									
85	66.147	470.0	1.828	1.131	156.0	68.129	469.5	1.825	1.138	155.3	70.175	469.9	1.822	1.146	154.5						95									
90	64.423	475.7	1.840	1.123	158.5	66.392	475.2	1.840	1.129	157.8	68.347	474.5	1.837	1.131	157.1						100									
95	62.966	481.3	1.858	1.117	160.8	64.778	480.8	1.855	1.123	160.2	66.656	480.3	1.853	1.129	159.5						105									
100	61.529	486.9	1.873	1.113	163.1	63.294	486.4	1.870	1.119	162.5	65.106	485.9	1.867	1.123	161.9						110									
105	60.202	492.4	1.887	1.110	165.3	61.904	492.0	1.885	1.115	164.7	63.654	491.5	1.882	1.119	164.2						115									
110	58.952	498.0	1.902	1.109	167.3	60.608	497.5	1.899	1.113	166.8	62.295	497.1	1.895	1.117	165.3						120									
115	57.773	503.5	1.915	1.108	169.4	59.374	503.1	1.913	1.111	168.3	61.014	502.7	1.910	1.115	164.4						125									
120	56.656	509.0	1.929	1.109	171.3	58.219	508.7	1.927	1.111	170.3	59.811	508.3	1.924	1.115	170.4						130									
125	55.609	514.5	1.941	1.109	173.0	57.124	514.2	1.940	1.110	172.3	58.671	513.9	1.929	1.116	172.3						135									
130	54.594	520.1	1.957	1.110	174.7	56.078	519.8	1.954	1.113	174.1	57.593	519.4	1.951	1.116	174.2						140									
135	53.541	525.7	1.970	1.112	176.3	55.094	525.3	1.967	1.114	176.5	56.560	525.0	1.963	1.117	176.1						145									
140	52.455	531.2	1.982	1.114	177.8	54.141	530.9	1.981	1.117	178.2	55.594	530.5	1.976	1.119	177.6						150									
145	51.340	536.7	1.993	1.117	179.3	53.245	536.5	1.994	1.119	179.9	54.646	536.1	1.991	1.121	178.6						155									
150	50.310	542.4	2.009	1.120	180.8	52.376	542.1	2.007	1.120	181.6	53.759	541.7	2.004	1.124	181.3						160									
155	49.223	548.0	2.022	1.123	182.0	51.540	547.7	2.020	1.121	183.3	52.907	547.4	2.017	1.127	183.0						165									
160	48.155	553.6	2.035	1.127	183.2	50.751	553.4	2.033	1.123	184.9	52.079	553.1	2.030	1.130	184.5						170									
165	47.220	559.3	2.048	1.131	184.8	49.985	559.0	2.045	1.132	186.5	51.290	558.7	2.043	1.134	186.2						175									
170	46.022	565.0	2.060	1.134	186.3	49.252	564.7	2.058	1.135	188.0	50.532	564.4	2.055	1.136	187.7						180									
	ps=17.54 bar (ts=62°C)										ps=18.05 bar (ts=63°C)										ps=18.47 bar (ts=64°C)									
65	89.495	431.7	1.715	1.343	131.4	92.676	430.6	1.710	1.374	131.9	96.453	429.5	1.706	1.409	130.4						65									
70	85.540	438.2	1.734	1.283	137.6	88.580	437.3	1.730	1.306	136.4	91.768	436.3	1.725	1.331	135.0						70									
75	82.181	444.6	1.752	1.241	141.4	84.967	443.7	1.749	1.258	140.3	87.872	442.9	1.745	1.277	139.2						75									
80	79.262	450.7	1.770	1.209	144.9	81.849	449.9	1.766	1.223	143.9	84.535	449.1	1.763	1.239	142.8						80									
85	76.685	456.7	1.787	1.186	148.1	79.																								

TABLE II: SUPERHEATED VAPOUR PROPERTIES SUVA HFC - 134a

t	[p] = bar					[h] = kJ/kg					[s] = kJ/(kg·K)					[cp] = kJ/(kg·K)					[c] = J/(kg·K)					[ρ] = kg/m ³					Saturation temperature in brackets															
	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	p	h	s	cp	c	t															
	ps=23.13 bar (ts=74°C)															ps=23.64 bar (ts=75°C)															ps=24.16 bar (ts=76°C)															
75	127.64	431.1	1.699	1.657	123.9	133.37	429.5	1.692	1.739	121.8						129.57	436.2	1.721	1.675	126.3																75										
80	119.73	439.0	1.721	1.502	123.8	124.47	437.7	1.716	1.550	129.1						129.57	436.2	1.721	1.675	126.3																80										
85	112.57	446.3	1.741	1.407	134.7	117.70	445.1	1.737	1.433	133.3						122.05	443.9	1.732	1.476	131.6																85										
90	108.50	453.1	1.760	1.343	133.0	112.27	452.1	1.755	1.366	137.6						116.11	451.1	1.752	1.333	135.5																90										
95	104.23	459.7	1.775	1.287	140.9	107.62	458.8	1.774	1.315	141.8						111.14	457.1	1.771	1.335	142.7																95										
100	100.50	466.1	1.788	1.263	146.5	103.64	465.3	1.792	1.278	145.5						106.92	464.4	1.788	1.253	144.4																100										
105	97.21	472.4	1.812	1.237	149.7	101.16	471.5	1.809	1.249	143.8						103.19	470.8	1.812	1.222	147.3																105										
110	94.25	478.5	1.829	1.217	152.6	97.94	477.9	1.825	1.227	151.9						99.99	477.1	1.829	1.208	151.1																110										
115	91.52	484.5	1.844	1.202	155.6	94.92	483.3	1.841	1.210	154.9						96.95	482.2	1.839	1.222	154.1																115										
120	89.15	490.5	1.859	1.190	158.3	91.53	489.9	1.855	1.197	157.5						94.27	489.3	1.853	1.215	156.9																120										
125	86.92	496.4	1.874	1.180	160.5	89.35	495.9	1.871	1.187	160.2						91.82	495.3	1.869	1.194	159.5																125										
130	84.85	502.3	1.889	1.173	163.3	87.18	501.3	1.868	1.173	162.7						89.55	501.2	1.862	1.195	162.1																130										
135	82.93	508.2	1.903	1.167	165.7	85.17	507.7	1.901	1.173	165.1						87.45	507.1	1.899	1.179	164.5																135										
140	81.14	514.1	1.917	1.164	167.9	83.25	513.5	1.915	1.163	167.4						85.51	513.0	1.912	1.173	166.8																140										
145	79.45	519.8	1.931	1.161	170.1	81.54	519.3	1.929	1.165	169.5						83.69	519.3	1.925	1.170	169.0																145										
150	77.85	525.6	1.945	1.159	172.2	79.89	525.2	1.943	1.163	171.7						81.96	524.7	1.943	1.167	171.2																150										
155	76.36	531.4	1.959	1.159	174.2	78.33	531.0	1.956	1.162	173.7						80.34	530.5	1.954	1.165	173.2																155										
160	74.94	537.2	1.972	1.159	176.1	76.86	536.8	1.970	1.162	175.7						78.81	536.4	1.967	1.165	172.5																160										
165	73.59	543.0	1.986	1.159	178.1	75.46	542.5	1.983	1.162	177.6						77.37	542.2	1.981	1.165	177.2																165										
170	72.31	548.8	1.999	1.160	179.9	74.13	548.4	1.996	1.163	179.5						75.99	548.0	1.994	1.166	179.1																170										
175	71.09	554.6	2.012	1.162	181.7	72.86	554.2	2.009	1.164	181.3						74.68	553.9	2.007	1.167	180.9																175										
180	69.92	560.4	2.025	1.164	183.5	71.65	560.1	2.022	1.166	183.1						73.43	559.7	2.020	1.169	182.7																180										
185	68.80	566.2	2.037	1.166	185.2	70.49	565.9	2.035	1.165	184.9						72.23	565.5	2.033	1.171	184.5																185										
190	67.72	572.1	2.050	1.169	186.9	69.38	571.7	2.048	1.171	186.6						71.08	571.4	2.046	1.173	186.2																190										
195	66.69	577.9	2.053	1.172	188.5	68.32	577.6	2.060	1.174	188.2						69.99	577.3	2.053	1.175	187.9																195										
	ps=24.69 bar (ts=77°C)															ps=25.23 bar (ts=78°C)															ps=25.77 bar (ts=79°C)															
80	135.07	434.7	1.705	1.673	124.4	141.07	433.0	1.699	1.754	122.3						147.66	431.2	1.693	1.855	120.1																80										
85	126.73	442.6	1.727	1.517	130.2	131.69	441.3	1.723	1.565	128.6						137.02	439.9	1.717	1.620	126.8																85										
90	120.21	450.0	1.742	1.421	135.2	124.54	448.8	1.743	1.454	133.8						129.12	447.5	1.739	1.490	132.3																90										
95	114.87	456.9	1.757	1.357	139.5	118.74	455.9	1.763	1.380	135.3						122.85	454.5	1.759	1.427	137.0																95										
100	110.32	463.6	1.785	1.310	143.4	113.95	462.7	1.781	1.329	142.3						117.59	461.7	1.787	1.349	141.2																100										
105	106.38	470.0	1.802	1.276	145.9	109.55	469.2	1.799	1.291	145.9						113.09	468.3	1.795	1.355	144.3																105										
110	102.88	476.3	1.818	1.250	150.2	105.97	475.6	1.815	1.252	149.3						109.16	474.8	1.812	1.275	149.4																110										
115	99.77	482.5	1.835	1.229	153.3	102.69	481.8	1.831	1.240	152.4						105.69	481.1	1.828	1.250	151.5																115										
120	96.94	488.5	1.852	1.213	156.1	99.71	488.0	1.847	1.222	155.4						102.55	480.3	1.844	1.232	154.5																120										
125	94.37	494.7	1.868	1.201	158.8	97.01	494.1	1.852	1.209	158.1						99.72	493.4	1.859	1.217	157.4																125										
130	92.01	500.7	1.880	1.192	161.4	94.53	500.1	1.877	1.198	160.7						97.12	499.5	1.875	1.235	160.1																130										
135	89.82	506.6	1.895	1.184	163.9	92.24	505.0	1.892	1.190	163.2						94.73	505.5	1.889	1.196	162.6																135										
140	87.78	512.5	1.909	1.179	166.2	90.11	512.0	1.907	1.184	165.5						92.51	511.4	1.904	1.189	165.0																140										
145	85.88	518.4	1.924	1.174	168.5	88.13	517.9	1.921	1.179	167.9						90.45	517.4	1.918	1.184	167.4																145										
150	84.09	524.2	1.937	1.172	170.6	85.27	523.8	1.935	1.176	170.1						88.51	523.3	1.932	1.182	169.5																150										
155	82.41	530.1	1.951	1.170	172.7	84.52	529.5	1.943	1.174	172.3						86.70	529.0	1.945	1.179	171.7																155										
160	80.82	535.9	1.965	1.169	174.8	82.83	535.5	1.962	1.172	174.5						84.99	535.1	1.962	1.179	171.2																160										
165	79.32	541.5	1.979	1.168	176.8	81.32	541.4	1.975	1.170	176.3						83.37	540.9	1.973	1.173	175.5																165										
170	77.89	547.6	1.992	1.169	178.7	79.84	547.2	1.982	1.170	178.2						81.84	546.6	1.977	1.175	177.5																170										
175	76.53	553.5	2.005	1.170	180.5	78.44	552.7	2.002	1.173	180.1						80.38	552.1	2.002	1.179	177.7																										

SPECIFIC ENTHALPY (kJ/kg) ENTHALPIE SPÉCIFIQUE (kJ/kg) SPEZIFISCHE ENTHALPIE (kJ/kg)

100 120 140 160 180 200 220 240 260 280 300 320 340 360 380 400 420 440 460 480 500 520 540 560 580 600


PRESSURE (bar) PRESSION (bar) DRUCK (bar)

PRESSURE (MPa) PRESSION (MPa) DRUCK (MPa)

SUVA
Refrigerant
Kältemittel
DU PONT

PRESSURE ENTHALPY
of
SUVA Refrigerant
HFC-134a
© Du Pont de Nemours

CRITICAL POINT
POINT CRITIQUE
KRITISCHER PUNKT



SPECIFIC ENTHALPY (kJ/kg) ENTHALPIE SPÉCIFIQUE (kJ/kg) SPEZIFISCHE ENTHALPIE (kJ/kg)

100 120 140 160 180 200 220 240 260 280 300 320 340 360 380 400 420 440 460 480 500 520 540 560 580 600




R134a application guide lines



Americold



ZANUSSI
ELETTROMECCANICA
T.I.A. N.J.M.
COMPRESSOR
COMPANY



Introduction

The replacement of R 12 refrigerant involves the revision of material and operating procedures presently used, often based on experience, all designed to achieve high system performance and

reliability.

The following notes are written, not as an exhaustive application manual, but as a foundation to good practice to be used as a check to identify and create production process compatibility.

Compressor

Only R 134a refrigerant must be used.

R 134a compressors are filled with a synthetic ester oil because the new refrigerant is not compatible with the lubricants presently used in R 12 compressors.

Ester oil must not be mixed nor refilled with any other lubricant. Ester oil is more hygroscopic than the lubricants presently used. Under no circumstances can the compressor be left with open pipes for more than 15 minutes.

When the pipes are open, immediately prior to coupling into the system, they should be protected from any source of forced air circulation.

Our production system limits water content in the compressor, before charging with oil, to a maximum of 100 mg. The water content of the ester oil is held to a maximum of 60 ppm.

Ester oil can cause irritation and contact with eyes and skin is to be avoided. Ensure adequate ventilation of the work area at all times.

For given operating conditions the discharge temperature of R 134a is about 10°C lower than R 12 which, because ester oil has a better thermal stability than the mineral oil, means that these factors give a better protection against the valve coking.

Refrigerating circuit

Tests on existing appliances have shown that the basic design of condenser and evaporator can be maintained.

There will be occasions where a larger condenser is advisable to reduce a discharge pressure peak caused by slightly higher load during pull down.

A modification in capillary length, usually an increase in length, is sometimes advisable as some appliances benefit from a reduction in capillary flow rate.

The optimum refrigerant charge for R 134a is usually 10-20% lower than R 12.

A longer pressure equalization time is usually required.

The dryers used in R 12 systems are not

compatible with R 134a, a suitable dryer (3 Å molecular sieve) is required (XH - 7 type or equivalent).

The dryer size has to be checked against the higher hygroscopicity of ester oil.

Ester oil has a satisfactory mixability with R 134a but not as good as that between mineral oil and R 12. For this reason the potential oil accumulation within the system has to be evaluated. For instance, the use of parallel channels in the evaporator should be reduced where ever possible.

Oil retention pockets and oversized cross sections, reducing fluid flow speed, have to be avoided.

Compatibility

The use of any products containing chlorine in the refrigerating circuit production process must be avoided.

The use of chlorinated solvents to wash system components is not allowed. The retrofit of R 134a compressors into R 12 systems is not allowed because it is impossible to avoid contamination between the different oils and refrigerants even after repeated flushing and vacuum procedures. Both the new refrigerant and ester oil make more severe demands on the purity requirements for the refrigerating circuit as far as soluble substances are concerned.

DIN 8964 allows up to 40 mg/m² of soluble substances on inner surfaces. In R 134a systems these substances can only be mineral oils with pour point compatible with the evaporating temperature.

Any grease, wax, paraffin, and generally, high viscosity substances must be avoided because their presence risks clogging the capillary tube.

The maximum water content of system components must be according to din norm 8964 (max 50 mg/m²).

Note: water is more critical to R 134a system reliability than with R 12 systems since it reduces the chemical stability of ester oil.

The reaction (hydrolysis) between ester and water produces alcohol and acid.

Metals commonly used, as copper, aluminium, steel, cast iron and brass, are compatible with R 134a and ester oil.

Elastomer compatibility must be checked. Some elastomers, for example viton (fluorocarbons), will exhibit, in the presence of R 134a and ester oil, swelling and/or reduction of tensile strength.

Contamination caused by the use of brazing flux must be avoided.

Brazing flux dissolved in water should not be used because of the potential risk of introducing water into the circuit.

Production process

The vacuum procedures and limits used presently can be maintained. Any contamination caused by vacuum pump oil vapour backflow must be avoided, preferably by using a vapour trap, unless compatible lubricants are used in the pump.

In order to prevent any form of contamination the vacuum and filling stations must be dedicated to R 134a.

Since the R 134a molecule is smaller than the R 12 molecule it is essential to recognise that all brazing processes and leak tests need to maintain a high level of integrity.

Most of the leak detectors presently

used detect the presence of chlorine. Since R 134a does not contain chlorine this method can no longer be used. A list of suitable leak detectors is available on request.

Please note that halogen detectors can give false indications because of the presence of CFC's coming from the foam or from other production lines. It is imperative that production, service and maintenance engineers recognise that mineral oils must not be used anywhere within the refrigerating circuit production process. For example, when enlarging tube ends a compatible lubricant (ester oil) must be used.



AZMAYESH INDUSTRIAL FACTORIES CO.

PROJECT NO. MP/IRA/94/403

UNIDO,s CONTRACT NO. 94/097



PROGRESS REPORT # 1



PREPARED BY: A. BAHMANI

Date: February 1995



کارخان صنعتی آزمایش

موضوع

نوع نشریه

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

طرح و اجرا - شماره

شماره نشریه : 94 - 097

TABLE OF CONTENTS

	<i>TITLE</i>	<i>PAGE</i>
SECTION I	REFRIGERATION LOAD CALCULATION	1
SECTION II	PRODUCT LOAD CALCULATION	4
SECTION III	REFRIGERATION SYSTEM CONDITION	7
SECTION IV	EQUIPMENT SELECTION	10
SECTION V	REFRIGERATION UNIT GOVERNING LAWS, EQUATIONS AND RELATIONS	11
SECTION VI	REFRIGERATOR MODEL <i>AR06</i> LOAD CALCULATION AND EQUIPMENT SELECTION	17
SECTION VII	REFRIGERATOR MODEL <i>AR08</i> LOAD CALCULATION AND EQUIPMENT SELECTION	31
SECTION IIX	REFRIGERATOR MODEL <i>AR10</i> LOAD CALCULATION AND EQUIPMENT SELECTION	46
SECTION IX	REFRIGERATOR MODEL <i>AR12</i> LOAD CALCULATION AND EQUIPMENT SELECTION	62
SECTION X	REF.FREEZER MODEL <i>ARF2</i> LOAD CALCULATION AND EQUIPMENT SELECTION	77



کارخانجات صنعتی آزمایش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

طرح و بهر نامه

SECTION I

PAGE 1

REFRIGERATOR LOAD CALCULATION

THE GOVERNING LAW AND EQUATION FOR HERMETIC DOMESTIC
REFRIGERATORS ARE AS FOLLOWS .

A. Heat gain through door and cabinet by conduction (Refrigerator compartment) .

$$Q_{TR} = U_{TR} \cdot A_{TR} \cdot \Delta T_{TR}$$

WHERE

Q_{TR} = Total heat gain by conduction in Refrigerator Compartment

U_{TR} = Total coefficient of heat transmission .

ΔT_{TR} = Temperature difference between Ambient temperature and Refrigerator Compartment .

$$U_R = \frac{1}{x_1/K_1 + x_2/K_2 + x_3/K_3 + \dots}$$

x₁ = Carbon steel thickness

x₂ = Foam thickness (Average)

x₃ = Inner liner ABS thickness

K₁ = steel thermal conductivity

K₂ = Foam thermal conductivity

K₃ = Plastic thermal conductivity

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX 98 21 777107

تاریخ وشم—ارده تغییرات :

تاریخ انش—ار :



A_{TR} = Total heat gain surface through Refrigeration Section .

$$A_{TR} = A_1 + A_2 + A_3 + A_4 + A_5$$

$$\Delta_{TR} = (t_a - t_r)$$

$$t_a = 43 \text{ }^\circ\text{C}$$

$$t_r = 5 + 2 \text{ }^\circ\text{C}$$

B. Heat gain through Evaporator compartment by conduction .

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot \Delta_{TE}$$

Where

Q_{TE} = Total heat gain by conduction in Evaporator compartment .

U_{TE} = Total Coefficient of Heat Transmission .

Δ_{TE} = Temperature difference between Ambient temperature and Evaporator compartment.

$$U_{TE} = \frac{1}{X_1/K_1 + X_2/K_2 + X_3/k_3 + X_4/K_4 + X_5/K_5}$$

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

X_1 = Carbon steel thickness

X_2 = Foam thickness

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107



X3 = Inner liner ABS thickness

PAGE 3

X4 = Air thickness between Evaporator and Refrigerator wall

X5 = Evaporator thickness .

K₁ = Steel Thermal conductivity .K₂ = Foam Thermal conductivity.K₃ = Plastic Thermal conductivity.K₄ = Air Thermal conductivity .K₅ = Evaporator (Aluminium) Thermal conductivity .

$$\Delta t_{E2} = t_{a_{max}} - t_E \quad t_{a_{max}} = 43 \text{ } ^\circ\text{C class T} \quad t_E = -12 \text{ } ^\circ\text{C}$$

Note : The designed ambient temperature as per ISO 7371 Para. 16.11 have been considered in refrigeration load calculation .

$$\Delta t_{E2} = t_R - t_E \quad t_R = 5 + 2 \text{ } ^\circ\text{C} \quad t_E = -12 \text{ } ^\circ\text{C}$$

$$A_{t_{E1}} = A_1 + A_2 \quad A_{E2} \quad A_{E3}$$

$$Q_{E1} = U_{E1} * A_{E1} * (t_A - t_E)$$

$$Q_{E2} = U_{E2} * A_{E2} * (t_A - t_E)$$

$$Q_{E3} = U_{E3} * A_{E3} * (t_R - t_E)$$



SECTION II

PRODUCT LOAD CALCULATION

$$Q_{TP} = (W * C * D_{tr}) + (W * C_i * \Delta t_r) + (W * h_{if}) + Q_{TBf}$$

$$\Delta t_r = (t_1 - t_2)$$

$$\Delta t_r = (t_1 - t_f)$$

$$Q_{TP} = Q_{TPR} + Q_{TPf} + Q_{TBf} + Q_{TL}$$

$$Q_{TBf} = W * C_i (t_r - t_3)$$

WHERE

Q_{TP} = Total product heat removal .

Q_{TR} = Product heat removal above freezing point .

Q_{TPf} = Product heat removal below freezing point .

Q_{TL} = Product heat removal by Latent Heat of Fusion .

W = Weight of product .

C = Specific heat above freezing .

t_1 = Initial temperature above freezing .

t_2 = Lower temperature above freezing .

t_3 = Final temperature below freezing .

 $t_f =$ Freezing temperature . $h_{if} =$ Latent heat of fusion . $C_i =$ Specific heat below freezing

$$\text{BTU per 24 hrs} = \frac{\text{Product load} \times 24}{\text{Hrs required for product load}}$$

$$Q_{GT} = Q_{TR} + Q_{TE} + \sum Q_{PR} + \sum Q_{PF} + \sum Q_{LF} + \sum Q_F$$

WHERE

 $Q_{GT} =$ Grand total heat gain per 24 Hrs . $Q_{TR} =$ Heat gain through Refrigerator compartment . $Q_{TE} =$ Heat gain through Evaporator compartment . $\sum Q_{PR} =$ Total heat removed from products above freezing point . $\sum Q_{PF} =$ Total heat removed below freezing point . $\sum Q_{LF} =$ Total heat removed by Latent heat of Fusion . $\sum Q_F =$ Total heat removed at Freezing point .

$$\text{BTU per 24 Hrs.} = \frac{Q_{GT}}{16} = \frac{\text{BTU/hr}}{3.4192} = \text{Watt/hr}$$



TABLE 1

PRODUCT NAME	LATENT HEAT BTU / lb	AVERAGE FREEZING POINT F	SPECIFIC HEAT (C) BTU / lb F	
			ABOVE FREEZING	BELOW FREEZING
WATER	143.5	32.018	0.999	1
VEGETABLE (MIXED)	130	30	0.90	0.45
BEEF	79	29	0.77	0.40
CUT MEET	95	29	0.72	0.40
LAMB	83.5	29	0.67	0.30
BUTTER	15	30	0.64	0.34
CHEESE	86	18	0.70	0.40
LETTUSE	136	31.2	0.96	0.48
LIMES	122	29	0.89	0.46
DATE	112	27.1	0.82	0.43
COT FISH	95	28	0.90	0.49
EGGS	100	27	0.76	0.40
APPLES	121	28.4	0.86	0.45
WATERMELONS	132	29.2	0.97	0.48
PEACHES	124	29.4	0.90	0.46
ORANGES	124	28	0.90	0.46
GRAPEFRUIT	126	28.4	0.91	0.46
PEARS	118	28.5	0.86	0.45
MASHROOMS	130	30.2	0.93	0.47
MILK	4.3-14	31	0.93	0.49



کارخانجات صنعتی آزمایش

موضوع :

نوع نشریه :

**AZMAYESH INDUSTRIAL
FACTORIES COMPANY**

شماره نشریه :

طرح و برنامه

PAGE 7

SECTION III

REFRIGERATOR SYSTEM CONDITION

A . Compressor Condition

- 1 . Inlet Pressure
- 2 . Outlet Pressure
- 3 . Inlet Temperature
- 4 . Outlet Temperature
- 5 . Inlet Entholpy
- 6 . Outlet Entholpy

B . Condenssor Condition

- 1 . Inlet Pressure
- 2 . Outlet pressure
- 3 . Inlet Temperature
- 4 . Outlet Temperature
- 5 . Inlet Entholpy
- 6 . Outlet Entholpy
- 7 . Entholpy Defference Sub-cool
- 8 . Entholpy defference

C . Capillary Tube Condition

- 1 . Inlet temperature
- 2 . outlet Temperature
- 3 . Specific Volume

D . Evaporator Condition

- 1 . Evaporatcr Condition

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107

تاریخ وشمه ————— دارد تغییرات :

تاریخ انتشار ————— ار :



- 2 . Evaporator Outlet Temperature
- 3 . Evaporator Pressure
- 4 . Entholpy at - 25 C
- 5 . Entholpy at 32 C

E . COP = Coeficient of compressor

$$COP = q_1 / W = (h_2 - h_1) / (h_2 - h_s)$$

$$q_1 = h_2 - h_1$$

$$q_2 = h_1 - h_s$$

$$W = h_2 - h_s$$

D . For a typical Compressor capacity of 87 watts , the following figures are found from HFC -134a Refrigerant , Pressure - Entholpy Diagram .

1 - Evaporating pressure at - 25 C	1.067	BAR
2 - Condensing pressure at + 55 C	14.912	BAR
3 - Entholpy h_2 , at -25 C / 32 C	431	kJ/kg
4 - Entholpy h_1 , at 55 C liquid	279	kJ/kg
5 - Entholpy difference $h_2 - h_1$	152	kJ/kg
6 - Compressor Capacity	87	Watts
7 - Mass flow	2.06	kg/h
8 - Gas temperature (outlet)	84	C
9 - Specific volume	0.28	m ³ /kg
10- Volume flow (inlet)	0.57	m ³ /kg
11- Inlet Capillary tube temp.	55	C

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107




Figure 11: Pressure-Enthalpy Diagram for HFC-134a (SI Units).



کارخانجات صنعتی آزمایش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

ط ————— رح و؛ ————— نامه

PAGE 9

11- Inlet Capillary tube temp.	55	C
12- Specific volume	0.927	dm ³ /kg
13- Volume flow	1.91	dm ³ /h
14 - Entholpy h_1 , at 55 C liquid	279	kJ/kg
15- Entholpy h_s , at 32 C liquid	244	kJ/kg
16- Entholpy difference ($h_1 - h_s$)	35	kJ/kg
17- Capacity with Sub-Cooling at 32 C = Mass flow X ($h_2 - h_s$)	385.2	kJ/h
18- Capacity whitout Sob-Cooling = Massflow X ($h_2 - h_1$)	313.1	kJ/h
19- Performance relation = ($h_4 - h_s$) / ($h_2 - h_s$)		

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ وشم ————— ارد تغییرات :

تاریخ انش ————— ار :



SECTION IV

EQUIPMENT SELECTION

The calculated hourly load is used as a guide in selection equipment . However the Compressor Sizes are limited to comparatively large increments .The compressor selection must be guided by the calculated load , and the actual selection of compressor may change the calculation time up or down . The evaporator should be selected to ballance The selected compressor capacity , and not the original calculated load .

The compressor operating time is suggested to be 16 Hours daily . Nevertheless Manufacturers recommendation will be considered during Equipment Selection .

The size of Evaporator and Condenser can be the same as those used for R-12 Refrigerant . sometimes , 10 - 15 % increase of condenser size is recommended . In our case we donot intend to increase the size of our condenser at the first step of our test and redesign of our Models . But , in Laboratory test we try to take it into our consideration .

The refrigerant charge size of R134a refrigerant system is about 10 - 20 % less than that of R12 system . The exact charge size is determined through laboratory test .

10 - 15 % increase of Capillary tube in laboratory test for checking the performance of Refrigeration Cycle will be accomplished .

Drier volume is 1.2 times of conventional type . for better Humidity absorbtion . so Driers Model XH7 or XH9 will be incorporated in our refrigeration system . the simillar type of Driers will be used as necessary .

Maximum acceptable moisture is 50 - 150 mg. Evacuation of 0.01 mm Hg. is recommended .



SECTION V

REFRIGERATOR UNIT GOVERNING EQUATIONS AND
RELATIONS

1. Governing Equations.

1. $W = Fnc1(T_7, T_2)$

2. $P = Fnc2(T_7, T_2)$

3. $Q_{comp} = Fnc3(T_7, T_2)$

4. $Q_{ps} = Fnc4(T_7, T_2)$

5. $Q_{cond} = Fnc6(T_2, T_7) *$

6. $Q_{cond} = W \cdot dh_{cond}$

7. $Q_{evap} = Fnc6(T_{ms}, T_7)$

8. $Q_{evap} + P = Q_{pc} + Q_{cond} + Q_{comp}$

WHERE

W = Compressor mass flow rate

P = Compressor power Consumption

Q_{comp} = Compressor heat rejectionQ_{pc} = Precooler heat rejection



کارخانجات صنعتی آزمايش

موضوع :

نوع نشریه :

**AZMAYESH INDUSTRIAL
FACTORIES COMPANY**

شماره نشریه :

ط ————— رح و ————— رنامه

PAGE 12

Q_{cond} = Condenser heat rejection .

Q_{evap} = System refrigeration capacity .

dh_{cond} = Refrigerant Enthalpy change through condenser .

T_2 = Condenser mid-point temperature .

T_7 = Evaporator inlet temperature .

T_a = Ambient room temperature .

T_{ma} = Cabinet air temperature entering evaporator . **

* Superheat subcooling heat rejection are measured to be a single - valued function of T_2 and T_a .

** Freezer and fresh food air are mixed in the return duct for a single evaporator configuration and a mixed -air temperature is calculated .

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107

تاریخ و شماره تغییرات :

تاریخ انتشار :

**2. Upright Natural Convection Wire and Tube Condenser , Governing relations**

$$a. h_{ext}A = \eta_w \cdot h_w \cdot A_w + h_{ct} \cdot A_t =$$

$$\eta_w \cdot h_{ncw} \cdot A_w + \eta_w \cdot A_w \cdot F_w \cdot [4 \sigma \epsilon (T_m)^3] + h_{nct} \cdot A_t + A_t \cdot F_t \cdot [4 \sigma \epsilon (T_m)^3]$$

$$- 2 (k_a / D_w)$$

$$b. h_{ncw} = \frac{2 (k_a / D_w)}{\ln [1 + 1 (L / D_w) (1 / N_{gr})^{0.25}]}$$

h_{ncw} = Natural Convection Wire Heat Transfer Coefficient .

η_w = Wire Fin Efficiency .

k_a = Thermal Conduction of Air .

N_{gr} = Grashof Number = $(1.72 \times 10^8 \times L^3)$.

L = Distance between Tubes .

A_w = Wire Surface Area .

F_w = Wire Radiation Configuration Factor = 0.85

4σ = Stephen Boltzman Coefficient = 0.68×10^{-3} BTU / Hr Ft² R⁴

T_m = (Mean Wire Temperature R)³

$$2 (K_a / D_t)$$

$$c. h_{nct} = \frac{2 (K_a / D_t)}{\ln [1 + 5 / N_{gr}^{0.025}]}$$



کارخانجات صنعتی آزمايش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

ط ————— رج ————— و نامه

PAGE 14

h_{nct} = Natural convection Tube Heat Transfer Coefficient

D_t = Tube Diamiter

N_{gr} = Grashof Number + $(1.72 \times 10^3 \times D_t^3)$

A_r = Tube Radiation Configuration Factor

T_{tm}^3 = (Mean Tube Temperature R)³

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ وشم ————— دارد تغییرات :

تاریخ انتشار ————— دارد :



3 . NATURAL CONVECTION EVAPORATOR GOVERNING RELATIONS .

$$Q_{evap} = h_{eff} \times A (T_2 - T_7)$$

h_{eff} = Effective Heat Transfer Coefficient

A = Surface Area

T2 = Compartment air Temperature

(Typically 5 F for Freezer and 38 F for refrigerator Compartment)

T7 = Evaporator Temperature

4 . VERTICAL PLATE NATURAL CONVECTION EVAPORATOR

Overall Heat Transfer Coefficient =

$$UA = \eta [h + 4 \sigma \epsilon (T_m)^3] . A$$

$$\eta = \text{Plate fin effectiveness} :: \frac{\tan . h . m . l}{m . l}$$

$$m = (2h / kg)^{.5}$$

g = Plate thickness

k = Plate conductivity

l = Tube spacing



h = Plate natural convection heat transfer coefficient .

$$h = 0.29 (\Delta T / L)^{0.24}$$

L = Plate height

$4 \sigma \epsilon (T_m)^3$ = Radiation Coefficient

T_m = Mean temperature of plate

A = Surface area of plate

5 . COMPRESSOR HOUSING HEAT DISSIPATION

$$Q_{comp} = U . A . \Delta T$$

$$U = h + 4 \sigma . \epsilon (T)^3 = 1.44$$

$$h = 0.19 (\Delta T)^{1/3}$$

ΔT = Temperature difference between shell and local ambient air

$4 \sigma \epsilon (T)^3$ = Radiation Coefficient

A = Shell surface area



SECTION VI

**REFRIGERATOR MODEL AR06 REFRIGERATION LOAD
CALCULATION**

A. Heat gain by conduction

1. Total heat gain by conduction in refrigerator compartment .

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot \Delta T_{TR}$$

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot (T_a - T_r)$$

$$U_{TR_{ave}} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 35 \text{ mm (average)} = 0.1145 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ ft}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr . ft . F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr . ft . F}$$

$$k_3 = \text{PLastic thermal conductivity} = 0.09 \text{ BTU / HR . ft . F}$$

$$A_{TR} = A_1 + A_2 + A_3 + A_4 + A_5$$

$$A_1 = A_2 \quad \& \quad A_3 = A_4$$




کارخانجات صنعتی ارومیت

موضوع

نوع شریه:

ظرف و به سرانته

شماره شریه:



AR06 MODEL DIMENSIONS

تاریخ و شماره تغییرات:

تاریخ انش:



$$A_{TR} = 2A_1 + 2A_3 + A_5$$

$$A_{TR} = 2(500 \times 685) + 2(534 \times 635) + (500 \times 534)$$

$$A_{TR} = 685000 + 731580 + 267000 = 1683580 \text{ sq.mm} = 18.123 \text{ sq.ft}$$

$$U_{TR} = \frac{1}{0.000063 + 11.001 + 0.0729} = \frac{1}{11.07395189}$$

$$U_{TR} = 0.090 \text{ BTU} / \text{Hr} \cdot \text{F} \cdot \text{sq.ft}$$

$$t_{a_{max}} = 43 \text{ C} = 109.4 \text{ F}$$

$$t_r = 5 + 2 \text{ C} = 41 + 4 \text{ F}$$

$$(t_a - t_r) = 109.4 - 41 = 68.4 \text{ F}$$

$$Q_{TR} = 0.090 \times 18.123 \times 68.4 = 111.56 \text{ BTU} / \text{Hr}$$

$$Q_{TR} = 111.56 \text{ BTU} / \text{Hr}$$



2 . Total heat gain by conduction in Evaporator compartment .

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot \Delta t_e$$

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot (T_a - T_E)$$

$$T_a = 109.4 \text{ F}$$

$$T_E = 10.4 \text{ F}$$

1

$$U_{TE\text{ave}} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3 + x_4 / k_4 + x_5 / k_5}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 35 \text{ mm (average)} = 0.1145 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ ft}$$

$$x_4 = \text{Air thickness betwvn Ref. wall and Evaporator} = 44.5 \text{ mm} = 0.146 \text{ ft}$$

$$x_5 = \text{Evaporator thickness} = 1.5 \text{ mm} = 0.005 \text{ ft}$$

$$x_{4u} = \text{Upper Evaporator air thickness} = 10 \text{ mm} = 0.033 \text{ Ft}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr. ft. F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr. ft.}$$



$$k_3 = \text{Plastic thermal conductivity} = 0.09 \text{ BTU / HR . ft . F}$$

$$k_4 = \text{Thermal conductivity for air at Atmospheric pressure and } 10.4 \text{ F}$$

$$k_4 = 0.0135 \text{ BTU / Hr . Ft F}$$

$$k_5 = \text{Thermal conductivity for Aluminium} = 117 \text{ BTU / Hr. Ft F}$$

$$A_1 = 500 \times 534 = 267000 \text{ sq.mm} = 2.874 \text{ sq.Ft}$$

$$x_1 / k_1 = 0.000063$$

$$x_2 / k_2 = 0.123 / 0.0104 = 11.798$$

$$x_3 / k_3 = 0.0729$$

$$x_4 / k_4 = 0.033 / 0.0135 = 2.44$$

$$x_5 / k_5 = 0.005 / 117 = 0.00004$$

$$U_{TE1} = \frac{1}{0.000063 + 11.798 + 0.0729 + 2.44 + 0.00004} = \frac{1}{14.311408}$$

$$U_{TE1} = 0.0698 \text{ BTU / Hr . sq.ft. F}$$

$$t_{a \text{ max}} = 43 \text{ C} = 109.4 \text{ F Room Temp.}$$

$$t_{TE1} = 10.4 \text{ F}$$

$$\Delta T_{TE1} = (t_a - t_{TE1}) = 109.4 - 10.4 = 99 \text{ F}$$



$$Q_{E1} = U_1 \cdot A_1 \cdot \Delta T_1$$

$$Q_{E1} = 0.0698 \times 2.874 \times 99 = 19.88 \text{ BTU / Hr}$$

$$Q_{E2} = U_{E2} \cdot A_{E2} \cdot \Delta T_2$$

$$A_{E2} = A_{E1} = 2.874 \text{ sq. Ft}$$

1

$$U_{TE2} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 / k_1 = 0.016 / 0.09 = 0.1778$$

$$x_2 / k_2 = 0.18 / 0.0135 = 13.366$$

$$x_3 / k_3 = 0.00004$$

1

$$U_{TE2} = \frac{1}{0.1778 + 13.366 + 0.00004}$$

$$U_{TE2} = 0.0738 \text{ BTU / Hr . sq.Ft . F}$$

$$\Delta T_{E2} = T_R - T_E = 41 - 10.4 = 30.6 \text{ F}$$

$$Q_{E2} = 0.0738 \times 2.874 \times 30.6 = 6.493 \text{ BTU / Hr}$$

$$Q_{E3} = U_{E3} \cdot A_{E3} \cdot \Delta T_3$$



1

$$U_{TE3} = \frac{1}{x_1/k_1 + x_2/k_2 + x_3/k_3 + x_4/k_4 + x_5/k_5}$$

$$x_1/k_1 = 0.000063$$

$$x_2/k_2 = 0.1145/0.0104 = 11.001$$

$$x_3/k_3 = 0.0656/0.09 = 0.729$$

$$x_4/k_4 = 0.146/0.0135 = 10.814$$

$$x_5/k_5 = 0.0049/117 = 0.00004$$

1

$$U_{TE3} = \frac{1}{0.000063+11.001+0.0729+10.814+0.00004}$$

$$U_{TE3} = 0.044 \text{ BTU / Hr . sq.Ft . F}$$

$$A_{E3T} = 2A_{E3} + 2A_{E4}$$

$$A_{E3} = 220 \times 500 = 110000 \text{ sq.mm} = 1.184 \text{ sq.ft}$$

$$A_{E4} = 220 \times 534 = 117480 \text{ sq.mm} = 1.264 \text{ sq.ft}$$

$$A_{E3T} = 2 (1.184 + 1.264) = 4.897 \text{ sq.ft}$$

$$\Delta T_{E3} = T_s - T_E = 109.4 - 10.4 = 99 \text{ F}$$

$$Q_{E3} = 0.044 \times 4.897 \times 99 = 21.332 \text{ BTU / Hr}$$

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = 19.881+6.493+21.332 = 47.7 \text{ BTU / Hr}$$



B. PRODUCT LOAD CALCULATION

$$Q_{PT} = \Sigma Q_{PR} + \Sigma Q_{PF} + \Sigma Q_{LF} + \Sigma Q_F$$

1. ΣQ_{PR} = Heat removed from products above freezing point

$$Q_{PR} = W_P \cdot C_P \cdot \Delta T_R = W_P \cdot C_P \cdot (t_1 - t_2)$$

WHERE

1 . t_1 = For red and white fresh meet (Ave.) = 82.4 F

2 . t_1 = For butter and cheese (Ave.) = 50 F

3 . t_1 = For mixed vegetables (Ave.) = 59 F

4 . t_1 = For fruits of any kind (Ave.) = 59 F

5 . t_1 = For water = 50 F

6 . t_2 = For all above products = (Ave.) 41 F

$$\Delta T_{R1-1} = 41.4 F$$

$$\Delta T_{R1-2} = 9 F$$

$$\Delta T_{R1-3} = 18 F$$

$$\Delta T_{R1-4} = 18 F$$

$$\Delta T_{R1-5} = 9 F$$

Average sum of " C " Specific heat for items 1 through 5 from " Table 1 " are as follows .



کارخانجات صنعتی آزمايش

موضوع :

نوع نشریه :

**AZMAYESH INDUSTRIAL
FACTORIES COMPANY**

شماره نشریه :

ط ————— ریح و ————— رنامه

PAGE 24

$$"C_1" = 0.72 \text{ BTU/lb.F}$$

$$"C_2" = 0.67 \text{ BTU/lb.F}$$

$$"C_3" = 0.93 \text{ BTU/lb.F}$$

$$"C_4" = 0.9 \text{ BTU/lb.F}$$

$$"C_5" = 0.999 \text{ BTU/lb.F}$$

$$"C_M" = \text{For milk} = 0.93 \text{ BTU/lb.F}$$

Average Product Weight per Pound .

$$W_1 = 5 \text{ lb Meert and Fish}$$

$$W_2 = 2 \text{ lb Butter and cheese}$$

$$W_3 = 4 \text{ lb Vegetable (mixed) and lettuce}$$

$$W_4 = 4 \text{ lb Fruit of any kind}$$

$$W_5 = 4 \text{ lb Water}$$

$$W_6 = 4 \text{ lb Milk}$$

$$Q_{PR1} = 5 \times 0.72 \times (82.4 - 41) = 149 \text{ BTU}$$

$$Q_{PR2} = 2 \times 0.67 \times (50 - 41) = 12 \text{ BTU}$$

$$Q_{PR3} = 4 \times 0.93 \times (59 - 41) = 66.96 \text{ BTU}$$

$$Q_{PR4} = 4 \times 0.90 \times (59 - 41) = 64.8 \text{ BTU}$$

$$Q_{PR5} = 4 \times 0.999 \times (50 - 41) = 35.96 \text{ BTU}$$

$$Q_{PR6} = 4 \times 0.93 \times (50 - 41) = 33.48 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماره تغییرات :

تاریخ انتشار :



کارخانجات صنعتی آزمايش

موضوع :

نوع شربه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره شربه :

طرح و شماره

PAGE 25

$$Q_{Pr} = Q_{Pr1} + Q_{Pr2} + Q_{Pr3} + Q_{Pr4} + Q_{Pr5} + Q_{Pr6}$$

$$Q_{Pr} = 149 + 12 + 66.96 + 64.8 + 35.96 + 33.48$$

$$Q_{Pr} = 362.2 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماره اورد تغییرات :

تاریخ انتشار :



2. ΣQ_{PF1} = Heat removed from products to freeze product from initial temperature to freezing point .

$$Q_{PF1} = W \times C \times \Delta t$$

1 - Fish 2 lbs

2- Meet 5 lbs

3 - Water 5 lbs

$$\Delta t = (t_{pi} - t_{pf})$$

4 - $\Delta t_{fish} = 50 - 28 = 22 \text{ F}$ "C" = 0.9 BTU / lb F

5 - $\Delta t_{meet} = 82.4 - 29 = 53.4 \text{ F}$ "C" = 0.72 BTU / lb F

6 - $\Delta t_{water} = 50 - 32 = 18 \text{ F}$ "C" = 0.999 BTU / lb F

7 - $Q_{PF1_{fish}} = 2 \times 0.9 \times 22 = 36.6 \text{ BTU}$

8 - $Q_{PF1_{meet}} = 5 \times 0.72 \times 53.4 = 195.24 \text{ BTU}$

9 - $Q_{PF1_{water}} = 5 \times 0.999 \times 18 = 89.91 \text{ BTU}$

$$\Sigma Q_{PF1} = Q_{PF1_{fish}} + Q_{PF1_{meet}} + Q_{PF1_{water}} = 39.6 + 195.24 + 89.91 = 324.75 \text{ BTU}$$

$$\Sigma Q_{PF1} = 324.75 \text{ BTU}$$



3 - ΣQ_{PF2} = Heat removed from freezing point to final temperature below freezing .

$$Q_{PF2} = W \times C_i \times (t_r - t_s)$$

1 - Fish 2 lbs

2- Meert 5 lbs

3 - Ice 5 lbs

4 - $\Delta t_{fish} = 28 - 10.4 = 17.6 F$ " C_{ifish} " = 0.49 BTU / lb F

5 - $\Delta t_{meert} = 29 - 10.4 = 18.6 F$ " C_{imeert} " = 0.42 BTU / lb F

6 - $\Delta t_{ice} = 32 - 10.4 = 21.6 F$ " C_{ice} " = 1 BTU / lb F

7 - $Q_{PF2fish} = 2 \times 0.49 \times 17.6 = 17.248 BTU$

8 - $Q_{PF2meert} = 5 \times 0.42 \times 18.6 = 39.06 BTU$

9 - $Q_{PF2ice} = 5 \times 1 \times 21.6 = 108 BTU$

$$\Sigma Q_{PF2} = Q_{PF2fish} + Q_{PF2meert} + Q_{PF2ice} = 17.248 + 39.06 + 108 = 164.31 BTU$$

$$\Sigma Q_{PF2} = 164.31 BTU$$



4 - Q_{LF} = Heat removal to freeze product

$$Q_{LF} = W \times h_{LF}$$

WHERE

1 - Weight of product per pound

2 - Latent heat per BTU / lb

3 - Fish 2 lbs

4 - Meet 5 lbs

5 - Ice 5 lbs

$$Q_{LF_{fish}} = 2 \times 95 = 190 \text{ BTU}$$

$$Q_{LF_{meet}} = 5 \times 85.8 = 429.16 \text{ BTU}$$

$$Q_{LF_{ice}} = 5 \times 143.5 = 717.5 \text{ BTU}$$

$$Q_{LF} = Q_{LF_{fish}} + Q_{LF_{meet}} + Q_{LF_{ice}}$$

$$Q_{LF} = 190.66 + 429.16 + 717.5 = 1336.66 \text{ BTU}$$

$$Q_{LF} = 1336.66 \text{ BTU}$$

$$\Sigma Q_{PT} = 362.2 + 324.75 + 164.31 + 1336.66 = 2187.92 \text{ BTU}$$

$$Q_{PT} = 2187.92 \text{ BTU}$$



PAGE 29

C. Total heat gain through Refrigerator and Evaporator and Products are calculated as follows .

$$Q_T = Q_{TR} + Q_{TE} + Q_{TP} = Q_{TC} + Q_{TP}$$

$$Q_{TR} = 111.56 \text{ BTU / Hr}$$

$$Q_{TE} = 47.7 \text{ BTU / Hr}$$

$$Q_{TC} = Q_{TR} + Q_{TE} = 111.56 + 47.7 = 159.26 \text{ BTU / Hr}$$

$$Q_{Tp} = 2187.92 \text{ BTU per 24 hours}$$

Note . Desired Compressor Operating Time = 16 Hours Daily

$$Q_{Tp} / \text{Hr} = 2187.92 / 16 = 136.745 \text{ BTU / Hr}$$

$$Q_T = 159.26 + 136.745 = 296 \text{ BTU / Hr}$$

$$Q_{GT} = Q_T + 10 \% Q_T = 296 + 29.6 = 325.6 \text{ BTU / Hr}$$

$$Q_{GT} = 325.6 \text{ BTU / Hr}$$

$$Q_{GT} = 325.6 \times 0.2931 = 95.43 \text{ Watts}$$

$$Q_{GT} = 95.43 \text{ Watts / Hr}$$



D . Compressor selection for Model AR06

The compressor selection for Model AR06 is based on available or existing Compressor Models in Iranian Market at present which are as follows . Compressor power is to be 1/8 Hp . in all compressor types from different manufacturers .

Manufacturer Name	Model	Capacity .Watts
DANFUS	TL5G	115
NECCHI	ETR4H	89
ASPERA	BP1084Z	103
GOLD STAR	NF 45	103
SICOM	AZ133YS	95

From the above figures the nearest possible Compressor Capacity which are compatible to our Energy Requirements for Model AR06 , could be either comp. Model AZ133YS from SICOM with 95 Watts Capacity .or Model ETR4H from NECCHI with comp. capacity of 89 watts , the other Compressor models could be considered as alternatives due to the Laboratory test analysis .

Note 1 . 10 % additional load has been considered for Fridge air replacement and infiltration during the day .

Note 2 . For other equipment selection such as condenser , evaporator and drier refer to Section IV .

Capillary tube inner diameter = 0.78 mm
 Refrigeration System internal Volume =
 Capillary tube length = 440 cm
 Evaporator Surface = 3510 cm² , Volume = 35.8 lit.
 Total Volume =

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107



SECTION VII

**REFRIGERATOR MODEL AR08 REFRIGERATION LOAD
CALCULATION**

A. Heat gain by conduction

1. Total heat gain by conduction in refrigerator compartment .

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot \Delta T_R$$

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot (T_a - T_r)$$

1

$$U_{TR_{ave}} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 35 \text{ mm (average)} = 0.1145 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ ft}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr. ft. F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr. ft. F}$$

$$k_3 = \text{PLastic thermal conductivity} = 0.09 \text{ BTU / HR. ft. F}$$

$$A_{TR} = A_1 + A_2 + A_3 + A_4 + A_5$$

$$A_1 = A_2 \quad \& \quad A_3 = A_4$$



$$ATR = 2A_1 + 2A_3 + A_5$$

$$ATR = 2(500 \times 871) + 2(534 \times 871) + (500 \times 534)$$

$$ATR = 871000 + 930228 + 267000 = 2068228 \text{ sq.mm} = 22.262 \text{ sq.ft}$$

$$U_{TR} = \frac{1}{0.000063 + 11.001 + 0.0729} = \frac{1}{11.07395189}$$

$$U_{TR} = 0.090 \text{ BTU / Hr. F. sq.ft}$$

$$t_{a,max} = 43 \text{ C} = 109.4 \text{ F}$$

$$t_r = 5 + 2 \text{ C} = 41 + 4 \text{ F}$$

$$(t_a - t_r) = 109.4 - 41 = 68.4 \text{ F}$$

$$Q_{TR} = 0.090 \times 22.262 \times 68.4 = 137.046 \text{ BTU / Hr}$$

$$Q_{TR} = 137.046 \text{ BTU / Hr}$$




فراخوان علمی آزمایش

موضوع

نوع نثریه

نوع و نام برنامه

شماره نثریه:



AROB MODEL DIMENSIONS

ناریج و شه - ارد تغییرات:

ناریج انش - ارد:



2 . Total heat gain by conduction in Evaporator compartment .

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot \Delta T_E$$

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot (T_s - T_E)$$

$$T_s = 109.4 \text{ F}$$

$$T_E = 10.4 \text{ F}$$

1

$$U_{TE,ave} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3 + x_4 / k_4 + x_5 / k_5}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 35 \text{ mm (average)} = 0.1145 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ ft}$$

$$x_4 = \text{Air thickness betwwn Ref. wall and Evaporator} = 44.5 \text{ mm} = 0.146 \text{ ft}$$

$$x_5 = \text{Evaporator thickness} = 1.5 \text{ mm} = 0.005 \text{ ft}$$

$$x_{4u} = \text{Upper Evaporator air thickness} = 10 \text{ mm} = 0.033 \text{ Ft}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr. ft. F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr. ft.}$$



$$k_3 = \text{Plastic thermal conductivity} = 0.09 \text{ BTU / HR . ft . F}$$

$$k_4 = \text{Thermal conductivity for air at Atmospheric pressure and } 10.4 \text{ F}$$

$$k_4 = 0.0135 \text{ BTU / Hr . Ft F}$$

$$k_5 = \text{Thermal conductivity for Aluminium} = 117 \text{ BTU / Hr. Ft F}$$

$$A_1 = 500 \times 534 = 267000 \text{ sq.mm} = 2.874 \text{ sq.Ft}$$

$$x_1 / k_1 = 0.000063$$

$$x_2 / k_2 = 0.123 / 0.0104 = 11.798$$

$$x_3 / k_3 = 0.0729$$

$$x_4 / k_4 = 0.033 / 0.0135 = 2.44$$

$$x_5 / k_5 = 0.005 / 117 = 0.00004$$

$$U_{TE1} = \frac{1}{0.000063 + 11.798 + 0.0729 + 2.44 + 0.00004} = \frac{1}{14.311408}$$

$$U_{TE1} = 0.0698 \text{ BTU} / \text{Hr . sq.ft. F}$$

$$t_{a \text{ max}} = 43 \text{ C} = 109.4 \text{ F Room Temp.}$$

$$t_{E1} = 10.4 \text{ F}$$

$$\Delta T_{T1} = (t_a - t_E) = 109.4 - 10.4 = 99 \text{ F}$$



$$Q_{E1} = U_1 \cdot A_1 \cdot \Delta T_1$$

$$Q_{E1} = 0.0698 \times 2.874 \times 99 = 19.88 \text{ BTU / Hr}$$

$$Q_{E2} = U_{E2} \cdot A_{E2} \cdot \Delta T_2$$

$$A_{E2} = A_{E1} = 2.874 \text{ sq. Ft}$$

$$1$$

$$U_{TE2} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 / k_1 = 0.016 / 0.09 = 0.1778$$

$$x_2 / k_2 = 0.18 / 0.0135 = 13.366$$

$$x_3 / k_3 = 0.00004$$

$$1$$

$$U_{TE2} = \frac{1}{0.1778 + 13.366 + 0.00004}$$

$$U_{TE2} = 0.0738 \text{ BTU / Hr . sq.Ft . F}$$

$$\Delta T_{E2} = T_R - T_E = 41 - 10.4 = 30.6 \text{ F}$$

$$Q_{E2} = 0.0738 \times 2.874 \times 30.6 = 6.493 \text{ BTU / Hr}$$

$$Q_{E1} = U_{E1} \cdot A_{E1} \cdot \Delta T_1$$



$$Q_{E1} = U_1 \cdot A_1 \cdot \Delta T_1$$

$$Q_{E1} = 0.0698 \times 2.874 \times 99 = 19.88 \text{ BTU / Hr}$$

$$Q_{E2} = U_{E2} \cdot A_{E2} \cdot \Delta T_2$$

$$A_{E2} = A_{E1} = 2.874 \text{ sq. Ft}$$

$$1$$

$$U_{TE2} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 / k_1 = 0.016 / 0.09 = 0.1778$$

$$x_2 / k_2 = 0.18 / 0.0135 = 13.366$$

$$x_3 / k_3 = 0.00004$$

$$1$$

$$U_{TE2} = \frac{1}{0.1778 + 13.366 + 0.00004}$$

$$U_{TE2} = 0.0738 \text{ BTU / Hr. sq.Ft. F}$$

$$\Delta T_{E2} = T_R - T_E = 41 - 10.4 = 30.6 \text{ F}$$

$$Q_{E2} = 0.0738 \times 2.874 \times 30.6 = 6.493 \text{ BTU / Hr}$$

$$Q_{E3} = U_{E3} \cdot A_{E3} \cdot \Delta T_3$$



1

$$U_{TE3} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3 + x_4 / k_4 + x_5 / k_5}$$

$$x_1 / k_1 = 0.000063$$

$$x_2 / k_2 = 0.1145 / 0.0104 = 11.001$$

$$x_3 / k_3 = 0.0656 / 0.09 = 0.729$$

$$x_4 / k_4 = 0.146 / 0.0135 = 10.814$$

$$x_5 / k_5 = 0.0049 / 117 = 0.00004$$

1

$$U_{TE3} = \frac{1}{0.000063 + 11.001 + 0.729 + 10.814 + 0.00004}$$

$$U_{TE3} = 0.044 \text{ BTU} / \text{Hr} \cdot \text{sq.Ft} \cdot \text{F}$$

$$A_{E3T} = 2A_{E3} + 2A_{E4}$$

$$A_{E3} = 220 \times 500 = 110000 \text{ sq.mm} = 1.184 \text{ sq.ft}$$

$$A_{E4} = 220 \times 534 = 117480 \text{ sq.mm} = 1.264 \text{ sq.ft}$$

$$A_{E3T} = 2(1.184 + 1.264) = 4.897 \text{ sq.ft}$$

$$\Delta T_{E3} = T_s - T_E = 109.4 - 10.4 = 99 \text{ F}$$

$$Q_{E3} = 0.044 \times 4.897 \times 99 = 21.332 \text{ BTU} / \text{Hr}$$

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = 19.881 + 6.493 + 21.332 = 47.7 \text{ BTU} / \text{Hr}$$



B. PRODUCT LOAD CALCULATION

$$Q_{PT} = \Sigma Q_{PR} + \Sigma Q_{PF} + \Sigma Q_{LF} + \Sigma Q_F$$

1. ΣQ_{PR} = Heat removed from products above freezing point

$$Q_{PR} = W_P \cdot C_P \cdot \Delta T_R = W_P \cdot C_P \cdot (t_1 - t_2)$$

WHERE

1 . t_1 = For red and white fresh meet (Ave.) = 82.4 F

2 . t_1 = For butter and cheese (Ave.) = 50 F

3 . t_1 = For mixed vegetables (Ave.) = 59 F

4 . t_1 = For fruits of any kind (Ave.) = 59 F

5 . t_1 = For water = 50 F

6 . t_1 = For bread = 75 F

7 . t_2 = For all above products = (Ave.) 41 F

$$\Delta T_{R1-1} = 41.4 F$$

$$\Delta T_{R1-2} = 9 F$$

$$\Delta T_{R1-3} = 18 F$$

$$\Delta T_{R1-4} = 18 F$$

$$\Delta T_{R1-5} = 9 F$$



$$\Delta T_{R1-6} = 34 F$$

Average sum of "C" specific heat for above products from Table 1 are as follows .

$$"C_1" = 0.72 \text{ BTU/lb.F}$$

$$"C_2" = 0.67 \text{ BTU/lb.F}$$

$$"C_3" = 0.93 \text{ BTU/lb.F}$$

$$"C_4" = 0.9 \text{ BTU/lb.F}$$

$$"C_5" = 0.999 \text{ BTU/lb.F}$$

$$"C_6" = 0.70 \text{ BTU/lb.F}$$

$$"C_7" = \text{For milk} = 0.93 \text{ BTU/lb.F}$$

Average Product Weight per Pound .

$$W_1 = 5 \text{ lb Meet and Fish}$$

$$W_2 = 2 \text{ lb Butter and cheese}$$

$$W_3 = 4 \text{ lb Vegetable (mixed) and lettuce}$$

$$W_4 = 4 \text{ lb Fruit of any kind}$$

$$W_5 = 4 \text{ lb Water}$$

$$W_6 = 2 \text{ lb Bread}$$

$$W_7 = 4 \text{ lb Milk}$$

$$Q_{PR1} = 5 \times 0.72 \times (82.4 - 41) = 149 \text{ BTU}$$

$$Q_{PR2} = 2 \times 0.67 \times (50 - 41) = 12 \text{ BTU}$$

$$Q_{PR3} = 4 \times 0.93 \times (59 - 41) = 66.96 \text{ BTU}$$



کارخانجات صنعتی آزمايش

موضوع

نوع تشریح :

**AZMAYESH INDUSTRIAL
FACTORIES COMPANY**

شماره تشریح :

خط ————— رج 9 ————— ورقه 4

PAGE 39

$$Q_{Pr4} = 4 \times 0.90 \times (59 - 41) = 64.8 \text{ BTU}$$

$$Q_{Pr5} = 4 \times 0.999 \times (50 - 41) = 35.96 \text{ BTU}$$

$$Q_{Pr6} = 2 \times 0.70 \times (75 - 41) = 47.6 \text{ BTU}$$

$$Q_{Pr7} = 4 \times 0.93 \times (50 - 41) = 33.48 \text{ BTU}$$

$$Q_{Pr} = Q_{Pr1} + Q_{Pr2} + Q_{Pr3} + Q_{Pr4} + Q_{Pr5} + Q_{Pr6} + Q_{Pr7}$$

$$Q_{Pr} = 178.85 + 12.06 + 66.96 + 129.6 + 71.93 + 47.6 + 33.48$$

$$Q_{Pr} = 540.48 \text{ BTU}$$



2. ΣQ_{PF1} = Heat removed from products to freeze product from initial temperature to freezing point above freezin point .

$$Q_{PF1} = W \times C \times \Delta t$$

Weight of products are as follows

- | | |
|-----------|-------|
| 1 - Fish | 2 lbs |
| 2- Meect | 5 lbs |
| 3 - Water | 5 lbs |

$$\Delta t = (t_{pi} - t_{pf})$$

$$4 - \Delta t_{fish} = 50 - 28 = 22 F \quad " C " = 0.9 \text{ BTU / lb F}$$

$$5 - \Delta t_{meect} = 82.4 - 29 = 53.4 F \quad " C " = 0.72 \text{ BTU / lb F}$$

$$6 - \Delta t_{water} = 50 - 32 = 18 F \quad " C " = 0.999 \text{ BTU / lb F}$$

$$7 - Q_{F_{fish}} = 2 \times 0.9 \times 22 = 39.6 \text{ BTU}$$

$$8 - Q_{F_{meect}} = 5 \times 0.72 \times 53.4 = 195.24 \text{ BTU}$$

$$9 - Q_{F_{water}} = 5 \times 0.999 \times 18 = 89.91 \text{ BTU}$$

$$\Sigma Q_{PF1} = Q_{PF1_{fish}} + Q_{PF1_{meect}} + Q_{PF1_{water}} = 39.6 + 195.24 + 89.91 = 324.75 \text{ BTU}$$

$$\Sigma Q_{PF1} = 324.75 \text{ BTU}$$



3 - ΣQ_{PF2} = Heat removed from freezing point to final temperature below freezing .

$$Q_{PF2} = W \times C_i \times (t_f - t_3)$$

1 - Fish 2 lbs

2 - Meert 5 lbs

3 - Ice 5 lbs

4 - $\Delta t_{fish} = 28 - 10.4 = 17.6 \text{ F}$ " C_{ifish} " = 0.49 BTU / lb F

5 - $\Delta t_{meert} = 29 - 10.4 = 18.6 \text{ F}$ " C_{imeert} " = 0.42 BTU / lb F

6 - $\Delta t_{ice} = 32 - 10.4 = 21.6 \text{ F}$ " C_{ice} " = 1 BTU / lb F

7 - $Q_{PF2fish} = 2 \times 0.49 \times 17.6 = 17.248 \text{ BTU}$

8 - $Q_{PF2meert} = 5 \times 0.42 \times 18.6 = 39.06 \text{ BTU}$

9 - $Q_{PF2ice} = 5 \times 1 \times 21.6 = 108 \text{ BTU}$

$$\Sigma Q_{PF2} = Q_{PF2fish} + Q_{PF2meert} + Q_{PF2ice} = 17.248 + 39.06 + 108 = 164.31 \text{ BTU}$$

$$\Sigma Q_{PF2} = 164.31 \text{ BTU}$$



4 - ΣQ_{LF} = Heat removal to freeze product

$$Q_{LF} = W \times h_{LF}$$

WHERE

Q_{LF} = Heat removal by latent heat

W = Weight of product

h_{LF} = Latent heat per BTU / lb

1 - Weight of product per pound

2 - Latent heat per BTU / lb

3 - Fish 2 lbs

4 - Meet 5 lbs

5 - Ice 5 lbs

$$Q_{LF_{fish}} = 2 \times 95 = 190 \text{ BTU}$$

$$Q_{LF_{meet}} = 5 \times 85.8 = 429.16 \text{ BTU}$$

$$Q_{LF_{ice}} = 5 \times 143.5 = 717.5 \text{ BTU}$$

$$Q_{LF} = Q_{LF_{fish}} + Q_{LF_{meet}} + Q_{LF_{ice}}$$

$$Q_{LF} = 190.66 + 429.16 + 717.5 = 1336.66 \text{ BTU}$$

$$Q_{LF} = 1336.66 \text{ BTU}$$



کارخانجات صنعتی آزمایش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

ط ————— ریح 9 ————— و نامه

PAGE 43

$$\Sigma Q_{PT} = 540.48 + 324.75 + 164.31 + 1336.66 = 2187.92 \text{ BTU}$$

$$Q_{PT} = 2366.2 \text{ BTU in 24 hours}$$

$$Q_{PT_{hr}} = 2366.2 / 16 = 147.9 \text{ btu / Hr.}$$

Note . Compressor operating time = 16 hours daily

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107

تاریخ وشم ————— ارد تغییرات :

تاریخ آنتش ————— ار :



C. Total heat gain through Refrigerator and Evaporator and Products are calculated as follows .

$$Q_T = Q_{TR} + Q_{TE} + Q_{TP} = Q_{TC} + Q_{TP}$$

Where

Q_{TC} = Total heat gain by conduction

Q_{TR} = Total heat removed from products

$$Q_{TR} = 137.046 \text{ BTU / Hr}$$

$$Q_{TE} = 47.7 \text{ BTU / Hr}$$

$$Q_{TC} = Q_{TR} + Q_{TE} = 137.046 + 47.7 = 184.746 \text{ BTU / Hr}$$

$$Q_{TP} = 2366.2 \text{ BTU per 24 hours}$$

Note . Desired Compressor Operating Time = 16 Hours Daily

$$Q_{TP} / \text{Hr} = 2366.2 / 16 = 147.9 \text{ BTU / Hr}$$

$$Q_T = 184.746 + 147.9 = 332.65 \text{ BTU / Hr}$$

$$Q_{GT} = Q_T + 10 \% Q_T = 332.65 + 33.26 = 365.91 \text{ BTU / Hr}$$

$$Q_{GT} = 365.91 \text{ BTU / Hr}$$

$$Q_{GT} = 365.91 \times 0.2931 = 107.25 \text{ Watts}$$

$$Q_{GT} = 107.25 \text{ Watts / Hr}$$




کارت استاندارد آزمایش

موضوع:

نوع شریه:

ذرات و ارتفاع

شماره شریه:



MODEL AR10

تاریخ و شماره تغییرات:

۸-۲

تاریخ انقضای کار:



کارخانجات صنعتی آزمایش

موضوع

نوع نشریه :

**AZMAYESH INDUSTRIAL
FACTORIES COMPANY**

شماره نشریه :

طرح و موضوع

D . Compressor selection for Model AR08

The compressor selection for Model AR08 is based on available or existing Compressor Model: in Iranian Market at present which are as follows , Compressor power is to be 1/8 Hp , in all compressor types from different manufacturers .

Manufacturer Name	Model	Capacity ,Watts
DANFUS	TL5G	115
NECCHI	ETR4H	89
ASPERA	BP1084Z	103
GOLD STAR	NF 45	103
SICOM	AZI33YS	95

From the above figures the nearest possible Compressor Capacity which are compatible to our Energy Requirements for Model AR08 , could be either comp. Model TL5G from DANFUS with 115 Watts Capacity .or Model NF 45 from GOLD STAR with comp. capacity of 103 watts , the other Compressor models could be considered as alternatives due to the Laboratory test analysis .

Note 1 . 10 % additional load has been considered for Fridge air replacement and infiltration during the day .

Note 2 . For other equipment selection such as condenser , evaporator and drier refer to Section IV .



SECTION VIII

REFRIGERATOR MODEL AR10 REFRIGERATION LOAD CALCULATION

A . Heat gain by conduction .

I . Total heat gain by conduction in refrigerator compartment .

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot \Delta T_R$$

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot (T_o - T_i)$$

1

$$U_{TR_{ave}} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

x_1 = Carbon steel thickness = 0.6 mm = 0.00197 ft.

x_2 = Foam thickness (ave.) = 35 mm (average) = 0.1145 ft (ave.)

x_3 = Inner liner ABS thickness = 2 mm = 0.00056 ft

k_1 = Steel thermal conductivity = 31.2 BTU / Hr . ft . F

k_2 = Foam thermal conductivity = 0.0104 BTU / Hr . ft . F

k_3 = PLastic thermal conductivity = 0.09 BTU / Hr . ft . F

$$A_{TR} = A_1 + A_2 + A_3 + A_4 + A_5$$

$$A_1 = A_2 \quad \& \quad A_3 = A_4$$



$$ATR = 2A_1 + 2A_3 + A_5$$

$$ATR = 2(500 \times 990) + 2(534 \times 990) + (495 \times 990)$$

$$ATR = 1029600 + 980100 + 257400 = 2267100 \text{ sq.mm} = 24.4 \text{ sq.ft}$$

$$U_{TR} = \frac{1}{0.000063 + 11.001 + 0.0729} = \frac{1}{11.07395189}$$

$$U_{TR} = 0.090 \text{ BTU / Hr} \cdot \text{F} \cdot \text{sq.ft}$$

$$t_{a, \max} = 43 \text{ C} = 109.4 \text{ F}$$

$$t_r = 5 + 2 \text{ C} = 41 + 4 \text{ F}$$

$$(t_a - t_r) = 109.4 - 41 = 68.4 \text{ F}$$

$$Q_{TR} = 0.090 \times 24.4 \times 68.4 = 150.22 \text{ BTU / Hr}$$

$$Q_{TR} = 150.22 \text{ BTU / Hr}$$



2 . Total heat gain by conduction in Evaporator compartment .

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = \bar{U}_{TE} \cdot A_{TE} \cdot \Delta T_E$$

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot (T_s - T_E)$$

$$T_s = 109.4 \text{ F}$$

$$T_E = 10.4 \text{ F}$$

1

$$U_{TE,ave} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3 + x_4 / k_4 + x_5 / k_5}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 35 \text{ mm (average)} = 0.1145 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ ft}$$

$$x_4 = \text{Air thickness betwvwn Ref. wall and Evaporator} = 44.5 \text{ mm} = 0.146 \text{ ft}$$

$$x_5 = \text{Evaporator thickness} = 1.5 \text{ mm} = 0.005 \text{ ft}$$

$$x_{4u} = \text{Upper Evaporator air thickness} = 10 \text{ mm} = 0.033 \text{ Ft}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr. ft. F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr. ft.}$$



$$k_3 = \text{Plastic thermal conductivity} = 0.09 \text{ BTU / HR. ft. F}$$

$$k_4 = \text{Thermal conductivity for air at Atmospheric pressure and } 10.4 \text{ F}$$

$$k_4 = 0.0135 \text{ BTU / Hr. Ft F}$$

$$k_5 = \text{Thermal conductivity for Aluminium} = 117 \text{ BTU / Hr. Ft F}$$

$$A_1 = 528 \times 465 = 261350 \text{ sq.mm} = 2.81 \text{ sq.Ft}$$

$$x_1 / k_1 = 0.000063$$

$$x_2 / k_2 = 0.123 / 0.0104 = 11.798$$

$$x_3 / k_3 = 0.0729$$

$$x_4 / k_4 = 0.033 / 0.0135 = 2.44$$

$$x_5 / k_5 = 0.005 / 117 = 0.00004$$

$$U_{TE1} = \frac{1}{0.000063 + 11.798 + 0.0729 + 2.44 + 0.00004} = 14.311$$

$$U_{TE1} = 0.064 \text{ BTU / Hr. sq.ft. F}$$

$$t_{a, \text{max}} = 43 \text{ C} = 109.4 \text{ F Room Temp.}$$

$$t_{E1} = 10.4 \text{ F}$$

$$\Delta T_{E1} = (t_a - t_E) = 109.4 - 10.4 = 99 \text{ F}$$



$$Q_{E1} = U_1 \cdot A_1 \cdot \Delta T_1$$

$$Q_{E1} = 0.064 \times 2.81 \times 99 = 17.8 \text{ BTU / Hr}$$

$$Q_{E2} = U_{E2} \cdot A_{E2} \cdot \Delta T_2$$

$$A_{E2} = A_{E1} = 2.81 \text{ sq. Ft}$$

1

$$U_{TE2} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 / k_1 = 0.016 / 0.09 = 0.1778$$

$$x_2 / k_2 = 0.213 / 0.0134 = 15.91$$

$$x_3 / k_3 = 0.00004$$

1

$$U_{TE2} = \frac{1}{0.1778 + 15.91 + 0.00004}$$

$$U_{TE2} = 0.062 \text{ BTU / Hr . sq.Ft . F}$$

$$\Delta T_{E2} = T_R - T_E = 41 - 10.4 = 30.6 \text{ F}$$

$$Q_{E2} = 0.064 \times 2.81 \times 30.6 = 5.3 \text{ BTU / Hr}$$

$$Q_{E3} = U_{E3} \cdot A_{E3T} \cdot \Delta T_3$$



1

$$U_{TE3} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3 + x_4 / k_4 + x_5 / k_5}$$

$$x_1 / k_1 = 0.000063$$

$$x_2 / k_2 = 0.1145 / 0.0104 = 11.798$$

$$x_3 / k_3 = 0.0656 / 0.09 = 0.729$$

$$x_4 / k_4 = 0.116 / 0.0135 = 10.814$$

$$x_5 / k_5 = 0.0049 / 117 = 0.00004$$

1

$$U_{TE3} = \frac{1}{0.000063 + 11.798 + 0.729 + 10.814 + 0.00004}$$

$$U_{TE3} = 0.044 \text{ BTU / Hr. sq.Ft. F}$$

$$A_{EST} = 2A_{E3} + 2A_{E4}$$

$$A_{E3} = 250 \times 495 = 123750 \text{ sq.mm} = 1.33 \text{ sq.ft}$$

$$A_{E4} = 250 \times 528 = 132000 \text{ sq.mm} = 1.42 \text{ sq.ft}$$

$$A_{EST} = 2(1.33 + 1.42) = 5.5 \text{ sq.ft}$$

$$\Delta T_{E3} = T_s - T_E = 109.4 - 10.4 = 99 \text{ F}$$

$$Q_{E3} = 0.044 \times 5.5 \times 99 = 23.98 \text{ BTU / Hr}$$

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = 19.17 + 5.27 + 23.98 = 48.42 \text{ BTU / Hr}$$



B. PRODUCT LOAD CALCULATION

$$Q_{PT} = \Sigma Q_{PR} + \Sigma Q_{PF} + \Sigma Q_{LF} + \Sigma Q_F$$

1. ΣQ_{PR} = Heat removed from products above freezing point

$$Q_{PR} = W_P \cdot C_P \cdot \Delta T_R = W_P \cdot C_P \cdot (t_1 - t_2)$$

WHERE

1 . t_1 = For red and white fresh meet (Ave.) = 82.4 F

2 . t_1 = For butter and cheese (Ave.) = 50 F

3 . t_1 = For mixed vegetables (Ave.) = 59 F

4 . t_1 = For fruits of any kind (Ave.) = 59 F

5 . t_1 = For water = 50 F

6 . t_1 = For bread = 75 F

7 . t_2 = For all above products = (Ave.) 41 F

$$\Delta T_{R1.1} = 41.4 F$$

$$\Delta T_{R1.2} = 9 F$$

$$\Delta T_{R1.3} = 18 F$$

$$\Delta T_{R1.4} = 18 F$$

$$\Delta T_{R1.5} = 9 F$$



کارخانجات صنعتی آرمایش

موضوع :

نوع تشریح :

**AZMAYESH INDUSTRIAL
FACTORIES COMPANY**

شماره تشریح :

طرح و برنامه

PAGE 53

$$\Delta t_{R1.6} = 34 F$$

Average sum of " C " specific heat for above products from Table 1 are as follows .

$$" C_1 " = 0.72 \text{ BTU / lb . F}$$

$$" C_2 " = 0.67 \text{ BTU / lb . F}$$

$$" C_3 " = 0.93 \text{ BTU / lb . F}$$

$$" C_4 " = 0.9 \text{ BTU / lb . F}$$

$$" C_5 " = 0.999 \text{ BTU / lb . F}$$

$$" C_6 " = 0.70 \text{ BTU / lb . F}$$

$$" C_7 " = \text{For milk} = 0.93 \text{ BTU / lb . F}$$

Average Product Weight per Pound .

$$W_1 = 8 \text{ lb Meert and Fish}$$

$$W_2 = 2 \text{ lb Butter and cheese}$$

$$W_3 = 6 \text{ lb Vegetable (mixed) and lettuce}$$

$$W_4 = 12 \text{ lb Fruit of any kind}$$

$$W_5 = 10 \text{ lb Water}$$

$$W_6 = 5 \text{ lb Bread}$$

$$W_7 = 6 \text{ lb Milk}$$

$$Q_{PR1} = 8 \times 0.72 \times (82.4 - 41) = 238.4 \text{ BTU}$$

$$Q_{PR2} = 2 \times 0.67 \times (50 - 41) = 12 \text{ BTU}$$

$$Q_{PR3} = 6 \times 0.93 \times (59 - 41) = 100.44 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماریه تغییرات :

تاریخ انتشار :



کارخانجات صنعتی آزمایش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

طرح و برنامه

PAGE 54

$$Q_{PR4} = 12 \times 0.90 \times (59 - 41) = 194.4 \text{ BTU}$$

$$Q_{PR5} = 10 \times 0.999 \times (50 - 41) = 89.91 \text{ BTU}$$

$$Q_{PR6} = 5 \times 0.70 \times (75 - 41) = 11.9 \text{ BTU}$$

$$Q_{PR7} = 6 \times 0.93 \times (50 - 41) = 50.22 \text{ BTU}$$

$$Q_{PR} = Q_{PR1} + Q_{PR2} + Q_{PR3} + Q_{PR4} + Q_{PR5} + Q_{PR6} + Q_{PR7}$$

$$Q_{PR} = 238.4 + 12.06 + 100.44 + 194.4 + 89.91 + 11.9 + 50.22$$

$$Q_{PR} = 697.3 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ وشم—ارده تغییرات :

تاریخ انتشار—ار :



2. ΣQ_{PF1} = Heat removed from products to freeze product from initial temperature to freezing point above freezin point .

$$Q_{PF1} = W \times C \times \Delta t$$

Weight of products are as follows

1 - Fish 4 lbs

2- Meet 7 lbs

3 - Water 5 lbs

$$\Delta t = (t_{pi} - t_{pf})$$

4 - $\Delta t_{fish} = 50 - 28 = 22 F$ " C " = 0.9 BTU / lb F

5 - $\Delta t_{meet} = 82.4 - 29 = 53.4 F$ " C " = 0.72 BTU / lb F

6 - $\Delta t_{water} = 50 - 32 = 18 F$ " C " = 0.999 BTU / lb F

7 - $Q_{PF1_{fish}} = 4 \times 0.9 \times 22 = 79.2 BTU$

8 - $Q_{PF1_{meet}} = 7 \times 0.72 \times 53.4 = 269.14 BTU$

9 - $Q_{PF1_{water}} = 5 \times 0.999 \times 18 = 89.91 BTU$

$$\Sigma Q_{PF1} = Q_{PF1_{fish}} + Q_{PF1_{meet}} + Q_{PF1_{water}} = 79.2 + 269.14 + 89.91 = 438.34 BTU$$

$$\Sigma Q_{PF1} = 438.34 BTU$$



3 - ΣQ_{PF2} = Heat removed from freezing point to final temperature below freezing .

$$Q_{PF2} = W \times C_i \times (t_f - t_s)$$

1 - Fish 4 lbs

2- Meet 7 lbs

3 - Ice 5 lbs

4 - $\Delta t_{fish} = 28 - 10.4 = 17.6 F$ " C_{fish} " = 0.49 BTU / lb F

5 - $\Delta t_{meet} = 29 - 10.4 = 18.6 F$ " C_{meet} " = 0.42 BTU / lb F

6 - $\Delta t_{ice} = 32 - 10.4 = 21.6 F$ " C_{ice} " = 1 BTU / lb F

7 - $Q_{PF2_{fish}} = 4 \times 0.49 \times 17.6 = 34.5 BTU'$

8 - $Q_{PF2_{meet}} = 7 \times 0.42 \times 18.6 = 54.68 BTU'$

9 - $Q_{PF2_{ice}} = 5 \times 1 \times 21.6 = 108 BTU'$

$$\Sigma Q_{PF2} = Q_{PF2_{fish}} + Q_{PF2_{meet}} + Q_{PF2_{ice}} = 34.5 + 54.68 + 108 = 197.18 BTU'$$

$$\Sigma Q_{PF2} = 197.18 BTU'$$



4 - ΣQ_{LF} = Heat removal to freeze product

$$Q_{LF} = W \times h_{LF}$$

WHERE

Q_{LF} = Heat removal by latent heat

W = Weight of product

h_{LF} = Latent heat per BTU / lb

1 - Weight of product per pound

2 - Latent heat per BTU / lb

3 - Fish 5 lbs

4 - Meet 7 lbs

5 - Ice 5 lbs

$$Q_{LF_{fish}} = 5 \times 95 = 380 \text{ BTU}$$

$$Q_{LF_{meet}} = 7 \times 85.8 = 600.6 \text{ BTU}$$

$$Q_{LF_{ice}} = 5 \times 143.5 = 717.5 \text{ BTU}$$

$$Q_{LF} = Q_{LF_{fish}} + Q_{LF_{meet}} + Q_{LF_{ice}}$$

$$Q_{LF} = 380 + 600.6 + 717.5 = 1698.1 \text{ BTU}$$

$$Q_{LF} = 1698.1 \text{ BTU}$$



کارخانجات صنعتی آزمايش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

طرح و شماره

PAGE 59

$$\Sigma Q_{PT} = 697.3 + 438.34 + 197.18 + 1698.1 = 3030.94 \text{ BTU}$$

$$Q_{PT} = 3030.94 \text{ BTU in 24 hours}$$

$$Q_{PT_{hr}} = 3030.94 / 16 = 189.43 \text{ BTU / Hr.}$$

Note . Compressor operating time = 16 hours daily

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماره تغییرات :

تاریخ انتشار



C. Total heat gain through Refrigerator and Evaporator and heat removed from Products are calculated as follows .

$$Q_T = Q_{TR} + Q_{TE} + Q_{TP} = Q_{TC} + Q_{TP}$$

Where

Q_{TC} = Total heat gain by conduction

Q_{TR} = Total heat removed from products

$$Q_{TR} = 150.2 \text{ BTU / Hr}$$

$$Q_{TE} = 48.42 \text{ BTU / Hr}$$

$$Q_{TC} = Q_{TR} + Q_{TE} = 150.2 + 48.42 = 198.62 \text{ BTU / Hr}$$

$$Q_{TP} = 3030.94 \text{ BTU per 24 hours}$$

Note . Desired Compressor Operating Time = 16 Hours Daily

$$Q_{TP} / \text{Hr} = 3030.94 / 16 = 189.43 \text{ BTU / Hr}$$

$$Q_T = 198.62 + 189.43 = 388.1 \text{ BTU / Hr}$$

$$Q_{GT} = Q_T + 10 \% Q_T = 388.1 + 38.81 = 426.91 \text{ BTU / Hr}$$

$$Q_{GT} = 426.91 \text{ BTU / Hr}$$

$$Q_{GT} = 426.91 \times 0.2931 = 125.12 \text{ Watts}$$

$$Q_{GT} = 125.12 \text{ Watts / Hr}$$

**D. Compressor selection for Model AR10**

The compressor selection for Model AR10 is based on available or existing Compressor Models in Iranian Market at present which are as follows , Compressor power is to be 1/6 Hp , in all compressor types from different manufacturers .

Manufacturer Name	Model	Capacity ,Watts
DANFUS	TL55F	130
NECCHI	ETR5.5H	123
ASPERA	BP1111Z	125
GOLD STAR	NF 52	135
SICOM	AZ1345YS	120

From the above figures the nearest possible Compressor Capacity which are compatible to our Energy Requirements for Model AR10 , could be either comp. Model TL55F from DANFUS with 130 Watts Capacity ,or Model BP1111z from ASPERA with comp. capacity of 125 watts or compressor Model NF 52 from GOLD STAR, the other Compressor models could be considered as alternatives due to the Laboratory test analysis .

Note 1 . 10 % additional load has been considered for Fridge air replacement and infiltration during the day .

Note 2 . For other equipment selection such as condenser , evaporator and drier refer to Section IV .



SECTION IX

REFRIGERATOR MODEL AR12 REFRIGERATION LOAD CALCULATION

A. Heat gain by conduction

1. Total heat gain by conduction in refrigerator compartment.

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot \Delta T_R$$

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot (T_o - T_i)$$

1

$$U_{TR_{ave}} = \frac{1}{x_1/k_1 + x_2/k_2 + x_3/k_3}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 35 \text{ mm (average)} = 0.1145 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ ft}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr. ft. F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr. ft. F}$$

$$k_3 = \text{PLastic thermal conductivity} = 0.09 \text{ BTU / HR. ft. F}$$

$$A_{TR} = A_1 + A_2 + A_3 + A_4 + A_5$$

$$A_1 = A_2 \quad \& \quad A_3 = A_4$$




کارخانجات صنعتی آرمایش

موضوع:

نوع نثره:

نوع و شماره

شماره نثره:



MODEL AR12

نارنج و شماره: دارد سبیرات:

نارنج اتش: ار:



$$ATR = 2A_1 + 2A_3 + A_5$$

$$ATR = 2(528 \times 1115) + 2(495 \times 1115) + (528 \times 495)$$

$$ATR = 1177440 + 1103850 + 261360 = 2542650 \text{ sq.mm} = 27.37 \text{ sq.ft}$$

$$U_{TR} = \frac{1}{0.000063 + 11.001 + 0.0729} = \frac{1}{11.07395189}$$

$$U_{TR} = 0.090 \text{ BTU / Hr. F. sq.ft}$$

$$t_{max} = 43 \text{ C} = 109.4 \text{ F}$$

$$t_r = 5+2 \text{ C} = 41+4 \text{ F}$$

$$(t_a - t_r) = 109.4 - 41 = 68.4 \text{ F}$$

$$Q_{TR} = 0.090 \times 27.37 \times 68.4 = 168.48 \text{ BTU / Hr}$$

$$Q_{TR} = 168.48 \text{ BTU / Hr}$$



2 . Total heat gain by conduction in Evaporator compartment .

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot \Delta t_e$$

$$Q_{TE} = U_{TE} \cdot A_{TE} \cdot (T_s - T_e)$$

$$T_s = 109.4 \text{ F}$$

$$T_e = 10.4 \text{ F}$$

1

$$U_{TE(ave)} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3 + x_4 / k_4 + x_5 / k_5}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 35 \text{ mm (average)} = 0.1145 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ ft.}$$

$$x_4 = \text{Air thickness betwvwn Ref. wall and Evaporator} = 44.5 \text{ mm} = 0.146 \text{ ft}$$

$$x_5 = \text{Evaporator thickness} = 1.5 \text{ mm} = 0.005 \text{ ft}$$

$$x_{4u} = \text{Upper Evaporator air thickness} = 10 \text{ mm} = 0.033 \text{ Ft}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr. ft. F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr. ft.}$$



$$k_3 = \text{Plastic thermal conductivity} = 0.09 \text{ BTU / HR. ft. F}$$

$$k_1 = \text{Thermal conductivity for air at Atmospheric pressure and } 10.4 \text{ F}$$

$$k_1 = 0.0135 \text{ BTU / Hr. Ft F}$$

$$k_5 = \text{Thermal conductivity for Aluminium} = 117 \text{ BTU / Hr. Ft F}$$

$$A_1 = 528 \times 465 = 261350 \text{ sq.mm} = 2.81 \text{ sq.Ft}$$

$$x_1 / k_1 = 0.000063$$

$$x_2 / k_2 = 0.123 / 0.0104 = 11.798$$

$$x_3 / k_3 = 0.0729$$

$$x_4 / k_4 = 0.0492 / 0.0135 = 3.645$$

$$x_5 / k_5 = 0.005 / 117 = 0.00004$$

$$U_{TE1} = \frac{1}{0.000063 + 11.798 + 0.0729 + 3.645 + 0.00004} = \frac{1}{15.51}$$

$$U_{TE1} = 0.064 \text{ BTU / Hr. sq.ft. F}$$

$$t_{s \text{ max}} = 43 \text{ C} = 109.4 \text{ F Room Temp.}$$

$$t_{e1} = 10.4 \text{ F}$$

$$\Delta T_{TE1} = (t_s - t_e) = 109.4 - 10.4 = 99 \text{ F}$$



$$Q_{E1} = U_1 \cdot A_1 \cdot \Delta T_1$$

$$Q_{E1} = 0.064 \times 2.81 \times 99 = 17.8 \text{ BTU / Hr}$$

$$Q_{E2} = U_{E2} \cdot A_{E2} \cdot \Delta T_2$$

$$A_{E2} = A_{E1} = 2.81 \text{ sq. Ft}$$

1

$$U_{TE2} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 / k_1 = 0.016 / 0.09 = 0.1778$$

$$x_2 / k_2 = 0.213 / 0.0134 = 15.91$$

$$x_3 / k_3 = 0.00004$$

1

$$U_{TE2} = \frac{1}{0.1778 + 15.91 + 0.00004}$$

$$U_{TE2} = 0.062 \text{ BTU / Hr} \cdot \text{sq.Ft} \cdot \text{F}$$

$$\Delta T_{E2} = T_R - T_E = 41 - 10.4 = 30.6 \text{ F}$$

$$Q_{E2} = 0.064 \times 2.81 \times 30.6 = 5.3 \text{ BTU / Hr}$$

$$Q_{E3} = U_{E3} \cdot A_{E3T} \cdot \Delta T_3$$



1

$$U_{TE3} = \frac{1}{x_1/k_1 + x_2/k_2 + x_3/k_3 + x_4/k_4 + x_5/k_5}$$

$$x_1/k_1 = 0.000063$$

$$x_2/k_2 = 0.1145/0.0104 = 11.798$$

$$x_3/k_3 = 0.0656/0.09 = 0.0729$$

$$x_4/k_4 = 0.146/0.0135 = 10.814$$

$$x_5/k_5 = 0.0049/117 = 0.00004$$

1

$$U_{TE3} = \frac{1}{0.000063+11.798+0.0729+10.814+0.00004}$$

$$U_{TE3} = 0.044 \text{ BTU / Hr . sq.Ft . F}$$

$$A_{EST} = 2A_{E3} + 2A_{E4}$$

$$A_{E3} = 325 \times 495 = 160875 \text{ sq.mm} = 1.73 \text{ sq.ft}$$

$$A_{E4} = 325 \times 528 = 171600 \text{ sq.mm} = 1.85 \text{ sq.ft}$$

$$A_{EST} = 2(1.73 + 1.85) = 7.16 \text{ sq.ft}$$

$$\Delta T_{E3} = T_s - T_e = 109.4 - 10.4 = 99 \text{ F}$$

$$Q_{E3} = 0.044 \times 7.16 \times 99 = 31.18 \text{ BTU / Hr}$$

$$Q_{TE} = Q_{E1} + Q_{E2} + Q_{E3}$$

$$Q_{TE} = 17.8+5.33+31.18 = 54.31 \text{ BTU / Hr}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107



B . PRODUCT LOAD CALCULATION FORMODEL ARI2

$$Q_{PT} = \Sigma Q_{PR} + \Sigma Q_{PF} + \Sigma Q_{LF} + \Sigma Q_F$$

1. ΣQ_{PR} = Heat removed from products above freezing point

$$Q_{PR} = W_P \cdot C_P \cdot \Delta t_R = W_P \cdot C_P \cdot (t_1 - t_2)$$

WHERE

1 . t_1 = For red and white fresh meet (Ave.) = 82.4 F

2 . t_1 = For butter and cheese (Ave.) = 50 F

3 . t_1 = For mixed vegetables (Ave.) = 59 F

4 . t_1 = For fruits of any kind (Ave.) = 59 F

5 . t_1 = For water = 50 F

6 . t_1 = For bread = 75 F

7 . t_2 = For all above products = (Ave.) 41 F

$$\Delta t_{R1-1} = 41.4 F$$

$$\Delta t_{R1-2} = 9 F$$

$$\Delta t_{R1-3} = 18 F$$

$$\Delta t_{R1-4} = 18 F$$

$$\Delta t_{R1-5} = 9 F$$



$$\Delta T_{R1-6} = 34 \text{ F}$$

Average sum of "C" specific heat for above products from Table 1 are as follows .

$$"C_1" = 0.72 \text{ BTU / lb . F}$$

$$"C_2" = 0.67 \text{ BTU / lb . F}$$

$$"C_3" = 0.93 \text{ BTU / lb . F}$$

$$"C_4" = 0.9 \text{ BTU / lb . F}$$

$$"C_5" = 0.999 \text{ BTU / lb . F}$$

$$"C_6" = 0.70 \text{ BTU / lb . F}$$

$$"C_7" = \text{For milk} = 0.93 \text{ BTU / lb . F}$$

Average Product Weight per Pound .

$$W_1 = 10 \text{ lb Meet and Fish}$$

$$W_2 = 4 \text{ lb Butter and cheese}$$

$$W_3 = 10 \text{ lb Vegetable (mixed) and lettuce}$$

$$W_4 = 16 \text{ lb Fruit of any kind}$$

$$W_5 = 10 \text{ lb Water}$$

$$W_6 = 6 \text{ lb Bread}$$

$$W_7 = 8 \text{ lb Milk}$$

$$Q_{PR1} = 10 \times 0.72 \times (82.4 - 41) = 298 \text{ BTU}$$

$$Q_{PR2} = 4 \times 0.67 \times (50 - 41) = 24.1 \text{ BTU}$$

$$Q_{PR3} = 10 \times 0.93 \times (59 - 41) = 167.4 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107



کارخانجات صنعتی آزمایش

موضوع

نوع شریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره شریه :

طرح و مشخصات

PAGE 70

$$Q_{PR4} = 16 \times 0.90 \times (59 - 41) = 259.2 \text{ BTU}$$

$$Q_{PR5} = 10 \times 0.999 \times (50 - 41) = 89.91 \text{ BTU}$$

$$Q_{PR6} = 6 \times 0.70 \times (75 - 41) = 142.8 \text{ BTU}$$

$$Q_{PR7} = 8 \times 0.93 \times (50 - 41) = 67 \text{ BTU}$$

$$Q_{PR} = Q_{PR1} + Q_{PR2} + Q_{PR3} + Q_{PR4} + Q_{PR5} + Q_{PR6} + Q_{PR7}$$

$$Q_{PR} = 298 + 24.1 + 167.4 + 259.2 + 89.91 + 142.8 + 67$$

$$Q_{PR} = 1048.5 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و مشخصات تغییرات :

تاریخ انتشار



کارخانجات صنعتی آزمایش

موضوع

نوع شربه

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره شربه:

طرح و شماره

PAGE 71

2. ΣQ_{PF1} = Heat removed from products to freeze product from initial temperature to freezing point above freezin point .

$$Q_{PF1} = W \times C \times \Delta t$$

Weight of products are as follows

1 - Fish 6 lbs

2 - Water 12 lbs

3 - Meef 10 lbs

$$\Delta t = (t_{pi} - t_{pf})$$

4 - $\Delta t_{fish} = 50 - 28 = 22 F$ " C " = 0.9 BTU / lb F

5 - $\Delta t_{meef} = 82.4 - 29 = 53.4 F$ " C " = 0.72 BTU / lb F

6 - $\Delta t_{water} = 50 - 32 = 18 F$ " C " = 0.999 BTU / lb F

9 - $Q_{PF1 fish} = 6 \times 0.9 \times 22 = 118.8 BTU$

10 - $Q_{PF1 meef} = 12 \times 0.72 \times 53.4 = 461.3 BTU$

11 - $Q_{PF1 water} = 5 \times 0.999 \times 18 = 90 BTU$

$$\Sigma Q_{PF1} = Q_{PF1 fish} + Q_{PF1 meef} + Q_{PF1 water}$$

$$\Sigma Q_{PF1} = 118.8 + 461.3 + 90$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماره وارد تغییرات:

تاریخ انقضای:



کارخانجات صنعتی آزمایش

موضوع

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

ط ————— رج 9 ————— رفاهه

PAGE 72

$$\Sigma Q_{PF1} = 670.1 \text{ BTU}$$

3 - ΣQ_{PF2} = Heat removed from freezing point to final temperature below freezing .

$$Q_{PF2} = W \times C_i \times (t_r - t_f)$$

1 - Fish 6 lbs

2 - Meet 12 lbs

3 - Ice 5 lbs

4 - $\Delta t_{fish} = 28 - 10.4 = 17.6 \text{ F}$ " C_{ifish} " = 0.49 BTU / lb F

5 - $\Delta t_{meet} = 29 - 10.4 = 18.6 \text{ F}$ " C_{imeet} " = 0.42 BTU / lb F

6 - $\Delta t_{ice} = 32 - 10.4 = 21.6 \text{ F}$ " C_{iice} " = 1 BTU / lb F

7 - $Q_{PF2fish} = 6 \times 0.49 \times 17.6 = 51.7 \text{ BTU}$

8 - $Q_{PF2meet} = 12 \times 0.42 \times 18.6 = 93.7 \text{ BTU}$

9 - $Q_{PF2ice} = 5 \times 1 \times 21.6 = 108 \text{ BTU}$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ وشمه ————— اورد تغییرات :

تاریخ انش ————— ار :



PAGE 73

$$\Sigma Q_{PF2} = Q_{PF2fish} + Q_{PF2meat} + Q_{PF2ice} = 51.7 + 93.71 + 108 = 253.4 \text{ BTU}$$

$$\Sigma Q_{PF} = 253.4 \text{ BTU}$$

4 - ΣQ_{LF} = Heat removal to freeze product

$$Q_{LF} = W \times h_{if}$$

WHERE

Q_{LF} = Heat removal by latent heat

W = Weight of product

h_{if} = Latent heat per BTU / lb

1 - Weight of product per pound

2 - Latent heat per BTU / lb

3 - Fish 6 lbs

4 - Meat 12 lbs

5 - Ice 5 lbs

$$Q_{LF_{fish}} = 6 \times 95 = 570 \text{ BTU}$$

$$Q_{LF_{meat}} = 12 \times 85.8 = 1029 \text{ BTU}$$



کارخانجات صنعتی آزمايش

موضوع :

نوع شربه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره شربه :

ط ————— رح و ب ————— ر ناعه

PAGE 74

$$Q_{L_{\text{Ice}}} = 5 \times 143.5 = 717.5 \text{ BTU}$$

$$Q_{LF} = Q_{LF_{\text{fish}}} + Q_{LF_{\text{meat}}} + Q_{LF_{\text{Ice}}}$$

$$Q_{LF} = 570 + 1029 + 717.5 = 2316.5 \text{ BTU}$$

$$Q_{LF} = 2316.5 \text{ BTU}$$

$$\Sigma Q_{PT} = 1048.5 + 670.1 + 253.4 + 2316.5 = 4288.5 \text{ BTU}$$

$$Q_{PT} = 4288.5 \text{ BTU in 24 hours}$$

$$Q_{PT_{\text{hr}}} = 4288.5 / 16 = 268 \text{ BTU / Hr.}$$

Note . Compressor operating time = 16 hours daily

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شدت تغییرات :

تاریخ انتشار :



کارخانجات صنعتی آزمایش

نوع شریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره شریه :

طرح 33 - رنانه

PAGE 75

C. Total heat gain through Refrigerator and Evaporator and heat removed from Products are calculated as follows .

$$Q_T = Q_{TR} + Q_{TE} + Q_{TP} = Q_{TC} + Q_{TP}$$

Where

Q_{TC} = Total heat gain by conduction

Q_{TR} = Total heat removed from products

$$Q_{TR} = 168.48 \text{ BTU / Hr}$$

$$Q_{TE} = 54.31 \text{ BTU / Hr}$$

$$Q_{TC} = Q_{TR} + Q_{TE} = 168.48 + 54.31 = 222.79 \text{ BTU / Hr}$$

$$Q_{TP} = 4288.5 \text{ BTU per 24 hours}$$

Note . Desired Compressor Operating Time = 16 Hours Daily

$$Q_{TP} / \text{Hr} = 4288.5 / 16 = 268 \text{ BTU / Hr}$$

$$Q_T = 222.79 + 268 = 490.79 \text{ BTU / Hr}$$

$$Q_{GT} = Q_T + 10 \% Q_T = 490.79 + 49.08 = 540.59 \text{ BTU / Hr}$$

$$Q_{GT} = 540.59 \text{ BTU / Hr}$$

$$Q_{GT} = 540.59 \times 0.2931 = 158.45 \text{ Watts}$$

$$Q_{GT} = 158.45 \text{ Watts / Hr}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماره تغییرات :

تاریخ انتشار :



کارخانجات صنعتی آزمايش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

طرح و شماره نامه

PAGE 76

D. Compressor selection for Model AR12

The compressor selection for Model AR12 is based on available or existing Compressor Models in Iranian Market at present which are as follows . Compressor power is to be 1/5 Hp , in all compressor types from different manufacturers .

Manufacturer Name	Model	Capacity .Watts
DANFUS	-----	----
NECCHI	ESC 8H	170
ASPERA	BP1112Z	152
GOLD STAR	NF 62	156
SICOM	AE1360YS	158

From the above figures the nearest possible Compressor Capacity which are compatible to our Energy Requirements for Model AR12 . could be either comp. Model AE1360YS from SICOM with comp. capacity of 158 watts or compressor Modl NF 62 from GOLD STAR, 156 Watts , the other Compressor models could be considered as alternatives due to the Laboratory test analysis .

Note 1 . 10 % additional load has been considered for Fridge air replacement and infiltration during the day .

Note 2 . For other equipment selection such as condenser , evaporator and drier refer to Section IV .

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماره نامه تغییرات :

تاریخ انتشار



SECTION X

REFRIGERATOR AND FREEZER MODEL ARF2 LOAD CALCULATION

A. Heat gain by conduction .

1 . Total heat gain by conduction in refrigerator compartment .

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot \Delta T_R$$

$$Q_{TA} = U_{TR} \cdot A_{TR} \cdot (T_e - T_r)$$

1

$$U_{TR_{ave}} = \frac{1}{x_1/k_1 + x_2/k_2 + x_3/k_3}$$

x_1 = Carbon steel thickness = 0.6 mm = 0.00197 ft.

x_{2-1} = Foam thickness (ave.) for fridge = 35 mm (average) = 0.1145 ft (ave.)

x_{2-2} = Foam thickness (Ave.) for freezer = 53 mm (Ave.) = 0.173 ft (Ave.)

x_3 = Inner liner ABS thickness = 2 mm = 0.00656 ft

k_1 = Steel thermal conductivity = 31.2 BTU / Hr . ft . F

k_2 = Foam thermal conductivity = 0.0104 BTU / Hr . ft . F

k_3 = PLastic thermal conductivity = 0.09 BTU / HR . ft . F

a-1 Heat gain by conduction through Fridge compartment .

$$A_{TR} = A_1 + A_2 + A_3 + A_4 + A_5$$

$$A_1 = A_2 \quad \& \quad A_3 = A_4$$




سازمان اسناد و کتابخانه ملی جمهوری اسلامی ایران

موضوع:

نوع نشریه:

شماره نشریه:

نوع نشریه:



ARF2

نوع و شماره نشریات:

نوع نشریه:



$$A1 = A2 \text{ \& } A3 = A4$$

$$ATR = 2A1 + 2A3 + A5$$

$$ATR = 2(1060 \times 495) + 2(520 \times 1060) + (520 \times 495)$$

$$ATR = 524700 + 551200 + 257400 = 2409161.6 \text{ sq.mm} = 25.932 \text{ sq.ft}$$

$$U_{TR} = \frac{1}{0.000063 + 11.001 + 0.0729} = \frac{1}{11.07395189}$$

$$U_{TR} = 0.090 \text{ BTU} / \text{Hr} \cdot \text{F} \cdot \text{sq.ft}$$

$$t_{a\max} = 43 \text{ C} = 109.4 \text{ F}$$

$$t_r = 5+2 \text{ C} = 41 +4 \text{ F}$$

$$(t_a - t_r) = 109.4 - 41 = 68.4 \text{ F}$$

$$Q_{TR} = 0.090 \times 25.932 \times 68.4 = 159.64 \text{ BTU} / \text{Hr}$$

$$Q_{TR} = 159.64 \text{ BTU} / \text{Hr}$$



a-2 . Total heat gain by conduction in Freezer compartment .

$$Q_{TF} = Q_{F1} + Q_{F2} + Q_{F3}$$

$$Q_{TF} = U_{TF} \cdot A_{TF} \cdot \Delta T_F$$

$$Q_{TF} = U_{TF} \cdot A_{TF} \cdot (T_a - T_F)$$

$$T_a = 109.4 \text{ F}$$

$$T_F = 0.4 \text{ F}$$

$$\Delta T_F = 109.4 - 0.4 = 109 \text{ F}$$

$$U_{TFave} = \frac{1}{x_1 / k_1 + x_2 / k_2 + x_3 / k_3}$$

$$x_1 = \text{Carbon steel thickness} = 0.6 \text{ mm} = 0.00197 \text{ ft.}$$

$$x_2 = \text{Foam thickness (ave.)} = 53 \text{ mm (average)} = 0.174 \text{ ft (ave.)}$$

$$x_3 = \text{Inner liner ABS thickness} = 2 \text{ mm} = 0.00656 \text{ f}$$

$$k_1 = \text{Steel thermal conductivity} = 31.2 \text{ BTU / Hr. ft. F}$$

$$k_2 = \text{Foam thermal conductivity} = 0.0104 \text{ BTU / Hr. ft.}$$

$$k_3 = \text{Plastic thermal conductivity} = 0.09 \text{ BTU / HR. ft. F}$$

$$A_{F1} = A_1 + A_2 + A_3 + A_4$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107



$$A_{T1} = A_1 + A_2 + A_3 + A_4$$

$$A_1 = A_2 \text{ \& } A_3 = A_4$$

$$A_1 = 360 \times 195 = 178560 \text{ sq.mm} = 1.92 \text{ sq.ft}$$

$$A_3 = 505 \times 195 = 249975 \text{ sq.mm} = 2.69 \text{ sq.ft}$$

$$x_1/k_1 = 0.000063$$

$$x_2/k_2 = 0.174 / 0.0104 = 16.72$$

$$x_3/k_3 = 0.0729$$

$$U_{T1} = \frac{1}{0.000063 + 16.72 + 0.0729} = \frac{1}{16.792963}$$

$$U_{T1} = 0.059 \text{ BTU / Hr. sq.ft. F}$$

$$t_{a, \text{room}} = 43 \text{ C} = 109.4 \text{ F Room Temp.}$$

$$t_{f1} = 0.4 \text{ F}$$

$$\Delta T_{T1} = (t_a - t_f) = 109.4 - 0.4 = 109 \text{ F}$$

$$Q_{T1} = U_{T1} \cdot A_{T1} \cdot \Delta T_{T1}$$

$$Q_{T1} = 0.059 \times 9.22 \times 109 = 59.3 \text{ BTU / Hr}$$



$$Q_{F2} = U_{F2} \cdot A_{F2} \cdot \Delta T_2$$

$$A_{F2} = A_{F1} = 228160 \text{ sq. mm} = 2.456 \text{ sq. Ft}$$

1

$$U_{TF2} = \frac{1}{x_1/k_1 + x_2/k_2 + x_3/k_3}$$

$$x_1/k_1 = 0.000063$$

$$x_2/k_2 = 18.93$$

$$x_3/k_3 = 0.0729$$

1

$$U_{TF2} = \frac{1}{0.000063 + 18.93 + 0.0729}$$

$$U_{TF2} = 0.052 \text{ BTU / Hr. sq.Ft. } ^\circ\text{F}$$

$$\Delta T_{F2} = T_R - T_F = 41 - 0.4 = 40.6 \text{ } ^\circ\text{F}$$

$$Q_{F2} = 0.052 \times 2.456 \times 40.6 = 13.92 \text{ BTU / Hr}$$

$$Q_{F3} = U_{F3} \cdot A_{F3T} \cdot \Delta T_3$$

$$U_{F3} = U_{F2}$$

$$U_{F3} = 0.052 \text{ BTU / Hr sq.ft. } ^\circ\text{F}$$



کارخانجات صنعتی آزمایش

موضوع:

نوع شریه:

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره شریه:

ط ————— رج 9 ————— رتاعه

PAGE 82

$$U_{F3} = 0.052 \text{ BTU} / \text{Hr} \cdot \text{sq.Ft} \cdot \text{F}$$

$$A_{F1} = A_{F2}$$

$$A_{F3} = 2.456 \text{ sq. FT}$$

$$\Delta T_{FR} = T_R - T_F = 11 - 0.4 = 10.6 \text{ F}$$

$$Q_{F3} = 0.052 \times 2.456 \times 40.6 = 5.185 \text{ BTU} / \text{Hr}$$

$$Q_{TF} = Q_{F1} + Q_{F2} + Q_{F3}$$

$$Q_{TF} = 59.3 + 13.92 + 5.185 = 78.4 \text{ BTU} / \text{Hr}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ و شماره تغییرات:

تاریخ انتشار:



B. PRODUCT LOAD CALCULATION FORMODEL ARF2

$$Q_{PT} = \Sigma Q_{PR} + \Sigma Q_{PF} + \Sigma Q_{LF} + \Sigma Q_F$$

1. ΣQ_{PR} = Heat removed from products above freezing point

$$Q_{PR} = W_P \cdot C_P \cdot \Delta T_R = W_P \cdot C_P \cdot (t_1 - t_2)$$

WHERE

1 . t_1 = For red and white fresh meet (Ave.) = 82.4 F

2 . t_1 = For butter and cheese (Ave.) = 50 F

3 . t_1 = For mixed vegetables (Ave.) = 59 F

4 . t_1 = For fruits of any kind (Ave.) = 59 F

5 . t_1 = For water = 50 F

6 . t_1 = For bread = 75 F

7 . t_2 = For all above products = (Ave.) 41 F

$$\Delta T_{R:1} = 41.4 F$$

$$\Delta T_{R:2} = 9 F$$

$$\Delta T_{R:3} = 18 F$$

$$\Delta T_{R:4} = 18 F$$

$$\Delta T_{R:5} = 9 F$$



کارخانجات صنعتی آزمايش

موضوع

نوع نشریه :

**AZMAYESH INDUSTRIAL
FACTORIES COMPANY**

شماره نشریه :

ط ————— روح و ————— رفاه

PAGE 84

$$\Delta Tr_{1-6} = 34 F$$

Average sum of " C " specific heat for above products from Table 1 are as follows .

$$" C_1 " = 0.72 \text{ BTU / lb . F}$$

$$" C_2 " = 0.67 \text{ BTU / lb . F}$$

$$" C_3 " = 0.93 \text{ BTU / lb . F}$$

$$" C_4 " = 0.9 \text{ BTU / lb . F}$$

$$" C_5 " = 0.999 \text{ BTU / lb . F}$$

$$" C_6 " = 0.70 \text{ BTU / lb . F}$$

$$" C_7 " = \text{For milk} = 0.93 \text{ BTU / lb . F}$$

Average Product Weight per Pound .

$$W_1 = 10 \text{ lb Meet and Fish}$$

$$W_2 = 4 \text{ lb Butter and cheese}$$

$$W_3 = 10 \text{ lb Vegetable (mixed) and lettuce}$$

$$W_4 = 16 \text{ lb Fruit of any kind}$$

$$W_5 = 10 \text{ lb Water}$$

$$W_6 = 6 \text{ lb Bread}$$

$$W_7 = 8 \text{ lb Milk}$$

$$Q_{Pr1} = 10 \times 0.72 \times (82.4 - 41) = 298 \text{ BTU}$$

$$Q_{Pr2} = 4 \times 0.67 \times (50 - 41) = 24.1 \text{ BTU}$$

$$Q_{Pr3} = 10 \times 0.93 \times (59 - 41) = 167.4 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ وشم ————— اورد تغییرات :

تاریخ انتشار ————— ار :



کارخانجات صنعتی آزمايش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

طرح و پیمان نامه

PAGE 85

$$Q_{Pr4} = 16 \times 0.90 \times (59 - 41) = 259.2 \text{ BTU}$$

$$Q_{Pr5} = 10 \times 0.999 \times (50 - 41) = 89.91 \text{ BTU}$$

$$Q_{Pr6} = 6 \times 0.70 \times (75 - 41) = 142.8 \text{ BTU}$$

$$Q_{Pr7} = 8 \times 0.93 \times (50 - 41) = 67 \text{ BTU}$$

$$Q_{Pr} = Q_{Pr1} + Q_{Pr2} + Q_{Pr3} + Q_{Pr4} + Q_{Pr5} + Q_{Pr6} + Q_{Pr7}$$

$$Q_{Pr} = 298 + 24.1 + 167.4 + 259.2 + 89.91 + 142.8 + 67$$

$$Q_{Pr} = 1048.5 \text{ BTU}$$

P.O. BOX 16745 - 1898 TEHRAN IRAN

FAX. 98 21 777107

تاریخ وشمارة تغییرات :

تاریخ انتشار :



2. $\sum Q_{PFI}$ = Heat removed from products to freeze product from initial temperature to freezing point above freezin point .

$$Q_{PFI} = W \times C \times \Delta t$$

Weight of products are as follows

1 - Fish 6 lbs

2- Vegetables 8 lbs

3 - Water 8 lbs

4 - Meet 10 lbs

$$\Delta t = (t_{pi} - t_{pf})$$

5 - $\Delta t_{fish} = 50 - 28 = 22 F$ "C" = 0.9 BTU / lb F

6 - $\Delta t_{meet} = 82.4 - 29 = 53.4 F$ "C" = 0.72 BTU / lb F

7 - $\Delta t_{water} = 50 - 32 = 18 F$ "C" = 0.999 BTU / lb F

8 - $\Delta t_{veg.} = 59 - 30 = 29 F$ "C" = 0.93 BTU / lb F

9 - $Q_{PFI_{fish}} = 6 \times 0.9 \times 22 = 118.8 BTU$

10 - $Q_{PFI_{meet}} = 10 \times 0.72 \times 53.4 = 384.48 BTU$

11 - $Q_{PFI_{water}} = 8 \times 0.999 \times 18 = 143.85 BTU$

12 - $Q_{PFI_{veg.}} = 8 \times 0.93 \times 29 = 215.76 BTU$

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107



PAGE 87

$$\Sigma Q_{PF1} = Q_{PF1 \text{ fish}} + Q_{PF1 \text{ meet}} + Q_{PF1 \text{ water}} + Q_{PF1 \text{ veg}}$$

$$\Sigma Q_{PF1} = 118.8 + 215.76 + 384.48 + 143.85$$

$$\Sigma Q_{PF1} = 826.9 \text{ BTU}$$

3 - ΣQ_{PF2} = Heat removed from freezing point to final temperature below freezing .

$$Q_{PF2} = W \times C_i \times (t_r - t_s)$$

1 - Fish 6 lbs

2- Meet 10 lbs

3 - Ice 8 lbs

4 - Vegetable 8 lbs

5 - $\Delta t_{\text{fish}} = 28 - 10.4 = 17.6 \text{ F}$ " $C_{i \text{ fish}}$ " = 0.49 BTU / lb F

6 - $\Delta t_{\text{meet}} = 29 - 10.4 = 18.6 \text{ F}$ " $C_{i \text{ meet}}$ " = 0.42 BTU / lb F

7 - $\Delta t_{\text{ice}} = 32 - 10.4 = 21.6 \text{ F}$ " $C_{i \text{ ice}}$ " = 1 BTU / lb F

8 - $\Delta t_{\text{veg}} = 30 - 0.4 = 29.6 \text{ F}$ " $C_{i \text{ veg}}$ " = 0.45 BTU / lb

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107



کارخانجات صنعتی آزمايش

موضوع :

نوع نشریه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره نشریه :

طرح و برنامه

PAGE 88

$$9 - Q_{PF2fish} = 6 \times 0.49 \times 27.6 = 81.14 \text{ BTU}$$

$$8 - Q_{PF2meat} = 10 \times 0.40 \times 28.6 = 114.4 \text{ BTU}$$

$$9 - Q_{PF2ice} = 8 \times 1 \times 31.6 = 251.2 \text{ BTU}$$

$$10 - Q_{PF2veg} = 8 \times 0.45 \times 29.6 = 106.56 \text{ BTU}$$

$$\Sigma Q_{PF2} = Q_{PF2fish} + Q_{PF2meat} + Q_{PF2ice} + Q_{PF2veg}$$

$$\Sigma Q_{PF2} = 81.14 + 114.4 + 251.2 + 106.56$$

$$\Sigma Q_{PF} = 553.3 \text{ BTU}$$

4 - $\Sigma Q_{LF} =$ Heat removal to freeze product

$$Q_{LF} = W \times h_{if}$$

WHERE

Q_{LF} = Heat removal by latent heat

W = Weight of product

h_{if} = Latent heat per BTU / lb

1 - Weight of product per pound

2 - Latent heat per BTU / lb

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107

تاریخ و شماره تغییرات :

تاریخ انتشار :



کارخانجات صنعتی آزمايش

موضوع :

نوع شريه :

AZMAYESH INDUSTRIAL
FACTORIES COMPANY

شماره شريه :

ط ————— رح 9 : رنامه

PAGE 89

4 - Meert 10 lbs

5 - Ice 8 lbs

6 - Vegetable 8

$$QLF_{fis} = 6 \times 95 = 570 \text{ BTU}$$

$$QLF_{meert} = 10 \times 85.8 = 858 \text{ BTU}$$

$$QLF_{ice} = 8 \times 143.5 = 1148 \text{ BTU}$$

$$QLF_{ice} = 8 \times 130 = 1040 \text{ BTU}$$

$$QLF = QLF_{fis} + QLF_{meert} + QLF_{ice} + QLF_{veg}$$

$$QLF = 570 + 858 + 1148 + 1040 = 3796 \text{ BTU}$$

$$QLF = 3796 \text{ BTU}$$

$$\Sigma Q_{PT} = 1048.5 + 862.9 + 553.3 + 3796 = 6361 \text{ BTU}$$

$$Q_{PT} = 6361 \text{ BTU in 24 hours}$$

$$Q_{PT,hr} = 6361 / 16 = 397.56 \text{ BTU / Hr.}$$

Note . Compressor operating time = 16 hours daily

P.O. BOX 16745 - 1898 TEHRAN IRAN FAX. 98 21 777107

تاريخ وشماره تغييرات :

تاريخ انشاء :



C. Total heat gain through Refrigerator and Evaporator and heat removed from Products are calculated as follows .

$$Q_T = Q_{TR} + Q_{TE} + Q_{TP} = Q_{TC} + Q_{TP}$$

Where

Q_{TC} = Total heat gain by conduction

Q_{TR} = Total heat removed from products

$$Q_{TR} = 159.64 \text{ BTU / Hr}$$

$$Q_{TE} = 78.4 \text{ BTU / Hr}$$

$$Q_{TC} = Q_{TR} + Q_{TE} = 159.64 + 78.4 = 238.04 \text{ BTU / Hr}$$

$$Q_{TP} = 6361 \text{ BTU per 24 hours}$$

Note . Desired Compressor Operating Time = 16 Hours Daily

$$Q_{TP} / \text{Hr} = 6361 / 16 = 397.56 \text{ BTU / Hr}$$

$$Q_T = 238.04 + 397.56 = 635.6 \text{ BTU / Hr}$$

$$Q_{GT} = Q_T + 10 \% Q_T = 635.6 + 63.56 = 699.16 \text{ BTU / Hr}$$

$$Q_{GT} = 699.16 \text{ BTU / Hr}$$

$$Q_{GT} = 699.16 \times 0.2931 = 204.92 \text{ Watts}$$

$$Q_{GT} = 204.92 \text{ Watts / Hr}$$

**D. Compressor selection for Model ARF2**

The compressor selection for Model ARF2 is based on available or existing Compressor Models in Iranian Market at present which are as follows , Compressor power is to be 1/5 Hp , in all compressor types from different manufacturers .

Manufacturer Name	Model	Capacity ,Watts
DANFUS	-----	----
NECCHI	ESC 9HK	203
ASPERA	BP1116Z	207
GOLD STAR	VF 75	205
SICOM	AE1370YS	186

From the above figures the nearest possible Compressor Capacity which are compatible to our Energy Requirements for Model ARF2 , could be either comp. Model ESC 9HK from NECCHI with comp. capacity of 203 watts or compressor Modl BK1116z from ASPERA, 207 Watts , the other Compressor models could be considered as alternatives due to the Laboratory test analysis .

Note 1 . 10 % additional load has been considered for Fridge air replacement and infiltration during the day .

Note 2 . For other equipment selection such as condenser , evaporator and drier refer to Section IV .



AZMAYESH INDUSTRIAL FACTORIES CO.

PROJECT NO. MP/IRA/94/403

UNIDO,s CONTRACT NO. 94/097



PROGRESS REPORT # 2



PREPARED BY: A. BAHMANI

EDITED AND APPROVED BY: N. IMANI

Date: May 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

TABLE OF CONTENTS

<u>DESCRIPTION</u>	<u>CHAPTER</u>	<u>PAGE</u>
<i>PRODUCT SPECIFICATION</i>	<i>CHAPTER 1</i>	<i>1 - 1</i>
<i>WORKING PERFORMANCE CHARACTERISTICS</i>	<i>CHAPTER 2</i>	<i>2 - 1</i>
<i>DETERMINATION OF CONSTANT " C "</i>	<i>CHAPTER 3</i>	<i>3 - 1</i>
<i>SELECTION OF R134_a COMPATIBLE COMPONENTS</i>	<i>CHAPTER 4</i>	<i>4 - 1</i>
<i>EVALUATION OF PROTOTYPES</i>	<i>CHAPTER 5</i>	<i>5 - 1</i>
<i>TEMPERATURE TEST PROCEDURE</i>	<i>CHAPTER 6</i>	<i>6 - 1</i>
<i>ENERGY CONSUMPTION</i>	<i>CHAPTER 7</i>	<i>7 - 1</i>
<i>OPTIMIZATION METHOD</i>	<i>CHAPTER 8</i>	<i>8 - 1</i>
<i>PREPARATION OF TRIAL EQUIPMENTS</i>	<i>CHAPTER 9</i>	<i>9 - 1</i>



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2



PROJECT NO . MP / IRA / 94 / 405

CONTRACT NO . 94 / 097

III

8 - Preparation of " Optimization Method " for selecting suitable components like compressor , condenser , capillary tube , Refrigerant weight and Insulation type and material .

9 - A summary about preparation and accomplishment of trial test and documentaion regarding selection of some component for our prototypes .



CHAPTER 1

PRODUCT SPECIFICATION

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PROGRESS REPORT # 2

PROTOTYPE TEST RESULTS ANALYSIS

With respect to contract No. 94/097 with UNIDO Para 2.09 a , Azmayesh company is honored here with to present the second progress report regarding making prototypes as well as accomplishing necessary modifications and optimization with regard to energy consumption .

This report contains the Analysis of 5 Azmayesh Refrigerator and Ref-Freezer Models AR06 , AR08 , AR10 , AR12 and ARF2 , R134a prototypes performance test in comparison with application refrigerant R12 , in order to reach a reasonable result for selecting R134a refrigerant as well as trying all possible ways of optimizing the refrigeration system for obtaining the required energy consumption .

This report will discuss the following subjects .

- 1 - Products specifications
- 2 - Working performance characteristics of 5 Models of Azmayesh Refrigerator and Ref-Freezers



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 403

CONTRACT NO . 94 / 097

3 - Determination of Constant " C " in order to determine actual heat resistance coefficient factor and also actual sum of heat transfer in WATT .

4 - Selection of HFC 134a compatible components like compressor and drier . It should be noticed that through our experiences , evaporator , condenser and capillary tube will not be changed , but a modification on refrigerator water drainage tray under freezer compartment will be accomplished .

5 - Reviewing , Analyzing , Evaluating and Comparing test results of Refrigerator and Ref - Rreezer models AR06 , AR08 , AR10 , AR12 and ARF2 .

6 - Preparation of " Storage Temperature Test Procedure " in accordance with , ISO 7371 , ISO 8187 and DIN 8950 for Classification Code " T " under ambient temperature 43 , 32 and 18 degree centigrade .

7 - Preparation of " Energy Consumption Test Procedure " under ambient temperature of 18 degree centigrade in accordance with ISO 7173 , and ISO 8187 .

**AZMAYESH INDUSTRIAL FACTORIES COMPANY**

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 405

CONTRACT NO. 94 / 097

PAGE 1 - 1**MODEL AR06 TECHNICAL SPECIFICATION**

STAR CODE	TWO STAR
EGG SHELVES / NUMBER OF EGGS	1 / 9
BUTTER AND CHEESE COMPARTMENT	1
BOTTLE SHELVES / NUMBER OF BOTTLE	1 / 4
VARIABLE HEIGHT STAGE	2
MEAT TRAY	1
FRUIT COMPARTMENT	1
VOLUME LIT.	180
COOLING WATT CAPACITY WATT	95
ENERGY CONSUMPTION KW / 24 HRS.	1.3
COMPRESSOR SIZE (C Cm.)	4.3
EVAPORATOR TYPE	ROLLBOND
VOLTAGE RANGE	165-230VOLT
DIMENSION	98 X 60 X50
NET WEIGHT Kg.	42



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 406

CONTRACT NO. 94 / 097

PAGE 1 - 2

MODEL AR08 TECHNICAL SPECIFICATION

STAR CODE	TWO STAR
EGG SHELVES / NUMBER OF EGGS	1 / 9
BUTTER AND CHEESE COMPARTMENT	1
BOTTLE SHELVES / NUMBER OF BOTTLE	2 / 10
VARIABLE HEIGHT STAGE	3
MEAT TRAY	1
FRUIT COMPARTMENT	1
VOLUME LIT.	230
COOLING WATT CAPACITY WATT	108
ENERGY CONSUMPTION KW / 24 HRS.	1.5
COMPRESSOR SIZE (C.Cm.)	4.3
EVAPORATOR TYPE	ROLLBOND
VOLTAGE RANGE	165-230VOLT
DIMENSION	119 X 60 X 59
NET WEIGHT Kg.	45

**AZMAYESH INDUSTRIAL FACTORIES COMPANY**

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 405

CONTRACT NO. 94 / 097

PAGE 1 - 3**MODEL ARI0 TECHNICAL SPECIFICATION**

STAR CODE	TWO STAR
EGG SHELVES / NUMBER OF EGGS	2 / 18
BUTTER AND CHEESE COMPARTMENT	2
BOTTLE SHELVES / NUMBER OF BOTTLE	2 / 10
VARIABLE HEIGHT STAGE	3
MEAT TRAY	1
FRUIT COMPARTMENT	1
VOLUME LIT.	280
COOLING WATT CAPACITY WATT	125
ENERGY CONSUMPTION KW / 24 HRS.	1.85
COMPRESSOR SIZE (C.Cm .)	5.2
EVAPORATOR TYPE	ROLLBOND
VOLTAGE RANGE	165-230VOLT
DIMENSION	141 X 60 X 59
NET WEIGHT Kg.	57.2

**AZMAYESH INDUSTRIAL FACTORIES COMPANY***ELECTRICALS / HOME APPLIANCES***PROGRESS REPORT # 2**

PROJECT NO. AP / IRA / 94 / 408

CONTRACT NO. 94 / 087

PAGE 1 - 1**MODEL ARI2 TECHNICAL SPECIFICATION**

STAR CODE	TWO STAR
EGG SHELVES / NUMBER OF EGGS	2 / 18
BUTTER AND CHEESE COMPARTMENT	2
BOTTLE SHELVES / NUMBER OF BOTTLE	2 / 10
VARIABLE HEIGHT STAGE	3
MEAT TRAY	1
FRUIT COMPARTMENT	1
VOLUME LIT.	340
COOLING WATT CAPACITY WATT	158
ENERGY CONSUMPTION KW / 24 HRS.	2.25
COMPRESSOR SIZE (C.Cm.)	6.6
EVAPORATOR TYPE	ROLL BOND
VOLTAGE RANGE	165-230 VOLT
DIMENSION	164 X 60 X 59
NET WEIGHT Kg.	60



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 408

CONTRACT NO. 95 / 087

PAGE 1 - 5

MODEL ARF2 TECHNICAL SPECIFICATION

STAR CODE	THREE STAR
EGG SHELVES / NUMBER OF EGGS	1 / 9
BUTTER AND CHEESE COMPARTMENT	1
BOTTLE SHELVES / NUMBER OF BOTTLE	2 / 10
VARIABLE HEIGHT STAGE	3
FRUIT COMPARTMENT	1
TOTAL VOLUME LIT.	310
FREEZER VOLUME LIT.	78
COOLING WATT CAPACITY WATT	205
ENERGY CONSUMPTION KW / 24 HRS.	3
NUMBER OF EVAPORATOR	2
EVAPORATOR TYPE	ROLL-BOND TUBE
VOLTAGE RANGE	165-230 VOLT
DIMENSION	164 X 60 X 59
NET WEIGHT Kg.	61



CHAPTER 2

WORKING PERFORMANCE

CHARACTERISTIC

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 007

PAGE 2 - 1

WORKING PERFORMANCE CHARACTERISTICS
MODEL ARC6

REFRIGERANT	R12
THERMOSTAT TYPE	PUSH BOTTON DEFROST
COOLING CAPACITY	95 WATT
AMBIENT TEMPERATURE	43 C
ENERGY CONSUMPTION Kw 24 / Hrs	1.3
THERMOSTAT ON POSITION TIME	6'50"
THERMOSTAT OFF POSITION	4' 50"
FREEZER MEAN TEMPERATURE	-12 C
CABINET MEAN TEMPERATURE	+ 5 C
CELLAR MEAN TEMPERATURE	+ 10 C
EVAPORATING TEMPERATURE	- 18 C
SUCTION TEMPERATURE	+45 C
CONDENSER INLET TEMPERATURE	+ 65 C
CONDENSER OUTLET TEMPERATURE	+ 51 C
COMPRESSOR SHELL	+ 65 C
SUB-COOLING TEMPERATURE	+ 32 C
REFRIGERANT WEIGHT	110 Gr.
ICE MAKING CAPACITY	2 Kg / Hr
COMPRESSOR RUNNING TIME	LESS THAN 75 %



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 2 - 2

WORKING PERFORMANCE CHARACTERISTICS
MODEL ARC8

REFRIGERANT	R12
THERMOSTAT TYPE	PUSH BOTTOM DEFROST
COOLING CAPACITY	108 WATT
AMBIENT TEMPERATURE	43 C
ENERGY CONSUMPTION Kwatt / 24 Hrs	1.5
THERMOSTAT ON POSITION TIME	6'50"
THERMOSTAT OFF POSITION	4' 50"
FREEZER MEAN TEMPERATURE	-12 C
CABINET MEAN TEMPERATURE	+ 5 C
CELLAR MEAN TEMPERATURE	+ 10 C
EVAPORATING TEMPERATURE	- 18 C
SUCTION TEMPERATURE	+ 45 C
CONDENSER INLET TEMPERATURE	+ 65 C
CONDENSER OUTLET TEMPERATURE	+ 51 C
COMPRESSOR SHELL	+ 65 C
SUB-COOLING TEMPERATURE	+ 32 C
REFRIGERANT WEIGHT	110 Gr.
ICE MAKING CAPACITY	2 Kg / Hr
COMPRESSOR RUNNING TIME	LESS THAN 75 %



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 007

PAGE 2 - 3

WORKING PERFORMANCE CHARACTERISTICS
MODEL ARI0

REFRIGERANT	R12
THERMOSTAT TYPE	PUSH BOTTONDEFROST
COOLING CAPACITY	125 WATT
AMBIENT TEMPERATURE	32 C
ENERGY CONSUMPTION Kwatt 24 / Hrs	1.85
THERMOSTAT ON POSITION TIME	3'
THERMOSTAT OFF POSITION	5' 30"
FREEZER MEAN TEMPERATURE	-10 C
CABINET MEAN TEMPERATURE	+ 2.5 C
CELLAR MEAN TEMPERATURE	+ 6 C
EVAPORATING TEMPERATURE	- 21 C
SUCTION TEMPERATURE	+ 32 C
CONDENSER INLET TEMPERATURE	+ 48 C
CONDENSER OUTLET TEMPERATURE	+ 38 C
COMPRESSOR SHELL	+ 58 C
SUB-COOLING TEMPERATURE	+ 32 C
REFRIGERANT WEIGHT	140 Gr.
ICE MAKING CAPACITY	1 Kg / Hr
COMPRESSOR RUNNING TIME	LESS THAN 75 %

**AZMAYESH INDUSTRIAL FACTORIES COMPANY****ELECTRICAL / HOME APPLIANCES****PROGRESS REPORT # 2**

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 007

PAGE 2-4**WORKING PERFORMANCE CHARACTERISTICS
MODEL AR12**

REFRIGERANT	R12
THERMOSTAT TYPE	PUSH BUTTON DEFROST
COOLING CAPACITY	158 WATT
AMBIENT TEMPERATURE	32 C
ENERGY CONSUMPTION Kwatt / 24 Hrs	2.25
THERMOSTAT ON POSITION TIME	2' 50"
THERMOSTAT OFF POSITION	4' 50"
FREEZER MEAN TEMPERATURE	-12 C
CABINET MEAN TEMPERATURE	+4.25 C
CELLAR MEAN TEMPERATURE	+7 C
EVAPORATING TEMPERATURE	-18 C
SUCTION TEMPERATURE	+33 C
CONDENSER INLET TEMPERATURE	+50 C
CONDENSER OUTLET TEMPERATURE	+40 C
COMPRESSOR SHELL	+64 C
SUB-COOLING TEMPERATURE	+32 C
REFRIGERANT WEIGHT	150 Gr.
ICE MAKING CAPACITY	1 Kg / Hr
COMPRESSOR RUNNING TIME	LESS THAN 75 %



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403


CONTRACT NO . 94 / 097

PAGE 2-5


WORKING PERFORMANCE CHARACTERISTICS
MODEL ARF2

REFRIGERANT	R12
THERMOSTAT TYPE	PUSH BOTTON DEFROST
COOLING CAPACITY	204 WATT
AMBIENT TEMPERATURE	32 C
ENERGY CONSUMPTION Kwatt / 24 Hrs	3
THERMOSTAT ON POSITION TIME	18'
THERMOSTAT OFF POSITION	16'
FREEZER MEAN TEMPERATURE	- 24 C
CABINET MEAN TEMPERATURE	+ 3 C
CELLAR MEAN TEMPERATURE	+ 4 C
EVAPORATING TEMPERATURE	- 27 C
SUCTION TEMPERATURE	+ 33 C
CONDENSER INLET TEMPERATURE	+ 55 C
CONDENSER OUTLET TEMPERATURE	+ 42 C
COMPRESSOR SHELL	+ 59 C
SUB-COOLING TEMPERATURE	+ 32 C
REFRIGERANT WEIGHT	220 Gr.
ICE MAKING CAPACITY	1 Kg / Hr
COMPRESSOR RUNNING TIME	LESS THAN 75 %


HFC 134a CHARACTERISTICS



Cl → H



<p>HFC134a has no chlorine.</p>	<ul style="list-style-type: none"> ◆ ODP(Ozone Depletion Potential) is Zero. ◆ Poor miscibility with existing oil. (Mineral/Alkyl benzene) ◆ Ester-base oil is necessary. <div style="text-align: center;">↓</div> <div style="border: 1px solid black; padding: 5px; margin: 5px auto; width: 80%;"> <ul style="list-style-type: none"> ● High Hygroscopicity ● Chemical Reaction </div> <ul style="list-style-type: none"> ◆ No metal chloride coat formation on bearing metal surfaces. <div style="text-align: center;">↓</div> <div style="border: 1px solid black; padding: 5px; margin: 5px auto; width: 80%;"> <ul style="list-style-type: none"> ● Poor Lubricity </div>
<p>HFC134a's specific volume of gas phase is greater than CFC12's.</p>	<ul style="list-style-type: none"> ◆ Mass flow rate is reduced. <div style="text-align: center;">↓</div> <div style="border: 1px solid black; padding: 5px; margin: 5px auto; width: 80%;"> <ul style="list-style-type: none"> ● Poor Cooling Capacity </div>



CHAPTER 3

DETERMINATION OF

CONSTANT " C "

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 3-1

Determination of Constant " C "

One of the most important means to reduce the energy consumption and refrigeration system optimization is determination of actual Constant " C " , constant C figure has 2 parameters :

a . Insulation Material

b . Watt energy

1 - Finding the Insulation Material Thermal Conductivity

Finding the insulation Material Thermal Conductivity is actually impractical because of the mixture of three different types of chemical substances . So this measurement should be performed either repeatedly by Measuring Devices through sampling procedures or determination of Constant " C " by achieving steps 3 through 9 , We believe that determination of " C " constant in our factory is not repeatedly practical , because we have an accurate measuring device which could easily measure the actual foam constant " K " factor, but for determination of WATT energy required to be transferred and also calculating exact sum of



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 405

CONTRACT NO . 94 / 097

PAGE 3-2

area of cooling and freezing compartment which transfer heat .

2 - Assumption of WATT energy

For energy transfered by heat in WATT , we measure constant "C " by accomplishing steps 3 through 9 as follows .

3 - Determination of the Cabinet Constant " C "

3 - 1 The refrigerator is kept in test room at (t_a) .

3 - 2 Installation of electrical heater of (P) inside the refrigerator cabinet for getting inside temperature (t_i) .

3 - 3 The defference ($t_i - t_a$) should be equal - 20 k

$$\text{Cabinet Constant " C " } = \frac{P}{(t_i - t_a)}$$

P in Watt

($t_i - t_a$) in k



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 3-3

3 - 4 For model AR08 Refrigerator

$$P = 20 \text{ Watt}$$

$$t_i = 37.86 \text{ C}$$

$$t_a = 25.43 \text{ C}$$

$$C = \frac{p}{(t_i - t_a)} = \frac{20 \text{ watt}}{36.86 - 25.43} = 1.61 \text{ W/k}$$

$$\underline{\underline{'' C '' = 1.61 \text{ W / K}}}$$

3 - 5 the cabinet constant C of refrigerator Model AR08 is 1.61 W / K

3 - 6 The practical overall Heat Transfer Coefficient (K) can be found from " C " as follows :

$$\underline{\underline{K = C / A \text{ Units for C in W/K and A in square inch .}}}$$

$$\underline{\underline{A = \text{Effective Heat Transmission Area}}}$$

3 - 7 Simple derivation for separate cabinet constant of freezer compartment and refrigerator compartment (cooling compartment) enclosing cellar compartment can be found as follows :



CHAPTER 4

*SELECTION OF R134
COMPATIBLE COMPONENTS*

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



SELECTION OF R134a COMPATIBLE COMPONENTS

The theoretical assessment of refrigerator cycle for use of refrigerant R134a will only lead us to select major components like compressor , which we essentially rely on Compressor Manufacturer Technical Data and Specifications . The selection of other components like Capillary tube , Evaporator , Condenser will be discussed in the following paragraphs .

1 - Compressor

The compressor is the heart of refrigeration system . The compressor insufficiencies are motor losses , suction gas heating , bearing losses , suction and discharge port pressure drops , and non-isothermal compression . A direct means of reducing compressor losses is to improve the electric motor efficiency , lubricants and reduce suction gas heating which is beyond the scope of our progress report . The amount of most of these losses are related to the pressure ratio across the compressor .



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 4 - 2

In our case , the concept is using refrigerant R134a , we are not much flexible in designing and selecting compressors , so we are seriously depend on Manufacturer Compressor Capability , Capacity , Compatibilty , Efficiency and Energy consumption ratio , which for each manufacturer the above factors are largely different . For instance , the factor for converting DANFOSS Compressor characteristics from CECOMAF Standard to ASHRAE Standard (with consideration of sub - cooling incorporation) , we have to multiply Watt Capacity in CECOMAF condition by Constant value of 1.231 plus consideration of almost 4.1 Watt / Degree for - 23.3 C evaporating temperature . This condition for ZANUSSI compressor is completely different , it means that for converting CECOMAF Standard to ASHRAE Standards we have to use Constant factor 1.18 or less .

Therefore these facts tell us , not to rely only on COPMRESSOR MANUFACTURER technical specifications but rely mostly on our Laboratory test results as well as those figures that could lead us to select a suitable compressor .

Table 1 shows the variety of compressor selection and Watt



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 4 - 3

capacity . More than ten major Compressor manufacturers and suppliers (listed below)are supplying so many defferent kinds of Compressors with different prices and characteristics as well as two domestic large Compressor Manufacturers which shall produce more than two milion units per year in the near future .

In order to have better understanding about Hermetic Compressors using ESTER OIL and Refrigerant R134a it will be very usefull to enclose an analytical investigation report prepared by GOLD STAR Co . in this regard .

The following Compressor Manufacturers are offering their products to Iranian household Refrigerator manufacturer .

COMPRESSOR MANUFACTURER

- 1 - MATSUSHITA (NATIONAL)
- 2 - ZANUSSI (ELECTROLUX)
- 3 - DANFOSS
- 4 - NECCHI
- 5 - GOLDSTAR



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 04 / 403

CONTRACT NO . 04 / 007

PAGE 4-4

6 - SAMSUNG

7 - ASPERA

8 - ELECTROLUX

9 - SICOM

10-TECUMSEH

According to the above discussion the following parameters are considered :

1 - Our refrigerator cooling capacities are as follows

AR06	95 WATT
AR08	108 WATT
AR10	125 WATT
AR12	158 WATT
ARF2	205 WATT

2 - ASHRAE TEST STANDARD

Evaporating temp . = - 23.3

Condensing temp. = + 55



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 405

CONTRACT NO . 94 / 097

PAGE 4-5

Sub - Cooling temp . = + 32 C

Suction temp . = + 32 C

Ambient temp . = + 32 C

- 3 - Minimum Compressor power ratio .
- 4 - Laboratory Performance test approval .
- 5 - Reasonable and price .
- 6 - Compatibility of compressor with our refrigeration system components .

2 - Evaporator and condenser

Efficiency losses in evaporator and condenser are associated with finite temperature differences between the refrigerator and air , with pressure drop , and with reduction in heat transfer due to oil circulation with refrigerants . Maximization of heat transfer along with minimization of pressure drop is largely a matter of performance - cost tradeoffs .

designing compact evaporators and condenser could be an art , specially with the space constraints imposed due to Refrigerator



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 4-6

and Freezer volume and standard size .

In our R12 into R134a Models conversion programme , through laboratory tests and also recommendation from most large refrigerator and household manufacturer and also restriction imposed due to design of refrigerators , we did not consider any changes or modifications on evaporator and condenser , Azmayesh Co . has planned to change its tube and plate type of condenser and rollbond type of evaporator into wire tube evaporator and condenser in the near future after investigation of their efficiency on our products and engineering assessment and research .

But up to now , we found it unnecessary to change evaporator and condenser design .

3 - Capillary tube

The refrigerant expansion in a capillary tube is a non-reversible process . It has a potential for work , but requires a mechanism such as a miniature turbine to extract work . Such a mechanism will unlikely to be implemented due to the cost consideration .

AZMAYESH NON CFC REFRIGERATOR TRIAL PRODUCTION COMPRESSOR SELECTION FORM

R134a COMPRESSOR MODELS

MANUFACTURER

ZANUSSI			DANFOSS			NECCHI			GOLDSTAR			MATSUSHITA			ASPERA		
MODEL	WATT POWER	QTY	MODEL	WATT POWER	QTY	MODEL	WATT POWER	QTY	MODEL	WATT POWER	QTY	MODEL	WATT POWER	QTY	MODEL	WATT POWER	QTY
REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08		
GL40AH OR GL40AA	95 94		TL4G	85					VS36LAEG	84		S48C10KAX0	95		BP1048Z22	108	
REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08			REF. MODEL. AR08		
GL45AH OR GL45AA	113 112		TL5G	106		ESC511	107		NR45LAEG	108		S48C13KAX5 OR QA51C11RAX5	110		BP1048Z22	108	
REF. MODEL. AR10			REF. MODEL. AR10			REF. MODEL. AR10			REF. MODEL. AR10			REF. MODEL. AR10			REF. MODEL. AR10		
GL50AH OR GL50AA	129 128		TL55F	128					NR58LAEG	124		QA57C13RAX5	122		BP1111Z	125	
REF. MODEL. AR12			REF. MODEL. AR12			REF. MODEL. AR12			REF. MODEL. AR12			REF. MODEL. AR12			REF. MODEL. AR12		
GL60AH OR GL60AA	155 154		TL57F	167		ESC8H	172		NR62LAEG	156		QA77C18RAX5 D66C15RAX5	151		B1116Z	158	
REF. MODEL. AR17			REF. MODEL. AR17			REF. MODEL. AR17			REF. MODEL. AR17			REF. MODEL. AR17			REF. MODEL. AR17		
GL80AH OR GL80AA	204 201		FR10G	189		ESC9H	214		V75LAEG	194		QA71C20RAX D91C21RAX5	227		B1118Z	204	

TEST CONDITION ASHRAE, EVAP. TEMP. = 21.1 C, AMB. TEMP. = 32 C, COND. TEMP. = 54 OR 55 C, SUCTION TEMP. 32 C, SUBCOOLING TEMP. 32 C

TABLE 1



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 04 / 403

CONTRACT NO . 04 / 007

PAGE 4 - 7

The insertion of capillary tube into the suction line will create a better heat transfer in order to get Sub-Cooling temperature of 32 degree centigrade .

For determination of length of capillary tube we tested our prototypes in two conditions .

a) With reducing 10% weight of refrigerant without changing the changing length of capillary tube .


b) With reducing 10% weight of refrigerant and also increasing 10% length of capillary tube .

The results of laboratory tests show that there is not much difference between these two conditions , but the correct amount of refrigerant will guide us to an optimized condition .For this reason we are not going to increase the length of capillary tube unless in optimizing programme if we could see a remarkable energy saving and also compressor selection consideration .

so the optimization programme in this regard will need a long term period programme which Azmayesh Co . is planning to achieve

COMPRESSOR PERFORMANCE

NEW FREON COMPRESSOR PERFORMANCE (STANDARD VERSION)



Note : * Under development

Sample available from Jan, 1994
 Production available from July, 1994

■ COMPRESSOR LIFE TEST STATUS

TEST	TEST CONDITIONS		RESULTS					
	CFC 12/MINERAL	HFC 134a/ESTER	OIL		MOTOR		COMPRESSION PARTS	
			COLOR	T.A.N	HI POT	INSULATION	VALVES	WEAR
HI LOAD TEST	Ps/Pd = 1/24 (Kg/cm ²) Ambient 43°C Duration 48 Hrs	1/27 (Kg/cm ²) 43°C 168 Hrs	L 0.5 ~1.5	0.01 ~0.05	O.K	O.K	No Sludge (Build-up)	· Limit: 10μ · Actual wear : 0~6μ
LIFE TEST	Continuous Run Ps/Pd = 1/15 (Kg/cm ²) Ambient 43°C Duration 2,200 Hrs	1/17 (Kg/cm ²) 43°C 2,200 Hrs 4,400 Hrs	L 0.5 ~1.5	0.10 ~0.04	O.K	O.K	No Sludge (Build-up)	· Limit: 10μ · Actual wear : 0~5μ
	On/Off Ps/Pd = 1/15 (Kg/cm ²) Ambient 43°C On 5 min./Off 5 min. Duration 30,000 Cycles	1/17 (Kg/cm ²) 43°C 5 min./5 min. 30,000 Cycles	L 0.5 ~1.5	0.01 ~0.05	O.K	O.K	No Sludge (Build-up)	· Limit: 10μ · Actual wear : 0~6μ

◆ Actual wear with HFC 134a/Ester application shows the same wear level compared to CFC12's.

REFRIGERATOR LIFE TEST STATUS

TEST PLACE	TEST CONDITIONS	QUANTITY (unit)	TEST PERIOD	RESULTS
TEST ROOM	<ul style="list-style-type: none"> ● Ambient 15℃/43℃ (Night/Day) ● Cycling Run ● Auto Defrost 	Around 100 units	March. '90 ~Dec. '92	<ul style="list-style-type: none"> ● No capillary blockage ● Capi - tube flow rate decrease : 4%~8% ⇒ Considered allowable ● Compressor analysis showed reliable results
		120 units	May. '93 ~	● No problem has been found
FIELD	● Home Use	Around 200 units	May. '92 ~	● No claim has been received
		Around 3,000 units	May. '93 ~	● No claim has been received


TECHNICAL TASKS FOR HFC 134a/ESTER COMPRESSOR DEVELOPMENT

<p>◆ HFC 134a's specific volume increase ⇒ 37% Increase compared to CFC12's. (-30℃/GAS)</p>	
Effect	<ul style="list-style-type: none"> · Cooling capacity reduced by around 15%
Counter-measure	<ul style="list-style-type: none"> · Gas passage improvement · Displacement increase · Motor torque optimization

<p>◆ HFC 134a has no chlorine. ◆ HFC 134a has higher compression ratio. ⇒ 26% Increase compared to CFC12's. (Eva. -23.3℃/Cond. 54.4℃)</p>	
Effect	<ul style="list-style-type: none"> · Wear increase · Noise/Vibration increase
Counter-measure	<ul style="list-style-type: none"> · Anti-Wear coat for bearing surfaces · Wear mechanism improvement · Higher viscosity oil [15→22Cst 22→32Cst · Muffler/ Suspension improvement

<p>◆ Chlorinated detergent regulation 1.1.1-TCE CFC 113</p>	
Effect	<ul style="list-style-type: none"> · Impurities may increase if there's no adequate substitutes
Counter-measure	<ul style="list-style-type: none"> · Powerful substitutes development · Washing system improvement

<p>◆ Ester oil has high hygroscopicity. ⇒ Moisture absorption leads to acid formation in oil and deteriorates metals and organic materials.</p>	
Effect	<ul style="list-style-type: none"> · Sludge(Metallic soap) and extractions results in capillary tube blockage
Counter-measure	<ul style="list-style-type: none"> · Powerful dehydration system · Process control(Moisture prevention) · Special dryer should be needed · Charging machines should be for Ester only



■ **NEW OIL**

◆ **TYPE : Polyol Ester**

◆ **MAKER**

- KYODO OIL - JAPAN(Approved)
- SUN OIL - JAPAN(Approved)
- ICI - U.K(Under Testing)
- LUBRIZOHL - U.S.A(Under Testing)

◆ **VISCOSITY RANGE**

10/15/22/32 Cst @ 40℃

◆ **CHARACTERISTICS(KYODO)**

- Color : L 0.5(ASTM)
- T. A. N : 0.01(mgKOH/g)
- Pour Point : -50℃ below
- Phase Separation : -43℃ below
- Resistivity : 10⁹ (Ω·cm @25℃)
- Additives : Oxidation Inhibitor
Acid Scavenger

<HYGROSCOPICITY>

ITEM	OIL	ESTER OIL	MINERAL OIL
	SATURATED WATER CONTENTS		
	AT 25℃ (ppm)	1500	53
HYGROSCOPIC TEST	0 min.	23	21
WATER CONTENTS	10 min.	56	25
	(ppm) 30 min.	165	30
	1 hr.	198	43
	2 hr.	296	47
	4 hr.	479	49
	8 hr.	744	50
	24 hr.	1007	52

ESTER OIL CHARACTERISTICS

TARGETS OF NEW OILS FOR HFC 134a

TARGET

Resistivity
 $\rho \geq 10^{13} (\Omega \cdot \text{cm})$

INSULATION

MISCIBILITY

As low as possible

HYGROSCOPICITY

REFRIGERATING OIL

LUBRICITY

As small as possible

EFFECT ON ORGANIC MATERIALS

STABILITY

TARGET

Miscible range below -40°C

Falex Test: Wear better than R-12/Mineral


Chemical Stability:
Stable at Sealed Glass Tube Test
① $175^{\circ}\text{C} \times 14 \text{ Days (ASTM)}$

Hydrolytic Stability:
Stable at Bomb Test
① $175^{\circ}\text{C} \times 14 \text{ Days}$

COMPRESSOR LIFE TEST RESULTS

■ RELIABILITY DESIGN POINTS

DESCRIPTIONS	SPECIFICATION		IMPROVEMENT POINTS
	CONVENTIONAL (CFC 12)	IMPROVED (HFC 134a)	
1. Refrigerating Oil	Mineral	Ester (+ Additives)	· Compatible to HFC134a application
2. Motor Insulations – Insulation film – Sleeve(plastic) – Winding Coat	· PET · PBT · Enamel Coat + Paraffinic Wax	· Improved PET · Improved PBT · No Wax (Self Lubricating Wire)	· Lower oligomer extraction/Higher thermal resistivity · Lower oligomer extraction · Lower sludge formation
3. Material (Bearing Parts)	· Mild Steel	· Hi -- carbon Steel · Surface Coat	· Higher wear resistivity
4. Parts Cleaning	· Alkaline Wash · 1.1.1 – TCE Degrease	· Improved Alkaline Wash	· Substitute for chlorine detergent · Higher parts cleanness level
5. Dehydration	· Drying System (Open shell status)	· Evacuation System	· More effective moisture removal



CHAPTER 5

EVALUATION OF PROTOTYPES

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 5 - 1

EVALUATION OF PROTOTYPES

1 - In this chapter we are going to Review , Analyze , Evaluate and compare briefly test results of refrigerator and ref-freezer Models AR06 , AR08 , AR10 , AR12 and ARF2 using refrigerant R134a in their refrigeration cycle , in comparison with previous R12 test results .

2 - Azmayesh Industrial Factories Company is using Iranian Test Standards for its laboratory test procedure , so far . It seems that it would almost impractical to compare two different standards in different conditions , so it is reasonable to consider only some important data from our previous test results to compare with R134a .

3 - To compare the application of refrigerant R12 and R134a we basically consider the performance of the refrigerator at the same ambient temperature usually 32 degree centigrade or 43 degree centigrade , since we perform our laboratory test in 47 degree centigrade to comply with Iranian standards , for some Models we have compared 43 and 47 degree centigrade .



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 406

CONTRACT NO . 94 / 097

PAGE 5 - 2

4 - In this evaluation we are not going to discuss the advantage and disadvantage of use of refrigerant R134a , because these evaluation has been done previously by most famous and large Compressor and Refrigerator Manufacturer such as Danfoss , Goldstar , Leibherr , AEG and etc.

5 - Our laboratey test results show that at almost the same test condition we can get the following results . In this review we have neglected the compressor defferent manufacturer . The compressor effects in this regard have discussed by manufacturer in their respective reports to their customers .

**AZMAYESH INDUSTRIAL FACTORIES COMPANY**

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 405

CONTRACT NO. 94 / 097

PAGE 5-3**MODELS AR06 and AR08**

<i>Description</i>		<i>R134a</i>	<i>R12</i>
<i>Freezer Mean Temperature</i>	<i>C</i>	<i>-20</i>	<i>-12</i>
<i>Freezer Bulb Temperature</i>	<i>C</i>	<i>-22</i>	<i>-18</i>
<i>Refrigerator Compartment Mean Temp.</i>	<i>C</i>	<i>+3</i>	<i>+5</i>
<i>Suction Temperature</i>	<i>C</i>	<i>+45</i>	<i>+45</i>
<i>Condenser Inlet Temperature</i>	<i>C</i>	<i>+65</i>	<i>+65</i>
<i>Condenser Outlet Temperature</i>	<i>C</i>	<i>+50</i>	<i>+51</i>
<i>Compressor Running Time</i>	<i>%</i>	<i>65 %</i>	<i>52 %</i>
<i>Ambient Temperature</i>	<i>C</i>	<i>43</i>	<i>43</i>

NOTE : For Models AR06 and AR08 we use the same
Refrigeration system

**AZMAYESH INDUSTRIAL FACTORIES COMPANY***ELECTRICAL / HOME APPLIANCES***PROGRESS REPORT # 2**

PROJECT NO. MP / IRA / 94 / 405

CONTRACT NO. 94 / 097

PAGE 5 - 4**MODEL AR10**

<i>Description</i>		<i>R13+e</i>	<i>R12</i>
<i>Freezer Mean Temperature</i>	<i>C</i>	<i>- 13</i>	<i>- 12</i>
<i>Freezer Bulb Temperature</i>	<i>C</i>	<i>- 22</i>	<i>- 19</i>
<i>Refrigerator Compartment Mean Temp. C</i>		<i>+ 6</i>	<i>+ 3.6</i>
<i>Suction Temperature</i>	<i>C</i>	<i>+ 45</i>	<i>+ 44</i>
<i>Condenser Inlet Temperature</i>	<i>C</i>	<i>+ 75</i>	<i>+ 62</i>
<i>Condenser Outlet Temperature</i>	<i>C</i>	<i>+ 50</i>	<i>+ 44</i>
<i>Compressor Running Time</i>	<i>%</i>	<i>56 %</i>	<i>55 %</i>
<i>Ambient Temperature</i>	<i>C</i>	<i>43</i>	<i>43</i>

**AZMAYESH INDUSTRIAL FACTORIES COMPANY**

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 04 / 405

CONTRACT NO. 04 / 097

PAGE 5 - 5**MODEL AR12**

<i>Description</i>		<i>R13 %</i>	<i>R12</i>
<i>Freezer Mean Temperature</i>	<i>C</i>	<i>- 18</i>	<i>- 12</i>
<i>Freezer Bulb Temperature</i>	<i>C</i>	<i>- 24</i>	<i>- 18</i>
<i>Refrigerator Compartment Mean Temp.</i>	<i>C</i>	<i>+ 4</i>	<i>+ 4.3</i>
<i>Suction Temperature</i>	<i>C</i>	<i>+ 34</i>	<i>+ 33</i>
<i>Condenser Inlet Temperature</i>	<i>C</i>	<i>+ 65</i>	<i>+ 65</i>
<i>Condenser Outlet Temperature</i>	<i>C</i>	<i>+ 53</i>	<i>+ 50</i>
<i>Compressor Running Time</i>	<i>%</i>	<i>41 %</i>	<i>37 %</i>
<i>Ambient Temperature</i>	<i>C</i>	<i>32</i>	<i>3</i>



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 405

CONTRACT NO . 94 / 097

PAGE 5 6

MODEL ARF2

<i>Description</i>		<i>R154a</i>	<i>R12</i>
<i>Freezer Mean Temperature</i>	<i>C</i>	<i>- 15</i>	<i>- 23</i>
<i>Freezer Bulb Temperature</i>	<i>C</i>	<i>- 11</i>	<i>- 27</i>
<i>Refrigerator Compartment Mean Temp . C</i>		<i>+ 1</i>	<i>+ 3</i>
<i>Suction Temperature</i>	<i>C</i>	<i>+ 45</i>	<i>+ 39</i>
<i>Condenser Inlet Temperature</i>	<i>C</i>	<i>+ 90</i>	<i>+ 61</i>
<i>Condenser Outlet Temperature</i>	<i>C</i>	<i>+ 50</i>	<i>+ 48</i>
<i>Compressor Running Time</i>	<i>%</i>	<i>74 %</i>	<i>72 %</i>
<i>Ambient Temperature</i>	<i>C</i>	<i>43</i>	<i>47</i>



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 408

CONTRACT NO. 94 / 097

PAGE 5 - 7

5 -1- From the test results figure of our refrigerator , we find out that the Freezer mean temperature for R134a is better than R12 and condenser outlet and inlet temperature are almost the same , it means that it is not necessary to modify our evaporator and condenser assembly .

5 - Compressor running time is also acceptable because they are below 80% and comparing with R12 it is sometimes much less . So , we conclude that R134a compressor types are more efficient than R12 compressor on our refrigerators .



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IFA / 04 / 403

CONTRACT NO . 93 / 097

PAGE 5 - 8

7 - Suction temperature is almost the same and it means that our Refrigeration cycle is suitable for R134a .

8 - The evaporating temperature varies from -22 to -24 degree centigrade using R134a refrigerant , these figures show that our test condition could be ASHRAE Standard and by Optimizing the refrigerant weight and suitable air distribution in fresh food compartment we can easily get -23.3 degree centigrade evaporating temperature .

9 - The suction temperature is around 33 degree C for 32 degree C ambient temperature and 43 to 45 degree C for 43 C ambient temperature , these two figures are acceptable it shows that our test condition comply with ASHRAE standard .

10 - As previously mentioned , through these test and evaluation we found out that our products has a minor problem in distributing cold air inside fresh food compartment , in order to get a unified and stable air temperature we have modified our water drain tray under evaporator compartment to get mean temperature of + 5 "C" in fresh food compartment .

This defect has no relation with selection of refrigerant R134a and design failure of internal part existed before even with R12 .

AZMAYESH INDUSTRIAL FACTORIES CO.

R12 PROTOTYPE TEST SHEET

PAGE 5-3

FORM NO. 0001

DATE APRIL 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : ARO6
SERIAL NUMBER :	PROTOTYPE NUMBER : NON
CLASSIFICATION: TEST CONDITION * T *	AMBIENT TEMPERATURE 43 C
COMPRESSOR NAME : ZANUSSI	MODEL : G45AW
WATT CAPACITY : 95 WATT	POWER CONSUMPTION WATT 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 10
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. 180

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	OFF
Freezer Air Temp. t_{11} :		
Freezer Air Temp. t_{12} c		
Freezer Air Temp. t_{13} c		
Freezer Mean Temp t_{m1}	-11	-13
Freezer Bulb Temp. t_{14}	-12	-13
Refrigerator Comp. Temp. t_{15}	0	0
Refrigerator Comp. Temp. t_{16}	-5	+5
Refrigerator Co	+10	+10
Refrigerator Comp. Mean Temp t_{m2}	+5	+5
Crisper Comp. Temp. t_{17}	+10	+10
Compressor Shell Temp.	64	65
Condenser Inlet Temp.	47	65
Condenser Outlet Temp.	45	51
Suction Temp.	43	45

REMARKS

COMPRESSOR OPERATING TIME 52 %

AZMAYESH INDUSTRIAL FACTORIES CO .

R12 PROTOTYPE TEST SHEET

PAGE 5-10

FORM NO. 0002

DATE : APRIL 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : AROB
SERIAL NUMBER :	PROTOTYPE NUMBER : NON
CLASSIFICATION/TEST CONDITION * T *	AMBIENT TEMPERATURE : 43 C
COMPRESSOR NAME : ZANUSSI	MODEL : G45AW
WATT . CAPACITY : 108 WATT	POWER CONSUMPTION . WATT / 24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR 110
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT . 230

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON . NO.	OFF . NO.
Freezer Air Temp . t ₁ c		
Freezer Air Temp . t ₂ c		
Freezer Air Temp . t ₃ c		
Freezer Mean Temp . t _m	-11	-15
Freezer Bulb Temp . t ₄	-12	-18
Refrigerator Comp. Temp . t ₅	0	0
Refrigerator Comp. Temp . t ₆	+5	+5
Refrigerator Co	+10	+10
Refrigerator Comp. Mean Temp . t _{ma}	+5	+5
Crisper Comp. Temp . t _a	+10	+10
Compressor Shell Temp.	64	65
Condenser Inlet Temp .	47	65
Condenser Outlet Temp .	45	51
Suction Temp.	43	5

<p>REMARKS</p> <p style="text-align: center;">COMPRESSOR OPERATING TIME 52 %</p>

AZMAYESH INDUSTRIAL FACTORIES CO.

R12 PROTOTYPE TEST SHEET

PAGE 5 - II

FORM NO. 0003

DATE: APRIL 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : ARIO
SERIAL NUMBER :	PROTOTYPE NUMBER : NON
CLASSIFICATION, TEST CONDITION " N "	AMBIENT TEMPERATURE : 32 C
COMPRESSOR NAME : MATSUSHITA	MODEL : FNSIQIG
WATT . CAPACITY : 125 WATT	POWER CONSUMPTION . WATT 24 Hr
VOLT 220 AMPER HRTZ. 50	RIFRIGERANT WEIGHT GR 140
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT 285
THERMOSTAT TYPE	THERMOSTAT SETTING
	ON NO OFF NO
Freezer Air Temp. t_1 c	
Freezer Air Temp. t_2 c	
Freezer Air Temp. t_3 c	
Freezer Mean Temp. t_{m1}	-6 -10
Freezer Bulb Temp. t_4	-17 -21
Refrigerator Comp. Temp. t_5	-1 -1
Refrigerator Comp. Temp. t_6	+2 +2
Refrigerator Co	+6 +6
Refrigerator Comp. Mean Temp t_{m2}	2.5 +2.5
Crisper Comp. Temp. t_7	+6 +6
Compressor Shell Temp.	55 58
Condenser Inlet Temp.	36 48
Condenser Outlet Temp.	34 38
Suction Temp.	30 32
REMARKS COMPRESSOR OPERAYNG TIME 35 %	

AZMAYESH INDUSTRIAL FACTORIES CO.

R12 PROTOTYPE TEST SHEET

PAGE 5 - 12

FORM NO. 0004

DATE : APRIL 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : AR12
SERIAL NUMBER :	PROTOTYPE NUMBER : NON
CLASSIFICATION: TEST CONDITION " N "	AMBIENT TEMPERATURE : 32 C
COMPRESSOR NAME : MATSUSHITA	MODEL : FNSIQIG
WATT . CAPACITY : 158 WATT	POWER CONSUMPTION , WATT 24 Hrs
VOLT 220 AMPER HRTZ. 50	RIFRIGERANT WEIGHT GR 150
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT 340

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	OFF
Freezer Air Temp. t ₁ :		
Freezer Air Temp. t ₂ :		
Freezer Air Temp. t ₃ :		
Freezer Mean Temp. t _m :	-12	-12
Freezer Bulb Temp. t ₄ :	-15	-18
Refrigerator Comp. Temp. t ₅ :	+1	+1
Refrigerator Comp. Temp. t ₆ :	+5	+5
Refrigerator Co	+7	+7
Refrigerator Comp. Mean Temp. t _{ma} :	4.3	+4.3
Crisper Comp. Temp. t _e :	+7	+7
Compressor Shell Temp.	60	64
Condenser Inlet Temp.	40	50
Condenser Outlet Temp.	30	40
Suction Temp.	33	33

REMARKS	COMPRESSOR OPERAYING TIME 37 %
----------------	--------------------------------

AZMAYESH INDUSTRIAL FACTORIES CO .

R12 PROTOTYPE TEST SHEET

PAGE 5-13

FORM NO. 0005

DATE : APRIL 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : ARF2
SERIAL NUMBER :	PROTOTYPE NUMBER : NON
CLASSIFICATION : TEST CONDITION " N "	AMBIENT TEMPERATURE : 32 C
COMPRESSOR NAME : MATSUSHITA	MODEL : FN77G1BG
WATT . CAPACITY : 205 WATT	POWER CONSUMPTION . WATT : 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 220
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LT .310

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	NO
Freezer Air Temp. t ₁ c		
Freezer Air Temp. t ₂ c		
Freezer Air Temp. t ₃ c		
Freezer Mean Temp. t _{m1}	-18	-24
Freezer Bulb Temp. t ₄	-20	-27
Refrigerator Comp. Temp. t ₅		
Refrigerator Comp. Temp. t ₆	+1	+1
Refrigerator Co	+4	+4
Refrigerator Comp. Mean Temp. t _{m2}	4.3	+4.3
Crisper Comp. Temp. t ₇	+7	+7
Compressor Shell Temp.	53	50
Condenser Inlet Temp.	35	55
Condenser Outlet Temp.	34	42
Suction Temp.	23	33

REMARKS COMPRESSOR OPERAYING TIME 53 %

AZMAYESH INDUSTRIAL FACTORIES CO.

R13-4a PROTOTYPE TEST SHEET

5-19

FORM NO. _____

DATE 3 Sep 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR06
SERIAL NUMBER --	PROTOTYPE NUMBER <i>R6-01</i>
CLASSIFICATION/TEST CONDITION --	AMBIENT TEMPERATURE 18 c
COMPRESSOR NAME Goldstar	MODEL NR45 LAEG
WATT CAPACITY 95	POWER CONSUMPTION WATT 24 Hrs --
VOLT 220 AMPER -- HRTZ 50	REFRIGERANT WEIGHT GR 110
INSULATION TYPE C.F.C.R FOQM	REF. INSIDE VOLUME LIT. 180

THERMOSTAT TYPE	THERMOSTAT SETTINGS	
	ON NO	OFF NO
Freezer Air Temp. t_1	-10	-15
Freezer Air Temp. t_2	-11	-16
Freezer Air Temp. t_3	-12	-16
Freezer Mean Temp. t_{m1}	-11	-16
Freezer Bulb Temp. t_4	-19	-20
Refrigerator Comp. Temp. t_5	-2	-3
Refrigerator Comp. Temp. t_6	2	1
Refrigerator Comp. Temp. t_7	4	2
Refrigerator Comp. Mean Temp. t_{m2}	1	0
Crisper Comp. Temp. t_8	+4	-4
Compressor Shell Temp.	20	30
Condenser Inlet Temp.	20	28
Condenser Outlet Temp.	19	22
Suction Temp.	-19	20

REMARKS Working percentage = 25%

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-15

FORM NO. _____

DATE 3. Sep. 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR06
SERIAL NUMBER --	PROTOTYPE NUMBER <i>R6-01</i>
CLASSIFICATION TEST CONDITION Moderate	AMBIENT TEMPERATURE 32 c
COMPRESSOR NAME Goldstar	MODEL NR 45 LAEG
WATT. CAPACITY 95	POWER CONSUMPTION. WATT 24 Hrs
VOLT 220 AMPER -- HRTZ. 50	REFRIGERANT WEIGHT GR 110
INSULATION TYPE C.F.C.P. FQAM	REF. INSIDE VOLUME LIT. 180

THERMOSTAT TYPE	TEMPERATURE SETTING	
	ON	OFF
Freezer Air Temp. t ₁	-11	-15
Freezer Air Temp. t ₂	-12	-16
Freezer Air Temp. t ₃	-13	-16
Freezer Mean Temp. t _{m1}	-12	-16
Freezer Bulb Temp. t ₄	-15	-21
Refrigerator Comp. Temp. t ₅	-4	+3
Refrigerator Comp. Temp. t ₆	+5	+4
Refrigerator Comp. Temp. t ₇	-6	+5
Refrigerator Comp. Mean Temp. t _{m2}	+5	+4
Crisper Comp. Temp. t ₈	+5	+5
Compressor Shell Temp.	35	60
Condenser Inlet Temp.	54	50
Condenser Outlet Temp.	33	42
Suction Temp.	32	33

REMARKS	Working percentage = 33%
---------	--------------------------

AZMAYESH INDUSTRIAL FACTORIES CO .

R134a PROTOTYPE TEST SHEET

5.16

FORM NO. _____

DATE 3 Sep 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR06
SERIAL NUMBER -	PROTOTYPE NUMBER <i>RB-01</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43 c
COMPRESSOR NAME Goldstar	MODEL NR 45 LAEG
WATT CAPACITY 95	POWER CONSUMPTION WATT 24 Hrs
VOLT 220 AMPER -- HRTZ. 50	REFRIGERANT WEIGHT GR. 110
INSULATION TYPE C.F.C.R FOAM	REF. INSIDE VOLUME LIT. 180

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	OFF
Freezer Air Temp. t ₁	-10	-15
Freezer Air Temp. t ₂	-11	-16
Freezer Air Temp. t ₃	-9	-14
Freezer Mean Temp. t _{m1}	-10	-15
Freezer Bulb Temp. t ₄	-14	-20
Refrigerator Comp. Temp. t ₅	-1	-1
Refrigerator Comp. Temp. t ₆	-8	-3
Refrigerator Comp. Temp. t ₇	-8	-7
Refrigerator Comp. Mean Temp. t _{m2}	+6	+5
Crisper Comp. Temp. t ₈	-8	-8
Compressor Shell Temp.	60	73
Condenser Inlet Temp.	45	70
Condenser Outlet Temp.	44	60
Suction Temp.	43	44

REMARKS	Working percentage = 75%
----------------	--------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R13-2 PROTOTYPE TEST SHEET

5-17

Date - 4 Sep 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : AR06
SERIAL NUMBER : NON	PROTOTYPE NUMBER : R6-02
CLASSIFICATION TEST CONDITION : T	AMBIENT TEMPERATURE : 43°C
COMPRESSOR NAME : Goldstar	MODEL : NR 45 LAEG
WATT . CAPACITY : WATT 95	POWER CONSUMPTION . WATT/24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR 100
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. 180

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NO	OFF	NO
Freezer Air Temp. t ₁ c	-10		-15	
Freezer Air Temp. t ₂ c	-11		-16	
Freezer Air Temp. t ₃ c	-9		-13	
Freezer Mean Temp. t _m	-11		-16	
Freezer Bulb Temp. t ₄	-14		-22	
Refrigerator Comp. Temp. t ₅	+1		+1	
Refrigerator Comp. Temp. t ₆	+8		+8	
Refrigerator Comp. t ₇	+8		+8	
Refrigerator Comp. Mean Temp. t _{mz}	+7		+5	
Crisper Comp. Temp. t ₈	+8		+8	
Compressor Shell Temp.	60		73	
Condenser Inlet Temp.	45		70	
Condenser Outlet Temp.	44		60	
Suction Temp.	43		44	

REMARKS COMPRESSOR OPERAYING TIME % 75

AZMAYESH INDUSTRIAL FACTORIES CO .

R134a PROTOTYPE TEST SHEET

5-18

Date: 4 Sep 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>AR06</i>
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>R6-03</i>
CLASSIFICATION TEST CONDITION : <i>T</i>	AMBIENT TEMPERATURE : <i>43°C</i>
COMPRESSOR NAME : <i>Necchi</i>	MODEL : <i>ESC4H</i>
WATT . CAPACITY : <i>95 WATT</i>	POWER CONSUMPTION . WATT/ 24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR <i>100</i>
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>180</i>

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NC	OFF	NC
Freezer Air Temp. t_1 c	-10		-17	
Freezer Air Temp. t_2 c	-12		-18	
Freezer Air Temp. t_3 c	-10		-14	
Freezer Mean Temp. t_m	11		-16	
Freezer Bulb Temp. t_4	-15		-24	
Refrigerator Comp. Temp. t_5	+8		+9	
Refrigerator Comp. Temp. t_6	+8		+8	
Refrigerator Comp. t_7	+7		+6	
Refrigerator Comp. Mean Temp. t_{m2}	+7		+5	
Crisper Comp. Temp. t_8	+8		+8	
Compressor Shell Temp.	65		80	
Condenser Inlet Temp.	50		75	
Condenser Outlet Temp.	45		60	
Suction Temp.	43		50	

REMARKS	COMPRESSOR OPERAYING TIME % <i>70</i>
----------------	---------------------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R1342 PROTOTYPE TEST SHEET

5-19

Date 4 Sep 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>AR06</i>
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>R6-04</i>
CLASSIFICATION TEST CONDITION : <i>T</i>	AMBIENT TEMPERATURE : <i>43°C</i>
COMPRESSOR NAME : <i>Domfoss</i>	MODEL : <i>TL4G</i>
WATT . CAPACITY : <i>95 WATT</i>	POWER CONSUMPTION . WATT / 24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR <i>100</i>
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>180</i>

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	OFF
Freezer Air Temp. t_1 c	-9	-15
Freezer Air Temp. t_2 c	-11	-16
Freezer Air Temp. t_3 c	-10	-13
Freezer Mean Temp. t_m	-10	-15
Freezer Bulb Temp. t_4	-15	-22
Refrigerator Comp. Temp. t_5	+8	+8
Refrigerator Comp. Temp. t_6	+8	+8
Refrigerator Comp. t_7	+7	+6
Refrigerator Comp. Mean Temp. t_{m2}	+7	+5
Crisper Comp. Temp. t_8	+8	+8
Compressor Shell Temp.	60	75
Condenser Inlet Temp.	55	65
Condenser Outlet Temp.	50	65
Suction Temp.	30	45

REMARKS	COMPRESSOR OPERAYING TIME % <i>65</i>
----------------	---------------------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-20

FORM NO. _____

DATE _____

DESCRIPTION	DESCRIPTION
PRODUCT NAME AR	MODEL AR08
SERIAL NUMBER --	PROTOTYPE NUMBER <i>R8-1</i>
CLASSIFICATION TEST CONDITION --	AMBIENT TEMPERATURE 18 c <i>K</i>
COMPRESSOR NAME Aspera	MODEL Ep 1048 Z 22 <i>K</i>
WATT CAPACITY 103 <i>K</i>	POWER CONSUMPTION WATT 24 Hrs
VOLT 220 AMPER HERTZ 50	REFRIGERANT WEIGHT GR 100 <i>K</i>
INSULATION TYPE C.F.C Foam	REF. INSIDE VOLUME LIT. 220

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NO.	OFF	NO.
Freezer Air Temp. t_1	-12		-15	
Freezer Air Temp. t_2	-13		-16	
Freezer Air Temp. t_3	-12		-15	
Freezer Mean Temp. t_m	-12		-15	
Freezer Bulb Temp. t_4	-15		-21	
Refrigerator Comp. Temp. t_5	-1		-1	
Refrigerator Comp. Temp. t_6	2		1	
Refrigerator Comp. Temp. t_7	+3		+2	
Refrigerator Comp. Mean Temp. t_{m2}	+1		+1	
Crisper Comp. Temp. t_8	+4		+4	
Compressor Shell Temp.	40		44	
Condenser Inlet Temp.	23		37	
Condenser Outlet Temp.	+19		23	
Suction Temp.	+18		19	

REMARKS Working Percentage = 19%

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-21

FORM NO. _____

DATE _____

DESCRIPTION	DESCRIPTION
PRODUCT NAME AP	MODEL AP03
SERIAL NUMBER --	PROTOTYPE NUMBER RB-1
CLASSIFICATION: TEST CONDITION	AMBIENT TEMPERATURE 32 c
COMPRESSOR NAME ASpera	MODEL 3P 1043 Z 22
WATT CAPACITY 108	POWER CONSUMPTION, WATT 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 100
INSULATION TYPE C.F.C R. Foam	REF. INSIDE VOLUME LIT. 230

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON NO.	OFF NO.
Freezer Air Temp. t_1	-12	-15
Freezer Air Temp. t_2	-13	-16
Freezer Air Temp. t_3	-12	-15
Freezer Mean Temp. t_m	-12	-15
Freezer Bulb Temp. t_4	-15	-21
Refrigerator Comp. Temp. t_5	-2	-3
Refrigerator Comp. Temp. t_6	+2	+1
Refrigerator Comp. Temp. t_7	+3	+2
Refrigerator Comp. Mean Temp. t_m	+1	0
Crisper Comp. Temp. t_8	+6	+3
Compressor Shell Temp.	55	60
Condenser Inlet Temp.	30	45
Condenser Outlet Temp.	+19	30
Suction Temp.	18	19

REMARKS Working percentage = 30.5

AZMAYESH INDUSTRIAL FACTORIES CO

R134a PROTOTYPE TEST SHEET

PAGE 5-22

FORM NO. 0018

DATE May 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR08
SERIAL NUMBER <u>NON</u>	PROTOTYPE NUMBER <u>R8-1</u>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE <u>43</u>
COMPRESSOR NAME Aspera	MODEL BP 1048 Z 22
WATT. CAPACITY 108	POWER CONSUMPTION, WATT/24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR. 100
INSULATION TYPE C.P.C.R. FOAM	REF. INSIDE VOLUME LIT. 230

THERMOSTAT TYPE	TEMPERATURE	
	ON	NO
Freezer Air Temp. t_1	-10	-20
Freezer Air Temp. t_2	-11	-21
Freezer Air Temp. t_3	-10	-20
Freezer Mean Temp. t_m	-10	-20
Freezer Bulb Temp. t_4	-14	-22
Refrigerator Comp. Temp. t_5	+3	+2
Refrigerator Comp. Temp. t_6	+4	+3
Refrigerator Comp. Temp. t_7	+5	+4
Refrigerator Comp. Mean Temp. t_m	+4	+3
Crisper Comp. Temp. t_8	+7	+6
Compressor Shell Temp.	70	75
Condenser Inlet Temp.	45	65
Condenser Outlet Temp.	45	50
Suction Temp.	44	45

REMARKS	Working percentage <u>+ 65 %</u>
---------	----------------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-23

Date 10 May 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : ARO8
SERIAL NUMBER : NON	PROTOTYPE NUMBER : R8-02
CLASSIFICATION: TEST CONDITION . T.	AMBIENT TEMPERATURE : 43°C
COMPRESSOR NAME : Zanussi	MODEL : GL45AA
WATT . CAPACITY : 108 WATT	POWER CONSUMPTION . WATT / 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 100
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. 230

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NO	ON	NO
Freezer Air Temp. t ₁ c	-10		-20	
Freezer Air Temp. t ₂ c	-11		-22	
Freezer Air Temp. t ₃ c	-10		-21	
Freezer Mean Temp. t _{m1}	-10		-21	
Freezer Bulb Temp. t ₄	-14		-24	
Refrigerator Comp. Temp. t ₅	+3		+2	
Refrigerator Comp. Temp. t ₆	+5		+3	
Refrigerator Comp. t ₇	+5		+4	
Refrigerator Comp. Mean Temp. t _{m2}	+8		+5	
Crisper Comp. Temp. t ₈	+7		+6	
Compressor Shell Temp.	75		80	
Condenser Inlet Temp.	45		67	
Condenser Outlet Temp.	45		50	
Suction Temp.	40		45	

REMARKS COMPRESSOR OPERAYING TIME % 65

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-24

Date: 10 May 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>ARO 8</i>
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>R2-03</i>
CLASSIFICATION TEST CONDITION : T	AMBIENT TEMPERATURE : <i>43°C</i>
COMPRESSOR NAME : <i>Necchi</i>	MODEL : <i>ESC5H</i>
WATT . CAPACITY : <i>108</i> WATT	POWER CONSUMPTION . WATT/24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR <i>110</i>
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LT. <i>230</i>

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON NO.	OFF NO.
Freezer Air Temp. t_1 c	-10	-18
Freezer Air Temp. t_2 c	-11	-17
Freezer Air Temp. t_3 c	-10	-19
Freezer Mean Temp. t_m	-10	-18
Freezer Bulb Temp. t_4	-15	-22
Refrigerator Comp. Temp. t_5	+4	+3
Refrigerator Comp. Temp. t_6	+6	+3
Refrigerator Comp. t_7	+5	+6
Refrigerator Comp. Mean Temp. t_{m2}	+5	+4
Crisper Comp. Temp. t_8	+8	+7
Compressor Shell Temp.	70	80
Condenser Inlet Temp.	50	65
Condenser Outlet Temp.	45	50
Suction Temp.	40	45

REMARKS COMPRESSOR OPERAYING TIME % *60*

AZMAYESH INDUSTRIAL FACTORIES CO.

R1342 PROTOTYPE TEST SHEET

5-25

Date: 10 May 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>AR08</i>
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>RP-04</i>
CLASSIFICATION TEST CONDITION *T*	AMBIENT TEMPERATURE : <i>43°C</i>
COMPRESSOR NAME : <i>Danfoss</i>	MODEL : <i>TLSG</i>
WATT CAPACITY : <i>108</i> WATT	POWER CONSUMPTION . WATT/24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR <i>100</i>
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>230</i>

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	NC
Freezer Air Temp. <i>t1 c</i>	-11	-20
Freezer Air Temp. <i>t2 c</i>	-12	-22
Freezer Air Temp. <i>t3 c</i>	-10	-21
Freezer Mean Temp. <i>t m1</i>	-11	-21
Freezer Bulb Temp. <i>t4</i>	-15	-25
Refrigerator Comp. Temp. <i>t5</i>	+5	+3
Refrigerator Comp. Temp. <i>t6</i>	+6	+4
Refrigerator Comp <i>t7</i>	+7	+3
Refrigerator Comp. Mean Temp. <i>t m2</i>	+6	+3
Crisper Comp. Temp. <i>t8</i>	+8	+8
Compressor Shell Temp.	65	80
Condenser Inlet Temp.	55	65
Condenser Outlet Temp.	40	45
Suction Temp.	40	45

REMARKS COMPRESSOR OPERAYING TIME % *65*

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-25

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>AR10</i>
SERIAL NUMBER : <i>NON</i>	PROTOTYPE NUMBER : <i>210-1</i>
CLASSIFICATION/TEST CONDITION : <i>N</i>	AMBIENT TEMPERATURE : <i>18 °C</i>
COMPRESSOR NAME : <i>Goldstar</i>	MODEL : <i>NR58 LAEG</i>
WATT. CAPACITY : <i>125 WATT</i>	POWER CONSUMPTION : <i>WATT/24 Hrs</i>
VOLT <i>220</i> AMPER <i>50</i> HRTZ <i>50</i>	REFRIGERANT WEIGHT GR <i>125</i>
INSULATION TYPE : <i>POLYURITHINE</i>	REF. INSIDE VOLUME LT. <i>295</i>

THERMOSTAT TYPE

	THERMOSTAT SETTINGS	
	ON	OFF
Freezer Air Temp. t_1 °C	-12	-15
Freezer Air Temp. t_2 °C	-13	-16
Freezer Air Temp. t_3 °C	-12	-16
Freezer Mean Temp. t_m	-12	-16
Freezer Bulb Temp. t_4	-16	-23
Refrigerator Comp. Temp. t_5	-1	-1
Refrigerator Comp. Temp. t_6	+2	+1
Refrigerator Co	+3	+2
Refrigerator Comp. Mean Temp. t_m	+1	+1
Crisper Comp. Temp. t_7	+4	+4
Compressor Shell Temp.	40	45
Condenser inlet Temp.	24	38
Condenser Outlet Temp.	+18	25
Suction Temp.	+18	20

REMARKS

COMPRESSOR OPERATING TIME % *20*

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-27

DESCRIPTION	DESCRIPTION			
PRODUCT NAME : REFRIGERATOR	MODEL : <i>AR10</i>			
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>R10-1</i>			
CLASSIFICATION: TEST CONDITION <i>N</i>	AMBIENT TEMPERATURE : <i>32°C</i>			
COMPRESSOR NAME : <i>Goldstar</i>	MODEL : <i>NR5B LAEG</i>			
WATT . CAPACITY : <i>125</i> WATT	POWER CONSUMPTION . WATT. 24 Hrs			
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR. <i>125</i>			
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>285</i>			
THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NC	OFF	NC
Freezer Air Temp. <i>t1 c</i>	<i>-11</i>		<i>-15</i>	
Freezer Air Temp. <i>t2 c</i>	<i>-12</i>		<i>-17</i>	
Freezer Air Temp. <i>t3 c</i>	<i>-13</i>		<i>-16</i>	
Freezer Mean Temp. <i>t m1</i>	<i>-12</i>		<i>-16</i>	
Freezer Bulb Temp. <i>t4</i>	<i>-15</i>		<i>-23</i>	
Refrigerator Comp. Temp. <i>t5</i>	<i>+2</i>		<i>+2</i>	
Refrigerator Comp. Temp. <i>t6</i>	<i>+3</i>		<i>+1</i>	
Refrigerator Comp <i>t2</i>	<i>+4</i>		<i>+2</i>	
Refrigerator Comp. Mean Temp. <i>t m2</i>	<i>+3</i>		<i>+2</i>	
Crisper Comp. Temp. <i>t7</i>	<i>+4</i>		<i>+3</i>	
Compressor Shell Temp.	<i>55</i>		<i>60</i>	
Condenser Inlet Temp.	<i>35</i>		<i>45</i>	
Condenser Outlet Temp.	<i>20</i>		<i>30</i>	
Suction Temp.	<i>25</i>		<i>26</i>	
REMARKS COMPRESSOR OPERAYING TIME <i>634</i>				

AZMAYESH INDUSTRIAL FACTORIES CO .

R134a PROTOTYPE TEST SHEET

PAGE 5-28

FORM NO. 0016

DATE MAY 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR10
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>R10-1</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43 c
COMPRESSOR NAME Goldstar	MODEL NR 58 LAE G
WATT . CAPACITY 125	POWER CONSUMPTION . WATT/ 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 125
INSULATION TYPE C.F.C. FOAM	REF. INSIDE VOLUME LIT . 285

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NO.	OFF	NO.
Freezer Air Temp. t ₁	-13		-20	
Freezer Air Temp. t ₂	-12		-19	
Freezer Air Temp. t ₃	-13		-20	
Freezer Mean Temp. t _m	-13		-20	
Freezer Bulb Temp. t ₄	-16		-23	
Refrigerator Comp. Temp. t ₅	+3		+2	
Refrigerator Comp. Temp. t ₆	+5		+4	
Refrigerator Comp. Temp. t ₇	+7		+6	
Refrigerator Comp. Mean Temp. t _{ma}	+5		+4	
Crisper Comp. Temp. t ₈	+7		+6	
Compressor Shell Temp.	80		85	
Condenser Inlet Temp.	45		60	
Condenser Outlet Temp.	45		98	
Suction Temp.	44		45	

REMARKS	Working percentage = 65 %
---------	---------------------------

AZMAYESH INDUSTRIAL FACTORIES CO .

R134a PROTOTYPE TEST SHEET

PAGE 5-29

FORM NO. 0017

DATE MAY 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL ARI0
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>80-2</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43
COMPRESSOR NAME Aspera	MODEL BP 1111 Z
WATT. CAPACITY 125	POWER CONSUMPTION, WATT/24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR. 125
INSULATION TYPE C.F.C.R - FOAM	REF. INSIDE VOLUME LIT. 285

THERMOSTAT TYPE	TEMPERATURE SETTING	
	ON	NO
Freezer Air Temp. t ₁	-3	-13
Freezer Air Temp. t ₂	-10	-11
Freezer Air Temp. t ₃	-8	-12
Freezer Mean Temp. t _{m1}	-9	-13
Freezer Bulb Temp. t ₄	-16	-22
Refrigerator Comp. Temp. t ₅	+6	+6
Refrigerator Comp. Temp. t ₆	+5	+5
Refrigerator Comp. Temp. t ₇	+7	+7
Refrigerator Comp. Mean Temp. t _{m2}	+6	+6
Crisper Comp. Temp. t ₈	+7	+7
Compressor Shell Temp.	80	86
Condenser Inlet Temp.	47	77
Condenser Outlet Temp.	46	50
Suction Temp.	44	45

REMARKS	Working percentage = 56 %
---------	---------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R13-3 PROTOTYPE TEST SHEET

5-30

Date: 15 May 95

DESCRIPTION	DESCRIPTION			
PRODUCT NAME : REFRIGERATOR	MODEL : <i>AR10</i>			
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>R10-03</i>			
CLASSIFICATION/TEST CONDITION : <i>T</i>	AMBIENT TEMPERATURE : <i>43°C</i>			
COMPRESSOR NAME : <i>Zanussi</i>	MODEL : <i>GL60AA</i>			
WATT . CAPACITY : <i>125 WATT</i>	POWER CONSUMPTION . WATT/24 Hrs			
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR. <i>125</i>			
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>285</i>			
THERMOSTAT TYPE	THERMOSTAT SETTINGS			
	ON	NO.	OFF	NO.
Freezer Air Temp. <i>t1 c</i>	-14		-18	
Freezer Air Temp. <i>t2 c</i>	-12		-19	
Freezer Air Temp. <i>t3 c</i>	-11		-20	
Freezer Mean Temp. <i>t m1</i>	-12		-19	
Freezer Bulb Temp. <i>t4</i>	-16		-23	
Refrigerator Comp. Temp. <i>t5</i>	+3		+2	
Refrigerator Comp. Temp. <i>t6</i>	+6		+5	
Refrigerator Comp <i>t7</i>	+6		+4	
Refrigerator Comp. Mean Temp. <i>t m2</i>	+5		+4	
Crisper Comp. Temp. <i>t8</i>	+8		+7	
Compressor Shell Temp.	80		85	
Condenser Inlet Temp.	50		65	
Condenser Outlet Temp.	40		60	
Suction Temp.	40		45	
REMARKS COMPRESSOR OPERAYING TIME % <i>60</i>				

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-31

Date: 15 May 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>ARID</i>
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>R10-04</i>
CLASSIFICATION/TEST CONDITION 'T'	AMBIENT TEMPERATURE : <i>43°C</i>
COMPRESSOR NAME : <i>Danfoss</i>	MODEL : <i>FR 7.5G</i>
WATT . CAPACITY : <i>125 WATT</i>	POWER CONSUMPTION . WATT / 24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR <i>12.5</i>
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>285</i>

THERMOSTAT TYPE	THERMOSTAT SETTINGS			
	ON	NO.	OFF	NO.
Freezer Air Temp. t_1 c	-14		-16	
Freezer Air Temp. t_2 c	-12		-18	
Freezer Air Temp. t_3 c	-10		-17	
Freezer Mean Temp. t_m	-12		-17	
Freezer Bulb Temp. t_4	-19		-22	
Refrigerator Comp. Temp. t_5	+4		+3	
Refrigerator Comp. Temp. t_6	+6		+5	
Refrigerator Comp t_7	+5		+5	
Refrigerator Comp. Mean Temp. t_{m2}	+5		+4	
Crisper Comp. Temp. t_8	+9		+9	
Compressor Shell Temp.	80		85	
Condenser Inlet Temp.	50		60	
Condenser Outlet Temp.	40		49	
Suction Temp.	38		45	

REMARKS COMPRESSOR OPERAYING TIME % *70*

AZMAYESH INDUSTRIAL FACTORIES CO .

R134a PROTOTYPE TEST SHEET PAGE 5-32

FORM NO. 0009

DATE APRIL 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR12
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>12-2</i>
CLASSIFICATION/TEST CONDITION --	AMBIENT TEMPERATURE 18 c
COMPRESSOR NAME Danfoss	MODEL FR 8.5 G
WATT .CAPACITY 158	POWER CONSUMPTION . WATT/24 Hrs --
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 150
INSULATION TYPE C.F.C.R FOAM	REF. INSIDE VOLUME T. 340

THERMOSTAT TYPE	THERMOSTAT SET POINT			
	ON	NO	OFF	NO
Freezer Air Temp. t ₁	-13		-14	
Freezer Air Temp. t ₂	-14		-15	
Freezer Air Temp. t ₃	-13		-14	
Freezer Mean Temp. t _{m1}	-13		-14	
Freezer Bulb Temp. t ₄	-15		-20	
Refrigerator Comp. Temp. t ₅	+2		+1	
Refrigerator Comp. Temp. t ₆	+2		+1	
Refrigerator Comp. Temp. t ₇	+3		+2	
Refrigerator Comp. Mean Temp. t _{m2}	+2		+1	
Crisper Comp. Temp. t ₈	5		4	
Compressor Shell Temp.	30		35	
Condenser Inlet Temp.	22		32	
Condenser Outlet Temp.	20		22	
Suction Temp.	18		19	

REMARKS Working percentage = 17 %

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET PAGE 5-33

FORM NO. 2015

DATE May 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR12
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>R12-4</i>
CLASSIFICATION: TEST CONDITION	AMBIENT TEMPERATURE 18 c
COMPRESSOR NAME Aspera	MODEL B 1116 Z
WATT. CAPACITY 158	POWER CONSUMPTION . WATT. 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR. 135
INSULATION TYPE C.F.C.R - FOAM	REF. INSIDE VOLUME LIT. 340

THERMOSTAT TYPE	TEMPERATURE SET POINT	
	ON	OFF
Freezer Air Temp. t ₁	-12	-17
Freezer Air Temp. t ₂	-15	-18
Freezer Air Temp. t ₃	-14	-17
Freezer Mean Temp. t _m	-4	-17
Freezer Bulb Temp. t ₄	-17	-24
Refrigerator Comp. Temp. t ₅	1	0
Refrigerator Comp. Temp. t ₆	2	1
Refrigerator Comp. Temp. t ₇	3	2
Refrigerator Comp. Mean Temp. t _{ma}	2	1
Crisper Comp. Temp. t ₈	5	5
Compressor Shell Temp.	26	32
Condenser Inlet Temp.	21	27
Condenser Outlet Temp.	20	22
Suction Temp.	18	19

REMARKS	Working percentage = 20 %
----------------	---------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

PAGE 5.39

FORM NO. 0011

DATE APRIL 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR12
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>R12-2</i>
CLASSIFICATION/TEST CONDITION Moderate	AMBIENT TEMPERATURE 32 c
COMPRESSOR NAME Danfoss	MODEL FR 8.5 G
WATT CAPACITY 158	POWER CONSUMPTION, WATT/24 Hrs --
VOLT 220 AMPER - HRTZ. 50	REFRIGERANT WEIGHT GR 150
INSULATION TYPE C.F.C.R FOAM	REF. INSIDE VOLUME LIT. 340

THERMOSTAT TYPE	THERMOSTAT SETTINGS			
	ON	NO	OFF	NO
Freezer Air Temp. t_1	-15		-16	
Freezer Air Temp. t_2	-14		-14	
Freezer Air Temp. t_3	-14		-15	
Freezer Mean Temp. t_m	-14		-15	
Freezer Bulb Temp. t_4	-15		-20	
Refrigerator Comp. Temp. t_5	+4		+3	
Refrigerator Comp. Temp. t_6	+5		+4	
Refrigerator Comp. Temp. t_7	+6		+5	
Refrigerator Comp. Mean Temp. t_m	+5		+4	
Crisper Comp. Temp. t_8	6		5	
Compressor Shell Temp.	54		58	
Condenser Inlet Temp.	39		55	
Condenser Outlet Temp.	35		39	
Suction Temp.	32		33	

REMARKS Working percentage = 40 %

AZMAYESHI INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

PAGE 5-35

FORM NO. 0014

DATE MAY 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME <u>A.R</u>	MODEL <u>ARI2</u>
SERIAL NUMBER <u>NON</u>	PROTOTYPE NUMBER <u>R124</u>
CLASSIFICATION/TEST CONDITION <u>Moderate</u>	AMBIENT TEMPERATURE <u>30 c</u>
COMPRESSOR NAME <u>Aspera</u>	MODEL <u>B 1116 Z</u>
WATT. CAPACITY <u>138</u>	POWER CONSUMPTION, WATT <u>24 Hrs</u>
VOLT <u>220</u> AMPER <u> </u> HRTZ. <u>50</u>	REFRIGERANT WEIGHT GR <u>135</u>
INSULATION TYPE <u>C.F.C.R - FOAM</u>	REF. INSIDE VOLUME LIT. <u>360</u>

THERMOSTAT TYPE	TEMPERATURE SENSORS	
	SW	NO
Freezer Air Temp. <u>t1</u>	-11	-16
Freezer Air Temp. <u>t2</u>	-12	-13
Freezer Air Temp. <u>t3</u>	-15	-19
Freezer Mean Temp. <u>t m1</u>	-14	-18
Freezer Bulb Temp. <u>t4</u>	-17	-24
Refrigerator Comp. Temp. <u>t5</u>	+2	+2
Refrigerator Comp. Temp. <u>t6</u>	+4	+4
Refrigerator Comp. Temp. <u>t7</u>	+6	+6
Refrigerator Comp. Mean Temp. <u>t m2</u>	+4	+4
Crisper Comp. Temp. <u>t8</u>	+7	+7
Compressor Shell Temp.	56	64
Condenser Inlet Temp.	37	53
Condenser Outlet Temp.	33	38
Suction Temp.	33	34

REMARKS	Working percentage = 41 %
----------------	---------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

RIJ-4a PROTOTYPE TEST SHEET PAGE 5-36

FORM NO. 0008

DATE APRIL 75

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR12
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>R12-1</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43
COMPRESSOR NAME Goldstar	MODEL NR 62 LAF G
WATT. CAPACITY 158	POWER CONSUMPTION, WATT/24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR. 135
INSULATION TYPE C.F.C.R - FOAM	REF. INSIDE VOLUME LIT. 340

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NO	OFF	NO
Freezer Air Temp. t ₁	-7		-9	
Freezer Air Temp. t ₂	-8		-10	
Freezer Air Temp. t ₃	-9		-11	
Freezer Mean Temp. t _{m1}	-8		-10	
Freezer Bulb Temp. t ₄	-13		-18	
Refrigerator Comp. Temp. t ₅	+4		+4	
Refrigerator Comp. Temp. t ₆	+5		+5	
Refrigerator Comp. Temp. t ₇	+6		+6	
Refrigerator Comp. Mean Temp. t _{ma}	+5		+5	
Crisper Comp. Temp. t ₈	10		10	
Compressor Shell Temp.	73		78	
Condenser Inlet Temp.	50		76	
Condenser Outlet Temp.	45		51	
Suction Temp.	44		45	

REMARKS Working Percentage = 55 %

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET PAGE 5-37

FORM NO. 00

DATE APRIL 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R	MODEL AR 12
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>R12-2</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43
COMPRESSOR NAME Danfoss	MODEL FR 8.5 G
WATT. CAPACITY 158	POWER CONSUMPTION, WATT. 24 Hrs
VOLT 220 AMPER -- HRTZ. 50	REFRIGERANT WEIGHT GR. 150
INSULATION TYPE C.F.C.R FOAM	REF. INSIDE VOLUME LIT. 280

THERMOSTAT TYPE	THERMOSTAT SETTINGS			
	ON	NC	OFF	NO
Freezer Air Temp. t ₁	-15		-16	
Freezer Air Temp. t ₂	-13		-14	
Freezer Air Temp. t ₃	-14		-15	
Freezer Mean Temp. t _{m1}	-14		-15	
Freezer Bulb Temp. t ₄	-16		-20	
Refrigerator Comp. Temp. t ₅	+7		+6	
Refrigerator Comp. Temp. t ₆	+8		+7	
Refrigerator Comp. Temp. t ₇	+9		+8	
Refrigerator Comp. Mean Temp. t _{ma}	+8		+7	
Crisper Comp. Temp. t ₈	+11		+10	
Compressor Shell Temp.	75		80	
Condenser Inlet Temp.	52		70	
Condenser Outlet Temp.	45		50	
Suction Temp.	43		44	

REMARKS	Working percentage = 64 %
---------	---------------------------

AZMAYESH INDUSTRIAL FACTORIES CO .

R134a PROTOTYPE TEST SHEET

PAGE 5-38

FORM NO. 0019

DATE : APRIL 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : AR12
SERIAL NUMBER : NON	PROTOTYPE NUMBER : R12 - 2
CLASSIFICATION/TEST CONDITION 'N'	AMBIENT TEMPERATURE : 43 C
COMPRESSOR NAME : DANFOSS	MODEL : FR 8.5 G
WATT . CAPACITY : 158 WATT	POWER CONSUMPTION . WATT/24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 130
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT 340
THERMOSTAT TYPE	THERMOSTAT SETTINGS
	ON NO OFF NO
Freezer Air Temp . t ₁ c	
Freezer Air Temp . t ₂ c	
Freezer Air Temp . t ₃ c	
Freezer Mean Temp . t _{m1}	-10 -14
Freezer Bulb Temp . t ₄	-15 -20
Refrigerator Comp. Temp . t ₅	1 0
Refrigerator Comp. Temp . t ₆	8 7
Refrigerator Comp. Temp . t ₇	8 8
Refrigerator Comp. Mean Temp . t _{ma}	5.6 5
Crisper Comp. Temp . t ₈	13 12
Compressor Shell Temp.	80 85
Condenser Inlet Temp .	55 72
Condenser Outlet Temp .	45 55
Suction Temp.	43 44
REMARKS COMPRESSOR OPERAYING TIME 68%	

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

PAGE 5-39

FORM NO. 0012

DATE MAY 1995

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R.	MODEL AR12
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>R12-3</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43
COMPRESSOR NAME Tecamseh	MODEL AE 360 KS 561
WATT CAPACITY 158	POWER CONSUMPTION, WATT/24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 130
INSULATION TYPE C.F.C.R - FOAM	REF. INSIDE VOLUME LIT. 340

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	NO	OFF	NO
Freezer Air Temp. t_1	-15		-21	
Freezer Air Temp. t_2	-16		-23	
Freezer Air Temp. t_3	-14		-22	
Freezer Mean Temp. t_m	-15		-22	
Freezer Bulb Temp. t_4	-15		-22	
Refrigerator Comp. Temp. t_5	+4		+3	
Refrigerator Comp. Temp. t_6	+6		+5	
Refrigerator Comp. Temp. t_7	+8		+7	
Refrigerator Comp. Mean Temp. t_m	+6		+5	
Crisper Comp. Temp. t_8	+8		+6	
Compressor Shell Temp.	52		73	
Condenser Inlet Temp.	50		68	
Condenser Outlet Temp.	46		55	
Suction Temp.	44		45	

REMARKS	Working percentage = 60 %
---------	---------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET PAGE 5-40

FORM NO. 0013

DATE MAY 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R.	MODEL AR12
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>R12-4</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43
COMPRESSOR NAME Aspera	MODEL B 1116 Z
WATT. CAPACITY 158	POWER CONSUMPTION, WATT/24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 135
INSULATION TYPE C.F.C.R - FOAM	REF. INSIDE VOLUME LIT. 340

THERMOSTAT TYPE	ON		OFF	
	NO	NO	NO	NO
Freezer Air Temp. t ₁	-17		-23	
Freezer Air Temp. t ₂	-16		-24	
Freezer Air Temp. t ₃	-18		-25	
Freezer Mean Temp. t _{m1}	-17		-24	
Freezer Bulb Temp. t ₄	-17		-24	
Refrigerator Comp. Temp. t ₅	+7		+6	
Refrigerator Comp. Temp. t ₆	+8		+7	
Refrigerator Comp. Temp. t ₇	+6		+4	
Refrigerator Comp. Mean Temp. t _{m2}	+7		+6	
Crisper Comp. Temp. t ₈	13		13	
Compressor Shell Temp.	70		80	
Condenser Inlet Temp.	50		75	
Condenser Outlet Temp.	48		55	
Suction Temp.	47		48	

REMARKS Working percentage = 61 %

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-91

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : ARFZ
SERIAL NUMBER : NON	PROTOTYPE NUMBER : RFZ-1
CLASSIFICATION/TEST CONDITION : N	AMBIENT TEMPERATURE : 18°C
COMPRESSOR NAME : Aspera	MODEL : B 1118Z
WATT . CAPACITY : 204 WATT	POWER CONSUMPTION . WATT . 24 Hr
VOLT 220 AMPER HRTZ . 50	REFRIGERANT WEIGHT GR 180
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT . 340

THERMOSTAT TYPE	THERMOSTAT SETTINGS			
	ON	NO	OFF	NO
Freezer Air Temp . t ₁ c	-15		-21	
Freezer Air Temp . t ₂ c	-16		-20	
Freezer Air Temp . t ₃ c	-14		-20	
Freezer Mean Temp . t _m	-15		-20	
Freezer Bulb Temp . t ₄	-17		-24	
Refrigerator Comp. Temp . t ₅	+5		+4	
Refrigerator Comp. Temp . t ₆	+4		+3	
Refrigerator Comp t ₇	+4		+3	
Refrigerator Comp. Mean Temp . t _m	+4		+3	
Crisper Comp. Temp . t ₈	+8		+6	
Compressor Shell Temp.	55		65	
Condenser Inlet Temp .	32		55	
Condenser Outlet Temp .	32		38	
Suction Temp.	33		34	

REMARKS	COMPRESSOR OPERAYING TIME % 25
----------------	--------------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5-42

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>ARF2</i>
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>RF2-1</i>
CLASSIFICATION: TEST CONDITION "N"	AMBIENT TEMPERATURE : <i>32°C</i>
COMPRESSOR NAME : <i>Aspera</i>	MODEL : <i>B 1118 2</i>
WATT . CAPACITY : <i>204WATT</i>	POWER CONSUMPTION . WATT. 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR <i>180</i>
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>340</i>

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	NC
Freezer Air Temp. t_1 c	-15	-18
Freezer Air Temp. t_2 c	-14	-19
Freezer Air Temp. t_3 c	-13	-18
Freezer Mean Temp. t_m	-14	-18
Freezer Bulb Temp. t_4	-18	-23
Refrigerator Comp. Temp. t_5	+6	+4
Refrigerator Comp. Temp. t_6	+5	+3
Refrigerator Comp t_2	+5	+3
Refrigerator Comp. Mean Temp. t_{me}	+5	+3
Crisper Comp. Temp. t_7	+8	+8
Compressor Shell Temp.	55	60
Condenser Inlet Temp.	37	45
Condenser Outlet Temp.	32	38
Suction Temp.	32	34

REMARKS COMPRESSOR OPERAYING TIME % *45*

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET PAGE 5-93

FORM NO. 0006

DATE APRIL 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R.F.	MODEL ARF2
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>RF2-1</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43
COMPRESSOR NAME Aspera	MODEL B 1113 Z
WATT. CAPACITY 204	POWER CONSUMPTION, WATT/24 Hrs
VOLT 230 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 150
INSULATION TYPE C.F.C.R FOAM	REF. INSIDE VOLUME LIT. 340

THERMOSTAT TYPE	THERMOSTAT SETTING	
	ON	OFF
Freezer Air Temp. t ₁	-6	-15
Freezer Air Temp. t ₂	-7	-14
Freezer Air Temp. t ₃	-6	-15
Freezer Mean Temp. t _{m1}	-6	-15
Freezer Bulb Temp. t ₄	+4	-11
Refrigerator Comp. Temp. t ₅	+5	+0
Refrigerator Comp. Temp. t ₆	+6	+1
Refrigerator Comp. Temp. t ₇	+7	+2
Refrigerator Comp. Mean Temp. t _{ma}	+6	+1
Crisper Comp. Temp. t ₈	+5	+7
Compressor Shell Temp.	75	85
Condenser Inlet Temp.	50	90
Condenser Outlet Temp.	45	50
Suction Temp.	44	45

REMARKS	Working percentage = 74%
---------	--------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET PAGE 5-44

FORM NO. 0007

DATE APRIL 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME A.R.F	MODEL AFR2
SERIAL NUMBER <i>NON</i>	PROTOTYPE NUMBER <i>RF2-2</i>
CLASSIFICATION/TEST CONDITION Tropical	AMBIENT TEMPERATURE 43
COMPRESSOR NAME Goldstor	MODEL V75 LAEG
WATT CAPACITY 204	POWER CONSUMPTION, WATT/24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 210
INSULATION TYPE C.F.C.R FOAM	REF. INSIDE VOLUME LIT. 300

THERMOSTAT TYPE	TEMPERATURE (°C)			
	ON	NO	OFF	NO
Freezer Air Temp. t ₁	-8		-15	
Freezer Air Temp. t ₂	-7		-15	
Freezer Air Temp. t ₃	-7		-14	
Freezer Mean Temp. t _{m1}	-7		-15	
Freezer Bulb Temp. t ₄	+3		-12	
Refrigerator Comp. Temp. t ₅	+6		+3	
Refrigerator Comp. Temp. t ₆	+7		+2	
Refrigerator Comp. Temp. t ₇	+5		+4	
Refrigerator Comp. Mean Temp. t _{ma}	+6		+3	
Crisper Comp. Temp. t ₈	+6		+3	
Compressor Shell Temp.	50		92	
Condenser Inlet Temp.	50		90	
Condenser Outlet Temp.	48		60	
Suction Temp.	44		45	

REMARKS	Working percentage = 88%
----------------	--------------------------

AZMAYESH INDUSTRIAL FACTORIES CO.

R13-1 PROTOTYPE TEST SHEET

5-95

Date: 11 June 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : <i>ARF2</i>
SERIAL NUMBER : NON	PROTOTYPE NUMBER : <i>RF-03</i>
CLASSIFICATION/TEST CONDITION : <i>T</i>	AMBIENT TEMPERATURE : <i>43°C</i>
COMPRESSOR NAME : <i>Zanussi</i>	MODEL : <i>GL80AA</i>
WATT CAPACITY : <i>204</i> WATT	POWER CONSUMPTION : WATT/24 Hrs
VOLT 220 AMPER HRTZ 50	REFRIGERANT WEIGHT GR <i>200</i>
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. <i>340</i>
THERMOSTAT TYPE	THERMOSTAT SETTINGS
	ON NC OFF NO
Freezer Air Temp. <i>t1</i> c	-5 -17
Freezer Air Temp. <i>t2</i> c	-8 -19
Freezer Air Temp. <i>t3</i> c	-7 -20
Freezer Mean Temp. <i>t m.</i>	-7 -18
Freezer Bulb Temp. <i>t4</i>	-15 -24
Refrigerator Comp. Temp. <i>t5</i>	+5 +3
Refrigerator Comp. Temp. <i>t6</i>	+7 +6
Refrigerator Comp <i>t7</i>	+8 +6
Refrigerator Comp. Mean Temp. <i>t m2</i>	+7 +5
Crisper Comp. Temp. <i>t8</i>	+6 +5
Compressor Shell Temp.	70 85
Condenser Inlet Temp.	50 85
Condenser Outlet Temp.	45 50
Suction Temp.	32 43
REMARKS COMPRESSOR OPERAYING TIME % <i>75</i>	

AZMAYESH INDUSTRIAL FACTORIES CO.

R134a PROTOTYPE TEST SHEET

5.46

Date 12 June 95

DESCRIPTION	DESCRIPTION
PRODUCT NAME : REFRIGERATOR	MODEL : ARF2
SERIAL NUMBER : NON	PROTOTYPE NUMBER : RF-04
CLASSIFICATION TEST CONDITION : T	AMBIENT TEMPERATURE : 43°C
COMPRESSOR NAME : Necchi	MODEL : ESC9H
WATT . CAPACITY : 204WATT	POWER CONSUMPTION . WATT / 24 Hrs
VOLT 220 AMPER HRTZ. 50	REFRIGERANT WEIGHT GR 200
INSULATION TYPE : POLYURITHINE	REF. INSIDE VOLUME LIT. 340

THERMOSTAT TYPE	THERMOSTAT SETTING			
	ON	VC	OFF	VC
Freezer Air Temp. t ₁ c	-6		-12	
Freezer Air Temp. t ₂ c	-7		-19	
Freezer Air Temp. t ₃ c	-8		-21	
Freezer Mean Temp. t _m	-7		-20	
Freezer Bulb Temp. t ₄	-16		-23	
Refrigerator Comp. Temp. t _s	+6		+4	
Refrigerator Comp. Temp. t ₆	+4		+4	
Refrigerator Co	+7		+5	
Refrigerator Comp. Mean Temp. t _{mz}	+6		+4	
Crisper Comp. Temp. t _e	+8		+7	
Compressor Shell Temp.	75		85	
Condenser Inlet Temp.	55		80	
Condenser Outlet Temp.	43		50	
Suction Temp.	38		45	

REMARKS COMPRESSOR OPERAYNG TIME % 70



CHAPTER 6

*TEMPERATURE TEST
PROCEDURE*

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 6 1

Azmayesh Refrigerators and Ref - Freezers Storage
Temperature Test Procedure

Model : AR06 , AR 08 , AR10, AR12, and ARF2

Refrigerant : R134a classification T

Publication NO. : ALAB-95-PO1

Revision No . :

Date of Issue : April-1995

Change No . : 0

1- Subject : This procedure explains the methods of laboratory test in Azmayesh Industrial Factories Company laboratory department in desired conditions for determination of product storage temperature.

2 - Scope : This procedure describes the methods of laboratory test for



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 408

CONTRACT NO. 94 / 007

PAGE 6 - 2

Azmayesh Refrigerator and Refrigerator- Freezer Model AR06 ,AR08
, AR10 , AR12, and ARF2

3 - Reference : ISO 7371 , ISO 8187, DIN 8950 .

4 - Instruction :

4 -1- This procedure shall comply with the above mentioned standards

4 -2- Prepration of hot room .

4 -2-1- The hot room Air tempereture should be kept steady and equal within the hot room space .

4 -2-2- Maximum 4 Appliances could be put in hot room at the same time for the purpose of test .



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 007

PAGE 6-3

4-2-3- All other objects which are not to be used for test shall be evacuated .

4-2-4- Relative humidity of hot room shall be adjusted in accordance with desired classification test (T) tropical .

4-2-5- All Record and temperature sensors shall be checked prior to test run

4-2-6- Assure that all Recorders are properly checked and calibrated .

4-2-7- Assure that all measuring Instruments are properly fitted and calibrated .

4-2-8- Check all measuring devices for calibration due date

4-2-9- Check hot room for cleanness and free of any obstruction during test .

4-2-10- Check for equality of temperature of hot room before starting



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP : IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 6 1

the appliances for performance test .

4-2-11- Consider and make sure that all pre-caution set-forth by compressor manufactures are applied to appliances prior and after the test .

4-3- Prepration of the appliance .

4-3-1 Each appliance shall be placed on a wooden Slide top platform in dull black colour , open for free air circulation under the platform , the top of the platform shall be 30 centimeter above the test room . floor and shall extend at least 30 centimeter but not more than 0.6 m . beyond all sides of the appliance except at the rear where it shall extend to the vertical partition.

4-3-2 Circulation of air about the appliance shall be restricted by surrounding the appliance by three vertical partitions , painted dull black.



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 6 - 5

4-3-3 One vertical partition shall be placed parallel the rear of the appliance , against the stops or at the distance of 5 centimeter from condenser tube vertical surface .

4-3-4 Two vertical partitions shall be placed parallel to the side of cabinet and shall be fixed on the platform 0.3 m. from the sides of the cabinet

4-3-5 The two side partitions shall be 0.3 m. wide.

4-3-6-The vertical partitions shall present no discontinuity they shall be such a height that they extend at least 0.3 m. above the top of the appliance .

4-3-7- The appliance shall be placed or shielded as to prevent direct radiation to or from the space cooling or heating equipment in the test room.

4-3-8- The appliance shall be placed far enough away from all other objects in the test room to eliminatate any possibillity of any point in



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 6 - 6

the space in which it is situated being at a temperature other than ambient .

4-3-9- Air temperature in test room shall be such that the specified ambient temperature are obtained within the limits of the specified tolerances.

4-3-10- Avoid from Air current fvelocity above 0.25m/s in test room.

4-3-11- The air circulation in the test room shall not interfere with the normal air circulation created by the appliance .

5- Test Procedure for Storage Temperature .

5-1- The evaporator shall be defrosted if necessary and the internall walls and components of the appliance dried.

5-2- All doors and means of access shall kept closed during tests.

5-3- The appliance shall be fully operational and in service , and shall



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 6 - 7

be operationally checked by Q.C department prior to test run .

5-3-1 All internal fittings such as ice trays shall be put into position ,
except Model ARF2 .

5-4- Thermostat position shall be in normal setting or between 3 or 4
grade.

5-5- The empty appliance shall be operated at least for 24 hrs. to reach
equilibrium.

5-6- The food freezer compartment and frozen food storage
compartment shall be equipped with test packages.

6- Class (T) Temperature Condition.

6-1- Storage temperature 18 degree C and 43 degreeC .

6-2- Energy consumption 32 degreeC .



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / DRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 6 - 8

6-3 The temperature at each measurement point shall be kept constant within ± 5 degree k of the nominal ambient temperature both during the periods required for obtaining stable operating condition and during the tests .

7- Humidity

Relative humidity shall be kept between 45% and 75%

8- Test packages

8-1 The tests shall be carried out with test packages loaded in the form of parrallelepipeds.

8-2- Test packages shall be prepared in accordance with ISO 8187 para 8.2.

9- Measuring procedure .

9 - 1 - Temperature shall be measured with temperature probe , the



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 6 - 9

sensors of which are inserted in test packages .

9 - 2 - The accuracy of measuring Instrument shall be within $\pm 0.3 K$

9 - 4 - The temperature t_1, t_2, t_3 and t_{c1}, t_{c2} shall be measured in copper or brass cylinders suspended and located at temperature sensing point as shown in figure 1 half way between the rear internal wall of the appliance and the internal wall of close door .

9-5- The mean Internal temperatures , t_m and t_{cm} shall then be calculated as an average of the mean temperatures of t_1, t_2, t_3 and t_{c1} and t_{c2}

9-10- The sensors surfaces shall be separated from any heat conducting surface by at least 25mm of air space .

10- Test period

The test period shall be at least 24hr after stable operating conditions have been attained.



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 6 - 10

11- Storage plan

11-1 The food freezer compartment shall be filled with as many test package as they can hold .

11-2 The test package temperature shall have been previously brought to approximately equal to the classification temperature of the compartment.

11-3- Test packages having a base of 100 x 200 mm shall be made using 1kg package (50x100x200)mm laid flat

11-4- Free air spaces of 15mm minimum as far as possible equal shall be left between adjacent stacks of test packages.

11-5 Door shelves and compartments shall be loaded with as many packages as possible , free air spaces shall be maintained between the packages and the inner surface of the door .



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 403

CONTRACT NO . 94 / 007

PAGE 6 - 11

12- Temperature measurement .

12-1- For ambient temperature of 43 degree C for class (T) test . The thermostat shall be adjusted , as necessary , to position which to get storage temperatures as follows , after stable operating conditions have been attained .

Note : For stable condition Reffer to para 3.4.8 I.S.O 8187

12-2- Appliance shall be capable of maintaining simultaneously ,the required storage temperature in the different compartments as follows.

12-3- The temperature of -12 degree C for Models AR06 , AR08 , AR10 and AR12 and -18 degree C for Model ARF2 shall be maintained in the Evaporator and Freezer Compartment.

12-4 For class T storage temperature in ambient temperature +18 degree C to 43 degree C for Model AR06 , AR08 , AR10 , AR12 and ARF2 in fresh food compartment the t_1 , t_2 , t_3 shall be between 0 degree C and +10 degree C and t_m max should be +5 ,+ - 0.5 degree C



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / TRA / 94 / 408

CONTRACT NO . 94 / 097

PAGE 6 - 12

12-5- t_m in cellar compartment for class T should be between + 8 degree C and +14 degree C .

12- 6- t_m in freezer compartment shall be -12 degree C for Models AR06 , AR08 , AR10 , AR12 and ARF2 .

12- 7 t_m in Freezer Compartment for Model ARF2 shall be - 18 C +- 0.5

12- 8 For temperature measurement , the stable operating condition are deemed to be reached when the temperature at all corresponding points during successive operating cycle agree within +- 0.5 C and no marked trend from the mean temperature happen during aperiod of 24 Hrs .

13 - Percentage running time "R "

The percentage running time shall not exceed 80%



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRONICS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 405

CONTRACT NO. 94 / 097

PAGE 6 - 13





Figure 1



CHAPTER 7

*ENERGY CONSUMPTION
TEST PROCEDURE*

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. NP / IRA / 94 / 408

CONTRACT NO. 94 / 097

PAGE 7 - 2

5 - 3 - 2 In the case of cyclic operation , the initial and final values shall be read immediately after the thermostat cuts out .

5 - 3 - 3 The measurement of energy consumption shall be carried out under storage conditions , as follows .

5 - 3 - 3 - 1 The energy consumption corresponds to the temperature $t_m = + 5$ degree C and ambient temperature of 32 degree C .

5 - 3 - 3 - 2 The energy consumption could also be corresponding to one of the following temperature condition .

a) Either $t_m = + 5$ degree C , with t_1 , t_2 , and t_3 between 0 degree C and + 10 degree C and simultaneously the maximum temperature of warmest test packages colder or equal to - 12 degree C for Models AR06 , AR08 , AR10 , AR12 and - 18 degree for ARF2
OR ,

b) The maximum temperature of the warmest test equal to - 12 degree C for Model AR06 , AR08 , AR10 and AR12 and - 18 degree C



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 7 - 3

3 - References

ISO 7371 , ISO 8187 and DIN 8950

4 - Instruction :

This procedure shall comply with above mentioned Standards and Publication No . ALAB - 95 - P01 as necessary .

5 - Procedure

5 - 1 Ambient temperature

32 degree C for class " T "

5 - 2 Appliance shall be prepared in accordance with Azmayesh Publication No . ALAB - 95 - P01 Dated April 1995 , Para . 4 - 2 through 4 - 3 .

5 - 3 Measurement

5 - 3 - 1 The value of the energy consumption shall be calculated and measured for a period of exactly 24 Hrs .



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. KP / IRA / 94 / 403

CONTRACT NO. 94 / 097


PAGE 7-1

ARF2 and simultaneously t_m between 0 degree C and + 5 degree C with t_1 , t_2 and t_3 between 0 and 10 degree C.

5 - 3 - 3 - 3 The energy consumption may be obtained by interpolation from results, one giving a temperature above and one below the specified temperature $t_m = + 5$ degree C for condition a) above or one giving a temperature above and one below classification temperature of freezing compartment - 12 degree C for Models AR08, AR08, AR10 and AR12 and - 18 degree C for Model ARF2.

5 - 3 - 3 - 4 The temperature deviation above and below = 5 degree C in condition a) or above and below the classification temperature in condition

b) shall be within limits of ± 2 K.



CHAPTER 8

OPTIMIZATION METHOD

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 3 - 1

Azmayesh Refrigerators and Ref-Freezer Optimization Method

Models : AR06 , AR08 , AR10 , AR12 and ARF2

Refrigerant : R134a

Publication No. : ALAB - 95 - P03

Date of Issue : APRIL 1995

Change No. : 0

1 - Subject : Refrigerator and Ref - Freezer optimization method .

2 - purpose : To have a standard method of product optimization for high efficiency low- energy consumption and proper equipment selection with company's policy consideration .

3 - Scope : This publication describes the method of refrigeration system optimization for Azmayesh Refrigerator and Ref - Freezer and also Freezer for defined Models .



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 405

CONTRACT NO . 94 / 097

PAGE 8 - 2

4 - Refrigeration System Optimization .

4 -1- Since We are limited in the number of Refrigeration System Modules and factors we divide , these Modules into two Systems

a) **Variable components:** like , Refrigerant , Capillary tube, Drier, compressor and Insulation

b) **Non-Variable components:** like Door, cabinet, Evaporator, and Condenser

Note : Evaporator and condenser are considered as Non-Variable components due to the Engineering and economical situation which we are not prepared to change them , unless , Such a modification could affect largely on Refrigeration System and limit our Variable components Selection .

4 - 1 - 1 Variable Components

Refrigerant

Since Refrigerant R12 is to be phased - out from our

production line and Refrigerant R134a has been selected as an



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

PAGE 8 - 3

production line and Refrigerant R134a has been Selected as an ODP Zero Refrigerant we discuss R134a in this regards. Due to the higher potential of R134a in a refrigerant cycle. It seems that at least 10% decrease of refrigerant weight in comparison with R12 could give us the same cooling capacity, but through our laboratory test we found out that only 80% of Refrigerator can correspond to the reduction of Refrigerant weight because of different models of compressors from different manufacturer. therefore for optimization of refrigerant it is reasonable to check the weight of Refrigerant and come to the correct amount of weight whenever we change our compressor unit. Due to the Market and Design and Economical Restrictions so we should take it into our consideration that printing gas weight in our Serial Number plugs must be accomplished just after the unit production by declaration of laboratory and not using preprinted Metal tags on the units.

Capillary tubes

Through our laboratory test we found out that increase and decrease of capillary tube could be a mean of optimization programme in some case but not all the time, and that is when we



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 007

PAGE 3-4

need to reach the Standard test condition , under **ASHRAE** standard , just when we want to adjust the Evaporating temperature and also Subcooling temperature . In case of **R134a** refrigerant , at the first step we tried to increase the length of capillary length in order to have the better Evaporating temperature , and then we chose the same length as it was before . we found out that there is not much difference between two conditions , so we recommend not to increase the length of capillary tube only in case of using Compressor either with higher cooling capacity than it is required or the amount of refrigerant gas can not be regulated by the weight properly .

Compressor

To our idea Compressor Unit is the most effective Variable component that could affect the efficiency of Refrigeration System . So it is very important to choose the correct and proper compressor in order to achieve the desired test condition , the following factor could be main steps for a correct compressor selection in order to optimize Refrigeration system and also make all Refrigeration modules compatible to each other .



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 405

CONTRACT NO. 94 / 097

PAGE 8 - 5

It should be noticed that compressor selection is only the theoretical step of optimization programme and final selection must be achieved after compressor laboratory operational and conformance test .

1 - Cooling Capacity

For a proper and favorable compressor selection we have to know our cooling Requirement first , in order to know our requirement we should know the cooling capacity of appliance that is under our optimization programme , it is very important because wrong cooling capacity leads us to select the wrong compressor.

2 - System Condition

The condition which we have calculated for our Refrigeration load is important too , the test condition which we have been considered for example There is a slight difference between ASHRAE standard and CECOMAF standard and that is higher evaporating temperature and higher Sub-cooling



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . NP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 3 - 6

temperature for **CECOMAF** standard , so in this case we will need more cooling capacity . For example , for our Refrigerator Model **AR08** with a cooling Requirement of **93 Kcal/hr** in **ASHRAE** standard condition we should choose Zanussi compressor Model **GL45AA** with cooling capacity of **92 Kcal/hr** but at the same condition for **CECOMAF** standard we have to select Zanussi Compressor Model **GL5DAA** the reason for this difference is the difference between **COP** of compressor in two standard condition which for Model **GL45AA** the **COP** in **ASHRAE** condition is 1.08 and in **CECOMAF** is 0.83 , in using an efficient Sub-cooling system by using almost 90 cm of Evaporator Return line for cooling the capillary outlet tube we have to select **ASHRAE** standard condition with Sub-cooling temperature , which in this standard test condition is 32 degree Centigrade .

3 - Evaporating Temperature

Evaporating temperature is one of the most important factor in determining the desired condition , for example in order to reach - 12 degree centigrade of test package inside evaporator compartment we have to know what evaporating temperature we need ?



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 097

PAGE 3 - 7

If we expect -25 degree centigrade with Sub- Cooling system , then we have to select a compressor with higher cooling capacity and better COP . Since most of compressors in among our sources uses -23.3 degree centigrade evaporating tempreture , test condition , we consider this figure as an aim to reach and select an optimized compressor and then we try to adjust the amount of refrigerant weight and also perform minor modification in designing of cabinet in order to keep -12 degree centigrade or -23.3 evaporating temperature in Freezer compartment .

4 - System Sizing

This subject could be considered as a guide to select proper compressor ,The following items are important subjects that could be taken into our consideration .

- a - Condenser sizing , (condensing temperature)
- b - Heat exchanger suction gas / liquid (superheat suction gas)
- c - Evaporator sizing . (evaporating temperature , suction gas temp.)



AZMAYESH INDUSTRIAL FACTORIES COMPANY

ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 405

CONTRACT NO . 94 / 007

PAGE 8 - 8

5 - Drier

Filter drier does not have such a remarkable affect in our Refrigeration System , unless proper selection and humidity absorbtion potential . which should be considered In case of R 134a refrigerant Drier XH7 & XH9 with a higher humidity absorbtion potential are recommended .

6 - Insullation:

Type of Insullation could affect the rate of energy consumption . Since changing Insulation type is not a repeatative activity in optimization programme we would rather to take this subject in energy consumption programme .

4 -1-2 Non- Variable Components .

1 - Door and Cabinet

As a matter of optimization device we can not consider th interchangeability of Refrigerator and Freezer Cabinet and door . unless minor modifications that are practicaly possible , such as



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 408

CONTRACT NO . 94 / 097


PAGE 8 - 9

designing or changing small parts to keep inside temperature stable and in this step , we found out that we have a problem in distributing air properly inside evaporator compartment and food compartment , so we planned to reinforce and seal the water drain tray under evaporator section in order to keep -12 degree centigrade air temperature in evaporator section constant .

2- Evaporator and Condenser

Evaporator and Condenser are of those component which could hardly be modified especially Evaporator because our Evaporator is Roll Bond type and we could not simply modify it , although in laboratory test we found out it is not necessary to modify our evaporator .

The condenser is not considered as a component to affect largely our refrigeration system , because we found out that we can get temperature 32 degree centigrade in condenser outlet tube easily and the temperature defferance of one third of condenser tube and midel of filter drier is not more than 5 degree centigrade .



CHAPTER 9

PREPARATION OF TRIAL EQUIPMENTS

AZMAYESH INDUSTRIAL FACTORIES COMPANY

MAY 1995



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 403

CONTRACT NO. 94 / 097

~~PAGE 4-1~~
PAGE 9-1

PREPARATION OF TRIAL EQUIPMENT

1 - Due to the contract No. 94 / 097 with UNIDO we have to prepare 4 prototypes for each Model . Taking into our consideration that for each Model we have to perform three condition tests as follows

- a) 43 C Cyclic run test
- b) 32 C Cyclic run test
- c) 18 C Cyclic run test

The above mentioned tests are principally performed in order to check the performance of each refrigerator model in new condition using refrigerant R134a and comparing them with R12 refrigerant .

Determination of energy consumption is another objective in this project that we have to accomplish it through testing different kind of Compressor Models .

As we mentioned in Selection of R134a Compatible Components Chapter , we actually deal with many different kinds of compressors which could affect our Energy consumption ratio , for this reason we

**AZMAYESH INDUSTRIAL FACTORIES COMPANY**

ELECTRICALS / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO. MP / IRA / 94 / 405

CONTRACT NO. 94 / 007

PAGE 9 - 2

which could affect our Energy consumption ratio, for this reason we have to consider the testing results of these numerous kind of compressor performance in our Optimizing Programme .

The following compressor models have been test in our laboratory so far for determination of R134a refrigeration cycle performance .

Compressor Model	Manufacturer
BP 1048 Z 22	ASPERA
B 1118 Z	ASPERA
B 1116 Z	ASPERA
BP 1111 Z	ASPERA
FR 8.5 G	DANFOSS
V 75 LAEG	GOLDSTAR
NR 62 LAEG	GOLDSTAR
NR 58 LAEG	GOLDSTAR
AE 360 KS 561	TECAMSEH



AZMAYESH INDUSTRIAL FACTORIES COMPANY
ELECTRICAL / HOME APPLIANCES

PROGRESS REPORT # 2

PROJECT NO . MP / IRA / 94 / 403

CONTRACT NO . 94 / 007

At the time of preparing this report some ^{PAGE 2-3} more compressor models from Danfoss , Matsushita and Necchi were going to be tested for determination of performance characteristics and energy consumption .

2 - Field Test

Through defferent catalogues and technical informations and specifications available in our company we prepared a spread sheet to select at least 30 defferent Compressor Model from 6 Manufactrurer .

From these Compressor Models after appropriate test in our laboratory we are going to install following Compressors on our Refrigerator Units for a quantity of 50 to 100 Units for the purpose of field test , then we are going to collect all external failure which could happen during field test evaluation and try to achive necessary modification and also suitable component selection . In this respect we are planning to train our servicemen all around Iran in order to give us correct and desireable technical information regarding technical , design and manufacturing deffects .