



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

22116

UNIDO Contract No. 97/001
UNIDO Project No. MP/CPR/96/087

Final Report

February 1st, 1999

1. Summary

After start-up of mass-production in the modified factory with the modified products pilot customer and independent laboratories reconfirmed the achievement of the conversion targets.

With this the project is successfully completed.

2. Work performed after start-up of modified plant

The modified plant started quantity production in November for selected pilot customers.

2.1 Haier

1000 compressors of QD 88 Y and more than 1000 pieces of QD 100 Y were delivered to Haier in Qindao, first part already in September.

More the 2000 pieces of QD 123 Y were also shipped to Haier.

Laboratory and field tests of Haier were successfull.

2.2 Wanbao

Samples of all models were delivered to Wanbao factory in Guangzhou for qualification. Positive test results werde confirmed in laboratory test reports by Wanbao.

2.3 dkk

Samples from first production month were shipped to dkk to cross-check the test data obtained from Chinese Standard Test Centre.

Results fully confirmed the previous measurement data.

(see attachment)

Test – Report

Measuring Calorimeter – R600a

Compressors: QD69Y, QD81Y, QD100Y, QD135Y

performed by dkk

UNIDO Project: Dongbei

Date: 1999-01-20

1. Design

Hermetic compressor for household refrigerators

Refrigerant: R600a

220V/50Hz

Climate class: N

Application: LST

QD68Y to QD100Y with run capacitor

QD135 without run capacitor

2. Conditions

ASHRAE conditions:

to -25 °C, -23,3 °C, -15 °C

$t_a = t_{g1} = 32,2 \text{ °C}$

$t_f = 54,5 \text{ °C}$ $t_{fl} = 32,2 \text{ °C}$

static ventilation

220V/ 50Hz

3. Conversion target

- I. Cooling Capacity R600a corresponds the range of 100 to 200 W
- II. COP not less than 1,3 W/W [ASHRAE rated point -23,3 °C]

4 Results

4.1 Calorimeter

The data of the calorimeter measuring are summarized in the tables QD69Y to QD135Y.
Furthermore all values are shown in the protocols of calorimeter measuring.

The cooling capacity is between 100 W and 200W. The designed target has been reached and even exceeded.

The compressor QD135Y was not delivered with run capacitor. The other models have the run capacitor with 3 μ F whereby the input power will be decreased. This improvement is to be seen in conjunction with an adjustment of the motor. The high efficiency motor improves therefore also the COP.

The COP values moves in a range from 1,35 W/W to 1,47 W/W at the ASHRAE rated point. The conversion has been performed successfull of all models.

Proposal for the rated values Q_o [W], P_1 [W], COP [W/W]

	Q_o [W]	P_1 [W]	COP [W/W]
QD69Y	102	79	1,29
QD81Y	125	95	1,31
QD100Y	165	115	1,43
QD135Y	200	145	1,38

The QD88Y and the QD123Y have been rated in a former report. (see behind)
Meanwhile Dongbei has improved the performance data of QD 88Y by adding a run capacitor.

4.2 Start test

The start of the compressors have been rated in conjunction with the measuring of the sweep voltage.

The sweep voltage is the measuring value where the compressor motor is just before he stop. The compressor has constant and stable conditions of temperature and pressure.

	U _k [V]
QD69Y	95
QD81Y	115
QD100Y	112
QD135Y	113

All compressors have a large reserve to the rated voltage and therefore the start reaction is sure.

Date

Date 27. 01. 1999

.....
d k k
Gesellschaft für Entwicklung
und Projektmanagement mbH
August-Bebei-Straße 24
D/09435 Scharfenstein
Tel. 0 37 25 / 7 07 60 . Fax 0 37 25 / 70 78 21

.....


Annex

List of abbreviations

Verzeichnis der Abkürzungen

Data Calorimeter

to	[°C]	Verdampfungstemperatur	Evaporating temperature
Q _o	[W]	Kälteleistung	Cooling Capacity
P _l	[W]	Leistungsaufnahme	Input Power
COP	[WW]	Leistungszahl	Coefficient of Performance
U _k	[V]	Kippspannung	Sweep Voltage
I _l	[A]	Betriebsstrom	Operating Current
Q _{vol}	[W/cm ³]	volumetrische Kälteleistung	vol. Cooling Capacity
t _w	[°C]	Wicklungstemperatur	winding temperature
t _{g3}	[°C]	Druckstutztemperatur	Discharge pipe temperature
t _{sch}	[°C]	Temperatur unter Schutzkappe	Temperature behind elec. casing
t _{ko}	[°C]	Temp. Kapsel oben	Temperature Casing top
t _{ku}	[°C]	Temp. Kapsel unten	Temperature Casing bottom
n	[°C]	Drehzahl	Revolution per minute
t _f	[°C]	Verflüssigungstemperatur	Condensing temperature
t _{fl}	[°C]	Unterkühlungstemperatur	Temperature of subcooled liquid
t _a	[°C]	Umgebungstemperatur	Ambient temperature
t _{g1}	[°C]	Sauggastemperatur	Suction gas temperature

General Data

R12	Kältemittel Dichlordifluormrthan	Refrigerant
R600a	Kältemittel Isobutan	Refrigerant
LST	niedriges Anlaufmoment	low starting torque

Calorimeter Data														Date:	1999-01-19
														Q/Ri	
		TYPE:	QD 69Y												
		Design:	run capacitor,R600a					Conditions:				220V/50Hz			
		Refrigerant:	R600a					ASHRAE							
		Recording:	qd69y dongbei 0199												
		Start:	0199												
Compr.No.	to °C	Ventilation	Qo W	P1 W	COP W/W	Uk V	l ₁ A	Qvol W/cm ³	tw °C	tg ₃ °C	tsch °C	tko °C	tku °C	n 1/s	remarks
981686	-25	static	96,3	74,2	1,30	92	0,45	.	85,4	57,5	64,5	60,5	64,0	49,3	
981686	-23,3	static	104,7	77,5	1,35	95	0,46	.	86,4	58,0	65,5	61,5	64,0	49,3	
981686	-15	static	179,5	97,5	1,84	105	0,55	.	84,4	69,0	66,0	62,0	63,0	49	

Calorimeter Data														Date:	1999-01-19
														Q/Ri	
TYPE:		QD 81Y													
Design:		run capacitor,R600a				Conditions:		220V/50Hz							
Refrigerant:		R600a				ASHRAE									
Recording:		qd81y dongbei 0199													
Start:		0199													
Compr.No.	to °C	Ventilation	Qo W	P1 W	COP W/W	Uk V	I ₁ A	Qvol W/cm³	tw °C	tg ₃ °C	tsch °C	t _{ko} °C	t _{ku} °C	n 1/s	remarks
981068	-25	static	114,3	88,3	1,29	100	0,52	-	97,5	63,5	64,0	61,5	62,0	49,1	
981068	-23,3	static	128,6	94,5	1,36	115	0,54	-	96,4	67,1	64,0	62,0	60,0	49,1	
981068	-15	static	208,1	115,2	1,81	128	0,63	-	94,4	76,3	65,5	63,0	59,0	48,9	

Calorimeter Data															Date:	1999-01-19
															Q/Ri	
TYPE:		QD 100Y														
Design:		run capacitor,R600a					Conditions:		220V/50Hz							
Refrigerant:		R600a					ASHRAE									
Recording:		qd100y dongbei 0199														
Start:		0199														
Compr.No.	to °C	Ventilation	Qo W	P1 W	COP W/W	Uk V	I ₁ A	Qvol W/cm³	tw °C	tg ₃ °C	tsch °C	tko °C	tku °C	n 1/s	remarks	
981684	-25	static	155,0	108,0	1,43	110	0,58	-	90,9	70,8	66,6	65,5	65,0	48,9		
981684	-23,3	static	166,8	113,8	1,47	112	0,6	-	91,9	72,7	68,5	65,5	63,5	48,9		
981684	-15	static	270,6	145,5	1,86	128	0,74	-	87,8	80,7	63,0	67,0	62,0	48,6		

Calorimeter Data															Date:	1999-01-19
															Q/Ri	
TYPE:		QD 135Y														
Design:		without run capacitor,R600a					Conditions:					220V/50Hz				
Refrigerant:		R600a										ASHRAE				
Recording:		qd135y dongbei 0199														
Start:		0199														
Compr.No.	to °C	Ventilation	Qo W	P1 W	COP W/W	Uk V	l ₁ A	Qvol W/cm³	tw °C	tg ₃ °C	tsch °C	tko °C	tku °C	n 1/s	remarks	
981688	-25	static	187,0	139,0	1,35	113	0,95	.	92,6	83,3	71,0	68,0	60,0	48,7		
981688	-23,3	static	204,0	145,0	1,41	120	0,98	.	89,8	84,2	71,0	69,0	64,0	48,6		
981688	-15	static	324,1	187	1,73	135	1,13	.	87,1	91,1	70,5	68,5	61,5	48,1		

Protocol 1

Compressor data

collected on 15.01.99

Compressor type : QD69Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981686

Recording : qd69y dongbei 0199

Calorimeter Data

Conditions

Measuring date 15.01.1999

Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0
 3. Evaporating temperature [°C] : -23,3
 Cooling capacity [W] : 86,0
 Input power [W] : 77,5
 COP [W/W] : 1,11
 Sweep voltage [V] : 95
 Current [A] : 0,465
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 86,4
 Discharge pipe temperature [°C] : 58
 Temperature behind elec. casing [°C] : 65,5
 Temperatur casing top [°C] : 61,5
 Temperature casing bottom [°C] : 64,0
 Revolution per minute [1/s] : 49,3
 Heating power total [W] : 104,7
 Heating power total [kcal/h] : 90,04

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 13,25
 R warm [Ohm] : 15,95
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 25
 Switch heating start [time] : 9.59
 Switch heating end [time] : 11.02
 Switch heating duration [s] : 3808
 Real power counter start [KWh] : 5,3982
 Real power counter end [KWh] : 5,4825
 Energy consumption [KWh] : 0,0843
 Energy consumption [Ws] : 303480
 Heating power [W] : 79,695
 factor [-] : 0,8215
 Viscosity [cSt] : -

Compressor data

collected on 15.01.99

Compressor type : QD69Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981686

Recording : qd69y dongbei 0199

Conditions like above listed

Measuring date 15.01.1999

2. Evaporating temperature [°C] : -25,0
 Cooling capacity [W] : 79,4
 Input power [W] : 74,2
 COP [W/W] : 1,07
 Sweep voltage [V] : 92
 Current [A] : 0,455
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 85,4
 Discharge pipe temperature [°C] : 57,5
 Temperature behind elec. casing [°C] : 64,5
 Temperatur casing top [°C] : 60,5
 Temperature casing bottom [°C] : 64,0
 Revolution per minute [1/s] : 49,3
 Heating power total [W] : 96,63
 Heating power total [kcal/h] : 83,1

Worker we
 R cold [Ohm] : 13,25
 R warm [Ohm] : 15,9
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 20
 Switch heating start [time] : 15.00
 Switch heating end [time] : 16.02
 Switch heating duration [s] : 3655
 Real power counter start [KWh] : 5,779
 Real power counter end [KWh] : 5,8568
 Energy consumption [KWh] : 0,0778
 Energy consumption [Ws] : 280080
 Heating power [W] : 76,629
 factor [-] : 0,8216
 Viscosity [cSt] : -

Protocol 2

Compressor data

collected on 15.01.99

Compressor type : QD69Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981686

Recording : qd69y dongbei 0199

Calorimeter Data

Conditions

Measuring date

15.01.1999

Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0
 3. Evaporating temperature [°C] : -15,0
 Cooling capacity [W] : 170,9
 Input power [W] : 115,2
 COP [W/W] : 1,48
 Sweep voltage [V] : 128
 Current [A] : 0,63
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 94,4
 Discharge pipe temperature [°C] : 76,3
 Temperature behind elec. casing [°C] : 65,5
 Temperatur casing top [°C] : 63,0
 Temperature casing bottom [°C] : 59,0
 Revolution per minute [1/s] : 48,9
 Heating power total [W] : 208,14
 Heating power total [kcal/h] : 179

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 13,05
 R warm [Ohm] : 16,1
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 25
 Switch heating start [time] : 9.59
 Switch heating end [time] : 11.02
 Switch heating duration [s] : 3808
 Real power counter start [KWh] : 5,3982
 Real power counter end [KWh] : 5,4825
 Energy consumption [KWh] : 0.0843
 Energy consumption [Ws] : 303480
 Heating power [W] : 79,695
 factor [-] : 0,8215
 Viscosity [cSt] : -

Protocol 3

Compressor data

collected on 14.01.99

Compressor type : QD81Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981068

Recording : qd81y dongbei 0199

Calorimeter Data

Conditions

Measuring date 14.01.1999

Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 13,05
 R warm [Ohm] : 16,2
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 56,5
 Switch heating start [time] : 10.33
 Switch heating end [time] : 11.34
 Switch heating duration [s] : 3687
 Real power counter start [KWh] : 4,8318
 Real power counter end [KWh] : 4,9056
 Energy consumption [KWh] : 0,0738
 Energy consumption [Ws] : 265680
 Heating power [W] : 72,059
 factor [-] : 0,8215
 Viscosity [cSt] : -

1. Evaporating temperature [°C] : -23,3
 Cooling capacity [W] : 105,6
 Input power [W] : 94,5
 COP [W/W] : 1,12
 Sweep voltage [V] : 115
 Current [A] : 0,54
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 96,4
 Discharge pipe temperature [°C] : 67,1
 Temperature behind elec. casing [°C] : 64,0
 Temperatur casing top [°C] : 62,0
 Temperature casing bottom [°C] : 60,0
 Revolution per minute [1/s] : 49,1
 Heating power total [W] : 128,56
 Heating power total [kcal/h] : 110,56

Compressor data

Compressor type : QD81Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981068

Recording : qd81y dongbei 0199

Calorimeter Data

Conditions like above listed

Measuring date 14.01.1999

2. Evaporating temperature [°C] : -25,0
 Cooling capacity [W] : 93,9
 Input power [W] : 88,3
 COP [W/W] : 1,06
 Sweep voltage [V] : 100
 Current [A] : 0,52
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 97,5
 Discharge pipe temperature [°C] : 63,5
 Temperature behind elec. casing [°C] : 64,0
 Temperatur casing top [°C] : 61,5
 Temperature casing bottom [°C] : 62,0
 Revolution per minute [1/s] : 49,1
 Heating power total [W] : 114,3
 Heating power total [kcal/h] : 98,3

Worker we
 R cold [Ohm] : 13,05
 R warm [Ohm] : 16,25
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 39
 Switch heating start [time] : 14.24
 Switch heating end [time] : 15.25
 Switch heating duration [s] : 3686
 Real power counter start [KWh] : 5,1154
 Real power counter end [KWh] : 5,1925
 Energy consumption [KWh] : 0,0771
 Energy consumption [Ws] : 277560
 Heating power [W] : 75,301
 factor [-] : 0,8216
 Viscosity [cSt] : -

Protocol 4

Compressor data

collected on 14.01.99

Compressor type : QD81Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981068

Recording : qd81y dongbei 0199

Calorimeter Data

Conditions

Measuring date 14.01.1999

Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0
 3. Evaporating temperature [°C] : -15,0
 Cooling capacity [W] : 170,9
 Input power [W] : 115,2
 COP [W/W] : 1,48
 Sweep voltage [V] : 128
 Current [A] : 0,63
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 94,4
 Discharge pipe temperature [°C] : 76,3
 Temperature behind elec. casing [°C] : 65,5
 Temperatur casing top [°C] : 63,0
 Temperature casing bottom [°C] : 59,0
 Revolution per minute [1/s] : 48,9
 Heating power total [W] : 208,14
 Heating power total [kcal/h] : 179

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 13,05
 R warm [Ohm] : 16,1
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 134
 Switch heating start [time] : 12.38
 Switch heating end [time] : 13.38
 Switch heating duration [s] : 3632
 Real power counter start [KWh] : 4,9823
 Real power counter end [KWh] : 5,0571
 Energy consumption [KWh] : 0,0748
 Energy consumption [Ws] : 269280
 Heating power [W] : 74,141
 factor [-] : 0,8212
 Viscosity [cSt] : -

Protocol 5

Compressor data

collected on 18.01.99

Compressor type : QD100Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981684

Recording : qd100y dongbei 0199

Calorimeter Data

Conditions

Measuring date 18.01.1999

Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0
 3. Evaporating temperature [°C] : -23,3
 Cooling capacity [W] : 137,0
 Input power [W] : 113,8
 COP [W/W] : 1,20
 Sweep voltage [V] : 112
 Current [A] : 0,6
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 91,9
 Discharge pipe temperature [°C] : 72,7
 Temperature behind elec. casing [°C] : 68,5
 Temperatur casing top [°C] : 65,5
 Temperature casing bottom [°C] : 63,5
 Revolution per minute [1/s] : 48,9
 Heating power total [W] : 166,81
 Heating power total [kcal/h] : 143,46

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 13,15
 R warm [Ohm] : 16,1
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 90
 Switch heating start [time] : 10.07
 Switch heating end [time] : 11.09
 Switch heating duration [s] : 3712
 Real power counter start [KWh] : 6,0409
 Real power counter end [KWh] : 6,1201
 Energy consumption [KWh] : 0,0792
 Energy consumption [Ws] : 285120
 Heating power [W] : 76,81
 factor [-] : 0,8215
 Viscosity [cSt] : -

Compressor data

collected on 18.01.99

Compressor type : QD100Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981684

Recording : qd100y dongbei 0199

Conditions like above listed

Measuring date 18.01.1999

2. Evaporating temperature [°C] : -25,0
 Cooling capacity [W] : 127,3
 Input power [W] : 108,0
 COP [W/W] : 1,18
 Sweep voltage [V] : 110
 Current [A] : 0,58
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 90,9
 Discharge pipe temperature [°C] : 70,8
 Temperature behind elec. casing [°C] : 66,6
 Temperatur casing top [°C] : 65,5
 Temperature casing bottom [°C] : 65,0
 Revolution per minute [1/s] : 48,9
 Heating power total [W] : 154,97
 Heating power total [kcal/h] : 133,27

Worker we
 R cold [Ohm] : 13,15
 R warm [Ohm] : 16,05
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 72,5
 Switch heating start [time] : 14.29
 Switch heating end [time] : 15.35
 Switch heating duration [s] : 3946
 Real power counter start [KWh] : 6,3942
 Real power counter end [KWh] : 6,4846
 Energy consumption [KWh] : 0,0904
 Energy consumption [Ws] : 325440
 Heating power [W] : 82,473
 factor [-] : 0,8216
 Viscosity [cSt] : -

Protocol 6

Compressor data

collected on 18.01.99

Compressor type : QD100Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : with run capacitor

Compressor No. : 981684

Recording : qd100y dongbei 0199

Calorimeter Data

Conditions

Measuring date

18.01.1999

Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0
 3. Evaporating temperature [°C] : -15,0
 Cooling capacity [W] : 222,2
 Input power [W] : 145,5
 COP [W/W] : 1,53
 Sweep voltage [V] : 128
 Current [A] : 0,74
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 87,8
 Discharge pipe temperature [°C] : 80,7
 Temperature behind elec. casing [°C] : 63,0
 Temperatur casing top [°C] : 67,0
 Temperature casing bottom [°C] : 62,0
 Revolution per minute [1/s] : 48,6
 Heating power total [W] : 270,64
 Heating power total [kcal/h] : 232,75

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 13,15
 R warm [Ohm] : 15,9
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 195
 Switch heating start [time] : 12.41
 Switch heating end [time] : 13.41
 Switch heating duration [s] : 3603
 Real power counter start [KWh] : 6,2627
 Real power counter end [KWh] : 6,3384
 Energy consumption [KWh] : 0,0757
 Energy consumption [Ws] : 272520
 Heating power [W] : 75,637
 factor [-] : 0,8212
 Viscosity [cSt] : -

Protocol 7

Compressor data

collected on 13.01.99

Compressor type : QD135Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : without run capacitor

Compressor No. : 981688

Recording : qd135y dongbei 0199

Calorimeter Data

Conditions

Measuring date

13.01.1999

Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0
 1. Evaporating temperature [°C] : -23,3
 Cooling capacity [W] : 167,5
 Input power [W] : 145,0
 COP [W/W] : 1,15
 Sweep voltage [V] : 120
 Current [A] : 0,98
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 89,8
 Discharge pipe temperature [°C] : 84,2
 Temperature behind elec. casing [°C] : 71,0
 Temperatur casing top [°C] : 69,0
 Temperature casing bottom [°C] : 64,0
 Revolution per minute [1/s] : 48,6
 Heating power total [W] : 203,95
 Heating power total [kcal/h] : 175,4

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 9,7
 R warm [Ohm] : 11,8
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 125,5
 Switch heating start [time] : 10 .05
 Switch heating end [time] : 11 .06
 Switch heating duration [s] : 3662
 Real power counter start [KWh] : 4,1191
 Real power counter end [KWh] : 4,1989
 Energy consumption [KWh] : 0,0798
 Energy consumption [Ws] : 287280
 Heating power [W] : 78,449
 factor [-] : 0,8212
 Viscosity [cSt] : -

Compressor data

Compressor type : QD135Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : without run capacitor

Compressor No. : 981688

Recording : qd135y dongbei 0199

Calorimeter Data

Conditions like above listed

Measuring date

13.01.1999

2. Evaporating temperature [°C] : -25,0
 Cooling capacity [W] : 153,6
 Input power [W] : 139,0
 COP [W/W] : 1,11
 Sweep voltage [V] : 113
 Current [A] : 0,955
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 92,6
 Discharge pipe temperature [°C] : 83,3
 Temperature behind elec. casing [°C] : 71,0
 Temperatur casing top [°C] : 68,0
 Temperature casing bottom [°C] : 60,0
 Revolution per minute [1/s] : 48,7
 Heating power total [W] : 186,96
 Heating power total [kcal/h] : 160,79

Worker we
 R cold [Ohm] : 9,7
 R warm [Ohm] : 11,9
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 112
 Switch heating start [time] : 15.00
 Switch heating end [time] : 16.02
 Switch heating duration [s] : 3693
 Real power counter start [KWh] : 4,517
 Real power counter end [KWh] : 4,5939
 Energy consumption [KWh] : 0,0769
 Energy consumption [Ws] : 276840
 Heating power [W] : 74,963
 factor [-] : 0,8216
 Viscosity [cSt] : -

Protocol 8

Compressor data

collected on 13.01.99

Compressor type : QD135Y
 Variant : sample Dongbei
 Design : R600a
 Remarks : without run capacitor

Compressor No. : 981688

Recording : qd135y dongbei 0199

Calorimeter Data


Conditions

Measuring date 13.01.1999


Operating Current [V] : 220,0
 Condensing temperature [°C] : 55,0
 Ambient temperature [°C] : 32,0
 tg2 Outlet calorimeter [°C] : 32,0
 3. Evaporating temperature [°C] : -15,0
 Cooling capacity [W] : 266,1
 Input power [W] : 187,0
 COP [W/W] : 1,42
 Sweep voltage [V] : 135
 Current [A] : 1,13
 Vol. Cooling Capacity [W/cm³] :
 Winding temperature [°C] : 87,1
 Discharge pipe temperature [°C] : 91,1
 Temperature behind elec. casing [°C] : 70,5
 Temperatur casing top [°C] : 68,5
 Temperature casing bottom [°C] : 61,5
 Revolution per minute [1/s] : 48,1
 Heating power total [W] : 324,09
 Heating power total [kcal/h] : 278,72

Worker we
 Ventilation static
 Frequency [Hz] : 50
 Liquid subcooled to [°C] : 55
 tg1 Suction pipe [°C] : 32
 tf2 on valve [°C] : 32
 R cold [Ohm] : 9,7
 R warm [Ohm] : 11,7
 Constant heating V [V] : 0
 Constant heating C [A] : 0
 Constant heating P [W] : 245
 Switch heating start [time] : 12.51
 Switch heating end [time] : 13.54
 Switch heating duration [s] : 3760
 Real power counter start [KWh] : 4,3575
 Real power counter end [KWh] : 4,4401
 Energy consumption [KWh] : 0,0826
 Energy consumption [Ws] : 297360
 Heating power [W] : 79,085
 factor [-] : 0,8216
 Viscosity [cSt] : -


Calorimeter data QD69Y - Dongbei




Calorimeter data QD81Y - Dongbei




Calorimeter data QD100Y - Dongbei




Calorimeter data QD135Y - Dongbei



Calorimeter data Qo - Dongbei series



Calorimeter data COP - Dongbei series



Test – Report

Measuring Calorimeter – R600a

performed by dkk

Compressor Type: - QD 88Y
 - QD 123Y

Producer of the Compressor: Dongbei

Date: 1998-08-20



Results:

Comparison between Measuring Dongbei - dkk

Calorimeter Measuring :

Conditions:	Evaporating temperature	$t_0 = -23,3^{\circ}\text{C}$
	Condensing temperature	$t_f = 54,4^{\circ}\text{C}$
	Temperature of subcooled liquid	$t_{f1} = 32,2^{\circ}\text{C}$
	Suction temperature	$t_{g1} = 32,2^{\circ}\text{C}$
	Ambient temperature	$t_a = 32,2^{\circ}\text{C}$

	QD 88Y 970627 I-26931		QD 123Y 970648 I-070584	
	Dongbei	dkk	Dongbei	dkk
Qo [W]	145,7	144,7	197,9	187,0
P1 [W]	118,6	123,0	146,4	139,8
COP [W/W]	1,22	1,18	1,35	1,34
I [A]	0,92	0,97	1,06	1,06
tw [°C]	90,7	95,8	87,4	86,1
t _{KO} [°C]		72		73,0
t _{KU} [°C]	67	67	61	63,0
t _{Sch} [°C]		77,5		75,0
t _{g3} [°C]		73,5		81,7
Uk [V]		117		115
Qvol [W/cm³]		15,5		15,2
n [min ⁻¹]	2920	2922	2910	2934



The tolerance between the measurings (dkk-Dongbei) of the Cooling Capacity, Input Power and COP are not greater than 3,6 % at QD 88Y.

The Cooling Capacity of the QD 123 Y differ by 5,8 %. The other values shows a acceptable correspondence.

The detailed design of the compressors are not known.

Annex 1

List of abbreviations Verzeichnis der Abkürzungen

Data Calorimeter

to	Verdampfungstemperatur	Evaporating temperature
Qo	Kälteleistung	Cooling Capacity
PI	Leistungsaufnahme	Input Power
COP	Leistungszahl	Coefficient of Performance
Uk	Kippspannung	Sweep Voltage
I1	Betriebsstrom	Operating Current
Qvol	volumetrische Kälteleistung	vol. Cooling Capacity
tw	Wicklungstemperatur	winding temperature
tg3	Druckstutztemperatur	Discharge pipe temperature
tsch	Temperatur unter Schutzkappe	Temperature behind elec. casing
tko	Temp. Kapsel oben	Temperature Casing top
tku	Temp. Kapsel unten	Temperature Casing bottom
n	Drehzahl	Revolution per minute
tf	Verflüssigungstemperatur	Condensing temperature
tfl	Unterkühlungstemperatur	Temperature of subcooled liquid
ta	Umgebungstemperatur	Ambient temperature
tgl	Sauggastemperatur	Suction gas temperature