



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

22157

To : Mrs Mounira Latrech

Contract officer

UNIDO headquarters

Final Report

For contract 98/134

Between UNIDO and Zhejiang Rongsheng Electric Co.Ltd.

From: Liang Rikui

Project Leader

Zhejiang Rongsheng Electric Co.Ltd.



中国浙江荣盛电器有限公司

CHINA ZHEJIANG RONGSHENG ELEC EQUIPMENT CO.,LTD.

公司地址: 浙江省吴山经济技术开发区

电话: (0572)8061000 8061476

传真: 8062818 8061000

TO:

FAX:

ATTN:

DATE: 21/12/1998

CC:

PAGESL:

RE:

Mrs. M. Latrech
UNIDO, Vienna
Fax: 00 431 260 26 6815
Subject: Second Progress Report
Ref. Contract no. 97/134, Project no MP/CPR/97/195

Dear Mrs. Latrech

I am glad to submit to you RSLG second progress report regarding achievement of our various activities to execute contract no 97/134.

We would like to acknowledge the deep cooperation between UNIDO and our company for implementation of the CFC phase project.

1.2 Zhejiang Rongsheng Electronic Co. Ltd.

Zhejiang Rongsheng Electronic Co. Ltd(Rongsheng) is a collective ownership plastic cement, refrigerator and freezer manufacturing company. The company was established in 1988. The plants are located in Deqing County and produce five different products: Horizontal Freezer and Freezing Showcase, Vertical Refrigerating Showcase, Twin Temperature Freezing Showcase, and Plastic Cement.

The production of freezers in Rongsheng started in 1994 with 440 employees. Currently, there are 800 employees, of which, 75 are in the management department and 90 are technicians.

The daily production rate of the factory is about 800 units in two shifts. In 1996 the actual production was 146,186 freezers.

The Company produces 13 models in eight basic size ranges between 98 and 510 litres including Upright Cooler and Chest Cooler/Freezer.

The factory is operating with CFC-12 and CFC-11.

Table 7. Volume of refrigerator production at RONGSHENG

Year	Units
1994	60,058
1995	132,165
1996	146,186
1997 (expected)	230,000

Table 8. Product mix of RONGSHENG

<i>Model</i>	<i>Description</i>	<i>Share in total production, %</i>	<i>Charge, g/unit</i>	<i>Foam weight (cabinet + door) kg/unit</i>
BD-98	freezer, volume 98 l	6.7	150	3.3
BD-122	freezer, volume: 122 l	10.1	155	4.2
BD-158	freezer, volume: 158 l	21.3	155	4.84
BD-172	freezer, volume: 172 l	39.8	175	5.54
BD-268	freezer, volume: 268 l	10.3	205	7.1
BD-308	freezer, volume: 308 l	5.1	209	8.07
BD-408	freezer, volume 408 l	4	265	9.58
BD-510	freezer, volume 510 l	3	315	11.50
Total or average		100	179.66	5.77

Rongsheng is currently running two production lines for foaming and two for assembly of products. They are installed in two separate buildings. One assembly

line is placed in one building and two foaming machines (the cabinet and door foaming lines) and the second assembly line are in another building. The thermoforming machine is located in a separate building.

Rongsheng manufactures 40% of components for the use in their refrigerators. About 10% of the compressors are imported the rest are of domestic origin.

The freezer compartments are equipped with plate tube type evaporators produced locally.

The polyol, isocyanate and the CFCs are from ICI. There is 17% CFC-11 in the currently applied formulation on two lines as foam blowing agent. The technologies and some of the equipment are of Chinese origin, there is no technological agreement with any major international producer regarding refrigerator manufacturing. The foaming of cabinets are carried out in bath position. The arrangements for doors and cabinets are made in carousel. Preheating of cabinets and doors before foaming are with hot air. The preheating ovens are heated with steam. Curing time is eight minutes.

The major manufacturing equipments are as follows:

- 1 set High pressure cabinet foaming machine with one foaming head. Manufactured by Cannon A-100 system, Italy 1994
- 1 set Cabinet foaming carousel with up to 20 moulds. Manufactured by Jiangsu Kunshan Moulds Factory, China
- 1 set Low pressure door foaming machine with one foaming head. Manufactured by Cannon A-40 system, Italy 1989
- 1 set Door foaming carousel with 12 moulds (double) moulds. Manufactured by Jiangsu Kunshan Moulds Factory, China
- 2 sets Preheating oven heated with steam
- 2 sets CFC-12 refrigerant charging boards type 150 Manufactured by Shanghai Aeroplane Manufacturing Co. China
- 2 sets Evacuation carousel equipped with 40 vacuum pumps. Shanghai Vacuum Pumps Factory. 2x2 - 4 Manufactured in China 1993
- 3 sets Leak detectors used on the production and testing lines Manufactured in China 1993

1 set Testing conveyor for testing 120 units simultaneously. The refrigerator travel at 60 Sec./unit speed

1 set Fully automatic thermoforming lines, type: four position. Manufactured by Hungary in 1988. The lines produce inner liners from ABS sheet.

The quality control is extended to every piece (electrical safety, cooling performance), and random thorough tests are applied for a part of the production. Rongsheng has a test room equipped with basic instruments to measure the performance of refrigerators. The appliances designed for refrigerator 5° C and for freezer -18° C. According to the Chinese standard the performance is tested at ambient temperature 16-32°C, 60% humidity.

In 1996 Rongsheng used approximately 27.5 mt of CFC-12 and 150.3 mt of CFC-11

II. PROJECT OBJECTIVE

The objective of this project is to eliminate the use of CFC-11 and CFC-12 in the production of domestic refrigerators/freezers and in refrigeration servicing at Rongsheng through conversion to the use of HFC-134a as refrigerant for the cooling system and cyclopentane as blowing agent for the polyurethane insulation foam

The project will be finalised by end 1999 and thus will contribute to the freeze target of the country by phasing out 177.5 ODP tonnes in line with NEPA's ODS phase out programme.

III. PROJECT DESCRIPTION

Rongsheng has already recognized the need to comply with the Montreal Protocol and has agreed to participate in China's ODS phase out programme. It is prepared to phase out ODS as soon as the new technologies have been acquired, the necessary machinery installed and the technical staff have been trained. Rongsheng is committed to phase out CFCs by converting its foaming equipment to cyclopentane use and using HFC-134a as refrigerant.

This project document describes the activities needed to carry out the phase out process.

III.1. Justification for Selection of Alternative Technologies

III.1.1. Refrigerant

Among the technological options currently available on commercial basis (see Table 9) and in line with the established policy of NEPA and CNCLI to phase out the use of ODS. In the selection of the substitute refrigerant technology for this project the following factors were also taken into account:

Activities

We are delighted to explain some of our activities during execution of the project.

Achievement of Calculation of Models and Methods of Calculation

Calculation of models for redefinition of the prototypes for conversion into R134a refrigerant circuit system.

We chose ASHREA standard to calculate refrigeration load necessary to determine suitable components specially compressor that is the heart of refrigeration system. Other components such as Capillary tube, Evaporator, and condenser are relatively adjusted to achieve best results. In order to determine the correct amount of R134a refrigerant charge, and other data such as pressure at different point of refrigeration circuits, we have to know the performance characteristics of each component, such Suction and Discharge temperature of compressor, inlet and outlet temperature of condenser or saturated liquid and vapor temperature, therefore we should perform theoretical cycle calculations for both pure refrigerants and blends.

The theoretical performances can be compared to one of the following CFC/HCFC fluids: R12, R502 and R22. The calculations are best used as a means of finding trends in fluid performance. The cycle has not been designed to model experimental equipment in detail. Several factors, such as those from heat exchangers and compressor volumetric inefficiencies are not included in the theoretical cycle.

Definition of the Theoretical Cycle:

The calculations are based on a point cycle. The points are as follows

- (1) Evaporator Inlet - Liquid/vapour flash
- (2) Evaporator Outlet - Saturated Vapour
- (3) Compressor Inlet - Superheated Vapour
- (4) Compressor Outlet - Compressed Vapour
- (5) Condenser Inlet - Saturated Vapour
- (6) Condenser Outlet - Saturated Liquid
- (7) Expansion Device Inlet - Subcooled Liquid

INPUT FIELDS

Evaporator Temperature: defined as the average of the liquid/vapour flash temperature at the evaporator inlet and that of the saturated vapour at the evaporator outlet. The latter is taken to be the dew point temperature at the calculated evaporator pressure. Unlike pure refrigerants, for the R32/R125/R134a blends the inlet and outlet temperature will be different.

Condenser Temperature: defined as the average of the temperature of the

saturated vapour at the condenser inlet and the temperature of the saturated liquid at the condenser outlet. They are taken to be the dew and bubble point temperatures respectively at the condenser pressure.

Superheating: defined as the temperature difference between the superheated vapour at the compressor inlet and the saturated vapour at the evaporator outlet. It is assumed that the compression process begins under identical conditions to those at the compressor inlet i.e. the compressor inlet conditions are the same as the suction conditions.

Sub-cooling: defined as the temperature difference between the saturated liquid at the condenser outlet and that of the sub-cooled liquid at the expansion device inlet.

Efficiency: An isentropic compression process is used for the theoretical cycle calculations. The isentropic efficiency is the value, relative to a theoretical maximum of 100%, of the efficiency with which the compressor can isentropically compress the superheated vapour from the suction pressure up to a pressure equivalent to the condenser pressure. It scales directly with the required compressor power.

The Constraint: Cooling Duty or Volumetric Flowrate:

In order to compare the calculations of several refrigerants on the same basis there is an option to constrain either the cooling duty or the volumetric flowrate of the superheated vapour prior to compression (i.e. the compressor inlet).

Cooling Duty: the required cooling capacity of the system. In this program, it is defined as the cooling that occurs from directly after the expansion device to the evaporator outlet i.e. the saturated vapour condition.

Volumetric Flowrate: defined for the superheated vapour immediately prior to the compression process (i.e. at the compressor inlet point).

DEFINITION OF CALCULATED FIELDS

Pressure: the pressure for which the average of the calculated evaporator inlet and outlet temperatures give the input evaporator temperature.

Condenser Pressure: the pressure for which the average of the calculated condenser inlet (dew point) and outlet (bubble point) temperatures give the input condenser temperature.

Coefficient of Performance: the ratio of the refrigeration effect to the heat of compression. The refrigeration effect is defined in two ways, as the difference between the evaporator inlet condition (expansion valve outlet) and either the evaporator outlet condition (exclusive of superheating), or the compressor inlet condition (inclusive of superheating). The heat of compression is defined as the enthalpy rise of the vapour as a result of the compression process.

EER - Energy Ratio: the ratio of the gross capacity (see below) in Btu/hr to the compressor power in watts. The EER has been defined in this way for all cycle calculations, including those in SI and METRIC units.

Cooling Duty: same definition as given in input fields.

Gross Capacity: The calculated gross cooling capacity of the system. It is defined as the cooling that occurs from directly after the expansion device to the compressor inlet i.e.. superheated vapour.

Compressor Power: The heat (enthalpy) required from the compressor.

Mass Flow rate: The refrigerant mass flow rate required around the system to meet the input constraint value at the input conditions.

Suction Line Temperature: The temperature of the superheated vapour at the compressor inlet point.

Discharge Temperature: The temperature of the compressed vapour at the compressor outlet, which in this cycle is also taken as the point at the end of the compression process.

Temperature Glide in the Evaporator: The difference between the evaporator inlet and outlet temperatures.

Temperature Glide in the Condenser: The difference between the condenser inlet and outlet temperatures.

Refrigeration Load Calculation for Upright Ref.- Freezer, Chest Freezer and Display cases

Refrigeration load consist of three individual components:

- 1- Transmission load;
Heat transfer through side walls by conduction
- 2 - Product load;
Heat Removed from and produced by the products which are stored.
- 3 - Internal load;
Heat produced by internal sources such as lights, fan or heaters;
- 4 - Infiltration load
Heat gains associated with air entering the refrigerated space and door opening and etc.;

In this section , the above mentioned components will be discussed separately to analyze and extract the most useful and practical equipment's.

- 1) Making Prototypes;
- 2) Testing Prototypes;
- 4) Calculating Heat Leaks;
- 5) Being familiar with Montreal Protocol and UNIDO's Projects;
- 6) Being familiar with aim of the project in Iran;
- 7) Selecting Components for each models;
- 9) Preparing Technical Specifications and Characteristics;
- 10) and other services as mentioned in the subject contracts;

Activities

Following activities were accomplished during execution of the contract

- 1 - Collecting necessary data from each .

- 3 - Measuring Actual Dimension of each model;
- 4 - Reviewing and evaluating data
- 5 - Performing heat leak calculation for models
- 6 - Determining heat loads for models;
- 7 - Determining product load for models;
- 8 - Determining heat gain by infiltration;
- 9 - Preparing data acquisition form;
- 10 - Preparing product specification models;
- 11 - Preparing prototype data summary sheet;
- 12 - Recommending suitable compressors for each prototypes;
- 13 - Reviewing more than 30 compressor technical specifications

in

order to recommend an appropriate compressor as follows

a - Danfuss;

TL5G, TLS6F, TLS7F, FR7.5G, FR8.5G, and FR10G

b - Gold Star;

NR45L, NF45N, NR62L, NR52L, VF75N, V75L

c- Matsushita;

SA3C10AX0, QA66C15RAX5, QA77C18RAX5, D66C15RAX5,
D77C18RAX5, QA,51C11RAX5, QA91C20RAX5, S43C10KAX0

d - Necchi;

ESC5, ESC7K, ESC7, ESC8.5, ESC8.5K, ESC9, ESC9K, ESC11,
ESCHK,

e - Zanussi

GL45AA, GL50AA, GL60AA, GL70AA, GL80AA, GL90AA, GL99AA,
GL80AH,

d- Aspera

BP104822, BP1116Z, BP1118Z

e- Techomseh

Different models of Techomseh compressor specifications were reviewed and we finally chose appropriate compressor models for each models and we decided to install Techomseh Compressor on our prototypes, because we believe that the technical specification of these compressor matches our refrigeration load requirements.

Method of Refrigeration Load Calculation

Refrigeration load consist of four individual components:

- 1- Transmission load;
Heat transfer through walls (sides, back panels, top and bottom) and door panel.
- 2 - Product load;
Heat Removed from and produced by the products which are brought and stored in the refrigerator;
- 3 - Internal load;
Heat produced by internal sources such as lights, fan or heaters;
- 4 - Infiltration load
Heat gains associated with air entering the refrigerated space;

In this section , the above mentioned components will be discussed separately to analyze and extract the most useful and practical equipment□s.

Transmission Load

Heat gain through walls of a refrigerated space depend on cabin Temperature, liner, insulation and cabin conductivity and also the surrounded ambient air. In other word, there are four different resistance opposing heat flow between cabin space and ambient air as given in resistance circuit.

Considering the above mentioned resistances, R_l , R_c and R_a are not compareable in magnitude with R_i (Insulation resistance) and so can

be neglected in our calculations. Therefore, the resultant circuit and related equations is.

$$R = \frac{x}{KA} \text{ Heat Resistance and } Q_{\pi} = \frac{\Delta T}{R} \text{ Heat Transfer}$$

Where:

x = Insulation Thickness, mm

K = Insulation Conductivity, $\frac{Wmm}{m^2 \cdot C}$

A = Outside Area, m^2

ΔT = Temperature difference ($T_a - T_c$), C

If the insulation thickness of side walls, back panels, top, bottom and door are different, heat transfer for each part can be calculated separately and then summed for two door refrigerators, due to different cabin temperature of freezer and refrigerator compartments, heat transfer for each compartment should be calculated separately and then added together.

Product Load

Heat removed from products (meat, fruits, vegetables, water and etc.) to reduce temperature from receiving to storage temperature is known as product load. Following steps can be taken to calculate product loads.

1 - Heat removed from initial temperature (T_i) to storing temperature (T_{rs}) in refrigerator compartment is;

$$Q_{rs} = \dot{M}C (T_i - T_{rs})$$

Where:

\dot{M} = Mass of product, Kg / h

C = Specific heat of product, Kcal / Kg

2 - Heat removed from initial temperature (T_i) to freezing temperature (T_f) is ;

$$Q_{af} = \dot{M} C (T_i - T_f)$$

Where :

\dot{M} = Mass of product, Kg / h

C = Specific heat of product above freezing point, Kcal / Kg

3 - Latent heat of fusion for products is equal to;

$$Q_L = \dot{M} h$$

Where h = Latent heat of product, Kcal / Kg

4 - Heat removed from freezing temperature (T_f) to final storage temperature (T_{fs}) is;

$$Q_{bf} = \dot{M} C_{bf} (T_f - T_{fs})$$

Where: C_{bf} = Specific heat of products below freezing temperature.

For upright freezers or freezer compartment of refrigerators, total product load is

$$Q_{pl} = Q_{af} + Q_L + Q_{bf}$$

For storage products to some lower temperatures above freezing temperature in refrigerator compartment is;

$$Q_{pl} = Q_{rs}$$

Internal Load

Electrical energy dissipated in the refrigerated space such as lights, fan motors, heaters, are included in the internal heat load. Due to the

little amount of consumption of lightings, the effect of lighting can be negligible and only electrical heaters of two door refrigerators or fan motors (if exist) are considered in our load calculation.

Infiltration Load

Infiltration air load is the heat transfer due to exchanging of refrigerated air with ambient caused by opening of the door or leakage through the gasket area. Infiltration load is one of the most important load components and roughly it is about 20 % of total refrigeration load.

Total Refrigeration load

As it was mentioned before, transmission load (Q_{tl}), product load (Q_{pl}) and internal load (Q_{il}) can be calculated separately. For infiltration load (air exchange through doorways or gasket leakage), we take into account 25% of sum of the above mentioned components. (transmission load, product load and internal load). Therefore total refrigeration load can be expressed as:

$$\underline{Q_{TL} = 1.25 (Q_{TL} + Q_{PL} + Q_{IL})}$$

Making Prototypes

Several prototypes have been made so far and we decided to test two of them in our Hot Chamber.

Refrigerant charge

For making prototypes we decided to charge different amount of R134a refrigerant into the refrigeration system. We considered the same amount of refrigerant as the basis of R12 refrigeration system for prototypes number one and we reduced ten percent refrigerant weight from the basis of R12 for the second prototype.

Compressor

The compressor used are in accordance with the results of our calculation and we selected the nearest possible cooling capacity of the compressor to the cooling requirement as calculated.

Capillary tube

We decided to keep the length of capillary tube unchanged, due to our experience and information we received from the compressor manufacturers.

Evaporator

We believe that the evaporator does not need any adjustment due to the higher capacity of the evaporator than what we need.

Condenser

For the same reason that we did not adjust the evaporator we did not adjust the condenser.

Testing Prototypes

Two prototypes were tested under the following condition

Pull down test, Continuous run test and cyclic run test


Ambient temperature	32 C
Relative Humidity	73 %
Test Package	used
"M" Package	used
Number of Temp. Sensors	10

Following refrigeration system points temperature were measured and the results were satisfactory.

"M" packages, Compressor Discharge and suction, condenser outlet, ambient temperature, compressor shell, evaporator surface, energy consumption, starting current.

We enclose the completed test result sheet form for your information

With regards
Liang Rikui
Chief of technical department



"RSLG" Hot Chamber Test Sheet

Date 1998, 12.19		Test Type Cyclic Run		Test Number 4	Ambient Temp. 32°C
Model	Serial number	Overall Dim.	Internal Volume		
BP-16B	Prot. 01		168 Lit		
Comp. Model	Comp. Watt	Refrigerant Type	Refrigerant Charge		
AE1350Y	13BW	R134A	140 gr.		
Thermostat Type	Thermostat Model	Thermostat Setting			
Defrost	WPF30	Min.			
Test Results			Remarks		
Temp. °C	Therm. Cut in	Therm. Cut out	these temp. inside is little high. may be adjust the setting point in "Min"		
T1	-10.80	-10.70			
T2	-11.70	-11.67			
T3	-11.83	-11.61			
T4	-11.76	-11.61			
T5	-11.44	-11.21			
T6	-11.68	-11.65			
T7					
T8					
T9					
Comp. Suc.			Comments		
Comp. Disch.					
Comp. Shell					
Evap. Outlet					
Evap. inlet					
Cond. Outlet					
Bald Temp					
Comp. Running Time %	26.19%				
Energy Consump. Kw/24 Hrs	0.9214 kw/h/24h				
Starting Current Amp.	1.01				
Running Current Amp.	0.85				
Lab. Specialist: Xian Yingdi			Supervisor: Liang Kikui		

"RSLG" Hot Chamber Test Sheet

Date 1998. 12. 19		Test Type <i>Cyclic Run</i>		Test Number 3	Ambient Temp. 32			
Model		Serial number		Overall Dim.	Internal Volume			
<i>BD-168</i>		<i>Prt. 01</i>			<i>168 Lit</i>			
Comp. Model		Comp. Watt		Refrigerant Type	Refrigerant Charge			
<i>AZ1350Y</i>		<i>138W</i>		<i>R134a</i>	<i>140gr.</i>			
Thermostat Type		Thermostat Model		Thermostat Setting				
<i>Defrost</i>		<i>WPF30</i>		<i>Mid.</i>				
Test Results				Remarks				
Temp. °C	Therm. Cut in	Therm. Cut out	<p><i>Temp inside may be a little high. but the position of the thermostat can be adjust. So this result we think it's ok too.</i></p>					
T1	<i>-14.79</i>	<i>-14.91</i>						
T2	<i>-15.71</i>	<i>-15.90</i>						
T3	<i>-15.87</i>	<i>-15.70</i>						
T4	<i>-15.86</i>	<i>-15.76</i>						
T5	<i>-15.60</i>	<i>-15.34</i>						
T6	<i>-15.90</i>	<i>-15.95</i>						
T7								
T8								
T9								
Comp. Suc.			Comments					
Comp. Disch.								
Comp. Shell								
Evap. Outlet								
Evap. inlet								
Cond. Outlet								
Bald Temp								
Comp. Running Time %		<i>33%</i>						
Energy Consump. Kw/24 Hrs		<i>1.0481 kw/24h</i>						
Starting Current Amp.		<i>0.968</i>						
Running Current Amp.		<i>0.85</i>						
Lab. Specialist: <i>Xian Yingdi</i>						Supervisor: <i>Liang Rikui</i>		

"RSLG" Hot Chamber Test Sheet

Date <i>1995.12.18</i>		Test Type <i>Cyclic Run</i>		Test Number <i>2</i>	Ambient Temp. <i>32°C</i>			
Model	Serial number	Overall Dim.	Internal Volume					
<i>B7-100</i>	<i>Prt. 01</i>		<i>168 lit</i>					
Comp. Model	Comp. Watt	Refrigerant Type	Refrigerant Charge					
<i>AZ1350Y</i>	<i>138W</i>	<i>R134a</i>	<i>140 gr.</i>					
Thermostat Type	Thermostat Model	Thermostat Setting						
<i>Defrost</i>	<i>WPF30</i>	<i>Max.</i>						
Test Results			Remarks					
Temp. °C	Therm. Cut in	Therm. Cut out	<i>The result is ok.</i>					
T1	<i>-20.73</i>	<i>-22.44</i>						
T2	<i>-21.74</i>	<i>-23.44</i>						
T3	<i>-22.12</i>	<i>-22.74</i>						
T4	<i>-22.02</i>	<i>-22.72</i>						
T5	<i>-21.55</i>	<i>-22.58</i>						
T6	<i>-21.81</i>	<i>-23.46</i>						
T7								
T8								
T9								
Comp. Suc.	<i>15</i>	<i>31</i>	Comments					
Comp. Disch.	<i>32</i>	<i>58</i>						
Comp. Shell								
Evap. Outlet								
Evap. inlet	<i>-20</i>	<i>-27</i>						
Cond. Outlet	<i>+28</i>	<i>41</i>						
Bald Temp	<i>-19</i>	<i>-26</i>						
Comp. Running Time %	<i>57.16%</i>							
Energy Consump. Kw/24 Hrs	<i>1.5020 kwh/24h</i>							
Starting Current Amp.	<i>0.914</i>							
Running Current Amp.	<i>0.85</i>							
Lab. Specialist:						Supervisor: <i>Liang Rikui</i>		

"ASLG" Hot Chamber Test Sheet

Date 1998.12.18		Test Type <i>PULL DOWN</i>		Test Number <i>1</i>	Ambient Temp. <i>32°C</i>
Model	Serial number	Overall Dim.	Internal Volume		
<i>BD-168</i>	<i>Prt. 01</i>		<i>168 lit</i>		
Comp. Model	Comp. Watt	Refrigerant Type	Refrigerant Charge		
<i>AE1350Y</i>	<i>138W</i>	<i>R134a</i>	<i>140 gr.</i>		
Thermostat Type	Thermostat Model	Thermostat Setting			
<i>Defrost</i>	<i>WPF30</i>	<i>Max.</i>			
Test Results			Remarks		
Temp. °C	Therm. Cut in	Therm. Cut out	<i>IN our standard, the pull down time from 32°C to -21.9 must be less than 90 minutes. BD-168 spent 68.63 min. So it's ok.</i>		
T1	<i>31.91</i>	<i>-21.92</i>			
T2	<i>31.41</i>	<i>-23.11</i>			
T3	<i>31.63</i>	<i>-22.38</i>			
T4	<i>31.58</i>	<i>-22.37</i>			
T5	<i>31.54</i>	<i>-22.10</i>			
T6	<i>31.43</i>	<i>-23.14</i>			
T7					
T8					
T9					
Comp. Suc.	<i>31</i>		<div style="text-align: center;">Comments</div>		
Comp. Disch.	<i>60</i>				
Comp. Shell	<i>55</i>				
Evap. Outlet					
Evap. inlet					
Cond. Outlet	<i>41</i>				
Bald Temp	<i>-26</i>				
Comp. Running Time %					
Energy Consump. Kw/24 Hrs					
Starting Current Amp.	<i>0.914</i>				
Running Current Amp.	<i>0.85</i>				
Lab. Specialist:			Supervisor: <i>Liang Bikui</i>		

"RSLG" Hot Chamber Test Sheet

Date <i>98. 12. 23</i>		Test Type <i>pull down</i>		Test Number <i>1</i>	Ambient Temp. <i>32°C</i>
Model	Serial number	Overall Dim.	Internal Volume		
<i>BD-182</i>	<i>Prt. 02</i>	<i>990x555x920</i>	<i>182 lit.</i>		
Comp. Model	Comp. Watt	Refrigerant Type	Refrigerant Charge		
<i>AE1360Y</i>	<i>157W</i>	<i>R134a</i>	<i>150 gr.</i>		
Thermostat Type	Thermostat Model	Thermostat Setting			
<i>Pressure Type.</i>	<i>WPF30</i>	<i>Max.</i>			
Test Results			Remarks		
Temp. °C	Therm. Cut in	Therm. Cut out			
T1					
T2					
T3					
T4					
T5					
T6					
T7					
T8					
T9					
Comp. Suc.			Comments		
Comp. Disch.					
Comp. Shell					
Evap. Outlet					
Evap. inlet					
Cond. Outlet					
Brld Temp					
Comp. Running Time %					
Energy Consump. Kw/24 Hrs					
Starting Current Amp.					
Running Current Amp.					
Lab. Specialist:			Supervisor:		

"RSLG" Hot Chamber Test Sheet

Date <i>99. 1. 9</i>		Test Type <i>pull down</i>		Test Number <i>1</i>		Ambient Temp. <i>32°c</i>	
Model		Serial number		Overall Dim.		Internal Volume	
<i>BCD-205</i>		<i>Prt-10</i>		<i>1065x555x920</i>		<i>205 Lit.</i>	
Comp. Model		Comp. Watt		Refrigerant Type		Refrigerant Charge	
<i>AE1350Y</i>		<i>138W</i>		<i>R134a</i>			
Thermostat Type		Thermostat Model		Thermostat Setting			
<i>Pressure Type.</i>		<i>WPF30</i>		<i>Max.</i>			
Test Results				Remarks			
Temp. °C		Therm. Cut in	Therm. Cut out				
T1							
T2							
T3							
T4							
T5							
T6							
T7							
T8							
T9							
Comp. Suc.							
Comp. Disch.							
Comp. Shell							
Evap. Outlet				Comments			
Evap. inlet							
Cond. Outlet							
Bald Temp							
Comp. Running Time %							
Energy Consump. Kw/24 Hrs							
Starting Current Amp.							
Running Current Amp.							
Lab. Specialist:				Supervisor:			

"RSLG" Hot Chamber Test Sheet

Date <i>99.1.7.</i>		Test Type <i>pull down.</i>		Test Number <i>1</i>	Ambient Temp. <i>32°C</i>
Model	Serial number	Overall Dim.	Internal Volume		
<i>BCD-188.</i>	<i>Prt. 09</i>	<i>990x555x920</i>	<i>188 Lit.</i>		
Comp. Model	Comp. Watt	Refrigerant Type	Refrigerant Charge		
<i>AE1350Y</i>	<i>138W</i>	<i>R134a</i>			
Thermostat Type	Thermostat Model	Thermostat Setting			
<i>Pressure Type.</i>	<i>WPF30</i>	<i>Max.</i>			
Test Results			Remarks		
Temp. °C	Therm. Cut in	Therm. Cut out			
T1					
T2					
T3					
T4					
T5					
T6					
T7					
T8					
T9					
Comp. Suc.			Comments		
Comp. Disch.					
Comp. Shell					
Evap. Outlet					
Evap. inlet					
Cond. Outlet					
Bald Temp					
Comp. Running Time %					
Energy Consump. Kw/24 Hrs					
Starting Current Amp.					
Running Current Amp.					
Lab. Specialist:			Supervisor:		

"RSLG" Hot Chamber Test Sheet

Date <i>99. 1. 7</i>		Test Type <i>pull down</i>		Test Number <i>1</i>		Ambient Temp. <i>32°C</i>	
Model		Serial number		Overall Dim.		Internal Volume	
<i>BCD-168</i>		<i>Prt. 08</i>		<i>900x555x920</i>		<i>168 Lit</i>	
Comp. Model		Comp. Watt		Refrigerant Type		Refrigerant Charge	
<i>AE1340Y</i>		<i>108W</i>		<i>R134a.</i>		<i>115 gr.</i>	
Thermostat Type		Thermostat Model		Thermostat Setting			
<i>Pressure Type.</i>		<i>WPF30</i>		<i>Max.</i>			
Test Results				Remarks			
Temp. °C		Therm. Cut in	Therm. Cut out				
T1							
T2							
T3							
T4							
T5							
T6							
T7							
T8							
T9							
Comp. Suc.				Comments			
Comp. Disch.							
Comp. Shell							
Evap. Outlet							
Evap. inlet							
Cond. Outlet							
Bald Temp							
Comp. Running Time %							
Energy Consump. Kw/24 Hrs							
Starting Current Amp.							
Running Current Amp.							
Lab. Specialist:				Supervisor:			

"RSLG" Hot Chamber Test Sheet

Date <i>99. 7. 5</i>		Test Type <i>Pull down.</i>		Test Number <i>1</i>		Ambient Temp. <i>32°C</i>	
Model		Serial number		Overall Dim.		Internal Volume	
<i>BD-400</i>		<i>Prt. 07.</i>		<i>385x700x920</i>		<i>400 Lit.</i>	
Comp. Model		Comp. Watt		Refrigerant Type		Refrigerant Charge	
<i>AE1390Y</i>		<i>224 W</i>		<i>R134a.</i>		<i>285 gr.</i>	
Thermostat Type		Thermostat Model		Thermostat Setting			
<i>Pressure Type.</i>		<i>WPF30.</i>		<i>Max.</i>			
Test Results				Remarks			
Temp. °C		Therm. Cut in	Therm. Cut out				
T1							
T2							
T3							
T4							
T5							
T6							
T7							
T8							
T9							
Comp. Suc.				Comments			
Comp. Disch.							
Comp. Shell							
Evap. Outlet							
Evap. inlet							
Cond. Outlet							
Bald Temp							
Comp. Running Time %							
Energy Consump. Kw/24 Hrs							
Starting Current Amp.							
Running Current Amp.							
Lab. Specialist:				Supervisor:			

"RSLG" Hot Chamber Test Sheet

Date <i>99. 7. 3.</i>		Test Type <i>pull down</i>		Test Number <i>1</i>	Ambient Temp. <i>32°C</i>
Model	Serial number	Overall Dim.	Internal Volume		
<i>BD-30B</i>	<i>Prt. 06</i>	<i>1125x700x920</i>	<i>30B Lit.</i>		
Comp. Model	Comp. Watt	Refrigerant Type	Refrigerant Charge		
<i>AE1390Y</i>	<i>224 W</i>	<i>R134a.</i>	<i>190 gr.</i>		
Thermostat Type	Thermostat Model	Thermostat Setting			
<i>Pressure Type.</i>	<i>WPF30.</i>	<i>Max.</i>			
Test Results			Remarks		
Temp. °C	Therm. Cut in	Therm. Cut out			
T1					
T2					
T3					
T4					
T5					
T6					
T7					
T8					
T9					
Comp. Suc.			Comments		
Comp. Disch.					
Comp. Shell					
Evap. Outlet					
Evap. inlet					
Cond. Outlet					
Bald Temp					
Comp. Running Time %					
Energy Consump. Kw/24 Hrs					
Starting Current Amp.					
Running Current Amp.					
Lab. Specialist:			Supervisor:		

"RSLG" Hot Chamber Test Sheet

Date <i>98. 12. 25</i>		Test Type <i>pull down</i>		Test Number <i>1</i>	Ambient Temp. <i>32°C</i>
Model	Serial number	Overall Dim.		Internal Volume	
<i>BD-2/0</i>	<i>Prt. 05</i>	<i>1065x555x920</i>		<i>2/0 Lit</i>	
Comp. Model	Comp. Watt	Refrigerant Type		Refrigerant Charge	
<i>AE1370Y</i>	<i>172 W</i>	<i>R134a</i>		<i>160 gr.</i>	
Thermostat Type	Thermostat Model	Thermostat Setting			
<i>Pressure Type.</i>	<i>WPF30.</i>	<i>Max.</i>			
Test Results				Remarks	
Temp. °C	Therm. Cut in	Therm. Cut out			
T1					
T2					
T3					
T4					
T5					
T6					
T7					
T8					
T9					
Comp. Suc.					
Comp. Disch.					
Comp. Shell					
Evap. Outlet					
Evap. inlet					
Cond. Outlet					
Bald Temp					
Comp. Running Time %					
Energy Consump. Kw/24 Hrs					
Starting Current Amp.					
Running Current Amp.					
Lab. Specialist:				Supervisor:	

"RSLG" Hot Chamber Test Sheet

Date <i>9 B. 12. 25</i>		Test Type <i>pull down</i>		Test Number <i>1</i>	Ambient Temp. <i>32°C</i>
Model	Serial number	Overall Dim.		Internal Volume	
<i>BD-195</i>	<i>Prt. 04</i>	<i>990x555x920</i>		<i>195 Lit.</i>	
Comp. Model	Comp. Watt	Refrigerant Type		Refrigerant Charge	
<i>AE1360Y</i>	<i>157W</i>	<i>R134a</i>		<i>150 gr.</i>	
Thermostat Type	Thermostat Model	Thermostat Setting			
<i>Pressure Type</i>	<i>WPF30</i>	<i>MAX.</i>			
Test Results				Remarks	
Temp. °C	Therm. Cut in	Therm. Cut out			
T1					
T2					
T3					
T4					
T5					
T6					
T7					
T8					
T9					
Comp. Suc.					
Comp. Disch.					
Comp. Shell					
Evap. Outlet					
Evap. inlet					
Cond. Outlet					
Bald Temp					
Comp. Running Time %					
Energy Consump. Kw/24 Hrs					
Starting Current Amp.					
Running Current Amp.					
Lab. Specialist:				Supervisor:	
				Comments	

"RSLG" Hot Chamber Test Sheet

Date <i>98. 12. 23</i>		Test Type <i>pull down</i>		Test Number <i>1</i>		Ambient Temp. <i>32°C</i>	
Model		Serial number		Overall Dim.		Internal Volume	
<i>BD-198</i>		<i>Prt. 03</i>		<i>1065x555x920</i>		<i>198 Lit.</i>	
Comp. Model		Comp. Watt		Refrigerant Type		Refrigerant Charge	
<i>AE1360Y</i>		<i>157W</i>		<i>R134a</i>		<i>160 gr.</i>	
Thermostat Type		Thermostat Model		Thermostat Setting			
<i>Pressure type</i>		<i>WPF30</i>		<i>MAX.</i>			
Test Results				Remarks			
Temp. °C		Therm. Cut in	Therm. Cut out				
T1							
T2							
T3							
T4							
T5							
T6							
T7							
T8							
T9							
Comp. Suc.				Comments			
Comp. Disch.							
Comp. Shell							
Evap. Outlet							
Evap. inlet							
Cond. Outlet							
Bald Temp							
Comp. Running Time %							
Energy Consump. Kw/24 Hrs							
Starting Current Amp.							
Running Current Amp.							
Lab. Specialist:				Supervisor:			

Transmission load calculation
Chest Freezer Model BD168
Dimensions

	Dimension Mt.	Area (sq. Mt.)	Insulation Thickness mm.
Side Walls	2x0.58x0.55	0.638	60
Back Panel	0.895x0.58	0.519	60
Door	0.895x0.55	0.49	40
Bottom Floor	0.895x0.55	0.49	65
Front Panel	0.895x0.58	0.519	60

Insulation Type: Pu Foam

CP5. Foam Thermal Conductivity: 0.0195 W /mt.C

Temperature Difference: $(\Delta T) = 32 - (-18) = 50 \text{ C}$

Ambient Temperature = 32 C

Freezer Air Temperature = - 18 C

Calculation :

$$Q_{TL} = Q_{SW} + Q_{BP} + Q_{BOTTOM} + Q_{Front} + Q_{DOOR}$$

$$Q = U A (T_a - T_f)$$

$$U = \frac{1}{X_1 / K_1 + X_2 / K_2 + \dots}$$

Where :

U = Heat Resistance Coefficient Factor

K₁ = Foam Thermal Conductivity

X₁ = Foam Thickness

Note : Due to the short thickness of cabinet out side panel (0.5 mm) and aluminum inner liner (0.5 mm) heat resistance of these materials have been considered negligible.

Therefore:

$$1- \quad Q_{\text{Side Walls}} = [U A (T_a - T_f)]$$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt. C}$$

$$A = 0.638 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Side Walls}} = 0.32 \times 0.638 \times 50 = 10.2 \text{ Watts}$$

$$Q_{\text{Side Walls}} = 10.2 \text{ Watts}$$

$$2 - \quad Q_{\text{Back panel}} = [U A (T_a - T_f)]$$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt. C}$$

$$A = 0.519 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Back panel}} = 0.32 \times 0.519 \times 50 = 8.3 \text{ Watts}$$

$$Q_{\text{Back panel}} = 8.3 \text{ Watts}$$

$$Q_{\text{Front Panel}} = [U A (T_a - T_f)]$$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt C}$$

$$A = 0.519 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Front Panel}} = 0.32 \times 0.519 \times 50 = \text{Watts}$$

$$Q_{\text{Top}} = 8.3 \text{ Watts}$$

$$4 - \quad Q_{\text{Bottom}} = [U A (T_a - T_f)]$$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.065 / 0.0195) = 0.30 \text{ W/Sq. Mt. C}$$

$$A = 0.49 \text{ Sq. Mt.}$$

$$T_a = 42\text{C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Bottom}} = 0.3 \times 0.49 \times 60 = 8.9 \text{ Watts}$$

$$Q_{\text{Bottom}} = 8.9 \text{ Watts}$$

$$5 - \quad Q_{\text{Door}} = [U A (T_a - T_f)]$$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.040 / 0.0195) = 0.49 \text{ W/ Sq. Mt. C}$$

$$A = 0.49 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Door}} = 0.49 \times 0.49 \times 50 = 12 \text{ Watts}$$

$$Q_{\text{Door}} = 12 \text{ Watts}$$

Total Heat Leaks;

$$Q_{\text{TL}} = 10.2 + 8.3 + 8.3 + 8.9 + 12 = 47.7$$

$$Q_{\text{Total Heat Leaks}} = 47.7 \text{ Watts}$$

b) Product Loads;

$$Q_{\text{product}} = 65 \% Q_{\text{Heat Leaks}}$$

$$Q_{\text{Product Loads}} = 47.7 \times 70\% = 33.4$$

$$Q_{\text{Misc}} = 30 \% (Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}})$$

$$Q_{\text{Misc}} = 30 \% = 24.3$$

$$Q_{\text{Misc}} = Q_{\text{Electricity}} + Q_{\text{Infiltration}} + Q_{\text{Door Opening}} + Q_{\text{Etc.}}$$

Total Cooling Capacity required is calculated as follows;

$$Q_{\text{Grand Total}} = Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}} + Q_{\text{Misc.}}$$

$$Q_{\text{Grand Total}} = 47.7 + 33.4 + 24.3 = 105.4 \text{ Watts}$$

$$Q_{\text{Grand Total}} = 105.4 \text{ Watts}$$

Type of Compressor suitable for this model is recommended Aspera Model BP 1111Z, or Compressor HUAYI Model AE1340Y, or Zanussi Model OF789CY.

Transmission load calculation
Chest Freezer Model BD182AF
Dimensions

	Dimension Mt.	Area (sq. Mt.)	Insulation Thickness mm.
Side Walls	2x0.58x0.55	0.638	60
Back Panel	0.985x0.58	0.57	60
Door	0.985x0.55	0.54	40
Bottom Floor	0.985x0.55	0.54	65
Front Panel	0.985x0.58	0.57	60

Insulation Type: Pu Foam

$$\text{CP5. Foam Thermal Conductivity: } 0.0195 \text{ W /mt.C}$$

Temperature Difference: $(\Delta T) = 32 - (-18) = 50 \text{ C}$

Ambient Temperature = 32 C

Freezer Air Temperature = - 18 C

Calculation :

$$Q_{TL} = Q_{SW} + Q_{BP} + Q_{BOTTOM} + Q_{Front} + Q_{DOOR}$$

$$Q = U A (T_a - T_f)$$

$$U = \frac{1}{X_1 / K_1 + X_2 / K_2 + \dots}$$

Where :

U = Heat Resistance Coefficient Factor

K₁ = Foam Thermal Conductivity

X₁ = Foam Thickness

Note : Due to the short thickness of cabinet out side panel (0.5 mm) and aluminum inner liner (0.5 mm) heat resistance of these materials have been considered negligible.

Therefore:

1- $Q_{Side\ Walls} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt. C}$$

$$A = 0.638 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{Side\ Walls} = 0.32 \times 0.638 \times 50 = 10.2 \text{ Watts}$$

$$Q_{Side\ Walls} = 10.2 \text{ Watts}$$

2 - $Q_{Back\ panel} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt. C.}$$

$$A = 0.57 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Back panel}} = 0.32 \times 0.57 \times 50 = 9.1 \text{ Watts}$$

$$Q_{\text{Back panel}} = 9.1 \text{ Watts}$$

3 - $Q_{\text{Front Panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt C}$$

$$A = 0.57 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Front Panel}} = 0.32 \times 0.57 \times 50 = 9.1 \text{ Watts}$$

$$Q_{\text{Top}} = 9.1 \text{ Watts}$$

4 - $Q_{\text{Bottom}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.065 / 0.0195) = 0.30 \text{ W/Sq. Mt C}$$

$$A = 0.54 \text{ Sq. Mt.}$$

$$T_a = 42 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Bottom}} = 0.3 \times 0.54 \times 60 = 9.7 \text{ Watts}$$

$$Q_{\text{Bottom}} = 9.7 \text{ Watts}$$

5 - $Q_{\text{Door}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.040 / 0.0195) = 0.49 \text{ W/ Sq. Mt. } ^\circ\text{C}$$

$$A = 0.54 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ } ^\circ\text{C}$$

$$T_f = -18 \text{ } ^\circ\text{C}$$

$$Q_{\text{Door}} = 0.49 \times 0.54 \times 50 = 13.2 \text{ Watts}$$

$$Q_{\text{Door}} = 13.2 \text{ Watts}$$

Total Heat Leaks;

$$Q_{\text{TL}} = 10.2 + 9.1 + 9.7 + 9.1 + 13.2 = 51.33$$

$$Q_{\text{Total Heat Leaks}} = 51.33 \text{ Watts}$$

b) Product Loads;

We consider 13 Kg ice making capacity for this model per 24 hours.

Therefore;

$$Q_{\text{product}} = Q_1 + Q_2 + Q_3,$$

where;

$Q_1 = mC_1 (T_1 - T_f)$ = energy required to freeze water from initial temperature to freezing point of $0 \text{ } ^\circ\text{C}$

$Q_2 = mC_2 (T_f - T_a)$ = energy required to freeze ice from zero degree temperature to $-18 \text{ } ^\circ\text{C}$

$Q_3 = m \times h$ = heat gain from latent heat of fusion of water

$$Q_1 = 13 \times 1 \times (24 - 0) = 312 \text{ Kcal per 24 hour}$$

$$Q_2 = 13 \times 1 [0 - (-18)] = 234 \text{ Kcal per 24 hours}$$

$$Q_3 = 13 \times 108 = 1404 \text{ Kcal per 24 hours}$$

$$Q_{\text{product}} = 312 + 234 + 1404 = 1950 \text{ Kcal per 24 hour} = 81 \text{ Kcal / hour} = 94 \text{ W}$$

$$Q_{\text{Misc}} = 10 \% (Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}})$$

$$Q_{\text{Misc}} = 10 \% (51 + 94) = 14.5$$

$$Q_{\text{Misc}} = Q_{\text{Electricity}} + Q_{\text{Infiltration}} + Q_{\text{Door Opening}} + Q_{\text{Etc.}}$$

Total Cooling Capacity required is calculated as follows;

$$Q_{\text{Grand Total}} = Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}} + Q_{\text{Misc.}}$$

$$Q_{\text{Grand Total}} = 51.1 + 94 + 14.5 = 159.6 \text{ Watts}$$

$$Q_{\text{Grand Total}} = 160 \text{ Watts}$$

Type of Compressor suitable for this model is recommended

Transmission load calculation
Chest Freezer Model BD198AE

Dimensions

	Dimension Mt.	Area (sq. Mt.)	Insulation Thickness mm.
Side Walls	2x0.58x0.55	0.638	60
Back Panel	1.06x0.58	0.61	60
Door	1.06x0.55	0.58	40
Bottom Floor	1.06x0.55	0.58	65
Front Panel	1.06x0.58	0.61	60

Insulation Type: Pu Foam

CP5. Foam Thermal Conductivity: 0.0195 W /mt.C

Temperature Difference: $(\Delta T) = 32 - (-18) = 50 \text{ C}$

Ambient Temperature = 32 C

Freezer Air Temperature = - 18 C

Calculation :

$$Q_{TL} = Q_{SW} + Q_{BP} + Q_{BOTTOM} + Q_{Front} + Q_{DOOR}$$

$$Q = U A (T_a - T_f)$$

$$U = \frac{1}{X_1 / K_1 + X_2 / K_2 + \dots}$$

Where :

U = Heat Resistance Coefficient Factor

K₁ = Foam Thermal Conductivity

X₁ = Foam Thickness

Note : Due to the short thickness of cabinet out side panel (0.5 mm) and aluminum inner liner (0.5 mm) heat resistance of these materials have been considered negligible.

Therefore:

1- $Q_{\text{Side Walls}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt. C}$$

$$A = 0.638 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Side Walls}} = 0.32 \times 0.638 \times 50 = 10.2 \text{ Watts}$$

$$Q_{\text{Side Walls}} = 10.2 \text{ Watts}$$

2 - $Q_{\text{Back panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt. C}$$

$$A = 0.61 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Back panel}} = 0.32 \times 0.61 \times 50 = 9.8 \text{ Watts}$$

$$Q_{\text{Back panel}} = 9.8 \text{ Watts}$$

3 - $Q_{\text{Front Panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.060 / 0.0195) = 0.32 \text{ W/ Sq. Mt C}$$

$$A = 0.61 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Front Panel}} = 0.32 \times 0.61 \times 50 = 9.8 \text{ Watts}$$

$$Q_{\text{Top}} = 9.8 \text{ Watts}$$

4 - $Q_{\text{Bottom}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.065 / 0.0195) = 0.30 \text{ W/Sq. Mt. C}$$

$$A = 0.58 \text{ Sq. Mt.}$$

$$T_a = 42 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Bottom}} = 0.3 \times 0.58 \times 60 = 10.4 \text{ Watts}$$

$$Q_{\text{Bottom}} = 10.4 \text{ Watts}$$

5 - $Q_{\text{Door}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.040 / 0.0195) = 0.49 \text{ W/ Sq. Mt. C}$$

$$A = 0.58 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Door}} = 0.49 \times 0.58 \times 50 = 14.2 \text{ Watts}$$

$$Q_{\text{Door}} = 14.2 \text{ Watts}$$

Total Heat Leaks;

$$Q_{\text{TL}} = 10.2 + 9.8 + 10.4 + 9.8 + 14.2 = 54.4$$

$$Q_{\text{Total Heat Leaks}} = 54.4 \text{ Watts}$$

b) Product Loads;

We consider 15 Kg ice making capacity for this model per 24 hours.
Therefore;

$$Q_{\text{product}} = Q_1 + Q_2 + Q_3,$$

where;

$Q_1 = mC_1 (T_i - T_f) =$ energy required to freeze water from initial temperature to freezing point of 0°C

$Q_2 = mC_2 (T_f - T_r) =$ energy required to freeze ice from zero degree temperature to -18°C

$Q_3 = m \times h =$ heat gain from latent heat of fusion of water

$$Q_1 = 15 \times 1 \times (24-0) = 360 \text{ Kcal per 24 hour}$$

$$Q_2 = 15 \times 1 \times [0 - (-18)] = 270 \text{ Kcal per 24 hours}$$

$$Q_3 = 15 \times 108 = 1620 \text{ Kcal per 24 hours}$$

$$Q_{\text{product}} = 360 + 270 + 1620 = 2250 \text{ Kcal per 24 hour} = 93 \text{ Kcal / hour} = 108.7 \text{ W}$$

$$Q_{\text{Misc}} = 10 \% (Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}})$$


$$Q_{\text{Misc}} = 10 \% (54.4 + 108.7) = 16.3$$

$$Q_{\text{Misc}} = Q_{\text{Electricity}} + Q_{\text{Infiltration}} + Q_{\text{Door Opening}} + Q_{\text{Etc.}}$$

Total Cooling Capacity required is calculated as follows;

$$Q_{\text{Grand Total}} = Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}} + Q_{\text{Misc.}}$$

$$Q_{\text{Grand Total}} = 54.4 + 108.7 + 16.3 = 179.4 \text{ Watts}$$



$$Q_{\text{Grand Total}} = 179 \text{ Watts}$$

Type of Compressor suitable for this model is recommended

Transmission load calculation

Chest Freezer Model BD308

Dimensions

	Dimension Mt.	Area (sq. Mt.)	Insulation Thickness mm.
Side Walls	$(0.8 \times 0.63) + (0.45 \times 0.63)$	0.79	70
Back Panel	$(0.8 \times 1.12) - (0.25 \times 0.24)$	0.89	70
Door	1.12×0.63	0.70	65
Bottom Floor	1.12×0.63	0.70	75
Front Panel	$(0.8 \times 1.12) - (0.25 \times 0.24)$	0.89	70

Insulation Type: Pu Foam

CP5. Foam Thermal Conductivity: 0.0195 W /mt.C

Temperature Difference: $(\Delta T) = 32 - (-18) = 50 \text{ C}$

Ambient Temperature = 32 C

Freezer Air Temperature = - 18 C

Calculation :

$$Q_{TL} = Q_{SW} + Q_{BP} + Q_{BOTTOM} + Q_{Front} + Q_{DOOR}$$

$$Q = U A (T_a - T_f)$$

$$U = \frac{1}{X_1 / K_1 + X_2 / K_2 + \dots}$$

Where :

U = Heat Resistance Coefficient Factor

K₁ = Foam Thermal Conductivity

X₁ = Foam Thickness

Note : Due to the short thickness of cabinet out side panel (0.5 mm) and aluminum inner liner (0.5 mm) heat resistance of these materials have been considered negligible.

Therefore:

1- $Q_{\text{Side Walls}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt. C}$$

$$A = 0.79 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Side Walls}} = 0.28 \times 0.79 \times 50 = 11 \text{ Watts}$$

$$Q_{\text{Side Walls}} = 11 \text{ Watts}$$

2 - $Q_{\text{Back panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature
 T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt. C}$$

$$A = 0.89 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Back panel}} = 0.28 \times 0.89 \times 50 = 12.5 \text{ Watts}$$

$$Q_{\text{Back panel}} = 12.5 \text{ Watts}$$

3 - $Q_{\text{Front Panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature
 T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt C}$$

$$A = 0.89 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Front Panel}} = 0.28 \times 0.89 \times 50 = 12.5 \text{ Watts}$$

$$Q_{\text{Top}} = 12.5 \text{ Watts}$$

4 - $Q_{\text{Bottom}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature
 T_f = Freezer air Temperature

$$U = 1 / (0.075 / 0.0195) = 0.26 \text{ W/Sq. Mt C}$$

$$A = 0.70 \text{ Sq. Mt.}$$

$$T_a = 42 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Bottom}} = 0.26 \times 0.70 \times 60 = 11 \text{ Watts}$$

$$Q_{\text{Bottom}} = 11 \text{ Watts}$$

$$5 - \quad Q_{\text{Door}} = [U A (T_a - T_f)]$$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.065 / 0.0195) = 0.3 \text{ W/ Sq. Mt. C}$$

$$A = 0.70 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Door}} = 0.3 \times 0.70 \times 50 = 10.5 \text{ Watts}$$

$$Q_{\text{Door}} = 10.5 \text{ Watts}$$

Total Heat Leaks;

$$Q_{\text{TL}} = 11 + 12.5 + 10.5 + 11 + 12.5 = 57.7$$

$$Q_{\text{Total Heat Leaks}} = 57.5 \text{ Watts}$$

b) Product Loads;

We consider 20 Kg ice making capacity for this model per 24 hours.

Therefore;

$$Q_{\text{product}} = Q_1 + Q_2 + Q_3,$$

where;

$Q_1 = mC_1 (T_1 - T_f)$ = energy required to freeze water from initial temperature to freezing point of 0 °C

$Q_2 = mC_2 (T_f - T_{ff})$ = energy required to freeze ice from zero degree temperature to -18 °C

$Q_3 = m \times h$ = heat gain from latent heat of fusion of water

$$Q_1 = 20 \times 1 \times (24-0) = 480 \text{ Kcal per 24 hour}$$

$$Q_2 = 20 \times 1 [0 - (-18)] = 360 \text{ Kcal per 24 hours}$$

$$Q_3 = 20 \times 108 = 2160 \text{ Kcal per 24 hours}$$

$$Q_{\text{product}} = 480 + 360 + 2160 = 3000 \text{ Kcal per 24 hour} = 125 \text{ Kcal / hour} = 145 \text{ W}$$

$$Q_{\text{Misc}} = 30 \% (Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}}) = 10\%(57.5 + 145) = 20 \text{ w}$$

$$Q_{\text{Misc}} = 20 \text{ Watts}$$

$$Q_{\text{Misc}} = Q_{\text{Electricity}} + Q_{\text{Infiltration}} + Q_{\text{Door Opening}} + Q_{\text{Etc.}}$$

Total Cooling Capacity required is calculated as follows;

$$Q_{\text{Grand Total}} = Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}} + Q_{\text{Misc.}}$$

$$Q_{\text{Grand Total}} = 57.5 + 145 + 20 = 220 \text{ Watts}$$

$$Q_{\text{Grand Total}} = 220 \text{ Watts}$$

Type of Compressor suitable for this model is recommended Compressor HUAYI Model

Transmission load calculation

Chest Freezer Model BD400

Dimensions

	Dimension Mt.	Area (sq. Mt.)	Insulation Thickness mm.
Side Walls	$(0.8 \times 0.63) + (0.45 \times 0.63)$	0.79	70
Back Panel	$(0.8 \times 1.38) - (0.25 \times 0.24)$	1.05	70
Door	1.38×0.63	0.87	65
Bottom Floor	1.38×0.63	0.87	75
Front Panel	$(0.8 \times 1.38) - (0.25 \times 0.24)$	1.05	70

Insulation Type: Pu Foam

CP5. Foam Thermal Conductivity: 0.0195 W /mt.C

Temperature Difference: $(\Delta T) = 32 - (-18) = 50$ C

Ambient Temperature = 32 C

Freezer Air Temperature = - 18 C

Calculation :

$$Q_{TL} = Q_{SW} + Q_{BP} + Q_{BOTTOM} + Q_{Front} + Q_{DOOR}$$

$$Q = U A (T_a - T_f)$$

$$U = \frac{1}{X_1 / K_1 + X_2 / K_2 + \dots}$$

Where :

U = Heat Resistance Coefficient Factor

K_1 = Foam Thermal Conductivity

X_1 = Foam Thickness

Note : Due to the short thickness of cabinet out side panel (0.5 mm) and aluminum inner liner (0.5 mm) heat resistance of these materials have been considered negligible.

Therefore:

1- $Q_{\text{Side Walls}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt. C}$$

$$A = 0.79 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Side Walls}} = 0.28 \times 0.79 \times 50 = 11 \text{ Watts}$$

$$Q_{\text{Side Walls}} = 11 \text{ Watts}$$

2 - $Q_{\text{Back panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt. C}$$

$$A = 1.05 \text{ Sq. Mt.}$$

$$T_a = 42 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Back panel}} = 0.28 \times 1.05 \times 60 = 17.64 \text{ Watts}$$

$$Q_{\text{Back panel}} = 17.6 \text{ Watts}$$

3 - $Q_{\text{Front Panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt C}$$

$$A = 1.05 \text{ Sq. Mt.}$$

$$T_a = 42 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Front Panel}} = 0.28 \times 1.05 \times 60 = 17.6 \text{ Watts}$$

$$Q_{\text{Top}} = 17.6 \text{ Watts}$$

4 - $Q_{\text{Bottom}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.075 / 0.0195) = 0.26 \text{ W/Sq. Mt C}$$

$$A = 0.87 \text{ Sq. Mt.}$$

$$T_a = 42 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Bottom}} = 0.26 \times 0.87 \times 60 = 11.3 \text{ Watts}$$

$$Q_{\text{Bottom}} = 11.3 \text{ Watts}$$

5 - $Q_{\text{Door}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.065 / 0.0195) = 0.3 \text{ W/ Sq. Mt. C}$$

$$A = 0.870 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Door}} = 0.3 \times 0.870 \times 50 = 13 \text{ Watts}$$

$$Q_{\text{Door}} = 13 \text{ Watts}$$

Total Heat Leaks;

$$Q_{\text{TL}} = 11 + 17.6 + 13 + 17.6 + 11.3 = 70.5$$

$$Q_{\text{Total Heat Leaks}} = 70.5 \text{ Watts}$$

b) Product Loads;

We consider 25 Kg ice making capacity for this model per 24 hours.
Therefore;

$$Q_{\text{product}} = Q_1 + Q_2 + Q_3,$$

where;

$Q_1 = mC_1 (T_1 - T_f) =$ energy required to freeze water from initial temperature to freezing point of 0°C

$Q_2 = mC_2 (T_f - T_n) =$ energy required to freeze ice from zero degree temperature to -18°C

$Q_3 = m \times h =$ heat gain from latent heat of fusion of water

$$Q_1 = 25 \times 1 \times (24-0) = 600 \text{ Kcal per 24 hour}$$

$$Q_2 = 25 \times 1 [0 - (-18)] = 450 \text{ Kcal per 24 hours}$$

$$Q_3 = 25 \times 108 = 2700 \text{ Kcal per 24 hours}$$

$$Q_{\text{product}} = 600 + 450 + 2700 = 3750 \text{ Kcal per 24 hour} = 156 \text{ Kcal / hour} = 182 \text{ W}$$

$$Q_{\text{Misc}} = 30 \% (Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}}) = 10\%(70.5 + 182) = 25 \text{ w}$$

$$Q_{\text{Misc}} = 25 \text{ Watts}$$

$$Q_{\text{Misc}} = Q_{\text{Electricity}} + Q_{\text{Infiltration}} + Q_{\text{Door Opening}} + Q_{\text{Etc.}}$$

Total Cooling Capacity required is calculated as follows;

$$Q_{\text{Grand Total}} = Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}} + Q_{\text{Misc.}}$$

$$Q_{\text{Grand Total}} = 70.5 + 182 + 25 = 277 \text{ Watts}$$

$$Q_{\text{Grand Total}} = 277 \text{ Watts}$$

Type of Compressor suitable for this model is recommended Compressor HUAYI Model

Transmission load calculation

Chest Freezer Model BD510

Dimensions

	Dimension Mt.	Area (sq. Mt.)	Insulation Thickness mm.
Side Walls	(0.8x0.63)+(0.45x0.63)	0.79	70
Back Panel	(0.8x1.7)-(0.25x0.24)	1.3	70
Door	1.7x0.63	1.07	65
Bottom Floor	1.7x0.63	1.07	75

Front Panel	(0.8x1.12)-(0.25x0.24)	1.3	70
-------------	------------------------	-----	----

Insulation Type: Pu Foam

CP5. Foam Thermal Conductivity: 0.0195 W /mt.C

Temperature Difference: $(\Delta T) = 32 - (-18) = 50 \text{ C}$

Ambient Temperature = 32 C

Freezer Air Temperature = - 18 C

Calculation :

$$Q_{TL} = Q_{SW} + Q_{BP} + Q_{BOTTOM} + Q_{Front} + Q_{DOOR}$$

$$Q = U A (T_a - T_f)$$

$$U = \frac{1}{X_1 / K_1 + X_2 / K_2 + \dots}$$

Where :

U = Heat Resistance Coefficient Factor

K₁ = Foam Thermal Conductivity

X₁ = Foam Thickness

Note : Due to the short thickness of cabinet out side panel (0.5 mm) and aluminum inner liner (0.5 mm) heat resistance of these materials have been considered negligible.

Therefore:

1- $Q_{Side\ Walls} = [U A (T_a - T_f)]$

T_a = Ambient Temperature

T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt. C}$$

$$A = 0.79 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Side Walls}} = 0.28 \times 0.79 \times 50 = 11 \text{ Watts}$$

$$Q_{\text{Side Walls}} = 11 \text{ Watts}$$

2 - $Q_{\text{Back panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature
 T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt. C}$$

$$A = 1.3 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Back panel}} = 0.28 \times 1.3 \times 50 = 18.2 \text{ Watts}$$

$$Q_{\text{Back panel}} = 18.2 \text{ Watts}$$

3 - $Q_{\text{Front Panel}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature
 T_f = Freezer air Temperature

$$U = 1 / (0.070 / 0.0195) = 0.28 \text{ W/ Sq. Mt C}$$

$$A = 1.3 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = -18 \text{ C}$$

$$Q_{\text{Front Panel}} = 0.28 \times 1.3 \times 50 = 18.2 \text{ Watts}$$

$$Q_{\text{Top}} = 18.2 \text{ Watts}$$

4 - $Q_{\text{Bottom}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature
 T_f = Freezer air Temperature

$$U = 1 / (0.075 / 0.0195) = 0.26 \text{ W/Sq. Mt. C}$$

$$A = 1.07 \text{ Sq. Mt.}$$

$$T_a = 42\text{C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Bottom}} = 0.26 \times 1.070 \times 60 = 16.7 \text{ Watts}$$

$$Q_{\text{Bottom}} = 16.7 \text{ Watts}$$

5 - $Q_{\text{Door}} = [U A (T_a - T_f)]$

T_a = Ambient Temperature
 T_f = Freezer air Temperature

$$U = 1 / (0.065 / 0.0195) = 0.3 \text{ W/ Sq. Mt. C}$$

$$A = 1.070 \text{ Sq. Mt.}$$

$$T_a = 32 \text{ C}$$

$$T_f = - 18 \text{ C}$$

$$Q_{\text{Door}} = 0.3 \times 1.07 \times 50 = 16 \text{ Watts}$$

$$Q_{\text{Door}} = 16 \text{ Watts}$$

Total Heat Leaks;

$$Q_{\text{TL}} = 11 + 18.2 + 16.7 + 18.2 + 16 = 80$$

$$Q_{\text{Total Heat Leaks}} = 80 \text{ Watts}$$

b) Product Loads;

We consider 30 Kg ice making capacity for this model per 24 hours.
 Therefore;

$$Q_{\text{product}} = Q_1 + Q_2 + Q_3,$$

where;

$Q_1 = mC_1 (T_i - T_f)$ = energy required to freeze water from initial temperature to freezing point of 0°C

$Q_2 = mC_2 (T_f - T_n)$ = energy required to freeze ice from zero degree temperature to -18°C

$Q_3 = m \times h = \text{heat gain from latent heat of fusion of water}$

$$Q_1 = 30 \times 1 \times (24-0) = 720 \text{ Kcal per 24 hour}$$

$$Q_2 = 30 \times 1 [0 - (-18)] = 540 \text{ Kcal per 24 hours}$$

$$Q_3 = 30 \times 108 = 3240 \text{ Kcal per 24 hours}$$

$$Q_{\text{product}} = 720 + 540 + 3240 = 4500 \text{ Kcal per 24 hour} = 187 \text{ Kcal / hour} = 218 \text{ W}$$

$$Q_{\text{Misc}} = 10 \% (Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}}) = 10\%(80 + 218) = 30 \text{ w}$$

$$Q_{\text{Misc}} = 30 \text{ Watts}$$

$$Q_{\text{Misc}} = Q_{\text{Electricity}} + Q_{\text{Infiltration}} + Q_{\text{Door Opening}} + Q_{\text{Etc.}}$$

Total Cooling Capacity required is calculated as follows;

$$Q_{\text{Grand Total}} = Q_{\text{Heat Leaks}} + Q_{\text{Product Loads}} + Q_{\text{Misc.}}$$

$$Q_{\text{Grand Total}} = 80 + 218 + 30 = 328 \text{ Watts}$$

$$Q_{\text{Grand Total}} = 328 \text{ Watts}$$

Type of Compressor suitable for this model is recommended Compressor HUAYI Model

NO:1
 试验内容: 储藏温度
 直冷型冰箱
 机型: BD-166(R134a)
 型号: AE1350Y, .66*2100 140
 厂号: 32170X
 温控器位置(n值=5)
 测试条件:

冷冻室: -21.9 °C 测温点数: 6 (t1, t2, t3, t4, t5, t6,)

格式 1 汇总统计表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (KWh)	功率 (W)	系数 (%)	电能2 (KWh/24h)	C.n	ΔT 秒	
1938-12-22																									
OFF	11:11:53	-19.87	-22.40	-22.29	-18.46	-18.77	-19.30											0.002	0.0279				5	834	
ON	11:25:47	-19.77	-22.35	-22.20	-18.40	-18.70	-19.24											0.907	0.0283				5	947	
OFF	11:41:34	-19.77	-22.27	-22.22	-18.47	-18.83	-19.38											0.002	0.0567	107.8	53.17	1.3938	5	837	
ON	11:55:31	-19.68	-22.27	-22.16	-18.30	-18.69	-19.20											0.915	0.0571				5	927	
OFF	12:10:58	-19.78	-22.30	-22.21	-18.44	-18.72	-19.27											0.001	0.0849	107.7	52.86	1.3875	5	820	
ON	12:24:38	-19.70	-22.30	-22.19	-18.39	-18.71	-19.28											0.919	0.0853				5	925	
OFF	12:40:3	-19.75	-22.26	-22.18	-18.40	-18.71	-19.30											0.000	0.1180	107.6	52.91	1.3894	5	779	
ON	12:53:2	-19.70	-22.28	-22.17	-18.38	-18.69	-19.24											0.912	0.1134				5	958	
OFF	13:9:0	-19.76	-22.26	-22.20	-18.42	-18.73	-19.28											0.002	0.1420	107.3	53.47	1.4023	5	823	
ON	13:22:43	-19.63	-22.23	-22.16	-18.38	-18.71	-19.27											0.909	0.1424				5	1000	
OFF	13:39:23	-19.75	-22.26	-22.16	-18.39	-18.72	-19.29											0.001	0.1721	106.9	53.75	1.4074	5	769	
ON	13:52:12	-19.72	-22.29	-22.15	-18.35	-18.63	-19.23											0.915	0.1720				5	933	
OFF	14:7:45	-19.77	-22.28	-22.16	-18.38	-18.69	-19.27											0.000	0.2004	107.4	53.92	1.4123	5	816	
ON	14:21:21	-19.72	-22.31	-22.16	-18.37	-18.68	-19.25											0.911	0.2008				5	925	
OFF	14:36:46	-19.77	-22.28	-22.19	-18.43	-18.74	-19.30											0.001	0.2285	107.5	53.81	1.4093	5	822	
ON	14:50:23	-19.69	-22.30	-22.18	-18.42	-18.72	-19.27											0.913	0.2290				5	958	
OFF	15:6:26	-19.76	-22.28	-22.18	-18.41	-18.70	-19.28											0.000	0.2575	107.0	53.81	1.4097	5	757	
ON	15:19:3	-19.68	-22.27	-22.14	-18.36	-18.70	-19.27											0.914	0.2579				5	816	

ON	17:13:15	-19.64	-22.26	-22.15	-18.39	-18.68	-19.22
OFF	17:34:32	-19.71	-22.25	-22.14	-18.39	-18.69	-19.25
ON	17:40:57	-19.68	-22.28	-22.16	-18.41	-18.71	-19.27
OFF	18:1:27	-19.71	-22.24	-22.14	-18.39	-18.68	-19.25
ON	18:15:38	-19.60	-22.28	-22.16	-18.41	-18.71	-19.27
OFF	18:31:57	-19.65	-22.20	-22.13	-18.39	-18.71	-19.26
ON	18:44:14	-19.60	-22.30	-22.21	-18.40	-18.70	-19.30
OFF	18:59:28	-19.71	-22.24	-22.16	-18.40	-18.70	-19.27
ON	19:13:20	-19.64	-22.24	-22.11	-18.34	-18.62	-19.17
OFF	19:28:30	-19.69	-22.22	-22.13	-18.39	-18.68	-19.24
ON	19:41:35	-19.63	-22.27	-22.17	-18.40	-18.69	-19.22
OFF	19:56:10	-19.71	-22.24	-22.16	-18.40	-18.69	-19.24
ON	20:10:57	-19.65	-22.26	-22.17	-18.40	-18.71	-19.28
OFF	20:25:19	-19.69	-22.23	-22.15	-18.35	-18.64	-19.19
ON	20:36:40	-19.64	-22.25	-22.15	-18.38	-18.69	-19.24
OFF	20:54:11	-19.73	-22.25	-22.23	-18.43	-18.74	-19.36
ON	21:0:50	-19.61	-22.21	-22.09	-18.31	-18.66	-19.17
OFF	21:21:24	-19.60	-22.20	-22.12	-18.32	-18.66	-19.14
ON	21:35:18	-19.47	-22.09	-22.01	-18.27	-18.59	-19.18
OFF	21:51:10	-19.72	-22.27	-22.19	-18.43	-18.76	-19.32
ON	22:3:59	-19.61	-22.20	-22.09	-18.33	-18.63	-19.18
OFF	22:18:35	-19.74	-22.27	-22.18	-18.41	-18.72	-19.28
ON	22:32:21	-19.66	-22.27	-22.16	-18.36	-18.69	-19.25
OFF	22:47:53	-19.67	-22.11	-22.10	-18.30	-18.63	-19.15
ON	23:1:8	-19.63	-22.24	-22.14	-18.35	-18.65	-19.21
OFF	23:16:12	-19.65	-22.21	-22.14	-18.35	-18.71	-19.23
ON	23:28:58	-19.58	-22.22	-22.13	-18.34	-18.62	-19.17
OFF	23:43:23	-19.68	-22.24	-22.17	-18.41	-18.71	-19.23
ON	23:57:50	-19.67	-22.27	-22.17	-18.37	-18.62	-19.15
1998-12-25							
OFF	0:12:59	-19.64	-22.18	-22.09	-18.32	-18.61	-19.20
ON	0:26:41	-19.60	-22.21	-22.09	-18.33	-18.62	-19.20
OFF	0:42:6	-19.68	-22.22	-22.15	-18.41	-18.71	-19.30
ON	0:54:27	-19.63	-22.24	-22.14	-18.37	-18.65	-19.21
OFF	1:8:54	-19.65	-22.20	-22.09	-18.33	-18.62	-19.17
ON	1:22:52	-19.59	-22.24	-22.12	-18.34	-18.67	-19.25
OFF	1:38:5	-19.65	-22.19	-22.08	-18.30	-18.65	-19.23
ON	1:50:54	-19.61	-22.20	-22.07	-18.32	-18.61	-19.19
OFF	2:0:0	-19.66	-22.20	-22.11	-18.37	-18.66	-19.25
ON	2:19:38	-19.59	-22.22	-22.10	-18.30	-18.64	-19.20
OFF	2:34:20	-19.56	-22.08	-21.96	-18.20	-18.53	-19.12
ON	2:46:58	-19.53	-22.20	-22.09	-18.33	-18.62	-19.19
OFF	3:1:6	-19.63	-22.17	-22.08	-18.34	-18.61	-19.16
ON	3:14:54	-19.58	-22.21	-22.11	-18.36	-18.65	-19.20
OFF	3:30:3	-19.64	-22.16	-22.08	-18.34	-18.61	-19.18
ON	3:42:30	-19.59	-22.20	-22.08	-18.35	-18.63	-19.17
OFF	3:56:55	-19.62	-22.15	-22.09	-18.33	-18.63	-19.20
ON	4:10:44	-19.59	-22.22	-22.11	-18.30	-18.60	-19.23
OFF	4:25:40	-19.59	-22.13	-22.05	-18.30	-18.60	-19.19
ON	4:36:0	-19.55	-22.20	-22.06	-18.32	-18.63	-19.23
OFF	4:53:20	-19.63	-22.18	-22.09	-18.33	-18.64	-19.21
ON	5:7:5	-19.54	-22.10	-22.04	-18.24	-18.57	-19.13
OFF	5:21:30	-19.62	-22.17	-22.08	-18.31	-18.64	-19.21
ON	5:34:45	-19.58	-22.18	-22.08	-18.30	-18.63	-19.19
OFF	5:49:10	-19.62	-22.14	-22.05	-18.27	-18.60	-19.15
ON	6:2:48	-19.49	-22.11	-22.04	-18.20	-18.50	-19.11
OFF	6:17:35	-19.57	-22.12	-22.05	-18.29	-18.64	-19.22
ON	6:29:57	-19.57	-22.18	-22.09	-18.32	-18.64	-19.22
OFF	6:44:0	-19.56	-22.10	-22.01	-18.20	-18.58	-19.17
ON	6:57:52	-19.52	-22.14	-22.03	-18.26	-18.58	-19.15
871	0.914	0.3701	0.914	0.3701	0.914	0.3701	0.914
917	0.000	0.4040	107.9	54.00	1.4130	5	5
745	0.914	0.4044				5	5
870	0.002	0.4305	107.9	54.05	1.4154	5	5
851	0.913	0.4309				5	5
931	0.000	0.4367	107.4	53.53	1.4122	5	5
785	0.916	0.4331				5	5
914	0.000	0.4304	107.4	53.92	1.4120	5	5
882	0.915	0.4308				5	5
910	0.000	0.5141	107.6	53.82	1.4030	5	5
785	0.917	0.5144				5	5
861	0.000	0.5409	108.1	53.77	1.4087	5	5
829	0.920	0.5413				5	5
904	0.000	0.5684	107.9	53.69	1.4067	5	5
817	0.917	0.5688				5	5
925	0.000	0.5307	108.1	53.60	1.4064	5	5
759	0.916	0.5370				5	5
874	0.000	0.6233	108.2	53.65	1.4066	5	5
834	0.918	0.6237				5	5
952	0.003	0.6323	107.8	53.64	1.4064	5	5
709	0.910	0.6327				5	5
876	0.000	0.6768	107.4	53.62	1.4069	5	5
820	0.918	0.6752				5	5
982	0.001	0.7072	108.1	53.59	1.4054	5	5
750	0.912	0.7076				5	5
898	0.002	0.7349	107.7	53.59	1.4055	5	5
827	0.914	0.7353				5	5
924	0.002	0.7630	107.7	53.50	1.4047	5	5
750	0.911	0.7633				5	5
503	0.001	0.7303	107.4	53.59	1.4055	5	5
822	0.916	0.7309				5	5
925	0.002	0.8180	107.7	53.57	1.4053	5	5
741	0.911	0.8190				5	5
807	0.000	0.8450	108.0	53.58	1.4057	5	5
836	0.911	0.8453				5	5
913	0.000	0.8727	107.6	53.53	1.4044	5	5
709	0.913	0.8732				5	5
900	0.000	0.9003	107.5	53.55	1.4049	5	5
818	0.912	0.9008				5	5
888	0.000	0.9274	107.6	53.50	1.4040	5	5
752	0.917	0.9279				5	5
850	0.000	0.9534	108.1	53.49	1.4040	5	5
820	0.916	0.9539				5	5
909	0.000	0.9812	107.9	53.46	1.4033	5	5
747	0.913	0.9816				5	5
865	0.000	1.0070	107.8	53.40	1.4036	5	5
829	0.918	1.0080				5	5
890	0.000	1.0349	107.9	53.42	1.4027	5	5
740	0.916	1.0354				5	5
920	0.002	1.0630	107.7	53.47	1.4042	5	5
825	0.915	1.0635				5	5
871	0.001	1.0897	108.1	53.42	1.4031	5	5
789	0.921	1.0902				5	5
871	0.000	1.1163	107.6	53.40	1.4026	5	5
812	0.913	1.1167				5	5
897	0.002	1.1430	107.7	53.37	1.4020	5	5
732	0.912	1.1439				5	5
849	0.000	1.1695	108.1	53.38	1.4024	5	5
820	0.914	1.1699				5	5

OFF	7:12:9	-19.58	-22.11	-22.02	-18.22	-18.54	-19.14
ON	7:24:31	-19.54	-22.15	-22.08	-18.29	-18.63	-19.20
OFF	7:38:45	-19.48	-22.00	-21.92	-18.19	-18.54	-19.12
ON	7:52:5	-19.61	-22.22	-22.13	-18.34	-18.68	-19.23
OFF	8:8:0	-19.62	-22.15	-22.08	-18.31	-18.63	-19.17
ON	8:20:19	-19.55	-22.12	-21.99	-18.21	-18.56	-19.14
OFF	8:34:1	-19.61	-22.14	-22.04	-18.26	-18.62	-19.15
ON	8:47:49	-19.53	-22.12	-22.01	-18.25	-18.55	-19.11
OFF	9:1:20	-19.60	-22.13	-22.05	-18.30	-18.63	-19.20
ON	9:14:8	-19.43	-22.04	-21.91	-18.15	-18.48	-19.07

0.000	1.1956	107.9	53.32	1.4009	5	857
0.913	1.1960				5	742
0.001	1.2218	108.4	53.33	1.4013	5	854
0.918	1.2222				5	800
0.001	1.2508	107.9	53.35	1.4019	5	955
0.914	1.2514				5	739
0.001	1.2761	108.0	53.34	1.4018	5	822
0.916	1.2765				5	828
0.000	1.3010	108.6	53.26	1.4000	5	811
0.916	1.3014				5	768

1998-12-23 9:14:8 (Fmax)=-18.15 °C

霜 33沉霜霜霜霜霜霜霜(Fmin)=-22.40 °C

霜霜霜霜霜 (ton)=88.80 °C (tm)=88.80 °C

(toff)=88.80 °C

电流=0.916 (A)

耗电量=1.4000 (KWh/24h)

(ON=压缩机通电,OFF=压缩机断电,*on=化霜加热器通电,*off=化霜加热器断电)

(max=状态变化之间冷冻室最热点时刻,min=状态变化之间冷冻室最冷点时刻)

(Fmax=冷冻室最热点,Fmin=冷冻室最冷点,d=化霜开始冷冻室最热点等于-18°C时刻)

(tm=ton值与上一状态平均值的再平均值)

(toff=off值与上一状态平均值的再平均值)

(*max=化霜开始冷冻室最热点时刻)

制表时间:1998-12-23 9:25:46

NO:2

试验内容:储藏温度

直冷型冰箱

机型:BD-168(R134a)

型号:AE1350Y .66*2100 150

厂商:32'70%

温控器位置On值=5

温度条件:

冷冻室:-21.9 °C 测温点数:8(t1, t2, t3, t4, t5, t6, t7, t8,)

格式 1 汇总统计表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (KWh)	功率 (W)	系数 (%)	电能2 (KWh/24h)	C n	ΔT 度	
1998-12-22																									
OFF	11:19:9	-20.29	-20.22	-17.11	-23.94	-22.63	-22.57	-21.80	-22.03									0.000	0.0392				5		
ON	11:39:24	-20.11	-20.22	-17.13	-23.63	-22.64	-22.60	-21.84	-22.07									0.944	0.0397				5	1215	
OFF	12:0:17	-20.33	-20.27	-17.16	-23.98	-22.65	-22.59	-21.82	-22.06									0.002	0.0872	100.3	57.04	1.4074	5	1013	
ON	12:26:23	-20.12	-20.21	-17.09	-23.59	-22.60	-22.53	-21.78	-22.00									0.952	0.0876				5	1200	
OFF	12:57:21	-20.36	-20.29	-17.15	-23.98	-22.61	-22.55	-21.81	-22.05									0.003	0.1419	105.3	58.91	1.5064	5	1858	
ON	13:18:36	-20.03	-20.15	-17.00	-23.48	-22.47	-22.41	-21.60	-21.88									0.934	0.1424				5	1275	
OFF	13:46:6	-20.43	-20.33	-17.28	-24.04	-22.63	-22.58	-21.84	-22.02									0.002	0.1909	105.8	58.08	1.4804	5	1650	
ON	14:0:38	-20.11	-20.22	-17.11	-23.60	-22.58	-22.53	-21.81	-22.00									0.938	0.1913				5	1232	
OFF	14:34:23	-20.37	-20.31	-17.18	-23.96	-22.60	-22.54	-21.78	-22.03									0.000	0.2402	105.9	57.93	1.4829	5	1665	
ON	14:55:9	-20.18	-20.28	-17.19	-23.67	-22.60	-22.63	-21.89	-22.11									0.932	0.2408				5	1240	
OFF	15:24:15	-20.38	-20.31	-17.18	-23.98	-22.61	-22.57	-21.82	-22.07									0.003	0.2920	105.7	58.02	1.4854	5	1740	
ON	15:45:16	-20.06	-20.25	-17.13	-23.63	-22.55	-22.59	-21.77	-22.05									0.946	0.2925				5	1261	
OFF	16:11:27	-20.45	-20.36	-17.25	-24.04	-22.69	-22.65	-21.89	-22.15									0.004	0.3388	106.2	57.61	1.4759	5	1571	
ON	16:31:53	-20.24	-20.32	-17.20	-23.68	-22.66	-22.61	-21.86	-22.09									0.940	0.3392				5	1226	
OFF	16:58:45	-20.38	-20.28	-17.20	-23.95	-22.60	-22.57	-21.81	-22.06									0.003	0.3867	106.2	57.49	1.4734	5	1612	
ON	17:19:0	-20.12	-20.22	-17.14	-23.62	-22.60	-22.56	-21.81	-22.03									0.947	0.3871				5	1215	
OFF	17:44:37	-20.33	-20.23	-17.17	-23.91	-22.58	-22.55	-21.79	-22.05									0.003	0.4325	106.4	57.30	1.4693	5	1537	
ON	18:4:58	-20.07	-20.17	-17.12	-23.57	-22.57	-22.51	-21.75	-21.99									0.950	0.4329				5	1221	
OFF	18:30:53	-20.36	-20.26	-17.21	-23.97	-22.62	-22.56	-21.77	-22.01									0.000	0.4789	106.7	57.16	1.4668	5	1555	
ON	18:51:5	-20.13	-20.22	-17.14	-23.59	-22.58	-22.54	-21.76	-21.99									0.946	0.4794				5	1212	
OFF	19:16:53	-20.31	-20.20	-17.14	-23.88	-22.55	-22.52	-21.74	-21.99									0.003	0.5252	106.8	57.06	1.4650	5	1548	
ON	19:37:6	-20.09	-20.17	-17.09	-23.53	-22.53	-22.48	-21.70	-21.94									0.948	0.5258				5	1213	
OFF	20:3:10	-20.28	-20.16	-17.12	-23.87	-22.61	-22.61	-21.83	-22.06									0.002	0.5719	106.4	56.99	1.4640	5	1564	
ON	20:23:21	-20.01	-20.12	-17.08	-23.50	-22.47	-22.39	-21.59	-21.81									0.934	0.5723				5	1211	

OFF	21:33:58	-20.26	-20.14	-17.09	-23.79	-22.48	-22.44	-21.64	-21.89
ON	21:53:36	-20.13	-20.20	-17.12	-23.53	-22.53	-22.50	-21.76	-22.03
OFF	22:19:8	-20.32	-20.22	-17.17	-23.90	-22.59	-22.55	-21.77	-22.03
ON	22:38:50	-20.12	-20.21	-17.14	-23.57	-22.58	-22.53	-21.75	-21.97
OFF	23:5:11	-20.20	-20.12	-17.13	-23.86	-22.48	-22.44	-21.68	-21.92
ON	23:24:59	-20.09	-20.16	-17.09	-23.49	-22.49	-22.44	-21.65	-21.90
OFF	23:51:13	-20.31	-20.21	-17.14	-23.81	-22.47	-22.47	-21.72	-22.01
1998-12-23									
ON	0:11:6	-20.11	-20.20	-17.13	-23.54	-22.52	-22.48	-21.69	-21.91
OFF	0:38:31	-20.29	-20.21	-17.15	-23.87	-22.53	-22.49	-21.72	-21.95
ON	0:58:32	-20.10	-20.19	-17.13	-23.56	-22.55	-22.48	-21.69	-21.91
OFF	1:24:50	-20.36	-20.25	-17.16	-23.89	-22.55	-22.47	-21.73	-21.98
ON	1:45:0	-20.14	-20.22	-17.17	-23.56	-22.55	-22.50	-21.73	-21.93
OFF	2:12:12	-20.29	-20.19	-17.15	-23.85	-22.51	-22.47	-21.67	-21.92
ON	2:32:43	-20.11	-20.22	-17.15	-23.53	-22.53	-22.50	-21.73	-21.96
OFF	2:57:43	-20.33	-20.27	-17.25	-23.90	-22.55	-22.54	-21.75	-22.06
ON	3:17:31	-20.08	-20.13	-17.12	-23.50	-22.49	-22.46	-21.67	-21.90
OFF	3:44:3	-20.29	-20.20	-17.19	-23.86	-22.52	-22.50	-21.73	-21.99
ON	4:4:11	-20.10	-20.20	-17.17	-23.55	-22.58	-22.48	-21.71	-21.94
OFF	4:30:18	-20.32	-20.21	-17.21	-23.87	-22.55	-22.50	-21.73	-22.02
ON	4:50:12	-20.14	-20.23	-17.19	-23.56	-22.56	-22.52	-21.70	-21.90
OFF	5:15:20	-20.23	-20.17	-17.14	-23.86	-22.56	-22.55	-21.75	-21.99
ON	5:35:19	-20.16	-20.18	-17.11	-23.53	-22.52	-22.47	-21.68	-21.92
OFF	6:2:5	-20.32	-20.23	-17.12	-23.87	-22.54	-22.47	-21.69	-21.94
ON	6:21:59	-20.23	-20.32	-17.16	-23.66	-22.67	-22.64	-21.87	-22.09
OFF	6:49:23	-20.40	-20.31	-17.16	-23.99	-22.64	-22.57	-21.78	-22.02
ON	7:3:44	-20.16	-20.26	-17.13	-23.66	-22.66	-22.59	-21.81	-22.03
OFF	7:34:54	-20.30	-20.16	-17.03	-23.83	-22.49	-22.47	-21.72	-21.97
ON	7:54:54	-20.12	-20.22	-17.15	-23.61	-22.59	-22.54	-21.75	-21.98
OFF	8:20:35	-20.30	-20.22	-17.17	-23.91	-22.62	-22.54	-21.74	-22.02
ON	8:40:23	-20.10	-20.18	-17.11	-23.57	-22.55	-22.48	-21.71	-21.91
OFF	9:3:32	-20.35	-20.22	-17.19	-23.93	-22.65	-22.61	-21.82	-22.07
ON	9:23:22	-20.06	-20.13	-17.09	-23.52	-22.55	-22.50	-21.70	-21.93

0.001	0.0024	100.7	50.79	1.4598	5	1500
0.934	0.6630				5	1178
0.003	0.7081	100.3	50.78	1.4596	5	1532
0.947	0.7086				5	1182
0.001	0.7552	100.2	50.81	1.4604	5	1581
0.949	0.7556				5	1188
0.000	0.8020	100.2	50.82	1.4606	5	1574
0.929	0.8025				5	1193
0.000	0.8509	100.0	50.88	1.4622	5	1645
0.929	0.8513				5	1201
0.001	0.8979	100.3	50.88	1.4621	5	1578
0.928	0.8984				5	1210
0.001	0.9464	100.1	50.91	1.4628	5	1632
0.942	0.9469				5	1231
0.003	0.9912	100.5	50.81	1.4607	5	1500
0.933	0.9916				5	1138
0.001	1.0385	100.1	50.83	1.4611	5	1592
0.950	1.0389				5	1208
0.004	1.0851	100.3	50.82	1.4607	5	1567
0.940	1.0856				5	1194
0.003	1.1302	100.6	50.77	1.4599	5	1508
0.949	1.1307				5	1199
0.000	1.1781	100.4	50.79	1.4605	5	1606
0.941	1.1785				5	1194
0.002	1.2270	100.2	50.84	1.4619	5	1644
0.942	1.2274				5	1221
0.002	1.2721	100.7	50.78	1.4604	5	1510
0.930	1.2726				5	1200
0.004	1.3182	100.6	50.76	1.4601	5	1541
0.939	1.3187				5	1188
0.003	1.3599	107.0	50.67	1.4581	5	1389
0.933	1.3604				5	1190

 1998-12-22 13:18:36 1998-12-22 13:46:6 (Fmax)=-17.00 °C
 1998-12-22 13:46:6 (Fmin)=-24.04 °C
 霜霜霜霜 (ton)=88.80 °C (tm)=88.80 °C (ton=贮藏室t10,t11,t12最热点的平均值,tm=ton值与上一状态平均值的再平均值)
 (toff)=88.80 °C (tn)=88.80 °C (toff=贮藏室t10,t11,t12最冷点的平均值,tn=toff值与上一状态平均值的再平均值)
 电流=0.933 (A)
 耗电量=1.4581 (KWh/24h)

(ON=压缩机通电,OFF=压缩机断电,*on=化霜加热器通电,*off=化霜加热器断电)
 (max=状态变化之间冷冻室最热点时刻,min=状态变化之间冷冻室最冷点时刻)
 (Fmax=冷冻室最热点,Fmin=冷冻室最冷点,d=化霜开始冷冻室最热点等于-18°C时刻)
 (*max=化霜开始冷冻室最热点时刻)

制表时间:1998-12-23 9:25:46

NO:1
 试验内容:满载温度
 直冷型冰柜
 机号:55-168(R13-1a)
 型号:AE1330F, .603x2100 140
 厂号:32705
 温控器位置Cn值=5
 温度条件:

冷冻室:-21.9 °C 调温点数:6(t1, t2, t3, t4, t5, t6)

格式 1 汇总统计表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (kWh)	功率 (W)	系数 (%)	电能2 (kWh/24h)	ΔT 秒
1958-12-18																							
ON	16:50:27	-21.12	-22.18	-22.57	-22.50	-22.01	-22.23											0.907	0.0904	107.4	59.49	1.5305	887
OFF	17:55:14	-23.01	-24.00	-23.27	-23.23	-23.00	-24.01											0.903	0.0269	107.4			804
ON	17:15:13	-21.14	-22.17	-22.57	-22.52	-22.04	-22.32											0.906	0.0272	107.0	58.65	1.5333	898
OFF	17:25:10	-22.89	-23.50	-23.14	-23.12	-22.95	-23.79											0.900	0.0522	107.0			802
ON	17:35:13	-21.05	-22.08	-22.45	-22.36	-21.92	-22.17											0.903	0.0520	107.9	58.47	1.5333	825
OFF	17:53:7	-22.84	-23.81	-23.06	-23.00	-22.90	-23.79											0.903	0.0775	107.9			806
ON	18:3:15	-21.05	-22.08	-22.46	-22.37	-21.91	-22.15											0.900	0.1027	107.2	56.48	1.5305	830
OFF	18:17:8	-22.85	-23.85	-23.09	-23.03	-22.90	-23.84											0.906	0.1051	107.9			590
ON	18:27:4	-21.13	-22.12	-22.51	-22.43	-21.98	-22.20											0.901	0.1280	107.9	58.32	1.5233	831
OFF	18:40:55	-22.84	-23.85	-23.08	-23.05	-22.88	-23.80											0.911	0.1284	107.9			603
ON	18:50:56	-21.04	-22.07	-22.45	-22.40	-21.95	-22.21											0.901	0.1530	107.9	58.23	1.5272	822
OFF	19:4:40	-22.79	-23.81	-23.02	-22.93	-22.72	-23.80											0.905	0.1534	107.9			603
ON	19:14:43	-20.85	-21.88	-22.25	-22.18	-21.73	-22.01											0.903	0.1781	107.3	58.21	1.5293	826
OFF	19:28:31	-22.77	-23.83	-23.07	-23.03	-22.85	-23.80											0.905	0.1785	107.9			597
ON	19:38:28	-20.92	-22.00	-22.36	-22.28	-21.83	-22.11											0.900	0.2029	107.9	56.12	1.5233	815
OFF	19:52:3	-22.72	-23.74	-22.97	-22.94	-22.77	-23.68											0.903	0.2034	107.9			602
ON	20:2:5	-20.81	-21.85	-22.19	-22.14	-21.68	-21.95											0.900	0.2277	107.9	58.05	1.5246	809
OFF	20:15:34	-22.72	-23.73	-22.97	-22.90	-22.77	-23.63											0.915	0.2281	107.9			597
ON	20:25:31	-21.02	-22.03	-22.40	-22.33	-21.90	-22.17											0.902	0.2523	107.8	58.00	1.5230	806
OFF	20:38:57	-22.74	-23.73	-22.99	-22.93	-22.75	-23.63											0.912	0.2520	107.0			596
ON	20:48:53	-21.02	-22.02	-22.40	-22.34	-21.90	-22.17											0.901	0.2770	107.0	57.95	1.5229	814
OFF	21:2:27	-22.83	-23.86	-23.00	-22.90	-22.78	-23.72											0.901	0.2774	107.1			605
ON	21:12:32	-21.02	-22.03	-22.38	-22.30	-21.86	-22.10											0.903	0.3015	107.1	57.87	1.5193	810
OFF	21:26:2	-22.74	-23.73	-22.98	-22.91	-22.81	-23.72											0.903	0.3015	107.1			611
ON	21:36:13	-20.91	-21.90	-22.24	-22.19	-21.83	-22.08											0.901	0.3205	107.2	57.81	1.5176	825
OFF	21:45:56	-22.76	-23.77	-22.99	-22.93	-22.83	-23.74											0.905	0.3203	107.2			613
ON	22:0:17	-20.83	-21.80	-22.26	-22.19	-21.72	-21.93											0.901	0.3514	107.0	57.75	1.5160	821
OFF	22:13:58	-22.70	-23.72	-22.95	-22.92	-22.76	-23.63											0.913	0.3518	107.0			619
ON	22:24:17	-20.83	-21.83	-22.31	-22.23	-21.73	-22.00											0.901	0.3768	107.3	57.71	1.5149	834
OFF	22:38:11	-22.73	-23.82	-23.04	-23.02	-22.80	-23.76											0.908	0.3772	107.3			625
ON	22:48:30	-20.83	-21.83	-22.31	-22.23	-21.73	-22.03											0.900	0.4018	107.3	57.69	1.5157	823
OFF	23:2:23	-22.72	-23.77	-22.95	-22.94	-22.76	-23.67											0.907	0.4022	107.3			618
ON	23:12:43	-20.85	-21.84	-22.25	-22.19	-21.74	-22.00											0.900	0.4267	107.2	57.60	1.5160	823
OFF	23:26:20	-22.67	-23.64	-22.88	-22.88	-22.76	-23.57											0.912	0.4272	107.2			613
ON	23:36:39	-20.87	-21.86	-22.24	-22.15	-21.71	-21.97											0.901	0.4517	107.5	57.60	1.5160	820
OFF	23:50:19	-22.67	-23.63	-22.92	-22.89	-22.72	-23.57											0.913	0.4522	107.5	57.61	1.5110	827
ON	0:9:49	-20.83	-21.83	-22.27	-22.22	-21.72	-21.86											0.900	0.4770	107.0			833
OFF	0:14:59	-22.71	-23.71	-22.92	-22.87	-22.77	-23.67																

5-10 min

0.906	0.5023	57.36	1.5101	5
0.001	0.5270	107.7		5
0.908	0.5275	57.52	1.5095	5
0.001	0.5521	107.6		5
0.910	0.5526	57.50	1.5094	5
0.000	0.5769	107.2		5
0.911	0.5773	57.47	1.5088	5
0.001	0.6010	107.6		5
0.911	0.6021	57.44	1.5082	5
0.001	0.6265	107.5		5
0.909	0.6270	57.42	1.5079	5
0.001	0.6512	107.6		5
0.910	0.6517	57.39	1.5074	5
0.001	0.6757	107.5		5
0.906	0.6761	57.36	1.5065	5
0.000	0.7004	107.5		5
0.911	0.7008	57.35	1.5061	5
0.000	0.7250	107.1		5
0.905	0.7253	57.34	1.5055	5
0.000	0.7494	107.2		5
0.910	0.7498	57.32	1.5048	5
0.001	0.7741	107.7		5
0.914	0.7746	57.29	1.5045	5
0.001	0.7994	107.1		5
0.910	0.7994	57.28	1.5041	5
0.001	0.8235	107.2		5
0.910	0.8241	57.26	1.5038	5
0.001	0.8484	107.1		5
0.913	0.8489	57.23	1.5033	5
0.001	0.8732	107.0		5
0.910	0.8737	57.21	1.5029	5
0.001	0.8979	107.7		5
0.908	0.8982	57.19	1.5023	5
0.001	0.9225	108.1		5
0.914	0.9230	57.16	1.5020	5

0.906	0.5023	57.36	1.5101	5
0.001	0.5270	107.7		5
0.908	0.5275	57.52	1.5095	5
0.001	0.5521	107.6		5
0.910	0.5526	57.50	1.5094	5
0.000	0.5769	107.2		5
0.911	0.5773	57.47	1.5088	5
0.001	0.6010	107.6		5
0.911	0.6021	57.44	1.5082	5
0.001	0.6265	107.5		5
0.909	0.6270	57.42	1.5079	5
0.001	0.6512	107.6		5
0.910	0.6517	57.39	1.5074	5
0.001	0.6757	107.5		5
0.906	0.6761	57.36	1.5065	5
0.000	0.7004	107.5		5
0.911	0.7008	57.35	1.5061	5
0.000	0.7250	107.1		5
0.905	0.7253	57.34	1.5055	5
0.000	0.7494	107.2		5
0.910	0.7498	57.32	1.5048	5
0.001	0.7741	107.7		5
0.914	0.7746	57.29	1.5045	5
0.001	0.7994	107.1		5
0.910	0.7994	57.28	1.5041	5
0.001	0.8235	107.2		5
0.910	0.8241	57.26	1.5038	5
0.001	0.8484	107.1		5
0.913	0.8489	57.23	1.5033	5
0.001	0.8732	107.0		5
0.910	0.8737	57.21	1.5029	5
0.001	0.8979	107.7		5
0.908	0.8982	57.19	1.5023	5
0.001	0.9225	108.1		5
0.914	0.9230	57.16	1.5020	5

(ON=压缩机通电,OFF=压缩机断电,xON=化霜加热器通电,xOFF=化霜加热器断电)
(max=状态变化之冷冻室最热点时刻,min=状态变化之冷冻室最冷点时刻)
(Fmax=冷冻室最热点,Fmin=冷冻室最冷点,t=化霜开始冷冻室最热点等于-18℃时刻)
(ton=化霜室t10,t11,t12最冷点的平均值,t=ton值与上一状态平均值的再平均值)
(toff=化霜室t10,t11,t12最冷点的平均值,t=toff值与上一状态平均值的再平均值)
(xmax=化霜开始冷冻室最热点时刻)

0.906	0.5023	57.36	1.5101	5
0.001	0.5270	107.7		5
0.908	0.5275	57.52	1.5095	5
0.001	0.5521	107.6		5
0.910	0.5526	57.50	1.5094	5
0.000	0.5769	107.2		5
0.911	0.5773	57.47	1.5088	5
0.001	0.6010	107.6		5
0.911	0.6021	57.44	1.5082	5
0.001	0.6265	107.5		5
0.909	0.6270	57.42	1.5079	5
0.001	0.6512	107.6		5
0.910	0.6517	57.39	1.5074	5
0.001	0.6757	107.5		5
0.906	0.6761	57.36	1.5065	5
0.000	0.7004	107.5		5
0.911	0.7008	57.35	1.5061	5
0.000	0.7250	107.1		5
0.905	0.7253	57.34	1.5055	5
0.000	0.7494	107.2		5
0.910	0.7498	57.32	1.5048	5
0.001	0.7741	107.7		5
0.914	0.7746	57.29	1.5045	5
0.001	0.7994	107.1		5
0.910	0.7994	57.28	1.5041	5
0.001	0.8235	107.2		5
0.910	0.8241	57.26	1.5038	5
0.001	0.8484	107.1		5
0.913	0.8489	57.23	1.5033	5
0.001	0.8732	107.0		5
0.910	0.8737	57.21	1.5029	5
0.001	0.8979	107.7		5
0.908	0.8982	57.19	1.5023	5
0.001	0.9225	108.1		5
0.914	0.9230	57.16	1.5020	5

(ON=压缩机通电,OFF=压缩机断电,xON=化霜加热器通电,xOFF=化霜加热器断电)
(max=状态变化之冷冻室最热点时刻,min=状态变化之冷冻室最冷点时刻)
(Fmax=冷冻室最热点,Fmin=冷冻室最冷点,t=化霜开始冷冻室最热点等于-18℃时刻)
(ton=化霜室t10,t11,t12最冷点的平均值,t=ton值与上一状态平均值的再平均值)
(toff=化霜室t10,t11,t12最冷点的平均值,t=toff值与上一状态平均值的再平均值)
(xmax=化霜开始冷冻室最热点时刻)

制表时间:1998-12-19 7:35:23

NO:2
试验内容:储藏温度
直冷型冰箱
机型号:BD-166(R134a)
型号:HE1350T.66*2100 150
厂号:3270%
温控器位置:值=3
温度条件:

冷冻室:-21.9℃ 霜温点数:8 (t1, t2, t3, t4, t5, t6, t7, t8,)

格式1 汇总表

冷冻室	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流	电能1	功率	系数	电能2	时间
-----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	----	-----	----	----	-----	----

10:1
 内容: 储藏温度
 直冷型冰柜
 机号: BD-108(R134a)
 型号: AEI350Y.00x2100 140
 向: 32.70%
 温控器位置: On值=3
 温度条件:

WP F30

冷室: -21.9℃ 测温点: t1, t2, t3, t4, t5, t6, ...

格式 1 汇总表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (kWh)	功率 (W)	系数 (%)	电能2 (kWh/24h)	ΔT 秒	
OFF	7:10:20	-21.93	-22.90	-22.24	-22.24	-22.02	-22.85											0.000	0.0029				3	1502
ON	8:08:00	-16.85	-17.44	-18.10	-17.97	-17.22	-17.30											0.903	0.0033				3	268
OFF	8:12:36	-15.93	-16.55	-17.21	-17.24	-16.53	-16.89											0.001	0.0127	125.0	17.07	0.5555	3	373
ON	8:22:19	-15.53	-16.48	-16.75	-16.72	-16.35	-16.53											0.937	0.0130				3	273
OFF	8:20:42	-15.58	-16.49	-16.46	-16.47	-16.62	-16.47											0.000	0.0223	125.0	22.33	0.7031	3	539
ON	8:36:11	-15.35	-16.25	-16.45	-16.40	-16.09	-16.31											0.906	0.0230				3	539
OFF	8:40:54	-15.33	-16.22	-16.09	-16.12	-15.70	-16.20											0.000	0.0331	124.1	25.52	0.7971	3	293
ON	8:49:57	-15.18	-16.05	-16.22	-16.16	-15.88	-16.12											0.904	0.0336				3	543
OFF	8:54:48	-15.20	-16.23	-16.08	-16.01	-15.82	-16.17											0.005	0.0457	124.9	27.43	0.8587	3	201
ON	9:3:47	-15.11	-16.08	-16.20	-16.14	-15.87	-16.11											0.972	0.0442				3	539
OFF	9:6:41	-15.17	-16.15	-15.91	-15.93	-15.82	-16.11											0.000	0.0545	127.0	26.75	0.9034	3	294
ON	9:17:37	-15.02	-15.83	-16.07	-16.00	-15.69	-15.96											0.967	0.0550				3	536
OFF	9:22:32	-15.12	-16.14	-15.90	-15.94	-15.55	-16.05											0.000	0.0653	126.7	29.73	0.9571	3	293
ON	9:31:31	-14.91	-15.81	-15.96	-15.94	-15.64	-15.92											0.970	0.0659				3	539
OFF	9:30:32	-15.03	-15.96	-15.75	-15.77	-15.36	-15.93											0.000	0.0765	126.2	30.50	0.9618	3	301
ON	9:45:20	-14.96	-15.90	-16.05	-15.97	-15.70	-15.96											0.971	0.0703				3	534
OFF	9:50:27	-15.06	-16.01	-15.78	-15.79	-15.38	-15.98											0.000	0.0875	126.2	31.12	0.9517	3	301
ON	9:59:25	-14.87	-15.61	-15.95	-15.90	-15.60	-15.88											0.975	0.0880				3	536
OFF	10:4:23	-14.98	-15.94	-15.72	-15.73	-15.33	-15.80											0.000	0.0955	126.0	31.58	0.9373	3	293
ON	10:13:21	-14.86	-15.80	-15.83	-15.88	-15.57	-15.84											0.973	0.0991				3	538
OFF	10:18:16	-14.98	-15.95	-15.76	-15.78	-15.30	-15.92											0.002	0.1093	126.5	31.93	1.0108	3	293
ON	10:27:16	-14.86	-15.77	-15.82	-15.85	-15.57	-15.83											0.962	0.1106				3	540
OFF	10:32:11	-15.00	-15.97	-15.73	-15.73	-15.33	-15.90											0.001	0.1263	125.0	32.22	1.0133	3	293
ON	10:41:14	-14.84	-15.74	-15.91	-15.84	-15.54	-15.81											0.970	0.1267				3	543
OFF	10:46:12	-14.83	-15.85	-15.67	-15.67	-15.27	-15.85											0.000	0.1312	127.3	32.47	1.0273	3	286
ON	10:54:43	-14.96	-15.86	-15.97	-15.85	-15.60	-15.83											0.967	0.1315				3	537
OFF	10:53:46	-14.99	-15.88	-15.72	-15.73	-15.31	-15.94											0.000	0.1423	126.6	32.75	1.0357	3	297
ON	11:6:43	-14.71	-15.68	-15.83	-15.77	-15.48	-15.76											0.973	0.1423				3	533
OFF	11:13:44	-14.91	-15.88	-15.67	-15.66	-15.26	-15.85											0.003	0.1529	127.5	32.62	1.0426	3	293
ON	11:22:28	-14.73	-15.71	-15.87	-15.86	-15.60	-15.80											0.968	0.1634				3	544
OFF	11:27:19	-14.91	-15.90	-15.70	-15.76	-15.34	-15.83											0.000	0.1657	127.3	33.65	1.0481	3	281

xxxxxx
 1998-12-19 11:58:49 (Fmax)=-14.71℃
 每两箱霜 (ton)=88.60℃ (toff)=88.80℃ (tm)=88.60℃ (ton=或截至t10, t11, t12最冷点的平均值, tn=toff值与上一状态平均值的再平均值)
 每两箱霜 (ton)=88.60℃ (toff)=88.80℃ (tm)=88.60℃ (ton=或截至t10, t11, t12最冷点的平均值, tn=toff值与上一状态平均值的再平均值)
 耗电=1.0181 (kWh/24h)
 电流=0.910 (A)
 (ON=压缩机通电, OFF=压缩机断电, non=化霜加热通电, xoff=化霜加热断电)
 (max=状态变化之制冷速度最热点时刻, min=状态变化之制冷速度最冷点时刻)
 (Fmax=制冷速度最热点, Fmin=制冷速度最冷点, d=化霜开始制冷速度最热点等于-16℃时刻)

直冷型冰箱
 型号:BD-168(R134a)
 型号:AE1350Y.66*2100 140
 方向:32/70%
 温控器位置:Ch值=1
 温度条件:

冷冻室:-21.9 °C 测温点数:0(t1, t2, t3, t4, t5, t6,)

格式 1 汇总表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (kWh)	功率 (W)	系数 (%)	电能2 (kWh/24h)	△T 秒
ON	11:45:25	-12.15	-13.12	-13.67	-13.61	-13.01	-13.21											1.010	0.0004				194
OFF	11:48:39	-11.85	-12.84	-13.10	-13.19	-12.52	-12.81											0.000	0.0079	138.4	26.40	0.8213	685
ON	11:59:14	-11.45	-12.34	-12.65	-12.63	-12.27	-12.47											1.013	0.0083				199
OFF	12:2:33	-11.23	-12.10	-12.25	-12.27	-11.80	-12.11											0.000	0.0160	138.4	24.24	0.8587	583
ON	12:12:26	-11.21	-12.09	-12.30	-12.26	-11.96	-12.16											1.012	0.0160				199
OFF	12:15:45	-11.00	-11.94	-11.99	-12.00	-11.59	-11.98											0.002	0.0242	138.0	24.65	0.8730	582
ON	12:25:27	-11.10	-11.98	-12.10	-12.11	-11.84	-12.08											1.014	0.0247				204
OFF	12:28:51	-10.89	-11.86	-11.83	-11.87	-11.48	-11.90											0.000	0.0325	135.9	25.08	0.8831	588
ON	12:38:19	-11.02	-11.90	-12.03	-11.97	-11.69	-11.94											1.013	0.0329				208
OFF	12:41:47	-10.93	-11.91	-11.85	-11.87	-11.49	-11.93											0.001	0.0403	136.0	25.42	0.8931	567
ON	12:51:14	-10.96	-11.90	-12.06	-12.00	-11.72	-11.95											1.013	0.0414				204
OFF	12:54:38	-10.91	-11.84	-11.77	-11.76	-11.35	-11.79											0.002	0.0492	138.7	25.60	0.9004	566
ON	13:4:4	-10.92	-11.84	-12.00	-11.94	-11.56	-11.89											1.017	0.0490				209
OFF	13:7:39	-10.80	-11.78	-11.74	-11.77	-11.38	-11.81											0.000	0.0570	137.1	25.83	0.9073	567
ON	13:16:50	-10.83	-11.77	-11.92	-11.86	-11.59	-11.84											1.015	0.0580				208
OFF	13:20:18	-10.80	-11.75	-11.69	-11.69	-11.29	-11.72											0.002	0.0660	130.4	25.96	0.9162	561
ON	13:29:39	-10.82	-11.70	-11.86	-11.80	-11.52	-11.78											1.016	0.0665				203
OFF	13:33:2	-10.82	-11.74	-11.70	-11.71	-11.32	-11.74											0.002	0.0744	139.9	26.04	0.9167	562
ON	13:42:24	-10.81	-11.67	-11.81	-11.75	-11.40	-11.72											1.015	0.0749				205
OFF	13:45:49	-10.72	-11.67	-11.62	-11.62	-11.20	-11.60											0.003	0.0827	137.3	26.14	0.9202	563
ON	13:55:2	-10.77	-11.67	-11.83	-11.80	-11.50	-11.75											1.018	0.0833				204
OFF	13:58:26	-10.71	-11.68	-11.60	-11.58	-11.17	-11.62											0.002	0.0911	138.5	26.19	0.9214	560
ON	14:7:40	-10.80	-11.70	-11.83	-11.76	-11.44	-11.68											1.016	0.0915				210
OFF	14:11:10	-10.70	-11.67	-11.61	-11.61	-11.21	-11.65											0.001	0.0995	137.1			

ON=压缩机通电, OFF=压缩机断电, kon=化霜加热强通电, *off=化霜制热强断电
 (max=状态变化之向冷冻室最热点时刻, min=状态变化之向冷冻室最冷点时刻)
 (fmax=冷冻室最热点, fmin=冷冻室最冷点, d=化霜开始冷冻室最热点等于-18°C时刻)
 (t10, t11, t12最热点的平均值, t1, t2, t3, t4, t5, t6, t7, t8, t9, t10, t11, t12最冷点的平均值, tn=toff值与上一状态平均值的再平均值)
 (toff=化霜开始冷冻室最热点时刻)
 (*max=化霜开始冷冻室最热点时刻)

制表时间:1998-12-19 14:13:37

NO:2
 试验内容:储藏温度
 直冷型冰箱
 机型:BD-168(R134a)
 型号:AE1350Y.66*2100 150
 方向:32/70%
 温控器位置:Ch值=1
 温度条件:

冷冻室:-21.9 °C 测温点数:8(t1, t2, t3, t4, t5, t6, t7, t8,)

10:1
 试验内容: 霜或温度
 直冷型冰箱
 机型号: BD-168(R134a)
 型号: K21301, 60x2100-140
 方向: 32° 70%
 温控器位置: 5
 温度等级:

冷冻室: -21.9 °C 测温点数: 6 (t1, t2, t3, t4, t5, t6,)

格式 1 汇总表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (kWh)	功率 (W)	系数 (%)	电能2 (kWh/24h)	Cn	ΔT 秒	
1998-12-18																									
ON	16:50:27	-21.12	-22.18	-22.57	-22.50	-22.01	-22.29											0.907	0.0604	107.4	39.49	1.5365	5	887	
OFF	17:5:14	-23.01	-24.06	-23.27	-23.23	-23.06	-24.01											0.908	0.0209	107.4			5	604	
ON	17:15:18	-21.14	-22.17	-22.57	-22.52	-22.04	-22.32											0.900	0.0272	107.0	58.65	1.5388	5	838	
OFF	17:23:16	-22.89	-23.90	-23.14	-23.12	-22.95	-23.79											0.900	0.0522	107.0			5	602	
ON	17:35:18	-21.05	-22.08	-22.45	-22.36	-21.92	-22.17											0.903	0.0526	107.9	58.47	1.5388	5	829	
OFF	17:53:7	-22.84	-23.84	-23.08	-23.06	-22.90	-23.79											0.913	0.0775	107.9			5	608	
ON	18:34:15	-21.05	-22.08	-22.45	-22.37	-21.91	-22.15											0.900	0.0779	107.2	58.43	1.5388	5	808	
OFF	18:17:8	-22.85	-23.85	-23.09	-23.09	-22.96	-23.84											0.908	0.1027	107.9			5	608	
ON	18:27:4	-21.13	-22.12	-22.51	-22.43	-21.98	-22.20											0.901	0.1031	107.9	58.23	1.5272	5	822	
OFF	18:40:55	-22.84	-23.85	-23.03	-23.05	-22.89	-23.60											0.911	0.1284	107.9			5	603	
ON	18:50:58	-21.04	-22.07	-22.43	-22.40	-21.95	-22.21											0.906	0.1530	107.9	58.23	1.5272	5	822	
OFF	19:4:40	-22.79	-23.81	-23.02	-22.93	-22.72	-23.60											0.906	0.1584	107.9			5	603	
ON	19:14:43	-20.85	-21.89	-22.25	-22.18	-21.73	-22.01											0.903	0.1781	107.9	58.21	1.5263	5	828	
OFF	19:28:31	-22.77	-23.83	-23.07	-23.09	-22.95	-23.86											0.909	0.1785	107.9			5	597	
ON	19:38:28	-20.92	-22.00	-22.36	-22.28	-21.83	-22.11											0.900	0.2029	107.9	58.12	1.5258	5	815	
OFF	19:52:13	-22.72	-23.74	-22.97	-22.94	-22.77	-23.68											0.908	0.2034	107.9			5	602	
ON	20:2:15	-20.81	-21.85	-22.19	-22.14	-21.68	-21.95											0.900	0.2277	107.9	58.00	1.5248	5	809	
OFF	20:15:34	-22.72	-23.78	-22.97	-22.96	-22.77	-23.63											0.915	0.2281	107.9			5	597	
ON	20:25:31	-21.02	-22.03	-22.40	-22.33	-21.90	-22.17											0.902	0.2523	107.8	58.00	1.5236	5	806	
OFF	20:38:57	-22.74	-23.78	-22.99	-22.98	-22.75	-23.63											0.912	0.2526	107.6			5	596	
ON	20:48:53	-21.02	-22.02	-22.40	-22.34	-21.90	-22.17											0.904	0.2774	107.6	57.95	1.5220	5	814	
OFF	21:2:27	-22.83	-23.86	-23.06	-22.96	-22.78	-23.72											0.901	0.3015	107.1	57.87	1.5193	5	810	
ON	21:12:52	-21.02	-22.03	-22.39	-22.30	-21.86	-22.10											0.903	0.3019	107.1			5	611	
OFF	21:26:23	-22.74	-23.75	-22.96	-22.97	-22.81	-23.72											0.901	0.3265	107.2	57.81	1.5170	5	823	
ON	21:36:13	-20.91	-21.96	-22.34	-22.29	-21.83	-22.08											0.909	0.3269	107.2			5	619	
OFF	21:49:58	-22.70	-23.77	-23.00	-22.98	-22.83	-23.74											0.909	0.3269	107.2			5	821	
ON	22:0:17	-20.88	-21.90	-22.26	-22.19	-21.72	-21.99											0.901	0.3514	107.0	57.75	1.5160	5	819	
OFF	22:13:58	-22.70	-23.72	-22.95	-22.92	-22.76	-23.69											0.913	0.3518	107.0			5	619	
ON	22:24:17	-20.88	-21.89	-22.31	-22.25	-21.78	-22.00											0.901	0.3768	107.5	57.71	1.5149	5	834	
OFF	22:38:11	-22.78	-23.82	-23.04	-23.02	-22.86	-23.70											0.908	0.3772	107.5			5	625	
ON	22:48:36	-20.86	-21.83	-22.31	-22.26	-21.78	-22.03											0.900	0.4018	107.1	57.69	1.5137	5	829	
OFF	23:2:25	-22.72	-23.77	-22.95	-22.94	-22.76	-23.67											0.907	0.4022	107.1			5	615	
ON	23:12:43	-20.85	-21.84	-22.25	-22.19	-21.74	-22.00											0.900	0.4267	107.2	57.66	1.5130	5	823	
OFF	23:26:26	-22.67	-23.64	-22.88	-22.88	-22.70	-23.57											0.912	0.4272	107.2			5	613	
ON	23:36:39	-20.87	-21.86	-22.24	-22.15	-21.71	-21.97											0.901	0.4517	107.5	57.61	1.5119	5	826	
OFF	23:50:19	-22.67	-23.63	-22.82	-22.89	-22.72	-23.57											0.913	0.4522	107.5			5	627	
ON	1998-12-19	-20.83	-21.88	-22.27	-22.22	-21.72	-21.98											0.900	0.4770	107.0	57.61	1.5119	5	833	

5-10 min

OFF 0:38:34 -22.00 -23.78 -22.94 -22.92 -22.78 -23.63
ON 0:49:2 -20.79 -21.81 -22.20 -22.14 -21.68 -21.92
OFF 1:2:47 -22.64 -23.03 -22.84 -22.81 -22.70 -23.57
ON 1:13:10 -20.70 -21.78 -22.15 -22.10 -21.64 -21.91
OFF 1:20:53 -22.68 -23.60 -22.89 -22.88 -22.75 -23.59
ON 1:37:17 -20.87 -21.91 -22.27 -22.18 -21.73 -21.98
OFF 1:50:49 -22.00 -23.64 -22.89 -22.91 -22.77 -23.63
ON 2:1:4 -20.60 -21.88 -22.29 -22.21 -21.74 -21.96
OFF 2:14:35 -22.61 -23.08 -22.80 -22.85 -22.67 -23.58
ON 2:24:50 -20.84 -21.86 -22.25 -22.18 -21.72 -21.96
OFF 2:38:33 -22.69 -23.71 -22.94 -22.86 -22.74 -23.64
ON 2:48:51 -20.80 -21.91 -22.28 -22.24 -21.76 -22.01
OFF 3:2:22 -22.62 -23.09 -22.83 -22.80 -22.70 -23.57
ON 3:12:40 -20.82 -21.84 -22.23 -22.17 -21.70 -21.94
OFF 3:20:4 -22.64 -23.07 -22.83 -22.82 -22.72 -23.63
ON 3:36:21 -20.76 -21.81 -22.16 -22.10 -21.64 -21.89
OFF 3:49:53 -22.61 -23.60 -22.84 -22.82 -22.67 -23.56
ON 4:0:9 -20.82 -21.83 -22.19 -22.16 -21.71 -21.97
OFF 4:13:41 -22.58 -23.60 -22.80 -22.78 -22.60 -23.51
ON 4:23:53 -20.80 -21.84 -22.19 -22.11 -21.60 -21.95
OFF 4:37:19 -22.00 -23.61 -22.85 -22.85 -22.72 -23.50
ON 4:47:34 -20.85 -21.81 -22.16 -22.12 -21.69 -21.94
OFF 5:1:5 -22.61 -23.62 -22.84 -22.82 -22.65 -23.56
ON 5:11:23 -20.76 -21.76 -22.14 -22.03 -21.64 -21.91
OFF 5:25:7 -22.57 -23.50 -22.79 -22.78 -22.63 -23.53
ON 5:35:24 -20.79 -21.79 -22.15 -22.05 -21.61 -21.85
OFF 5:48:54 -22.64 -23.60 -22.82 -22.86 -22.73 -23.56
ON 5:59:16 -20.71 -21.72 -22.07 -22.10 -21.60 -21.87
OFF 6:12:47 -22.61 -23.62 -22.80 -22.83 -22.66 -23.53
ON 6:23:10 -20.70 -21.73 -22.12 -22.05 -21.58 -21.82
OFF 6:36:48 -22.61 -23.61 -22.82 -22.78 -22.61 -23.53
ON 6:47:18 -20.71 -21.70 -22.10 -22.01 -21.57 -21.85
OFF 7:0:40 -22.54 -23.50 -22.78 -22.78 -22.64 -23.53
ON 7:11:4 -20.60 -21.60 -22.04 -22.00 -21.57 -21.84
OFF 7:24:38 -22.49 -23.49 -22.74 -22.72 -22.58 -23.46
ON 7:35:11 -20.73 -21.74 -22.12 -22.02 -21.55 -21.81

XX
1998-12-19 7:11:4 (Fmax)=-20.60 °C
舌叉压缩机霜层厚度(Fmin)=-24.60 °C
霜层厚度 (tcn) =38.80 °C (tm)=36.80 °C (top)=38.80 °C (tp)=38.80 °C
(toff)=66.80 (A)
电流=0.914
耗电量=1.5020 (kWh/24h)

制表时间:1998-12-19 7:35:25

NO.2
试验内容:储藏温度
直冷型冰箱
机型:50-168(R134a)
型号:AE1350T-60*2100-150
方向:32°70'
温控器位置:0值=5
温度条件:
冷冻室:-21.9 °C 调温点致:3(t1, t2, t3, t4, t5, t6, t7, t8,)

0.906	0.3023	57.56	1.5101	5	628
0.001	0.5270	107.7		5	825
0.908	0.5275	57.52	1.5095	5	829
0.001	0.5521	107.6		5	823
0.910	0.5520	57.50	1.5094	5	618
0.090	0.5709	107.2		5	812
0.911	0.5773	57.47	1.5088	5	615
0.001	0.6016	107.6		5	811
0.911	0.6021	57.44	1.5082	5	621
0.001	0.6265	107.5		5	817
0.909	0.6270	57.42	1.5079	5	618
0.001	0.6512	107.6		5	811
0.910	0.6517	57.39	1.5074	5	618
0.001	0.6757	107.5		5	804
0.906	0.6761	57.36	1.5065	5	617
0.000	0.7004	107.5		5	812
0.911	0.7008	57.35	1.5061	5	616
0.000	0.7250	107.1		5	812
0.905	0.7253	57.34	1.5055	5	612
0.000	0.7494	107.2		5	800
0.910	0.7498	57.32	1.5048	5	615
0.001	0.7741	107.7		5	811
0.914	0.7746	57.29	1.5045	5	624
0.001	0.7990	107.1		5	818
0.910	0.7994	57.28	1.5041	5	617
0.001	0.8235	107.2		5	810
0.910	0.8241	57.26	1.5038	5	622
0.001	0.8484	107.1		5	811
0.913	0.8483	57.23	1.5033	5	623
0.001	0.8732	107.6		5	812
0.910	0.8737	57.21	1.5029	5	625
0.001	0.8979	107.7		5	807
0.908	0.8982	57.19	1.5023	5	624
0.001	0.9225	108.1		5	809
0.914	0.9230	57.16	1.5020	5	623

(ON=压缩机通电,压缩机启动,OFF=压缩机断电,TON=压缩机通电,TOFF=压缩机断电)
(max=状态变化之前冷冻室最热点时刻,min=状态变化之后冷冻室最冷点时刻)
(Fmax=冷冻室最热点,Fmin=冷冻室最冷点,d=开始冷冻室最热点等于-18°C时刻)
(top=冷冻室平均温度,t1,t2最热点的平均值,tm=ton值与上一状态平均值的再平均值)
(tp=冷冻室平均温度,t1,t2最冷点的平均值,toff=ton值与上一状态平均值的再平均值)
(Amax=压缩机开始冷冻室最热点时刻)

1300-12-10

OFF	16:50:12	-25.28	-25.31	-25.33	-25.38	-25.44	-25.82	-25.38
ON	17:00:25	-23.20	-23.03	-23.18	-23.04	-23.49	-22.95	-23.25
OFF	17:24:09	-24.39	-25.00	-25.05	-25.11	-25.05	-25.51	-25.04
ON	17:34:02	-23.24	-23.12	-23.19	-23.10	-23.54	-23.01	-23.32
OFF	17:51:06	-25.08	-23.12	-25.10	-25.59	-25.15	-25.08	-25.52
ON	18:11:25	-23.15	-22.90	-23.00	-22.97	-23.30	-22.78	-23.09
OFF	18:18:34	-24.90	-21.97	-25.01	-25.47	-25.05	-25.00	-25.51
ON	18:28:52	-23.16	-23.00	-23.05	-22.82	-23.28	-22.70	-23.08
OFF	18:45:31	-24.89	-24.59	-24.50	-25.47	-25.00	-24.59	-24.90
ON	18:55:30	-23.39	-23.24	-23.30	-23.20	-23.57	-23.03	-23.10
OFF	19:11:45	-24.80	-24.82	-24.85	-25.35	-24.90	-24.80	-24.88
ON	19:21:55	-22.95	-22.84	-22.92	-22.80	-23.22	-22.75	-23.05
OFF	19:38:12	-24.71	-24.80	-24.77	-25.26	-24.82	-24.72	-24.66
ON	19:48:13	-23.23	-23.10	-23.16	-23.05	-23.41	-22.87	-23.18
OFF	20:14:20	-24.79	-24.88	-24.89	-25.33	-24.92	-24.83	-24.76
ON	20:14:23	-23.12	-22.90	-23.05	-22.90	-23.30	-22.83	-22.90
OFF	20:30:11	-24.60	-24.64	-24.60	-25.14	-24.75	-24.68	-24.64
ON	20:40:24	-23.01	-22.87	-22.95	-22.88	-23.24	-22.71	-23.07
OFF	20:56:28	-24.67	-24.73	-24.63	-25.13	-24.75	-24.64	-24.61
ON	21:06:35	-23.00	-22.89	-22.95	-22.87	-23.25	-22.75	-23.10
OFF	21:22:27	-24.59	-24.66	-24.68	-25.13	-24.72	-24.67	-24.60
ON	21:32:33	-22.92	-22.85	-22.92	-22.83	-23.19	-22.68	-23.00
OFF	21:48:22	-24.55	-24.57	-24.57	-25.15	-24.58	-24.63	-24.50
ON	21:58:34	-22.92	-22.77	-22.84	-22.75	-23.11	-22.61	-22.90
OFF	22:14:25	-24.60	-24.68	-24.60	-25.10	-24.70	-24.65	-24.63
ON	22:24:34	-22.94	-22.79	-22.84	-22.75	-23.14	-22.64	-22.70
OFF	22:40:21	-24.57	-24.64	-24.64	-25.12	-24.70	-24.60	-24.62
ON	22:50:19	-23.01	-22.90	-22.97	-22.87	-23.27	-22.75	-23.04
OFF	23:05:49	-24.60	-24.64	-24.65	-25.13	-24.67	-24.63	-24.61
ON	23:16:02	-22.91	-22.78	-22.80	-22.70	-23.15	-22.61	-22.71
OFF	23:31:43	-24.56	-24.63	-24.63	-25.13	-24.63	-24.62	-24.59
ON	23:41:57	-22.87	-22.72	-22.75	-22.71	-23.10	-22.59	-22.65
OFF	23:57:36	-24.53	-24.61	-24.64	-25.11	-24.63	-24.59	-24.53

1308-12-18

ON	0:57:35	-22.83	-22.80	-22.97	-22.88	-23.20	-22.74	-23.01
OFF	1:03:10	-24.54	-24.00	-24.00	-25.10	-24.03	-24.58	-24.50
ON	1:08:22	-23.02	-22.92	-22.98	-22.80	-23.25	-22.70	-22.82
OFF	1:13:27	-24.50	-24.57	-24.61	-25.09	-24.07	-24.59	-24.53
ON	1:18:24	-23.00	-22.85	-22.93	-22.87	-23.23	-22.74	-23.05
OFF	1:23:40	-24.54	-24.62	-24.59	-25.12	-24.08	-24.59	-24.57
ON	1:28:30	-23.01	-22.86	-22.93	-22.85	-23.19	-22.68	-23.01
OFF	1:33:30	-24.61	-24.67	-24.60	-25.17	-24.72	-24.53	-24.60
ON	1:38:28	-23.02	-22.90	-23.01	-22.89	-23.25	-22.70	-23.05
OFF	1:43:52	-24.52	-24.59	-24.50	-25.05	-24.00	-24.59	-24.50
ON	1:48:00	-22.93	-22.79	-22.83	-22.79	-23.14	-22.62	-22.72
OFF	1:53:40	-24.49	-24.57	-24.58	-25.07	-24.03	-24.50	-24.50
ON	1:58:54	-22.92	-22.72	-22.80	-22.72	-23.11	-22.50	-22.63
OFF	2:03:51	-24.52	-24.50	-24.50	-25.00	-24.04	-24.55	-24.57
ON	2:08:20	-22.88	-22.83	-22.90	-22.82	-23.17	-22.68	-22.73
OFF	2:13:45	-24.45	-24.53	-24.52	-25.02	-24.50	-24.55	-24.51
ON	2:18:52	-22.84	-22.72	-22.75	-22.69	-23.07	-22.55	-22.62
OFF	2:23:23	-24.45	-24.53	-24.51	-25.03	-24.58	-24.51	-24.40
ON	2:28:17	-22.83	-22.75	-22.85	-22.73	-23.15	-22.60	-22.72
OFF	2:33:41	-24.47	-24.52	-24.53	-25.03	-24.01	-24.54	-24.54
ON	2:38:58	-22.93	-22.80	-22.80	-22.78	-23.12	-22.61	-22.70
OFF	2:43:53	-24.45	-24.53	-24.51	-25.02	-24.55	-24.52	-24.45
ON	2:48:50	-22.90	-22.79	-22.84	-22.78	-23.12	-22.65	-22.73
OFF	2:53:15	-24.48	-24.54	-24.53	-25.02	-24.01	-24.54	-24.53
ON	2:58:11	-22.91	-22.79	-22.90	-22.80	-23.10	-22.64	-22.78
OFF	3:03:48	-24.52	-24.60	-24.58	-25.07	-24.00	-24.57	-24.53
ON	3:08:44	-22.95	-22.85	-22.92	-22.76	-23.10	-22.65	-22.70
OFF	3:13:51	-24.45	-24.47	-24.43	-24.33	-24.40	-24.35	-24.45
ON	3:18:51	-22.92	-22.83	-22.92	-22.82	-23.13	-22.69	-22.80
OFF	3:23:53	-24.42	-24.50	-24.49	-24.37	-24.47	-24.43	-24.45

0.000	0.026	0.052	0.078	0.104	0.130	0.156	0.182	0.208
0.001	0.052	0.104	0.156	0.208	0.260	0.312	0.364	0.416
0.002	0.104	0.208	0.312	0.416	0.520	0.624	0.728	0.832
0.003	0.156	0.312	0.468	0.624	0.780	0.936	1.092	1.248
0.004	0.208	0.416	0.624	0.832	1.040	1.248	1.456	1.664
0.005	0.260	0.520	0.780	1.040	1.300	1.560	1.820	2.080
0.006	0.312	0.624	0.936	1.248	1.560	1.820	2.080	2.340
0.007	0.364	0.728	1.092	1.456	1.820	2.184	2.548	2.912
0.008	0.416	0.832	1.248	1.664	2.184	2.548	2.912	3.276
0.009	0.468	0.936	1.456	1.820	2.340	2.704	3.068	3.432
0.010	0.520	1.040	1.664	2.080	2.548	2.912	3.276	3.640
0.011	0.572	1.144	1.820	2.340	2.704	3.068	3.432	3.796
0.012	0.624	1.248	2.080	2.548	2.912	3.276	3.640	3.952
0.013	0.676	1.352	2.340	2.704	3.068	3.432	3.796	4.108
0.014	0.728	1.456	2.548	2.912	3.276	3.640	3.952	4.264
0.015	0.780	1.560	2.704	3.068	3.432	3.796	4.108	4.420
0.016	0.832	1.664	2.912	3.276	3.640	3.952	4.264	4.576
0.017	0.884	1.768	3.068	3.432	3.796	4.108	4.420	4.732
0.018	0.936	1.872	3.276	3.640	3.952	4.264	4.576	4.888
0.019	0.988	1.976	3.432	3.796	4.108	4.420	4.732	5.044
0.020	1.040	2.080	3.640	3.952	4.264	4.576	4.888	5.200
0.021	1.092	2.184	3.848	4.108	4.420	4.732	5.044	5.356
0.022	1.144	2.288	4.016	4.264	4.576	4.888	5.200	5.512
0.023	1.196	2.392	4.184	4.420	4.732	5.044	5.356	5.668
0.024	1.248	2.496	4.352	4.576	4.888	5.200	5.512	5.824
0.025	1.300	2.600	4.520	4.732	5.044	5.356	5.668	5.980
0.026	1.352	2.704	4.688	4.888	5.200	5.512	5.824	6.136
0.027	1.404	2.808	4.856	5.044	5.356	5.668	5.980	6.292
0.028	1.456	2.912	5.024	5.200	5.512	5.824	6.136	6.448
0.029	1.508	3.016	5.192	5.356	5.668	5.980	6.292	6.604
0.030	1.560	3.120	5.360	5.512	5.824	6.136	6.448	6.760
0.031	1.612	3.224	5.528	5.668	5.980	6.292	6.604	6.916
0.032	1.664	3.328	5.696	5.824	6.136	6.448	6.760	7.072
0.033	1.716	3.432	5.864	5.980	6.292	6.604	6.916	7.228
0.034	1.768	3.536	6.032	6.136	6.448	6.760	7.072	7.384
0.035	1.820	3.640	6.200	6.292	6.604	6.916	7.228	7.540
0.036	1.872	3.744	6.368	6.448	6.760	7.072	7.384	7.696
0.037	1.924	3.848	6.536	6.604	6.916	7.228	7.540	7.852
0.038	1.976	3.952	6.704	6.760	7.072	7.384	7.696	8.008
0.039	2.028	4.056	6.872	6.916	7.228	7.540	7.852	8.164
0.040	2.080	4.160	7.040	7.072	7.384	7.696	8.008	8.320
0.041	2.132	4.264	7.208	7.228	7.540	7.852	8.164	8.476
0.042	2.184	4.368	7.376	7.384	7.696	8.008	8.320	8.632
0.043	2.236	4.472	7.544	7.540	7.852	8.164	8.476	8.788
0.044	2.288	4.576	7.712	7.696	8.008	8.320	8.632	8.944
0.045	2.340	4.680	7.880	7.852	8.164	8.476	8.788	9.100
0.046	2.392	4.784	8.048	8.008	8.320	8.632	8.944	9.256
0.047	2.444	4.888	8.216	8.164	8.476	8.788	9.100	9.412
0.048	2.496	4.992	8.384	8.320	8.632	8.944	9.256	9.568
0.049	2.548	5.096	8.552	8.476	8.788	9.100	9.412	9.724
0.050	2.600	5.200	8.720	8.632	8.944	9.256	9.568	9.880

0.000	0.026	0.052	0.078	0.104	0.130	0.156	0.182	0.208
0.001	0.052	0.104	0.156	0.208	0.260	0.312	0.364	0.416
0.002	0.104	0.208	0.312	0.416	0.520	0.624	0.728	0.832
0.003	0.156	0.312	0.468	0.624	0.780	0.936	1.092	1.248
0.004	0.208	0.416	0.624	0.832	1.040	1.248	1.456	1.664
0.005	0.260	0.520	0.780	1.040	1.300	1.560	1.820	2.080
0.006	0.312	0.624	0.936	1.248	1.560	1.820	2.080	2.340
0.007	0.364	0.728	1.092	1.456	1.820	2.184	2.548	2.912
0.008	0.416	0.832	1.248	1.664	2.184	2.548	2.912	3.276
0.009	0.468	0.936	1.456	1.820	2.340	2.704	3.068	3.432
0.010	0.520	1.040	1.664	2.080	2.548	2.912	3.276	3.640
0.011	0.572	1.144	1.820	2.340	2.704	3.068	3.432	3.796
0.012	0.624	1.248	2.080	2.548	2.912	3.276	3.640	3.952
0.013	0.676	1.352	2.340	2.704	3.068	3.432	3.796	4.108
0.014	0.728	1.456	2.548	2.912	3.276	3.640	3	

室内: 抽成温度
 型号: AF1356V .66x2100 150
 向: 32.70%
 控制位置: On值=3
 温度: 21.5 °C (温度点: t1, t2, t3, t4, t5, t6, t7, t8, t9, t10, t11, t12, t13, t14, t15, t16, t17, t18, t19, t20)

格式 1- 汇总表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电耗1 (kWh)	功率 (W)	系数 (%)	电耗2 (kWh/24h)	ΔT 秒	
OFF	1998-12-19 7:40:30	-21.90	-21.82	-21.93	-21.81	-22.25	-21.71	-21.93	-21.78									0.001	0.0037			3	748	
ON	7:53:41	-17.97	-17.84	-17.88	-17.82	-18.28	-17.68	-18.01	-17.81									0.974	0.0042	124.3	28.01	0.8758	3	291
OFF	8:3:53	-17.49	-17.46	-17.48	-17.50	-17.56	-17.35	-17.72	-17.50									0.001	0.0142	124.3	28.01	0.8758	3	560
ON	8:13:21	-17.23	-17.16	-17.25	-17.24	-17.42	-17.03	-17.31	-17.12									0.984	0.0147	126.6	31.03	0.9953	3	317
OFF	8:18:38	-17.01	-17.02	-17.02	-17.40	-17.04	-16.95	-17.32	-17.02									0.982	0.0263				3	544
ON	8:27:42	-17.04	-16.94	-16.97	-16.89	-17.13	-16.82	-17.06	-16.88									0.003	0.0376	123.9	38.41	1.0504	3	324
OFF	8:33:0	-16.90	-16.87	-16.89	-17.32	-17.01	-16.85	-17.24	-16.92									0.992	0.0381				3	335
ON	8:41:59	-16.89	-16.82	-16.87	-16.94	-17.00	-16.75	-17.02	-16.82									0.002	0.0457	127.5	34.51	1.0883	3	328
OFF	8:47:27	-16.84	-16.82	-16.81	-17.29	-16.88	-16.74	-17.16	-16.80									0.982	0.0501				3	329
ON	8:56:16	-16.93	-16.84	-16.90	-16.91	-17.03	-16.72	-16.99	-16.76									0.002	0.0619	127.7	35.28	1.1193	3	332
OFF	9:1:46	-16.80	-16.83	-16.84	-17.29	-16.94	-16.78	-17.18	-16.80									0.983	0.0623				3	325
ON	9:10:33	-16.97	-16.89	-16.93	-16.97	-17.12	-16.81	-17.08	-16.88									0.003	0.0742	126.6	35.91	1.1334	3	338
OFF	9:16:11	-16.80	-16.84	-16.85	-17.32	-16.93	-16.82	-17.22	-16.80									0.980	0.0746				3	322
ON	9:24:53	-16.75	-16.75	-16.75	-16.85	-16.88	-16.71	-16.85	-16.80									0.003	0.0803	126.8	36.33	1.1483	3	339
OFF	9:30:32	-16.74	-16.72	-16.72	-17.21	-16.84	-16.74	-17.16	-16.88									0.984	0.0876				3	327
ON	9:39:19	-16.79	-16.76	-16.75	-16.89	-16.90	-16.63	-16.88	-16.88									0.001	0.0980	126.7	36.72	1.1694	3	330
OFF	9:44:58	-16.77	-16.79	-16.79	-17.24	-16.88	-16.83	-17.19	-16.78									0.985	0.0984				3	322
ON	9:53:41	-16.85	-16.76	-16.79	-16.84	-16.92	-16.64	-16.89	-16.71									0.003	0.1114	127.6	37.90	1.1832	3	359
OFF	9:59:20	-16.88	-17.01	-16.79	-17.26	-17.07	-16.73	-17.19	-16.81									0.987	0.1119				3	328
ON	10:8:37	-16.83	-16.74	-16.80	-16.84	-16.98	-16.69	-16.95	-16.72									0.002	0.1239	127.6	37.24	1.1763	3	340
OFF	10:13:43	-16.76	-16.79	-16.80	-17.23	-16.81	-16.73	-17.18	-16.84									0.985	0.1244				3	327
ON	10:22:30	-16.81	-16.76	-16.81	-16.87	-17.04	-16.76	-17.00	-16.81									0.002	0.1358	126.9	37.31	1.1793	3	324
OFF	10:27:54	-16.83	-16.87	-16.76	-17.11	-16.75	-16.65	-17.01	-16.89									0.985	0.1363				3	332
ON	10:30:40	-16.82	-16.73	-16.81	-16.86	-16.96	-16.69	-16.91	-16.75									0.003	0.1462	127.8	37.11	1.1811	3	334
OFF	10:42:20	-16.83	-16.82	-16.84	-17.25	-16.90	-16.76	-17.12	-16.73									0.989	0.1486				3	322
ON	10:51:27	-16.81	-16.75	-16.81	-16.85	-16.98	-16.71	-16.90	-16.78									0.003	0.1600	127.8	37.55	1.1891	3	330
OFF	10:56:41	-16.75	-16.77	-16.76	-17.24	-16.88	-16.75	-17.16	-16.82									0.984	0.1611				3	322
ON	11:5:23	-16.83	-16.74	-16.81	-16.85	-16.95	-16.68	-16.92	-16.70									0.000	0.1731	127.3	37.70	1.1833	3	341
OFF	11:11:4	-16.83	-16.85	-16.83	-17.50	-16.88	-16.75	-17.15	-16.77									0.978	0.1736				3	317
ON	11:19:41	-16.83	-16.76	-16.81	-16.84	-16.94	-16.87	-16.87	-16.80									0.000	0.1832	127.6	37.78	1.1953	3	331
OFF	11:25:19	-16.73	-16.69	-16.67	-17.10	-16.81	-16.63	-17.09	-16.81									0.000	0.1832				3	331

(ON=压缩机通电, OFF=压缩机断电, tON=压缩机通电, tOFF=压缩机断电, tON=tOFF=压缩机通电/断电时间)
 (max=状态变化之前最高温度, min=状态变化之后最低温度, tmax=tmin=最高/最低温度)
 (Fmax=冷冻室最高温度, Fmin=冷冻室最低温度, tFmax=tFmin=冷冻室最高/最低温度)
 (ton=压缩机启动的平均值, toff=压缩机停止的平均值, tton=压缩机启动的平均值, toff=压缩机停止的平均值)
 (max=压缩机开始冷冻室最高温度, min=压缩机开始冷冻室最低温度, tmax=tmin=压缩机开始冷冻室最高/最低温度)

制表时间: 1998-12-19 11:30:59

耗电量=1.1803 (kWh/24h)

电流=0.992 (A)

(tm)=88.80 °C

(tr)=88.80 °C

格式 1 记录统计表


状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (kWh)	功率 (W)	系数 (%)	电能2 (kWh/24h)	△T 秒
	1988-12-19																						
ON	11:42:39	-14.02	-13.93	-13.89	-13.73	-14.17	-13.65	-13.93	-13.79									1.028	0.0005				242
OFF	11:46:41	-13.03	-13.02	-13.03	-13.88	-13.50	-13.44	-13.82	-13.62									0.603	0.0096	133.7	31.27	1.0701	532
ON	11:53:33	-13.54	-13.50	-13.54	-13.61	-13.74	-13.40	-13.70	-13.53									1.015	0.0101				226
OFF	11:59:21	-13.42	-13.44	-13.47	-13.75	-13.64	-13.42	-13.78	-13.51									0.601	0.0188	137.8	30.76	1.0632	323
ON	12:08:00	-13.62	-13.55	-13.57	-13.65	-13.72	-13.47	-13.67	-13.50									0.002	0.0193				233
OFF	12:11:58	-13.42	-13.41	-13.43	-13.75	-13.52	-13.33	-13.71	-13.40									1.013	0.0285	136.8	30.90	1.0600	515
ON	12:20:34	-13.60	-13.53	-13.58	-13.67	-13.75	-13.48	-13.74	-13.56									0.000	0.0375	135.0			239
OFF	12:24:33	-13.35	-13.30	-13.35	-13.67	-13.47	-13.20	-13.63	-13.35									1.017	0.0380	135.8	31.13	1.0707	512
ON	12:33:5	-13.59	-13.50	-13.63	-13.68	-13.75	-13.52	-13.75	-13.58									0.600	0.0465	135.8			230
OFF	12:37:1	-13.32	-13.30	-13.38	-13.70	-13.47	-13.27	-13.62	-13.34									1.021	0.0474		31.23	1.0733	508
ON	12:45:29	-13.32	-13.48	-13.52	-13.60	-13.68	-13.42	-13.68	-13.46									0.601	0.0503	138.0			232
OFF	12:49:21	-13.27	-13.28	-13.29	-13.62	-13.40	-13.23	-13.63	-13.35									1.021	0.0567		31.24	1.0775	511
ON	12:57:52	-13.49	-13.41	-13.47	-13.55	-13.62	-13.38	-13.62	-13.46									0.004	0.0658	137.8			237
OFF	13:1:49	-13.35	-13.35	-13.37	-13.68	-13.50	-13.28	-13.63	-13.37									1.013	0.0662		31.30	1.0801	512
ON	13:10:21	-13.61	-13.55	-13.58	-13.73	-13.43	-13.43	-13.71	-13.53									0.003	0.0754	130.1			243
OFF	13:14:24	-13.26	-13.32	-13.32	-13.65	-13.46	-13.26	-13.65	-13.40									1.018	0.0760		31.33	1.0843	516
ON	13:23:0	-13.49	-13.42	-13.46	-13.60	-13.61	-13.33	-13.58	-13.41									0.000	0.0850	136.3			238
OFF	13:26:58	-13.30	-13.30	-13.32	-13.64	-13.44	-13.20	-13.55	-13.20									1.021	0.0850		31.41	1.0856	510
ON	13:35:34	-13.50	-13.45	-13.45	-13.63	-13.63	-13.40	-13.60	-13.42									0.600	0.0940	137.5			235
OFF	13:39:29	-13.27	-13.26	-13.27	-13.60	-13.38	-13.15	-13.47	-13.18									1.022	0.0932		31.40	1.0878	513
ON	13:48:4	-13.50	-13.46	-13.51	-13.60	-13.63	-13.40	-13.64	-13.47									0.600	0.1041	137.2			235
OFF	13:51:59	-13.26	-13.25	-13.26	-13.60	-13.35	-13.14	-13.49	-13.20									1.028	0.1047		31.41	1.0888	511
ON	14:0:30	-13.45	-13.32	-13.36	-13.45	-13.51	-13.30	-13.54	-13.38									0.003	0.1137	136.8			238
OFF	14:4:28	-13.27	-13.27	-13.28	-13.60	-13.40	-13.19	-13.55	-13.20									1.020	0.1143		31.44	1.0903	511
ON	14:12:33	-13.47	-13.39	-13.45	-13.51	-13.58	-13.35	-13.57	-13.41														

(ON=压缩机运行, OFF=压缩机停止, *OFF=化霜加热器运行, *OFF=化霜加热器停止)
 (max=冷态最高温度, min=冷态最低温度, t1-t12=冷态最高/最低温度, t13-t16=冷态最高/最低温度-13℃时值)
 (tmax=冷态最高温度, tmin=冷态最低温度, t1-t12=冷态最高/最低温度, t13-t16=冷态最高/最低温度-13℃时值)
 (tmax=冷态最高温度, tmin=冷态最低温度, t1-t12=冷态最高/最低温度, t13-t16=冷态最高/最低温度-13℃时值)
 (tmax=冷态最高温度, tmin=冷态最低温度, t1-t12=冷态最高/最低温度, t13-t16=冷态最高/最低温度-13℃时值)

制表时间: 1988-12-19 14:13:37

1978-12-18

1986.12.16 14:41:58
 31.42 31.53 31.57 31.66 31.76 31.86 31.96 32.06
 结束 1986.12.16 14:47:53
 时间=65.92 分钟
 测试时间:符合要求
 结果=合格



T₀ — 箱内温度: Temp inside the Cabinet. T₀ — 排气管温度: Temp of Discharge tube
 T₁ — 冷风出口温度: Temp outlet the Cond. } get data on the panel.
 T₂ — 吸气入口: Temp inlet the comp.
 T₃ — 感温探头温度: Temp of the bulb
 T₄ — 回气管温度: Temp. of the Suction tube
 T₇ — 环境: Temp of the Ambient.
 T₆ — 压缩机: Temp of the Comp. shell.

NO:1
 试验内容:冷却速度 pull down.
 直冷型冰箱
 机型:50-108(R134a)
 型号:AE1350Y.60*2100 140
 厂向:32°70'
 温控器位置:0值=5
 测试时间:30分钟

温度条件:

冷感室:-21.0 °C 测温点数:6(t1, t2, t3, t4, t5, t6,)

开始	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16
1938.12.18 13:35:15	31.91	31.11	31.03	31.38	31.34	31.43										
结束	1938.12.18 14:13:53															

时间=30.38 分钟
 测试时间:符合要求

结果=合格

NO:2
 试验内容:冷却速度
 直冷型冰箱
 机型:50-108(R134a)
 型号:AE1350Y.60*2100 150
 厂向:32°70'
 温控器位置:0值=5
 测试时间:30分钟

温度条件:

冷感室:-21.0 °C 测温点数:6(t1, t2, t3, t4, t5, t6, t7, t8,)

开始	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16
1938.12.18 13:41:38	31.42	31.38	31.37	31.08	31.38	31.17	31.46	31.38								
结束	1938.12.18 14:17:33															

时间=36.32 分钟
 测试时间:符合要求

结果=合格

GRAPH

NO:1
 试验内容: 瞬态温度
 直接记录器
 机型: 50-100 (R134a)
 型号: AE13301, .60x2100 (140)
 厂商: 32703
 温控器位置: Ch值=3
 温度条件:

*With package and
 "m" package of 6.*

冷温室: -21.9 °C 测温点数: 6 (t1, t2, t3, t4, t5, t6,)

格式 1 汇总表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (KWh)	功率 (W)	系数 (%)	电能2 (KWh/24h)	Cn	ΔT 秒	
1998-12-21																									
ON	16:42:47	-19.71	-22.31	-22.18	-18.41	-18.62	-19.22											0.917	0.0005	106.2	61.71	1.5929	5	1204	
OFF	17:2:51	-19.80	-22.30	-22.20	-18.45	-18.65	-19.26											0.601	0.0361	106.2			5	747	
ON	17:13:18	-19.74	-22.32	-22.19	-18.41	-18.62	-19.21											0.907	0.0365	106.5	53.40	1.3841	5	988	
OFF	17:31:40	-19.80	-22.31	-22.20	-18.45	-18.66	-19.28											0.001	0.0658	106.5			5	1166	
ON	17:31:12	-19.72	-22.30	-22.20	-18.41	-18.62	-19.20											0.927	0.0663	107.5	55.35	1.4365	5	1086	
OFF	18:9:18	-19.78	-22.27	-22.21	-18.44	-18.65	-19.28											0.002	0.0988	107.5			5	731	
ON	18:21:29	-19.81	-22.38	-22.28	-18.48	-18.70	-19.29											0.908	0.0991	107.1	54.94	1.4293	5	1000	
OFF	18:35:9	-19.80	-22.29	-22.20	-18.41	-18.61	-19.22											0.000	0.1289	107.5			5	865	
ON	18:32:34	-19.73	-22.30	-22.22	-18.44	-18.65	-19.25											0.920	0.1293	107.5	55.39	1.4424	5	1012	
OFF	19:3:26	-19.77	-22.25	-22.15	-18.37	-18.59	-19.21											0.000	0.1596	107.5			5	752	
ON	19:21:58	-19.73	-22.31	-22.20	-18.42	-18.64	-19.22											0.914	0.1000	107.3	54.55	1.4221	5	999	
OFF	19:38:37	-19.71	-22.24	-22.17	-18.43	-18.62	-19.19											0.000	0.1898	107.3			5	979	
ON	19:34:56	-19.74	-22.37	-22.27	-18.51	-18.76	-19.36											0.922	0.1903	107.5	54.93	1.4338	5	1010	
OFF	20:11:46	-19.80	-22.30	-22.23	-18.45	-18.69	-19.28											0.002	0.2205	107.5			5	748	
ON	20:24:14	-19.75	-22.33	-22.23	-18.46	-18.70	-19.29											0.914	0.2210	106.9	54.88	1.4324	5	1058	
OFF	20:41:52	-19.79	-22.28	-22.18	-18.42	-18.85	-19.43											0.000	0.2525	106.9			5	883	
ON	20:50:35	-19.75	-22.35	-22.23	-18.48	-18.72	-19.31											0.920	0.2530	107.7	55.12	1.4390	5	1013	
OFF	21:13:28	-19.79	-22.30	-22.20	-18.46	-18.69	-19.29											0.000	0.2833	107.1			5	759	
ON	21:26:7	-19.67	-22.23	-22.13	-18.40	-18.69	-19.33											0.922	0.2837	107.1	54.22	1.4154	5	1081	
OFF	21:41:54	-19.82	-22.34	-22.25	-18.51	-18.76	-19.30											0.002	0.3119	107.5			5	947	
ON	21:59:55	-19.73	-22.32	-22.21	-18.46	-18.69	-19.27											0.920	0.3122	107.5	54.02	1.4201	5	1059	
OFF	22:17:34	-19.79	-22.28	-22.23	-18.46	-18.70	-19.29											0.000	0.3439	107.5			5	739	
ON	22:29:53	-19.72	-22.30	-22.19	-18.43	-18.67	-19.24											0.907	0.3443	107.1	54.48	1.4227	5	953	
OFF	22:45:46	-19.74	-22.29	-22.22	-18.45	-18.70	-19.32											0.000	0.3727	107.1			5	850	
ON	22:53:58	-19.75	-22.33	-22.22	-18.46	-18.69	-19.26											0.915	0.3731	107.2	54.02	1.4266	5	983	
OFF	23:10:19	-19.80	-22.30	-22.23	-18.51	-18.71	-19.33											0.001	0.4024	107.2			5	759	
ON	23:23:58	-19.68	-22.33	-22.15	-18.38	-18.62	-19.24											0.912	0.4029	106.9	54.48	1.4285	5	959	
OFF	23:44:57	-19.79	-22.31	-22.21	-18.48	-18.71	-19.32											0.000	0.4315	106.9			5	800	
ON	23:53:23	-19.75	-22.35	-22.24	-18.50	-18.73	-19.30											0.911	0.4319	107.0	54.73	1.4285	5	749	
1998-12-22																									
OFF	0:10:41	-19.78	-22.27	-22.18	-18.45	-18.70	-19.29											0.002	0.4628	107.0			5	1033	
ON	0:28:49	-19.77	-22.38	-22.24	-18.49	-18.69	-19.28											0.910	0.4631	106.9	54.75	1.4294	5	728	
OFF	0:44:23	-19.81	-22.33	-22.21	-18.50	-18.74	-19.32											0.001	0.4909	106.9			5	934	
ON	0:53:59	-19.75	-22.30	-22.24	-18.51	-18.75	-19.33											0.914	0.4913	106.9	54.59	1.4253	5	850	
OFF	1:13:12	-19.72	-22.26	-22.19	-18.48	-18.76	-19.34											0.002	0.5209	106.9			5	993	
ON	1:27:41	-19.82	-22.35	-22.22	-18.47	-18.77	-19.32											0.906	0.5212	106.9	54.73	1.4285	5	749	

OFF	2:18:27	-19.77	-22.26	-22.20	-18.41	-18.69	-19.28	0.000	0.5818	107.0	54.61	1.4255	5	1018
ON	2:30:32	-19.75	-22.34	-22.23	-18.45	-18.74	-19.32	0.908	0.5824	5	5	725		
OFF	2:47:50	-19.82	-22.29	-22.16	-18.39	-18.68	-19.26	0.000	0.6131	106.6	54.59	1.4248	5	1038
ON	3:2:28	-19.77	-22.36	-22.22	-18.42	-18.70	-19.27	0.515	0.6137	5	5	678		
OFF	3:19:22	-19.79	-22.31	-22.21	-18.41	-18.71	-19.29	0.001	0.6458	106.8	54.72	1.4278	5	1014
ON	3:31:56	-19.74	-22.35	-22.22	-18.42	-18.72	-19.28	0.907	0.6442	5	5	754		
OFF	3:48:16	-19.80	-22.34	-22.24	-18.45	-18.74	-19.31	0.001	0.6730	107.1	54.63	1.4257	5	967
ON	4:2:28	-19.77	-22.38	-22.24	-18.44	-18.74	-19.30	0.913	0.6734	5	5	865		
OFF	4:18:53	-19.74	-22.23	-22.19	-18.39	-18.71	-19.28	0.002	0.7028	107.0	54.60	1.4264	5	985
ON	4:32:14	-19.77	-22.33	-22.21	-18.43	-18.72	-19.30	0.911	0.7031	5	5	791		
OFF	4:48:17	-19.78	-22.29	-22.17	-18.38	-18.69	-19.28	0.000	0.7321	107.0	54.53	1.4230	5	973
ON	5:2:37	-19.79	-22.39	-22.28	-18.46	-18.73	-19.31	0.910	0.7324	5	5	860		
OFF	5:18:52	-19.75	-22.35	-22.19	-18.39	-18.72	-19.28	0.002	0.7616	107.1	54.62	1.4253	5	975
ON	5:32:16	-19.75	-22.30	-22.17	-18.38	-18.66	-19.21	0.907	0.7619	5	5	753		
OFF	5:48:17	-19.81	-22.33	-22.22	-18.44	-18.74	-19.31	0.000	0.7905	106.8	54.57	1.4240	5	962
ON	6:2:11	-19.75	-22.37	-22.27	-18.44	-18.72	-19.33	0.910	0.7910	5	5	844		
OFF	6:18:24	-19.83	-22.35	-22.25	-18.47	-18.76	-19.35	0.000	0.8200	107.0	54.53	1.4230	5	973
ON	6:32:30	-19.78	-22.33	-22.22	-18.44	-18.73	-19.31	0.909	0.8204	5	5	846		
OFF	6:48:35	-19.78	-22.29	-22.20	-18.42	-18.73	-19.33	0.000	0.8491	106.8	54.54	1.4234	5	965
ON	7:1:51	-19.75	-22.32	-22.20	-18.42	-18.69	-19.24	0.908	0.8496	5	5	790		
OFF	7:17:57	-19.82	-22.35	-22.21	-18.41	-18.75	-19.29	0.002	0.8784	107.1	54.49	1.4220	5	966
ON	7:32:11	-19.68	-22.27	-22.14	-18.38	-18.70	-19.31	0.917	0.8788	5	5	854		
OFF	7:47:32	-19.80	-22.31	-22.22	-18.43	-18.73	-19.30	0.002	0.9060	107.0	5	927		

(ON=压缩机通电, OFF=压缩机断电, *on=化霜加热器通电, *off=化霜加热器断电)
 (max=状态变化之间冷冻室最热点时刻, min=状态变化之间冷冻室最冷点时刻)
 (Fmax=冷冻室最热点, Fmin=冷冻室最冷点, d=化霜开始冷冻室最热点等于-18℃时刻)
 (ton=冷冻室t10, t11, t12最冷点的平均值, tm=ton值与上一状态平均值的再平均值)
 (toff=冷冻室t10, t11, t12最冷点的平均值, toff=toff值与上一状态平均值的再平均值)
 (tm)=88.80 ℃ (toff)=88.80 ℃ (toff)=88.80 ℃
 (*max=化霜开始冷冻室最热点时刻)

制表时间: 1998-12-22 7:43:28

试验内容: 储藏温度
 直冷型冰箱
 机型: BD-168(A134a)
 型号: AE1350Y .66*2100 (150)
 厂商: 82/70%
 温控器位置: On值=5
 温度条件:

冷冻室: -21.9 ℃ 测温点数: 8 (t1, t2, t3, t4, t5, t6, t7, t8,)

格式 1 汇总表

状态	时间	t1	t2	t3	t4	t5	t6	t7	t8	t9	t10	t11	t12	t13	t14	t15	t16	电流 (A)	电能1 (kWh)	功率 (%)	系数 (%)	电能2 (kWh/24h)	ΔT 秒
OFF	7:48:46	-20.43	-20.32	-16.99	-24.26	-22.52	-22.53	-21.98	-22.14									0.001	0.0086				
ON	8:11:52	-20.10	-20.17	-16.85	-25.77	-22.45	-22.48	-21.93	-22.11									0.933	0.0092				1386
OFF	8:33:50	-20.42	-20.27	-16.96	-24.22	-22.58	-22.61	-22.04	-22.25									0.003	0.0584	105.8	54.77	1.4029	1678
ON	9:1:42	-20.19	-20.23	-16.92	-23.84	-22.56	-22.58	-21.98	-22.16									0.936	0.0588				1312
OFF	9:33:35	-20.40	-20.20	-16.94	-24.14	-22.52	-22.55	-21.96	-22.18									0.002	0.1147	105.3	57.10	1.4574	1913
ON	9:55:28	-20.23	-20.29	-16.98	-23.84	-22.58	-22.57	-21.96	-22.13									0.952	0.1151				1313
OFF	10:25:56	-20.41	-20.28	-17.00	-24.16	-22.54	-22.55	-21.96	-22.15									0.003	0.1687	105.5	57.47	1.4601	1828
ON	10:47:42	-20.17	-20.25	-16.95	-23.81	-22.56	-22.53	-21.96	-22.07									0.938	0.1691				1306
OFF	11:17:10	-20.40	-20.28	-16.94	-24.10	-22.53	-22.50	-21.87	-22.10									0.001	0.2208	105.4	57.48	1.4601	1763
ON	11:38:30	-20.18	-20.23	-16.92	-23.86	-22.65	-22.63	-21.99	-22.17									0.932	0.2213				1260

ON	12:31:35	-20.20	-20.27	-15.97	-23.77	-22.59	-22.57	-21.94	-22.14	0.929	0.2763	57.91	1.4773	5	1501
OFF	13:11:42	-20.43	-20.32	-17.03	-24.12	-22.58	-22.56	-21.92	-22.10	0.003	0.3297	105.5	1.4773	5	1504
ON	13:23:15	-20.25	-20.32	-17.05	-23.82	-22.64	-22.60	-21.91	-22.10	0.924	0.3302	53.02	1.4731	5	1293
OFF	13:53:42	-20.43	-20.35	-17.16	-24.18	-22.59	-22.69	-22.01	-22.27	0.003	0.3635	105.1	1.4731	5	1627
ON	14:15:11	-20.19	-20.26	-17.01	-23.71	-22.56	-22.54	-21.89	-22.09	0.929	0.3639	56.25	1.4644	5	1289
OFF	14:47:9	-20.44	-20.39	-17.15	-24.17	-22.64	-22.59	-21.93	-22.12	0.000	0.4399	105.3	1.4644	5	1918
ON	15:08:50	-20.21	-20.29	-17.05	-23.73	-22.57	-22.55	-21.90	-22.09	0.925	0.4405	58.23	1.4643	5	1301
OFF	15:38:58	-20.45	-20.37	-17.11	-24.12	-22.62	-22.59	-21.91	-22.14	0.001	0.4932	105.4	1.4643	5	1803
ON	16:09:37	-20.28	-20.35	-17.10	-23.80	-22.67	-22.63	-21.91	-22.13	0.938	0.4937	55.26	1.5677	5	1304
OFF	16:41:1	-20.52	-20.50	-17.15	-24.22	-22.61	-22.61	-22.09	-22.23	0.002	0.5601	104.4	1.5677	5	2604
ON	17:12:21	-20.26	-20.31	-17.10	-23.82	-22.61	-22.61	-21.94	-22.13	0.925	0.5636	55.81	1.4565	5	1400
OFF	17:44:56	-20.43	-20.40	-17.15	-24.16	-22.65	-22.65	-21.95	-22.21	0.003	0.6175	105.5	1.4565	5	1649
ON	18:16:14	-20.20	-20.32	-17.11	-23.82	-22.67	-22.64	-21.90	-22.10	0.938	0.6175	58.16	1.4565	5	1342
OFF	18:48:5	-20.46	-20.31	-17.15	-24.12	-22.67	-22.65	-21.95	-22.15	0.002	0.6639	105.2	1.4565	5	1614
ON	19:19:45	-20.23	-20.23	-17.03	-23.69	-22.69	-22.59	-21.89	-22.12	0.932	0.6663	58.33	1.4867	5	1300
OFF	19:51:46	-20.43	-20.33	-17.23	-24.21	-22.78	-22.70	-22.02	-22.25	0.001	0.7138	106.4	1.4867	5	1677
ON	20:23:17	-20.20	-20.24	-17.05	-23.77	-22.74	-22.69	-21.89	-22.06	0.949	0.7162	58.93	1.4829	5	1294
OFF	20:55:55	-20.43	-20.29	-17.14	-24.06	-22.66	-22.62	-21.87	-22.10	0.002	0.7637	106.9	1.4829	5	1598
ON	21:27:53	-20.35	-20.26	-17.10	-23.71	-22.67	-22.63	-21.90	-22.11	0.949	0.7641	58.06	1.4820	5	1258
OFF	21:59:43	-20.48	-20.37	-17.24	-24.16	-22.75	-22.70	-22.02	-22.28	0.005	0.8134	106.4	1.4820	5	1670
ON	22:31:36	-20.18	-20.27	-17.13	-23.74	-22.73	-22.70	-21.97	-22.20	0.947	0.8138	57.97	1.4607	5	1253
OFF	23:03:41	-20.40	-20.29	-17.14	-24.07	-22.70	-22.66	-21.91	-22.16	0.005	0.8620	106.8	1.4607	5	1628
ON	23:35:26	-20.21	-20.27	-17.07	-23.71	-22.69	-22.64	-21.89	-22.10	0.940	0.8625	58.02	1.4820	5	1244
OFF	24:07:7	-20.44	-20.34	-17.11	-24.03	-22.69	-22.65	-21.90	-22.15	0.002	0.9147	105.6	1.4820	5	1779
ON	24:39:54	-20.32	-20.40	-17.18	-23.83	-22.78	-22.74	-21.98	-22.21	0.943	0.9151	57.99	1.4815	5	1247
OFF	25:11:56	-20.45	-20.32	-17.11	-24.05	-22.68	-22.62	-21.88	-22.11	0.002	0.9646	105.9	1.4815	5	1682
ON	25:43:49	-20.24	-20.32	-17.10	-23.74	-22.69	-22.63	-21.85	-22.03	0.932	0.9650	58.00	1.4798	5	1253
OFF	26:15:41	-20.45	-20.36	-17.17	-24.11	-22.73	-22.70	-21.95	-22.19	0.004	1.0163	105.8	1.4820	5	1752
ON	26:47:56	-20.22	-20.33	-17.16	-23.78	-22.78	-22.71	-21.99	-22.20	0.937	1.0169	57.98	1.4802	5	1257
OFF	27:19:8	-20.45	-20.37	-17.18	-24.09	-22.71	-22.63	-21.85	-22.11	0.004	1.0647	105.7	1.4802	5	1630
ON	27:51:6	-20.23	-20.32	-17.09	-23.67	-22.62	-22.59	-21.83	-22.02	0.926	1.0653	57.80	1.4798	5	1258
OFF	28:23:7	-20.41	-20.34	-17.17	-24.06	-22.72	-22.72	-21.93	-22.19	0.003	1.1147	105.9	1.4798	5	1681
ON	28:55:10	-20.20	-20.30	-17.12	-23.70	-22.70	-22.66	-21.89	-22.11	0.937	1.1153	57.83	1.4785	5	1269
OFF	29:27:41	-20.38	-20.29	-17.13	-24.02	-22.66	-22.63	-21.88	-22.12	0.000	1.1636	105.9	1.4785	5	1645
ON	29:59:29	-20.20	-20.31	-17.16	-23.77	-22.70	-22.70	-21.94	-22.17	0.942	1.1640	57.83	1.4785	5	1248
OFF	30:31:55	-20.40	-20.31	-17.09	-24.04	-22.68	-22.64	-21.88	-22.14	0.004	1.2142	105.9	1.4785	5	1706
ON	31:03:42	-20.21	-20.26	-16.83	-23.62	-22.59	-22.56	-21.84	-22.07	0.939	1.2147	57.80	1.4792	5	1267
OFF	31:35:46	-20.40	-20.30	-16.77	-24.02	-22.63	-22.59	-21.84	-22.08	0.000	1.2670	105.5	1.4792	5	1784
ON	32:07:26	-20.17	-20.26	-16.68	-23.66	-22.63	-22.59	-21.86	-22.07	0.924	1.2674	57.81	1.4781	5	1240
OFF	32:39:12	-20.35	-20.28	-16.79	-24.06	-22.71	-22.64	-21.90	-22.17	0.002	1.3150	105.8	1.4781	5	1621
ON	33:10:22	-20.14	-20.22	-16.75	-23.64	-22.61	-22.58	-21.83	-22.05	0.946	1.3155	57.80	1.4780	5	1245
OFF	33:42:22	-20.40	-20.36	-16.95	-24.11	-22.74	-22.69	-21.94	-22.21	0.004	1.3651	105.9	1.4780	5	1690
ON	34:14:4	-20.19	-20.30	-16.89	-23.68	-22.66	-22.64	-21.93	-22.15	0.943	1.3656	57.77	1.4774	5	1242
OFF	34:46:25	-20.38	-20.26	-16.92	-23.96	-22.60	-22.59	-21.87	-22.13	0.001	1.4139	106.0	1.4774	5	1641
ON	35:18:20	-20.09	-20.17	-16.89	-23.62	-22.61	-22.56	-21.83	-22.04	0.949	1.4143	57.75	1.4768	5	1255
OFF	35:50:10	-20.37	-20.27	-17.01	-24.02	-22.65	-22.67	-21.92	-22.17	0.002	1.4633	105.8	1.4768	5	1670
ON	36:22:1	-20.21	-20.29	-17.00	-23.70	-22.70	-22.64	-21.88	-22.09	0.936	1.4638	57.80	1.4768	5	1251

(ON=压缩机通电,OFF=压缩机断电,*ON=化霜加热器通电,*OFF=化霜加热器断电)
(max=状态变化之间冷冻室最热点时刻,min=状态变化之间冷冻室最冷点时刻)
(Fmax=冷冻室最热点,Fmin=冷冻室最冷点,d=化霜开始冷冻室最热点等于-18℃时刻)
(ton=冷冻室t10,t11,t12最热点的平均值,tm=ton值与上一状态平均值的再平均值)
(toff=冷冻室t10,t11,t12最冷点的平均值,tn=toff值与上一状态平均值的再平均值)
(*max=化霜开始冷冻室最热点时刻)

1998-12-22 4:34:26 (Fmax)=-10.68 °C
1998-12-21 7:48:46 (Fmin)=-24.26 °C
1998-12-21 7:48:46 (ton)=88.80 °C
1998-12-21 7:48:46 (toff)=88.80 °C
(A)
耗电量=1.4768 (KWh/24h)

制表时间:1998-12-22 7:48:28