



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

**UNIDO PROJECT MP/JOR/94/420 - HAMCO
UNIDO CONTRACT No 97/099**

COMMISSIONING & FINAL REPORT

COMMISSIONING REPORT

Commissioning

The commissioning at client's factory (Jordan) has been carried out in the presence of our technicians, from 30 November to 23 December 1998.

All the installation, commissioning, start up and the first part of "on the job training" in accordance to UNIDO contract, have been completed.

Certificate of Acceptance

Enclosed you will find the Certificate of Acceptance of the performed work: "Testing Report for Supply and Acceptance" dated 23 December 1998, signed by OMS technician (Mr. Tiziano Perego) and the Counterpart (Mr. Hayyan Jaber).

From 5th to 11th May 1999 our technician Mr. Vincenzo Cannata was at client's factory (Jordan) to verify and solve the problems reported in occasion of the commissioning carried out on last December 1998.

Commissioning Report

Enclosed you will find also the commissioning report (Performance Test) printed on OMS and HAMCO headed paper, drawn up on 11 May 1999.

Safety Certificate issued by CESI on June 1999

The Safety Certificate here enclosed covers also the points 2-5-6-7-8-9 of the minutes of the meeting held on 23 December 1999, for which OMS had sent a letter of clarification to HAMCO and in copy to UNIDO (letter dated 20 January 1999).

Here enclosed you will find also the transport documentation indicating the despatch of the "Special tools for maintenance" (last marked item) and the spare parts - item 16 and item 21 of the minutes of the meeting held on 23 December 1998 - (first four marked items).

The enclosed proforma invoice No 41/99 dated 26 May 1999 and Air Waybill dtd 1st June 1999 are related to the despatch of the Rossi fixture's electric motor replaced under guarantee and to the 5 m. hydraulic pipe, indicated in the minutes of meeting held on 11 May 1999.

16 June, 1999

The enclosed proforma invoice No 046/99 dated 11 June 1999 is related to the non-return valve provided by OMS under guarantee as per HAMCO's request accepted by our fax dated 4 June 1999 of which we are enclosing copy.

On the job training

The first stage of the training was held on last December 1998 by Mr. Tiziano Perego (OMS technician) and it was completed by Mr. Cannata Vincenzo (OMS technician) during the period from 5 May 1999 and 11 May 1999 as indicated at point 7 of Technical Service No 10/99 signed by HAMCO (Mr. Jaber).

FINAL REPORT


Works performed at the plant site

- Emplacement of C-Pentane tank and relevant valves and accessories
- Emplacement of C-Pentane transferring pumps
- Emplacement and connection of C-Pentane piping
- Emplacement and connection of fire-proof system
- Apply of antistatic paint in the foaming area
- Emplacement and mechanical/electric connection of the metering machine according to the safety standards
- Emplacement of cabinets and doors cabins
- Emplacement and connection of suction systems
- Emplacement and electric connection of cabinets foaming fixtures
- Modification to the cabinets and doors existing fixtures according to the C-Pentane foaming technology and the relevant safety requirements.
- Electric connection of all C-Pentane gas sensors
- Commissioning of the equipment and functional trials
- On the job training held in two stages

IMPIANTI OMS SPA



Italo Melizzi
Commercial Director



Marco Dell'Orto
OMS Consultant
(Project Leader)



Via Sabbionetta n. 4
 20050 Verano Brianza (MI)
 Partita IVA 0832500151

TESTING REPORT FOR SUPPLY ACCEPTANCE

TODAY 22/12/98 C/O: HAMCO (JORDAN)

Present for OMS:

Present for

MR PEREGO

.....

HAS BEEN CARRIED OUT THE TESTING IN RELATION TO THE SUPPLY AS PER:

WORK ORDER NO. 111 7249/97

DATED 19/08/97

PARTIAL SUPPLY

TOTAL SUPPLY

INTERNAL WORK ORDER REFERENCE NO. 102/97

and with specific reference to what here below described:

N°1 FIXTURE

.....

the testing has given **POSITIVE** result so the supply of what above is considered as accepted.

Possible observations of OMS:

Possible observations of the customer:

.....


TO SEE THE LIST OF PROBLEMS BY MR PEREGO MR SABER MR MALAYRI

ACCEPTANCE SIGNATURES:

For OMS:

Stamp and signature of the customer:

P. Perigo


22/12/1998



MINUTE OF MEETING

F -

PRESENTS:

MR. VICENZO CANNATA / OMS

MR. HAYYAN JABER / HAMCO

DATE: 11/05/1999

SUBJECT: ORDER No. 724/97

DURING THE PERIOD OF 05/05/1999 TO 11/05/1999 MR. VINCENZO CANNATA / TECHNICAL SERVICE - OMS HAS VISITED HAMCO - JORDAN AND HAVE CARRIED OUT THE CORRECTION AND/OR MODIFICATION OF ALL OUTSTANDING MATTERS OF THE ABOVE PROJECT, AND NOW THE PLANT IS WORKING NORMALLY, HOWEVER, BOTH PARTIES AGREED TO THE FOLLOWINGS:

1. THE MOVEMENT OF THE CABINET AREA FOAMING HEAD IS NOT SATISFACTORY, AND NEED TO MODIFIED TO MAKE EASY AND DURABLE HANDLING OF THE FOAMING HEAD.
2. OMS WILL SUPPLY, FREE OF COST AND FREIGHT, AS REPLACEMENT 5 METERS PIPE FOR HYDRAULIC, AND ONE MOTOR FOR THE ROSSI FIXTURE.
3. MODIFICATION DRAWINGS FOR ELECTRICAL WIRING DIAGRAM FOR THE FOAMING FIXTURE.

HAMCO CERTIFIED THAT THEY HAVE DURING THE PERIOD FROM JANUARY 1999 TO END OF MAY 1999, THAT HAMCO FACTORY HAVE PRODUCED ABOUT 900 REFRIGERATORS OF OMS EQUIPMENT.

FOR: OMS

FOR: HAMCO

VICENZO CANNATA

HAYYAN JABER

CESSERVICE

Services for Electrical Installations

Client Impianti OMS SpA - Verano Brianza (Italy)

Subject Inspection regarding safety aspects against risk of explosion on the OMS plant for the production and injection of expanded polyurethane in the HAMCO (Household Appliances Manufacturing Company) factory in Amman (Jordan).

Date and place of inspection 14 to 19 December 1998

Note: This document substitutes the preceding report SYST – 99/000132 on the same subject

This document shall not be reproduced except in full without the written approval of CESI

No. of pages 13 **No. of pages annexed** 1

Issue date June 1999

Prepared Ing. P. Ostano *P Ostano*

Approved SYST – Ing. A. Ardito

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Il Responsabile Tecnico Scientifico
Area Sistemi
Antonio Cheli

TABLE OF CONTENTS

1. Subject of the inspection	page 3
2. Scope of the inspection	page 3
3. Reference standards	page 3
4. Description of the plant	page 4
5. Flammable materials	page 4
6. Classification of hazardous areas, inspection of the electrical installations and of the safety measures adopted	
6.1 Methods of classification	page 5
6.2 Storage tank	page 6
6.3 Pentafoam unit	page 8
6.4 Cabinet foaming cabin	page 10
6.5 Door foaming cabin	page 12
7. Summary of the inspection results	page 13

Annex: OMS declaration

Reference documents

- Lay-out of the HAMCO plant (Prot. 99/000133)
- ASTRA technical note on the dimensioning of ventilation (Prot. N. 96/036820)
- OMS instructions for the use of cyclopentane (Prot. N. 96/036824)
- OMS technical note (Prot. N. 96/036825)
- OMS declaration Prot. 99/015269

1. SUBJECT OF THE INSPECTION

The inspection was made on the plants supplied by Impianti OMS for the production of expanded polyurethane using cyclopentane as blowing agent which feeds the lines for production of refrigerators in the HAMCO (Household Appliances Manufacturing Company) factory in Amman (Jordan).

The inspection was carried out by Mr. P. Ostano of CESI, with the attendance of Mr. Jaber (HAMCO) and Mr. Perego (OMS).

2. SCOPE OF THE INSPECTION

Scope of the inspection was to verify the safety measures adopted on the plant against the risk of explosion due to electrical causes (sparks or overtemperatures of electrical apparatus) in presence of vapours of cyclopentane emitted during the operation of the plant.

To this purpose a classification of the hazardous areas produced by OMS machines and plants because of cyclopentane presence has been made and an inspection on electrical plants and safety measures adopted has been carried out.

3. REFERENCE STANDARDS

The following standards have been used as reference:

- CEI EN 60079-10 (1996) "Electrical apparatus for explosive gas atmospheres - Part 10: Classification of hazardous areas"
- CEI EN 60079-14 (1998) "Electrical apparatus for explosive gas atmospheres - Part 14: Electrical installations in explosive gas atmospheres (other than mines)"

4. DESCRIPTION OF THE PLANT

The parts of the plant concerned with the cyclopentane circuit are the following:

- a) storage tank, 1.000 dm³ capacity, installed above ground, pressurized with nitrogen. Near the tank, a pump is installed for transferring cyclopentane to the Pentafoam unit for the production of the foam.
- b) mixing and foaming unit Pentafoam HP 100, including a nitrogen pressurized 250 dm³ storage tank and high pressure pumps.
- c) foaming cabin for refrigerator cabinets, with three foaming fixtures and one injection head, manually operated.
- d) foaming cabin for refrigerator doors, with two foaming fixtures and one injection head, manually operated.

More details about the OMS plants for production of polyurethane with use of cyclopentane are given in the reference document 96/036820.

5. FLAMMABLE MATERIALS

From the point of view of the explosion risk, the only dangerous material present in the OMS plant is the cyclopentane.

The data significant for the classification of hazardous areas relevant to this material are as follows:

Relative density (referred to air)	2.4
Flashpoint	< -20 °C
Lower explosive limit (LEL)	1.5 %
Upper explosive limit (UEL)	8.7 %
Group of electrical apparatus	IIA
Ignition temperature	191 °C
Temperature class	T4

Since the relative density of the cyclopentane is 2.4, the classification must be made according to the rules established for heavy gases and vapours.

6. CLASSIFICATION OF HAZARDOUS AREAS, INSPECTION OF THE ELECTRICAL INSTALLATIONS AND OF THE SAFETY MEASURES ADOPTED

6.1 Methods for classification of hazardous areas and selection of electrical equipment

The standard IEC 79-10 has recently been adopted in Europe, as CEI EN 60079-10 standard, for the classification of hazardous areas. Its basic criteria have therefore been used as reference in this work.

The CEI EN 60079-10 standard requires the evaluation of the possible losses of flammable gases and the consequent evaluation of the extent of the hazardous zones on the basis of the "hypothetical volume" V_z defined as follows:

$$V_z = \frac{f \cdot Q_g}{k \cdot \text{LEL} \cdot C} \quad [1]$$

where:

Q_g = emission flow of flammable substance (m^3/h)

f = quality factor of the ventilation, which takes into account the presence of obstacles

LEL = lower explosive limit (kg/m^3)

k = safety factor applied to LEL

$k=0.5$ for secondary grade release

$k=0.25$ for primary grade release

C = air exchanges (h^{-1})

The criteria for the selection of the electrical equipment as a function of the area classification are given in the CEI EN 60079-14 standard (corresponding to the international standard IEC 79-14) and they have been followed in the inspection.

6.2 Storage tank

6.2.1 Classification of hazardous areas

The flanges, the seals of valves and pumps are sources of release of secondary grade. Also the relief valve can be considered a secondary grade release taking into account that the tank is nitrogen pressurized.

Since the tank is installed in open air, the ventilation is natural and a value of $C = 100$ (air changes per hour) can be assumed as specified by CEI EN 60079-10 standard.

For the evaluation of possible losses, useful data are reported in the API Publication N. 4589 "Fugitive Hydrocarbon Emissions from Oil and Gas Production Operations", which gives the results of a large experimental investigation on components of petrochemical plants.

The highest losses on onshore gas production sites have been measured on valves, with a value of 0.115 kg/h of emitted substance.

The value of V_z results:

$$V_z = \frac{0.116}{0.5 \times 0.0437 \times 100} = 0.053 \text{ m}^3$$

having considered

$$k = 0.5$$

$$C = 100 \text{ air changes/h}$$

$$\text{LEL of cyclopentane} = 0.0437 \text{ kg/m}^3$$

$f = 1$ since no substantial obstacle to the ventilation are present around the tank cabin.

Assuming the hazardous area has the shape of a sphere this volume would give rise to an hazardous zone of 0.23 m of radius around each source of release.

Taking into account an adequate safety margin (in consideration of the effect of wind, characteristics of the substance, uncertainties of the calculation procedure) a **zone 2 of 1.5 m around each source of release is defined.**

In the pit surrounding the tank the ventilation is limited by the presence of a wall about 0.5 m high.

In the pit therefore a zone 1 must be defined.

6.2.2 Selection of electrical equipment

The electrical apparatus present in this area are:

- a) The motor driving the pump, manufacturer FIMM, type of protection EEx d IIB T4 (CESI certificate AD 81-119).

The motor is installed inside the pit, that is in an area classified as zone 1 and the type of protection is suitable for the zone of installation.

- b) The level meter VEGA with type EL capacitive electrode, protected by a VEGA intrinsic safety barrier, type 145, code of protection EEx ia IIC T6, installed outside the hazardous area.

This equipment is installed in zone 2 and its type of protection is suitable for the zone of installation.

- c) At the time of inspection a pressure switch (manufacturer OMS) was installed above the tank, that is in zone 2. This device is of normal type, not protected against the risk of explosion and it is therefore not suitable for the zone of installation. It was then requested to substitute it with a new one with suitable protection.

According to the OMS declaration Prot. 99/015269 annexed to this report the above mentioned pressure switch has been substituted by the pressure switch type SP 312-B2D/CI01, manufacturer Fantinelli, equipped with a Pepperl + Fuchs sensor type SJ2-N, with intrinsic safety protection type EEx ia IIC T6 (certificate PTB Nr. Ex-83/2022X).

The pressure switch is protected by a safety barrier Pepperl + Fuchs type KFD2 SR2 EX1W, code of protection [EEx ia] IIC (certificate PTB Nr. Ex-94.C.2086).

With these modifications the pressure switch is suitable for installation in zone 1 and 2 and can therefore operate safely in the tank area.

d) The other electrical equipment in the surrounding area (in particular two control panels outside the tank cabin) are installed in safe area and do not need protection against explosion risk.

6.3 Pentafoam unit

The Pentafoam cabin (1.2 x 2.5 x 2 m) is equipped with an artificial ventilation system composed of two independent fans and of a monitoring system of the cyclopentane vapours through two gas detectors placed inside the cabin.

The sources of emission are given by flanges and valves along the cyclopentane and mixture circuits and by the pump sealing.

The vent of the mixture tank is connected directly to the air ventilation output duct through a pipe.

These sources of emission originate secondary grade releases.

A 3,500 m³/h fan is continuously working.

Should the cyclopentane concentration in the ambient exceed 15% of LEL (lower explosive limit), the second fan enters into operation so bringing the ventilation to 6,000 m³/h.

Should 30 % of LEL be reached, the electrical power feed of the pump motors is switched off and the cyclopentane feeding is stopped.

A flow-meter controls ventilation continuity.

For the ventilation system dimensioning, a maximum poliol/cyclopentane mixture consumption of 250 Kg/h has been taken into account.

On this basis a maximum cyclopentane vapour emission of 3 Kg/h within the cabin has been estimated.

This value has been calculated assuming that, during the 250 dm³ tank refilling operation, the same volume of cyclopentane vapour is being introduced into the cabin through the safety valve. This is a conservative assumption since, in fact, the tank contains a mixture of cyclopentane and nitrogen vapours and the valve vent is connected to the air outlet. This assumption therefore takes into account other minor losses which may occur inside the cabin.

The air flow necessary to maintain the cyclopentane concentration below 15 % of LEL is:

$$24 \times 100 / M \times 0.15 \times \text{LEL} = 152 \text{ m}^3 \text{ aria/Kg of cyclopentane}$$

and therefore of $152 \times 3 = 456 \text{ m}^3/\text{h}$

where $M = 70$ (molecular weight of cyclopentane)

$\text{LEL} = 1.5\%$

A $3,500 \text{ m}^3/\text{h}$ air flow is therefore largely sufficient to guarantee that safety conditions are maintained inside the cabin under the above mentioned assumptions.

The ambient inside the Pentafoam cabin can therefore be defined as non-hazardous area, according to the definition of CEI EN 60079-10, due to artificial ventilation.

Within the cabin it is therefore allowed to install standard electrical equipment, not equipped with protection against explosion hazard.

The only exceptions are the fan motors and the gas detectors which must guarantee the safe operation also in case of hazardous gas concentration.

According to this criterion these equipment have been installed:

- fan motors (CEMP manufacturer) with type of protection EEx d IIB T4
- gas detectors (MSA manufacturer) with type of protection EEx d IIC T6.

The electrical equipment of the Pentafoam unit are therefore in accordance with the specifications of the standards for locations with risk of explosion mentioned at item 2.

It must be remarked that the ventilation in the Pentafoam unit must be kept continuously in operation, also during non-working hours, in order to avoid possible gas concentration inside the cabin which could result very dangerous at the start of service.

6.4 Cabinet foaming cabin

Three foaming fixtures are installed inside the cabinet foaming cabin, which has dimensions of 7.5 x 3.1 x 3.4(h) m, with large openings on the front and on the rear.

An artificial ventilation system is installed, consisting of two fans for each fixture, each fan ensuring an air flow of 3000 m³/h.

The floor of the cabin has been covered by an antistatic cover.

According to the data provided by the manufacturer, the duration of a foaming cycle is 7 minutes (8.57 cycles /h per each fixture) with injection of 6 Kg of foam for each cycle, that is

$$8.57 \times 6 \times 3 = 154 \text{ kg foam/h.}$$

The quantity of cyclopentane which evaporates during a foaming cycle is 5 g/Kg of foam (conservative figure).

It results an evaporation of

$$0.005 \times 154 = 0.77 \text{ Kg of cyclopentane per hour}$$

The air flow necessary to keep the cyclopentane concentration within 15% of LEL is:

$$0.77 \times 152 = 117 \text{ m}^3/\text{h.}$$

The ventilation system ensures a ventilation of 3,000 m³/h in normal conditions.

This value has been established in order to take into account the efficiency of the ventilation and to guarantee an air speed sufficient to ensure vapour catching.

A flow-meter controls ventilation flow continuously.

The cabin is equipped with four gas detectors placed near to the floor (two in the front of the foaming area and two on the lateral walls).

If the cyclopentane concentration in the ambient exceed 15% of LEL (lower explosive limit), the second fan enters into operation so bringing the ventilation to 6,000 m³/h.

Should 30 % of LEL be reached, the electrical power feed of the pump motors is switched off and the cyclopentane feeding is stopped.

It can be deduced that within the cabinet foaming cabin the cyclopentane concentration generally does not reach dangerous levels and the ambient can be defined as non-hazardous area.

Inside the cabin it is therefore allowed to install standard electrical equipment, not equipped with protection against explosion hazard.

The only exceptions are the fan motors and the gas detectors which must guarantee the safe operation also in case of hazardous gas concentration and are therefore of explosion-proof type.

The classification as non-hazardous area does not apply to the zone immediately near the injection head where a certain concentration of cyclopentane vapours may be present.

According to the data supplied by the customer, the maximum quantity of cyclopentane which evaporates during a foaming cycle in the cabinet foaming cabin is 30 g.

Considering the ventilation around the injection head and the fact that the cyclopentane vapours are heavier than air, it can be deduced that a significant concentration of cyclopentane is possible only in a very limited space around the injection head.

Taking into account a certain safety margin, it is reasonable to define a zone 1 with an extent of 0.5 m around the injection head.

In this zone the electrical devices must have a protection against explosion hazard suitable for zone 1 .

In the area of 0.5 m around the injection head only a proximity switch is installed. This apparatus is protected by an intrinsic safety barrier Pepperl & Fuchs, with type of protection [EEx ib] IIC and it is therefore suitable for the zone of installation.

The push-button board of the injection head is placed outside the hazardous area.

6.5 Door foaming cabin

Two foaming fixtures are installed inside the cabinet foaming cabin, which has dimensions of

4 x 2 x 2(h) m and is open on the front.

An artificial ventilation system is installed, consisting of two fans ,each fan ensuring an air flow of 3000 m³/h.

The floor of the cabin has been covered by an antistatic cover.

According to the data provided by the manufacturer, the duration of a foaming cycle is about 5 minutes (12 cycles /h per each fixture) with injection of 1.5 Kg of foam for each cycle, that is

$$12 \times 1.5 \times 2 = 36 \text{ kg foam/h.}$$

Since the quantity of cyclopentane which evaporates during a foaming cycle is 5 g/Kg of foam the vapours of cyclopentane produced are

$$0.005 \times 35 = 0.18 \text{ Kg of cyclopentane per hour}$$

The air flow necessary to keep the cyclopentane concentration within 15% of LEL is:

$$0.18 \times 152 = 27.4 \text{ m}^3/\text{h.}$$

The ventilation system ensures a ventilation of 3,000 m³/h in normal conditions.

This value has been established in order to take into account the efficiency of the ventilation and to guarantee an air speed sufficient to ensure vapour catching.

The air flow can be increased to 6000 m³/h in case of presence of gas concentration..

The cabin is equipped with two gas detectors placed near to the floor on the lateral walls.

The same safety operations described at the preceding paragraph are provided in case 15 % or 30 % of LEL is reached.

Taking into account these safety measures it can be deduced that within the door foaming cabin the cyclopentane concentration generally does not reach dangerous levels and the ambient can be defined as non-hazardous area.

Inside the cabin it is therefore allowed to install standard electrical equipment, not equipped with protection against explosion hazard.

The only exceptions are the fan motors and the gas detectors which must guarantee the safe operation also in case of hazardous gas concentration and are therefore of explosion-proof type.

The classification as non-hazardous area does not apply to the zone immediately near the injection head where a certain concentration of cyclopentane vapours may be present.

In this case the maximum quantity of cyclopentane which evaporates during a foaming cycle in the cabinet foaming cabin is $5 \times 1.5 = 7.5$ g.

Considering the ventilation around the injection head, also in this case it can be said that a significant concentration of cyclopentane is possible only in a very limited space around the injection head.

Taking into account a certain safety margin, it is reasonable to define a zone 1 with an extent of 0.5 m around the injection head.

In this zone the electrical devices must have a protection against explosion hazard suitable for zone 1 .

In the area of 0.5 m around the injection head only a proximity switch is installed. This apparatus is protected by an intrinsic safety barrier Pepperl & Fuchs, with type of protection [EEx ib] IIC and it is therefore suitable for the zone of installation.

The push-button board of the injection head is placed outside the hazardous area.

7. SUMMARY OF THE INSPECTION RESULTS

On the basis of the inspection made, taking into account the safety measures adopted and the modifications reported at item 6.2.2.c, it can be stated that the electrical installations of the OMS plant for the production and injection of expanded polyurethane in the HAMCO factory in Amman are provided with the protections against the risk of explosion required by international standards CEI-EN 60079-10 and CEI-EN 60079-14 and can therefore be declared in compliance with their specifications.

DICHIARAZIONE

Con la presente la IMPIANTI O.M.S. dichiara di aver sostituito lo strumento per il controllo della minima pressione azoto, montato a bordo serbatoio di stoccaggio ciclopentano installato presso la sede dello stabilimento HAMCO con sede in Amman (Giordania), con uno strumento analogo in versione Exi e di aver inserito nel relativo circuito elettrico una barriera di separazione.

Strumento: Manometro 0/2,5 bar con contatto induttivo di tipo namur
DIN19324 montato sull'equipaggio mobile.


Modello: SP 312-B2D/CI01

Costruttore: Fantinelli s.r.l. - Solbiate Olona

Sensore: Pepperl + Fuchs SJ2-N
certificato Ex n° PTB-83/2022 X

Barriera di separ.: Pepperl + Fuchs KFD2 SR2 EX1W

Verano Brianza 4/6/99



impianti  spa

PROT. n.	<u>99/015269</u>
CESI SYST	10 GIU 1999
COPIA	_____
A	_____

CESI PRODUCTS

CESITEST

Testing Services

CESICEPT

Inspection and Certification Services

CESIEMC

Services for Electronic Products

CESIPSC

Power System Consultant

CESISW

Software for Power System Analysis

CESISERVICE

Services for Electrical Installations

CESIRPF

Sistema Italiano Rilevamento Fulmini

CESIPROJECT

Design and Supply


CESI EDUCATION I

Training Services

CESI

Via Sabbionetta 4, 20050 Verano Brianza (Milano)
 Tel 0362/983.1 Fax 0362/983217
 Fax 335340 OMSVER I
 Email: impianti.oms@omsgroup.it

Cap. Soc. L. 4.500.000.000
 Sede Sociale Milano, Piazza Buonarroti 32
 Registro Imprese Milano N. 259496
 R.E.A. Milano N. 1218538
 C.F. P.I. IT 06322500151 - N. Mecc. MI 10225F



DESTINATARIO HANNOU P.O. BOX 926123 11110 AMMAN JORDANIA	CESSIONARIO: INTESTAZIONE FATTURA
LUOGO DESTINAZIONE DELLA MERCE C.S.	

DOCUMENTO DI TRASPORTO (DPR 472 del 14/08/96)

NS. RIF. CR99000046	VS. RIF. C.I. N.017/99AT-014/99AT	DATA DOCUMENTO 03/03/99	NUMERO DOCUMENTO DT99000255	PAG. 1
------------------------	--------------------------------------	----------------------------	--------------------------------	-----------

PARTITA IVA	PORTO C.I.F.	CAUSALE TRASPORTO Uscite per garanzia
-------------	-----------------	--

POS	CODICE ARTICOLO	DESCRIZIONE	U.M.	QUANTITÀ CIFRE	QUANTITÀ LETTERE
1	930600217	→ ORD CR99000046 V.RIF C.I. N.017/99AT-014/99AT DEL 19/01/99 FINECORSIA SIEMENS - TESTINA CON ROTELLA - IP67 - EN50041 MOD. 3SE3 120 IGV-2-ALTE AUSFUHRUNG BESCHRIFTUNG ALTE	NR	1,00	A,ZZ
1	025060100	→ VALVOLA + POMPANTE DIS. HPR275 + HPR278	NR	1,00	A,ZZ
1	921200401	→ ELETTROVALVOLA 5/2 1/8" COMPLETA DI BOBINA 110V 50/60HZ E CONNETTORE	NR	1,00	A,ZZ
1	921200102	→ ELETTROVALVOLA VE 133CN 2 VIE 3/4" N.C. EV21H9KB180	NR	1,00	A,ZZ
1	134173031	PULEGGIA 260 H100	NR	1,00	A,ZZ
1	134173028	PULEGGIA 214 H100	NR	1,00	A,ZZ
1	920301807	CINGHIA DENTATA 420 H 100	NR	1,00	A,ZZ
1	920300719	BILANCIATORE BHD 65	NR	1,00	A,ZZ
1	930100104	LIVELLO ELET.CO CAPA.VO ALC100 ELE 10/C	NR	1,00	A,ZZ
1	930401704	BARRIERA MOD.145	NR	1,00	A,ZZ
1	930100212	LIVELLO EL21 EXO CCRSSDXXKEX L=900 1"1/2 CON CERTIFICAZIONE PTB2097 PER ZONA 0,COMPLETO DI PREAMPLIFICATORE	NR	1,00	A,ZZ
1	930300701	CAVO RISCALDANTE 220V - LUNGHEZZA METRI 2 - 30W/m - CODULI lungh. 1000 - TEMPERATURA DI ESERCIZIO 150°C - art.CRF047010 RESISTOR	NR	1,00	A,ZZ
1	*	→ SET CASSETTA ATTREZZI	NR	1,00	A,ZZ
1	920100122	PRESSOSTATO 0-25 1 C. DN.100 831.2 1/2"	NR	1,00	A,ZZ
1	930401706	BARRIERA P&F A TRASFORMATORE ISOLATO USCITA A RELE' mod.KFD2-SR2-FX1W	NR	1,00	A,ZZ

TRASPORTO A CURA DEL VEICOLI	DATA E ORA INIZIO TRASPORTO 03/03/99 13:00	FIRMA CONDUCENTE
---------------------------------	---	------------------

VETTORE CORRIERE ROCCHI - VIA VARESE 8 - CERNUSCO S/N - MI	DATA E ORA DEL RITIRO 04/03/99 16,25	FIRMA VETTORE
--	--	-------------------

VETTORE ESI PARISI	DATA E ORA DEL RITIRO	FIRMA VETTORE
-----------------------	-----------------------	---------------

ASPETTO ESTERIORE DEL BENI 1 CASE + 1 CARTON	PESO KG 652 220	N. COLLI 2	FIRMA DESTINATARIO
---	-----------------------	---------------	--------------------

ANNOTAZIONI / VARIAZIONI

ISC 9032
Cert. n. 0577

Impianti OMS spa

Via Sabbionetta, 4
20050 Verano Brianza (Milano) Italy
Tel. 0362/983.1
Fax (0362) 983217
e-mail: impianti.oms@omsgroup.it
internet:www.omsgroup.it



ISO 9002
Cert. n° 0577



26/05/99

Verano Brianza,

Vs. rif.

Ns. rif.

HAMCO CO.

P.O.BOX 926123

11110 AMMAN

OGGETTO:

PROFORMA INVOICE N. 41/99

<i>Q.TY</i>	<i>Description</i>	<i>CODE</i>
01	MOTOR AS.3F POLES 4/8 KW 6.5/4.3 V380 HZ50	930201141
01	HOSE NYLAFLOW 620 3/8" CONNECTION 12S L=5000 MM	

- Value only for customs....USD. 110=
- Goods without value, under guarantee
- Goods rendered C.I.F. AMMAN AIRPORT

GOODS OF ITALIAN ORIGIN

N. 2 PACKAGES

1) CM. 64X52X55

2) CM. 48X34X11

TOTAL NET WEIGHT KG. 88=

TOTAL GROSS WEIGHT KG. 97.6

MARK: HAMCO CO.

11110 AMMAN (JORDAN)

CUSTOMS CODE: 84779010

074 MIL 88840662

074-88840662

Shipper's Name and Address IMPIANTI OMS SPA VIA SABBIONETTA, 4 20050 VERANO BRIANZA MI	Shipper's Account Number CF IT08322500151	Not negotiable Air Waybill Issued by K L M C A R G O KLM ROYAL DUTCH AIRLINES PO BOX 7700 1117 ZL SCHIPHOL THE NETHERLANDS
---	--	---

Copies 1, 2 and 3 of this Air Waybill are originals and have the same validity.

Consignee's Name and Address HAMCO CO P.O. BOX 926123 11110 AMMAN JORDAN	Consignee's Account Number	It is agreed that the goods described herein are accepted in apparent good order and condition (except as noted) for carriage SUBJECT TO THE CONDITION OF CONTRACT ON THE REVERSE HEREOF. ALL GOODS MAY BE CARRIED BY ANY OTHER MEANS INCLUDING ROAD OR ANY OTHER CARRIER UNLESS SPECIFIC CONTRARY INSTRUCTIONS ARE GIVEN HEREON BY THE SHIPPER, AND SHIPPER AGREES THAT THE SHIPMENT MAY BE CARRIED VIA INTERMEDIATE STOPPING PLACES WHICH THE CARRIER DEEMS APPROPRIATE. THE SHIPPER'S ATTENTION IS DRAWN TO THE NOTICE CONCERNING CARRIER'S LIMITATION OF LIABILITY. Shipper may increase such limitation of liability by declaring a higher value for carriage and paying a supplemental charge if required. Le merci qui decrites sont acceptées en apparence bon état et condition (sauf mention contraire) pour le transport en conformité avec les CONDITIONS DE CONTRAT DÉCRITES SUR LE RETO. TOUTES LES MARCHANDISES PEUVENT ÊTRE TRANSPORTÉES PAR D'AUTRES MOYENS Y COMPRIS LE ROUTIER OU PAR D'AUTRES CARRIER À MOINS QUE LE MITTENTE NE DONNE DES INSTRUCTIONS CONTRAIRES. LE MITTENTE ACCÉPTE QUE LA SPÉDITION POUVE ÊTRE TRANSPORTÉE À TRAVERS D'ESCALONS INTERMÉDIAIRES QUE LE VETTORE CONSIDÈRE OPPORTUN. SI RICHIAMATA L'ATTENZIONE DEL MITTENTE SULL'AVVISO CONCERNENTE LA LIMITAZIONE DI RESPONSABILITÀ DEL VETTORE. Il mittente può aumentare il limite di responsabilità del Vettore dichiarando un valore più elevato per il trasporto e pagando, ove richiesto, una tariffa addizionale.
---	----------------------------	---

Issuing Carrier's Agent Name and City AIR CARGO INTERNATIONAL SRL 02924860151 MILANO Tel.02 58011949 Tfx.58011917	Accounting Information "NON C.E.E. TRAFFIC" KLM REALI LINEE AEREE OLANDESI PALA ZZO RAFFAELLO VIA CASSANESE 2 MILANO OLTRE SEGRATE MI
--	--

Agent's IATA Code 00 0 0000 000 0	Account No.	NON VALE FATTURA AI FINI I.V.A.
--------------------------------------	-------------	---------------------------------

Airport of Departure (Addr. of First Carrier) and Requested Routing MILAN ITALY	Codice Fiscale / Partita IVA del Mittente IT08322500151	Imprenditore Non imprenditore <input type="checkbox"/> <input type="checkbox"/>	PF SD
--	--	--	----------

to	By First Carrier	Routing and Destination	to	by	to	by	Currency	CHGS Code	WT. VAL PPD COLL	Other PPD COLL	Declared Value for Carriage	Declared Value for Customs
AMS	KL		AMM	KL			ITL	XX	XX		NVD	NCV

Airport of Destination AMMAN, GIORDANIA	Flight/Date KL415	For Carrier Use only 020699	Flight/Date	Amount of Insurance XXXXXXXXXXXX	INSURANCE: If carrier offers insurance, and such insurance is requested in accordance with conditions on reverse hereof, indicate amount to be insured in figures in box marked "amount of insurance" ASSICURAZIONE: Quando il vettore offre una assicurazione e tale assicurazione sia richiesta in base alle condizioni indicate a tergo, indicare l'importo da assicurare in cifre nella casella "importo assicurato"
--	----------------------	--------------------------------	-------------	-------------------------------------	---

Handling Information
DOGANA A CURA BETA TRANS
PLS ADV ONEE IMM UPON ARRIVAL PHONE 00962/5/3650022 FAX 00962/5/3651893
2 PARCELS MARKED AS ADDR.
ATT. PROFORMA INVOICE
STATUS "C"

No of Pieces RCP	Gross Weight	Kg / lb	Rate Class	Chargeable Weight	Rate / Charge	Total	Nature and Quantity of Goods (incl. Dimensions or Volume)
			Commodity				
2	97.60			100.0	4.410	441.000	SPARE PARTS NATURA DELLA MERCE CON FORME AL DICHIARATO E QUARANTENA 24 ORE E EFFETTUATA PRESSO I NOE TRI MAGAZZINI ** THANK YOU FOR SHIP PING WITH AIR CARGO IN TERNATIONAL **
2	97.60					441.000	

Prepaid	Weight Charge	Collect	Other Charges	IAT-DIPT-C	P.B.A. Fee
441.000				3620	9000
Valuation Charge			Insurance Premium		
Tax					
Total Other Charges Due Agent			Shipper certifies that the particulars on the face hereof are correct and that insofar as any part of the consignment contains dangerous goods, such part is properly described by name and is in proper condition for carriage by air according to the applicable Dangerous Goods Regulations.		
Total Other Charges Due Carrier			Il mittente dichiara che le indicazioni contenute sul fronte della LTA sono esatte, e che qualora una parte della spedizione contenga merci pericolose, tale parte è debitamente indicata ed è nelle condizioni richieste ai fini del trasporto per via aerea secondo le norme sulle Merci Pericolose.		
14.080			IMPIANTI OMS SPA		
Total Prepaid			Signature of Shipper or his Agent		
455.080			F. DE GIAMPAULIS		
Currency Conversion Rates			As Agent of Carrier		
CC Charges in Dest. Currency			JUN 01ST 99 MILANO		
For Carriers Use only at Destination			Executed on (Date) at (Place) Signature of Issuing Carrier or its Agent		
Charges at Destination			051 999-00258-00 PD		
Total Collect Charges			074-88840662		

I.V.A. NON IMPONIBILE - ART. 9 PRIMO COMMA D.P.R. 633/72 PRO QUOTA

ORIGINAL 3 (FOR SHIPPER)

Impianti OMS spa

Via Sabbionetta, 4
20050 Verano Brianza (Milano) Italy
Tel. 0362/983.1
Fax (0362) 983217
e-mail: impianti.oms@omsgroup.it
internet:www.omsgroup.it



ISO 9002
Cert. n° 0577



11.06.1999

Verano Brianza,

Vs. rif.

Ns. rif.

HAMCO CO.

P.O. BOX 926123

11110 AMMAN, JORDAN

OGGETTO:

PROFORMA INVOICE NO. 046/99

<i>Q.TY</i>	<i>Description</i>	<i>CODE</i>
1	NON RETURN VALVE FPRI ¾"	920404019

- GOODS WITH NO COMMERCIAL VALUE, UNDER GUARANTEE
- VALUE FOR CUSTOMS PURPOSES ONLY USD 10

GOODS OF ITALIAN ORIGIN
NO. 1 CARTON CM 27X21X12
GROSS WEIGHT KG 0,2

MARK: HAMCO CO.
 P.O. BOX 926123
 11110 AMMAN, JORDAN

COD. BRUXELLES: 84779010



Impianti OMS S.p.A.
Via Sabbionetta, 4
20050 Verano Brianza (Mi) Italy

Phone Nr. 0362/9831
Fax Nr. 0362/983217
E-mail Impianti.oms@omsgroup.it

Telefax Ref. : 2161/99 MDO/pm
Date : 04.06.99
To : **HAMCO**
Attention : MR. H. JABER
Fax Nr. :
Nr.Pages : 01
REF./SUBJECT : **YOUR FAX MESSAGE DTD.03.04.99 - CYCLOPENTANE LINE, FIRE
ATTACK IN DOORS AREA**

**IF THIS MESSAGE IS RECEIVED GARBLED OR NOT COMPLETE PLEASE
CONTACT US ADVISING PAGE - NUMBER TO BE RESENT**

We will forward you the non return valve.

As to the electric diagram we await the coming back of our technician on next week, in order for us to give you a preciser answer.

Concerning the doors foaming fixture you placed in the foaming area, as already written to you on 20.05.99, it is recommended to check whether the earthing has been carried out.

We do confirm: that kind of danger can be avoided carrying out a good hearing of the fixture as it is shown in our handbooks. You should also replace the polythene film with some paper sheet that do not generate electrostatic charges.

Looking forward to hearing from you as soon as possible.

Best regards.

M. DELL'ORTO
IMPIANTI OMS SPA

impianti



s p a

Servizio Tecnico N. 10 22-01
 Technical Service No. _____
 Data 11-05-88
 Date _____
 Tecnico CANAATO
 Technician _____
 Cliente HAMECO Comm. N. _____
 Customer _____ Order No. _____

macchine per espansi poliuretanic

N. No.	Data Date	Ore viaggio Travel hours		Ore lavoro Working hours		Totale ore Total hours
		Andata Go	Ritorno Back	A.M.	P.M.	
1	5-5	10				10
2	6-5			6	5	11
3	7-5			5	5	10
4	8-5			5	5	10
5	9-5			5	5	10
6	10-5			5	5	10
7	11-5			5	5	10

Descrizione intervento Description of intervention

- 1 Assembling new SP tank level and LC tub control.
 - 2 Assembling new pressure gauge EX in the pump CP line.
 - 3 Assembling Heating of compressor vane in Rossi fixture
 - 4 Adjustment the Jo Klimatik head and piping.
 - 5 Assembling the new parts broken in the fixtures
 - 6 Disassemble the ruke and assembling new in the pentabend.
 - 7 Training on the HAMECO tenacif and foaming refrigerator and dorp.
- The plant working in conformity specifications

MATERIALI PER INTERVENTO / MATERIALS FOR INTERVENTION			
Descrizione Description	Quantità Qty	Quantità / Quantity	
		Prelev. Taken off	Mont. Assembled
10-5 10		-10	+5

Percorrenza Km. _____
 Km. Journey _____
 Spese Alloggio / Pranzi DINARI L. 850
 Board / Lodging _____
 Altre _____
 Others _____

Il magazziniere
The storeman

Note / Notes: _____

Expressly and without reservation all the clauses of above mentioned order and of conditions on the back with particular reference to clauses N° 1 - 2 - 3 - 4 - 5 - 6 - 7 - 8 - 9 - 10 are accepted.
 Regular invoice will follow.

Il tecnico
The Technician P. Canaato

Si accettano esplicitamente ed incondizionatamente tutte le clausole di cui all'ordine sopra steso ed alle condizioni retro indicate con particolare riferimento alle clausole N° 1 - 2 - 3 - 4 - 5 - 6 - 7 - 8 - 9 - 10.

Segue regolare fattura.

Il Cliente
The Customer H. Jaber / HAMECO