



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as "developed", "industrialized" and "developing" are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

22335

137 p.
tables
graphs
diagrams
illus.

United Nations Industrial Development Organization

Contract 97/106

*Phasing out CFC-11 and CFC-12
in the production of domestic refrigerators
and replacing them by
cyclopentane and HFC-134a*

UZINA MECANICA SADU
BUMBESTI JIU
ROMANIA

Final Report
on activities performed
from september 1997 to december 1998
and further assistance
by
Riviera S.r.l.
Varese, Italy

- WORK PLAN AFTER
VISITING THE COUNTER PART

OCTOBER 1997

RIVIERA S.r.l. - Contract 97/106 - U.M. Sadu, Romania

Methodology and concepts for conversion of U.M. Sadu plants to usage of non-Ozone Depleting Substances

Please find herebelow some preliminary information regarding the work plan for the project :

A. Refrigeration System

Working cycle

The usage of R 134a refrigerant does not require major changes regarding working cycle, compared to the usage of R 12. However, some extra care must be applied, especially regarding:

- internal cleanliness
- internal humidity/moisture
- vacuum level

It is necessary for all materials to have some protection, in their terminal part.

Also, there is a limit of time within which the components must be fixed on the units, from the moment they are open or remain un-protected :

- filter = 10 minutes
- compressor = 10 minutes
- cyrcuit and related parts = 30 minutes

The working cycle must be done respecting the following :

pre-fixing

- covers and protections must be removed only at the moment of junction or welding operations
- the return tube must be closed with a cover and the capillar must be closed with a cover or by pressing.

IMPORTANT :

- Parts and components for R 134a with 1 or more open terminal parts must be repaired, and inflated with dry air for 5 minutes at 6 bar pressure
- NB- terminals to be checked :
 - hot tube
 - return tube
 - capillar

Quality standards

- A- Internal cleanless
 - dissolvable and flowing residue mg/mq 100
 - no residue of : minerals
 - paraffin
 - greases
 - waxes
 - silicon
 - all materials non- R 134a compatible
 - absence of chlorine
- B- Internal humidity/moisture
 - residual moisture < 250 parts per million
- C- vacuum level
 - non-condensable gases < 1%

BAD QUALITY OF THE CHARGE = CAPILLAR OCCLUSION

Riviera S.r.l. - Contract 97/106 - U.M. Sadu, Romania

Methodology and concepts for the conversion of two plants to usage of non-ozone depleting substances

B. Foaming system

Introduction

The use of c-pentane during the production process will require adequate procedures, in addition to some safety instructions to control the presence of c-pentane in the working ambient.

The more potentially dangerous areas, to be kept under constant check, are :

- the c-pentane storage area
- the foam mixing area
- the injection points on the foaming jigs.

C-pentane can be used only by means of high pressure machines, with self-cleaning mixheads at impingement system.

The advantages of a high pressure system, compared to a low-pressure system are :

- better polyol-isocyanate mixing
- general better cleanliness of the working area
- general better working conditions for the operators in the foaming area

Polyol thermostating

The polyol temperature is of particular relevance to obtain a proper mixing with c-pentane, therefore the system comprises a its 250 tank, complete with a pneumatic pump for the loading from the drum. This permits the thermostatation with electric resistances and chiller, intervening after a signal from a probe.

Dry section (jigs, moulds and plugs)*

Jigs :

A particular execution is required for foaming jigs.

The heating, both for door and cabinet jig is done by means of water circulation, therefore eliminating resistances.

Jigs are enclosed in separate exhaustion booths, complete with exhausters flow-transducers and catalytic sensors.

Both the exhaustion and monitoring systems are controlled by an electric switchboard.

Moulds and plugs :

The use of C-pentane requires that moulds and plugs are made of alluminium and the temperature must precisely controlled.

Therefore, the cabinet foaming plugs are heated by a heating unit (fan + electric resistances), located outside the exhaustion booth.

The door moulds are, instead, fixed to the jigs' plane that keeps them at proper temperature.

*modification, only

Safety

As already mentioned, this particular aspect will be monitored by TUF later stage and described in a specific way, due to its importance.

However, in the machineries' project and production, all safety standards have been considered, due to the nature of c-pentane, which is potentially dangerous. As described, high-sensitivity sensors assure a complete and accurate check on the whole system, as well as the exhausters guarantee an adequate ventilation and air circulation, in compliance with all existing International Safety Rules.

b. storage precautions and advice

no smoking
no use of free flames
compulsory use of anti-spark fittings
compulsory hearthing of all equipments
compulsory protection against atmospheric discharges
compulsory safety electric systems

store in a fresh and ventilated ambient
protect from direct insulation and heat sources
keep away from above mentioned not-compatible substances

c. leakages

In case of leakages, following instructions should be followed :

circumscribe the area
before taking any action, wear protection outfits
remove any possible source of ignition or spark
to avoid the expansion of the leakage, use proper sand or
absorbing powder
spray with vaporized water to avoid gas expansion

In case of fire, use :

specific chemical powders
Co2
alchohol-resistant foams
spray the containers with water if exposed to the fire.

d. handling

According to situations and circumstances, following outfits must be worn :

Facial mask with filter for organic vapours
surrounding protection glasses
rubber gloves
anti-static boots.



21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 282984 - telefax 0332 / 240309 - telex 325126
Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

LIST OF CIVIL WORKS TO BE EXECUTED

LAVORI CHE DOVRANNO ESSERE ESEGUITI DA UZINA MECANICA SADU

AREA DI SCHIUMATURA ARMADI E PORTE DEI FRIGORIFERI CON COMPRESSORE

- Rimozione completa delle macchine dosatrici esistenti, del relativo piping e delle teste di miscelazione.
- Realizzazione su indicazione O.M.S. dei vari supporti e sostegni del nuovo piping rigido e flessibile.
- Predisposizione e dimensionamento delle varie utilities (energia elettrica, acqua, azoto, ecc.) nei rispettivi punti di attacco per le varie attrezzature, in accordo al Lay Out impianto.
- Allacciamento del piping di alimentazione ai componenti (FCL/ISO) dai serbatoi di stoccaggio ai punti d'allacciamento sulla macchina dosatrice.
- Spostamento di tutte le cassette di derivazione elettrica e componentistica varia, dalla zona di schiumatura
- Eventuale rifacimento delle connessioni elettriche con un grado di protezione idoneo.
- Pulizia in generale ed eventuale livellamento della pavimentazione dove richiesto.
- Modifica sia sulle maschere di schiumatura che sul prodotto, per adattare il foro di colata al diametro esterno delle nuove teste di miscelazione.

AREA DI STOCCAGGIO PENTANO PER ZONA FRIGORIFERI A COMPRESSORE

- Preparazione della struttura di contenimento e copertura del serbatoio di stoccaggio pentano da 3000 dm³ secondo indicazione da parte O.M.S.
- Realizzazione e montaggio dei vari supporti di sostegno del piping di trasferimento pentano.
- Montaggio, su indicazione O.M.S., dei piping di trasferimento pentano.
- Predisposizione e dimensionamento delle varie utilities (energia elettrica, azoto, ecc.) nei rispettivi punti di attacco per le varie attrezzature, in accordo al Lay Out impianto.



21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 282984 - telefax 0332 / 240309 - telex 325126
Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

AREA DI SCHIUMATURA ARMADI E PORTE DEI FRIGORIFERI AD ASSORBIMENTO

- Rimozione completa della macchina dosatrice esistente, del relativo piping e della testa di miscelazione.
- Realizzazione su indicazione O.M.S. dei vari supporti e sostegni del nuovo piping rigido e flessibile.
- Predisposizione e dimensionamento delle varie utilities (energia elettrica, acqua, azoto, ecc.) nei rispettivi punti di attacco per le varie attrezzature, in accordo al Lay Out impianto.
- Spostamento di tutte le cassette di derivazione elettrica e componentistica varia, dalla zona di schiumatura
- Eventuale rifacimento delle connessioni elettriche con un grado di protezione idoneo.
- Pulizia in generale ed eventuale livellamento della pavimentazione dove richiesto.
- Modifica sia sulle maschere di schiumatura che sul prodotto, per adattare il foro di colata al diametro esterno delle nuove teste di miscelazione.

AREA DI STOCCAGGIO PENTANO PER ZONA FRIGORIFERI AD ASSORBIMENTO

- Preparazione delle fondazioni di contenimento e copertura del serbatoio di stoccaggio pentano da 10.000 dm³ secondo indicazione da parte O.M.S.
- Realizzazione e montaggio dei vari supporti di sostegno del piping di trasferimento pentano.
- Montaggio, su indicazione O.M.S., del piping di trasferimento pentano.
- Predisposizione e dimensionamento delle varie utilities (energia elettrica, azoto, ecc.) nei rispettivi punti di attacco per le varie attrezzature, in accordo al Lay Out impianto.

- RE-DESIGN AND
PROTOTYPING OF
REFRIGERATORS AND
THERMOSTATS

DEC 1997 TO MAY 1998

- DESIGN AND
DRAWINGS OF THE
FOAMING LINES

SPRING 1998

Riviera S.r.l.

Contract 97/106

Conversion of Bumbesti Jiu
factory of Uzina Mecanica Sadu
to phase-out the use of CFC-11 and 12
in the production of domestic appliances.

The prototype program for the above-mentioned project has been done a.f. :

- 1- The first step was the execution of tests and the provision of technical data-sheets on Sadu's models at our premises in Italy.

Advice was given on various points :


- determination of the charging quantities of R 134a, compared to the previous quantities of R 12. Such quantities increased, in their models, in order to achieve good performances.
- advice on the handling of the capillar tubes, due to the high sensitivity of R 134a to moisture. The use of caps and protections was stressed as an essential operation.
- Advice was given on the proper execution and on the proper assembling, fixing and welding of their units, which was, also, one of the causes of the previous bad performances.
- determination of the injected foam quantities when passing from R 11 to CP as foam blowing agent. The required density of the foam increased from R11 to CP, therefore the quantities of blowing agent had to be increased, in accordance.
- We gave them a list of suppliers of new components (filters, compressors etc...) that had to be changed, and, also, we contacted various suppliers of CP, in order to follow-up the future supplies.

- 2- The studies and re-design of their thermostats has been done as per enclosed summary reports, for Your files. Please note none of their staff speaks english, therefore we decided to use italian for communication, which is widely accepted and spoken in Romania.
- 3- Part of their staff attended the tests and studies as per above points (1) and (2) during their visit to our premises in Italy.
- 4- All machineries and equipments included in the Project have not only been purchased but are, currently, under shipment.
- 5- The Project site has been inspected before and after the execution of all civil works carried out by Sadu, following our advice on the implementation of the safety procedures and strategy. All old machineries will be removed and disassembled before the installation and commissioning activities.



CARACTERISTICI TEHNICE
TECHNICAL STANDARD
CARACTÉRISTIQUES TECHNIQUES

| Tip Type Type | FRAM 140 L | FRAM 180 L | FRAM 240 L |
|---|----------------|-------------------|-----------------|
| Capacitate Capacity Capacité | 140 l | 180 l | 240 l |
| Compartiment congelator Ice box Compartiment congelator | 14 l | 19 l | 19 l |
| Dimensiuni Dimensions Dimensions | 85x55x60 cm | 104,3x55x60 cm | 132x55x60 cm |
| Greutate Gross weight Poids totale | 41 kg | 47 kg | 55 kg |
| Alimentare Voltage Voltage | 220 V/50 Hz | 220 V/50 Hz | 220 V/50 Hz |



Observatii

- clasa de temperatură: N (temperat normal)
- termostat de inalta precizie, reglabil, cu dezghet semiautomat

Observations

- temperature class: N (normal temperate)
- adjustable high precision thermostat with semi-automatic defrost

Observations

- la classe de temeperature: N (normal tempéré)
- thermostat réglable de grande précision avec un degivrage semi-automatique

Institutul de Cercetare și Proiectare pentru Electrotehnică
Research and Design Institute for Electrical Engineering



**LABORATORUL DE ÎNCERCĂRI PENTRU CERTIFICAREA
PRODUSELOR ELECTRICE**
Testing Department for Electrical Products Certification

AVIZ NR. 545 / 09.08.1996
APPROVAL NO.

PRODUSUL:
PRODUCT:

RACITOR ELECTRIC CU MOTOCOMPRESOR
FRAM 180 1 cod 2118

ÎNCERCAT LA SOLICITAREA:
TESTED ON REQUEST OF:

UZINA MECANICA SADU.-

FABRICAT DE:
MANUFACTURED BY:

UZINA MECANICA SADU.-

VALORI NOMINALE ȘI CARACTERISTICI
PRINCIPALE:
RATED VALUES AND MAIN
CHARACTERISTICS:

220V; 120 W; V brut = 180 l clasa N
V comp xx = 19 l
Clasa de protecție : I
Agent frigorific : R 134 a(85g)

MARCA DE FABRICĂ:
TRADE MARK:


F R A M.-

CONCLUZII:
CONCLUSIONS:

Produsul este considerat conform
STAS 2614/24-88 și STAS 2614/1-86, în
baza rezultatelor din BI 705/09.08.96

AVIZUL ESTE VALABIL:
APPROVAL IS VALID:

pînă la 09.08.1997



ŞEF LABORATOR
DEPARTMENT CHEF
ing. Nicolae Rogoveanu

INTOCMET DE
DRAWN UP BY
ing. Elena Plescan

COMMERCIALIZAREA PRODUSELOR CARE NU SUNT IDENTICE CU CEL PENTRU CARE S-A EMIS PREZENTUL AVIZ, SE FACE PE PROPRIA RĂSPUNDERE A BENEFICIARULUI AVIZULUI.

Institutul de Cercetare și Proiectare pentru Electrotehnica
Research and Design Institute for Electrical Engineering



**LABORATORUL DE ÎNCERCĂRI PENTRU CERTIFICAREA
PRODUSELOR ELECTRICE**
Testing Department for Electrical Products Certification

AVIZ NR. 546 / 09.08.1996
APPROVAL NO.

PRODUSUL:
PRODUCT:

RACITOR ELECTRIC CU MOTOCOMPRESOR
FRAM 240 1 cod 2124 .-

ÎNCERCAT LA SOLICITAREA:
TESTED ON REQUEST OF:

UZINA MECANICA SADU .-

FABRICAT DE:
MANUFACTURED BY:

UZINA MECANICA SADU .-

**VALORI NOMINALE ȘI CARACTERISTICI
PRINCIPALE:**
RATED VALUES AND MAIN
CHARACTERISTICS:

220 V; 150 W; V brut = 240 l clasa N
V comp xx = 19 1
Clasa de protecție : I
Agent frigorific : R 134a (loog)

MARCA DE FABRICĂ:
TRADE MARK:


F R A - M . -

CONCLUZII:
CONCLUSIONS:

Produsul este considerat conform
STAS 2614/24-88 și STAS 2614/1-86
în baza rezultatelor din BI 706/09.08
1996 .-

AVIZUL ESTE VALABIL:
APPROVAL IS VALID:

pînă la 09.08.1997 .-



SEF LABORATOR
DEPARTMENT CHEF
ing. Nicolae Rogoveanu

INTOCMIT DE
DRAWN UP BY
ing. Elena Pleșcan

COMERCIALIZAREA PRODUSELOR CARE NU SUNT IDENTICE CU CEL PENTRU CARE S-A EMIS PREZENTUL AVIZ SE FACE PE PROPRIA RĂSPUNDERE A BENEFICIARULUI AVIZULUI.

SPLAIUL UNIRII Nr.313, SECTOR 3, BUCUREŞTI, 74204, ROMÂNIA
TELEX : 10486, FAX : 3213769/3222748, TEL : 3236016

PERFORMANCE TESTS ("EMPTY" Conditions)


Riviera

NAME OF UNIT FRAM 240 L.

REF. RULES

FILE

| COMPRESSOR | CONDENSER | CAPILLAR | CHARGE | THERMOSTAT | EVAPORATOR |
|------------|-----------|----------|--------|------------|------------|
| | | 8 LT/MIN | | | |

| AMBIENT TEMP. °C | + 32°C (1) | | + 32°C (2) | | + 32°C (3) | |
|----------------------------|------------|----------|------------|----------|------------|----------|
| THERMOSTAT | 10/10 | 5/10 | 10/10 | 5/10 | | |
| POSITION | ON - OFF | ON - OFF | ON - OFF | ON - OFF | ON - OFF | ON - OFF |
| High temp. Refr. °C | - | + 6.1 | - | + 4.4 | - | - |
| - 1.8 | + 5.0 | - 2.3 | + 4.3 | - 2.5 | - | - |
| Medium temp. Refr. °C | - | + 5.7 | - | + 4.5 | - | - |
| - 1.6 | + 5.4 | - 2.6 | + 4.5 | - 1.0 | - | - |
| Low temp. Refr. °C | - | + 5.5 | - | + 4 | - | - |
| - 1.4 | + 5.3 | - 3.1 | + 4 | - 2.0 | - | - |
| Refr. average °C | - 1.6 | + 5.6 | - 2.6 | + 4.2 | - 2.4 | - |
| High temp. Freezer °C | - | - 6.4 | - | - 8 | - | - |
| Medium temp. Freezer °C | - | - | - | - | - | - |
| Low temp. Freezer °C | - | - 7.2 | - | - 8.4 | - | - |
| Freezer average °C | - 15.5 | - 6.8 | - 16.2 | - 8.2 | - 15.8 | - |
| therm. bumb temp. °C | - 24 | - 9.6 | - 24.5 | - 9.0 | - 23.0 | - |
| - 10 | - | - | - | - 10.2 | - | - |
| Functioning % | 100% | 56.5% | 100% | 43.4% | 100% | - |
| Consumption kwh/24 | | | | | | |
| Power W | | | | | | |
| CURRENT A | - | - | - | - | - | - |
| | - | - | - | - | - | - |
| | - | - | - | - | - | - |

NOTES : NEL PUNTO 3 LE PROVE SI RIFERISCONO CON CAPILLARE DI
CIRCA 4,5LT/MINUTO



PERFORMANCE TESTS ("EMPTY" Conditions)

NAME OF UNIT FRAM 150L.

REF. RULES

FILE

| COMPRESSOR | CONDENSER | CAPILLAR | CHARGE | THERMOSTAT | EVAPORATOR |
|------------|-----------|---------------|--------------|------------|------------|
| - | - | 8LT' / 4.5LT' | GR. 85 R134a | - | 19L |
| | | | | | |

| AMBIENT TEMP. °C | 32°C CAP. 8LT ① | | 32°C ② | | 32°C ③ | |
|----------------------------|-----------------|----------|----------|----------|----------|----------|
| THERMOSTAT | 10/10 | | 10/10 | | 10/10 | 8/10 |
| POSITION | ON - OFF | ON - OFF | ON - OFF | ON - OFF | ON - OFF | ON - OFF |
| High temp. Refr. °C | +8.4 | | +4.6 | | +1.6 | +4 |
| Medium temp. Refr. °C | +8.3 | | +4 | | +1.2 | +3.8 |
| Low temp. Refr. °C | +8 | | +3.7 | | +0.7 | +3.2 |
| Refr. average °C | +8.2 | | +4.1 | | +1.1 | +3.7 |
| High temp. Freezer °C | | | | | | -15 |
| Medium temp. Freezer °C | | | | | | |
| Low temp. Freezer °C | | | | | | -12.8 |
| Freezer average °C | -12.5 | | -14.8 | | 17.8 | -13.9 |
| therm. bumb temp. °C | -20.6 | | -20 | | -21.9 | -21.3 |
| Functioning % | 100% | | 100% | | | 75.2 |
| Consumption kwh/24 | | | | | | |
| Power W | | | | | | |
| CURRENT A | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

NOTES :



DOMENIU DE UTILIZARE USING FIELD DOMAINE D'UTILISATION

Termoregulatoarele sunt aparate care se utilizeaza la racitoarele electrice, congelatoare orizontale, verticale si instalatii frigorifice, avand rolul de a comanda inchiderea si deschiderea automata in limitele temperaturilor de regim stabilite prin caracteristicile tehnice ale produsului.

The thermostat is an apparatus used for electric coolers, refrigerating plants, horizontal and vertical deep freezers, for automatic switching in and releasing at the touch of the temperature established by the technical standard of the product.

Le thermostat est un appareil utilisé pour les réfrigérateurs électriques aux installations frigorifiques, aux congélateurs horizontaux et verticaux, pour l'enclanchement et le déclanchement automatique, à l'atteinte des températures établies par les caractéristiques techniques du produit.

CARACTERISTICI TEHNICE TECHNICAL STANDARD CARACTÉRISTIQUES TECHNIQUES

| Tipul termostatului Type of thermostat Type de thermostat | T3H | | T4H | | | T5H | | |
|--|---------------------------------------|-------|---|-------|-------|---|-------|-------|
| Dimensiuni Dimensions Dimensions | 66X29,4X54,3 mm | | 66X29,4X62,8 mm | | | 66X29,4X54,3 mm | | |
| Greutate Net weight Poids net | 0,110 kg | | 0,097 kg | | | 0,095 kg | | |
| Distanta intre gaurile de prindere Distance between catch holes Distance entre les trous d'accroissement | 55 mm | | 55 mm | | | 55 mm | | |
| Lungimea sondei Well length Longueur de la sonde | la cerere on demand sur l'ordre | | la cerere on demand sur l'ordre | | | la cerere on demand sur l'ordre | | |
| Tensiunea de alimentare Nominal voltage Voltage | 220 V | 250 V | 220 V | 250 V | 127 V | 220 V | 250 V | 127 V |
| | 50 Hz | 50 Hz | 50 Hz | 50 Hz | 50 Hz | 50 Hz | 50 Hz | 50 Hz |
| | | 60 Hz | | 60 Hz | 60 Hz | | 60 Hz | 60 Hz |
| Curentul nominal Nominal current Courant nominal | 2 A | 2 A | 2 A | 2 A | 3 A | 2 A | 2 A | 3 A |
| | | 4 A | | 4 A | 6 A | | 4 A | 6 A |
| Mod de dezghetare Mode of thaw Mode de dégivrage | manual manual manuel | | semiautomat halfautomatic semiautomatique | | | manual manual manuel | | |
| Domeniu de reglare Adjustable range Domaine réglable | -32°C - 0°C | | -25°C - +5°C | | | -25°C - 0°C | | |
| Domeniu de utilizare Useful range Domaine utile | 225° | | 180° sau 225° 180° or 225° 180° ou 225° | | | 180° sau 270° 180° or 270° 180° ou 270° | | |



**LABORATORUL DE ÎNCERCĂRI PENTRU CERTIFICAREA
PRODUSELOR ELECTRICE**
Testing Department for Electrical Products Certification

AVIZ NR. 539 / 31.07.1996
APPROVAL NO.

PRODUSUL:
PRODUCT:

Termoregulator tip T5H2

ÎNCERCAT LA SOLICITAREA:
TESTED ON REQUEST OF:

Uzina Mecanică Sadu

FABRICAT DE:
MANUFACTURED BY:

Uzina Mecanică Sadu

VALORI NOMINALE ȘI CARACTERISTICI
PRINCIPALE:
RATED VALUES AND MAIN
CHARACTERISTICS:

220 Vca, 2 A,
clasa I de protecție împotriva
electrocutării

MARCA DE FABRICĂ:
TRADE MARK:

FRAM

CONCLUZII:
CONCLUSIONS:

Produsul este considerat conform
cu STAS 2614/1-86 în baza rezul-
tatelor din BI nr. 691/31.07.96.

AVIZUL ESTE VALABIL:
APPROVAL IS VALID:

de la 31.07.96 până la 31.07.97

MANAGER GENERAL

Dr. ing. Nicolae Vasile



ŞEF LABORATOR

DEPARTAMENT CHEF

ing. Nicolae Rogoveanu

INTOCMIT DE
DRAWN UP BY

ing. Hahui Cornelia

COMERCIALIZAREA PRODUSELOR CARE NU SUNT IDENTICE CU CEL PENTRU CARE S-A EMIS PREZENTUL AVIZ SE FACE PE PROPRIA RĂSPUNDERE A BENEFICIARULUI AVIZULUI.

SPLAIUL UNIRII Nr.313, SECTOR 3, BUCUREŞTI, 74204, ROMÂNIA
TELEX : 10486, FAX : 3213769/3222748, TEL : 3236616

Institutul de Cercetare și Proiectare pentru Electrotehnică
Research and Design Institute for Electrical Engineering

**LABORATORUL DE ÎNCERCĂRI PENTRU CERTIFICAREA
PRODUSELOR ELECTRICE**
Testing Department for Electrical Products Certification

AVIZ NR. 540 / 31.07.1996
APPROVAL NO.

PRODUSUL:
PRODUCT:

Termoregulator tip T4H

ÎNCERCAT LA SOLICITAREA:
TESTED ON REQUEST OF:

Uzina Mecanică Sadu

FABRICAT DE:
MANUFACTURED BY:

Uzina Mecanică Sadu

VALORI NOMINALE ȘI CARACTERISTICI
PRINCIPALE:
RATED VALUES AND MAIN
CHARACTERISTICS:

220V.c.a, 2 A
clasa de protecție împotriva
electrococării : I

MARCA DE FABRICĂ:
TRADE MARK:


FRAM -

CONCLUZII:
CONCLUSIONS:

Produsul este considerat conform
cu STAS 2614/1-86 în baza rezulta-
telor din BI nr. 692/31.07.1996.

AVIZUL ESTE VALABIL:
APPROVAL IS VALID:

31.07.1996 până la 31.07.1997



SEF LABORATOR
DEPARTMENT CHEF
ing. Nicolae Radovoreanu

INTOCMIT DE
DRAWN UP BY

ing. Hahui Cornelia

COMERCIALIZAREA PRODUSELOR CARE NU SUNT IDENTICE CU CEL PENTRU CARE S-A EMIS PREZENTUL
AVIZ SE FACE PE PROPRIA RĂSPUNDERE A BENEFICIARULUI AVIZULUI.

SPLAIUL UNIRII Nr.313, SECTOR 3, BUCUREȘTI, 74204, ROMÂNIA
TELEX : 10486, FAX : 3213769/3222748, TEL : 3236616

20 dicembre 1997

RELAZIONE DI VISITA ALLA UZINA MECANICA SADU ROMANIA

Nei giorni 17 - 18 dicembre 1997 abbiamo incontrato i tecnici della UZINA MECANICA SADU e abbiamo visitato la fabbrica di termostati di Bumbesti Jiu.

Ai tecnici è stato illustrato il programma di lavoro studiato e la relativa procedura che intendiamo seguire per sostituire gli attuali gas di carica dei termostati (Freon 12 e Freon 22) con altri gas Non CFC.

Dopo la discussione tecnica, abbiamo consegnato il seguente materiale informativo:

- 1. Relazione Riviera datata 14.12.97 (pagine 9), con lo studio per l'eliminazione dei fluidi refrigeranti Freon, scelta dei nuovi gas di carica, modalità per determinare la pressione di carica dei nuovi gas per i loro modelli di termostato.**

- 2. Tabelle di conversione Temperatura/Pressione dei vari gas in esame R12, R22, R134A, Propano C3H8**

- 3. Relazione Riviera datata 15.12.97 (pagine 11), relativa alla analisi eseguita in Italia sui campioni di termostato ricevuti da SADU, T3H - T4H - T5H e sui soffietti caricati da SADU con Freon 22 e Freon 134A.

La relazione comprende:

- valori di temperatura riscontrati in Italia letti su banchi di controllo
- analisi gascromatografiche della qualità del gas di carica dei termostati e degli altri soffietti, con singoli cromatogrammi allegati
- esame della tenuta delle punte del capillare pinzato (sotto la goccia di stagno)

- 4. Tabella con la purezza dei gas di carica Propano grado 99.9%
- 5. Relazione Riviera sulla metodologia di depurazione del gas e dell'impianto di carica
- 6. Fascicoli Bibliografici sulle caratteristiche chimico - fisiche dei 4 gas in esame (freon 12 - freon 22 - R134A - propano C3H8)
- 7. Campioni di termostati e soffietti SADU caricati in Italia con propano C3H8 a 7 Atm e a 4 Atm per le prove di comparazione sui valori di temperatura.

Durante la visita agli impianti produttivi, abbiamo esaminato il loro impianto di carica.

Questo impianto, a nostro avviso, presenta i seguenti aspetti positivi e negativi, visti anche in relazione all'utilizzo del nuovo gas propano C3H8.

ASPETTI POSITIVI

- L'impianto è funzionante in locale a temperatura non inferiore a + 20°C, quando fuori la temperatura era di -15°C
- La bombola del gas è riscaldata
- Il gas prima della carica è ulteriormente riscaldato a +40°C

ASPETTI NEGATIVI

- La bombola del gas non può essere posizionata nel reparto di carica dei soffietti, ma deve essere posizionata all'esterno e sistemata secondo le normative di sicurezza vigenti in Romania. La bombola deve essere collegata all'impianto di carica mediante tubo in rame saldato e collaudato ad alta pressione - min 20 bar - (vedere schema di collegamento delle bombole di gas allegato A).

- Il manometro di regolazione della pressione di carica non deve essere del tipo a contatti elettrici per evitare esplosioni.
- L'impianto di carica è a comando manuale, quindi senza la possibilità di eseguire cicli di "lavaggio" dei soffietti in carica. Il vuoto a volte non è sufficiente a togliere completamente gli incondensabili dall'interno dei soffietti da caricare; lo conferma il fatto che su 5 soffietti caricati in SADU ed esaminati in Italia, nr 2 avevano dal 20 al 40% di gas estraneo al gas di carica, quando i limiti di incondensabili ammessi sono nell'ordine max di 100 PPM.
- Tutti i residui di gas di carica, specialmente con propano, devono essere portati all'esterno del locale di carica. Il tubo collegato alla pompa del vuoto deve sfogare all'esterno specialmente se vengono eseguiti cicli di lavaggio sia nel ciclo di carica che durante la fase di spуро dell'impianto.
- Sopra la zona di carica dei soffietti deve essere sistemato un aspiratore che aspiri e convogli all'esterno tutti i residui o fughe di gas durante le operazioni di carica dei soffietti.
- Verificare che il riscaldatore del gas di carica a +40°C non abbia interferenze con contatti elettrici ma che il gas sia incanalato in apposita serpentina posta all'interno del

riscaldatore. Il meglio sarebbe se la serpentina attraversasse un bagno d'olio riscaldato.

- Le pinze di tenuta sono inaffidabili, le guarnizioni sono incerte ed il bloccaggio delle pinze avviene manualmente. Questo fatto può procurare difficoltà di vuoto e relative cariche inquinate, inoltre pressioni di carica diverse da quelle prescritte dalle specifiche.
- La pinza tronca-capillare è una semplice cesoia tronca fili. Lascia i capillari troncati a forma di coda di pesce, poi ricoperti dalla goccie di stagno. Questo sistema è inaffidabile e può dar luogo a perdite di gas subito dopo la troncatura. Se la perdita è grossa si vede quando il mazzo di capillari viene introdotto nel bagno contenente disossidante liquido e viene eliminata; se la perdita è piccola non si vede e si stagna ugualmente la punta. Nel tempo poi l'effetto ghiaccio, che si manifesta sulla punta del capillare a contatto con l'evaporatore del frigorifero, può degenerare lo stagno fino a mettere in evidenza la microperdita della punta del capillare di rame pinzato.

Durante la visita all'impianto di carica, l'Ing. Panoiu ha fatto le seguenti richieste:

1. Tipo di elettrovalvola Danfoss per impianto carica da sostituire alla loro attuale

- 2. Tipo di manometro per indicare la esatta pressione di carica
- 3. Pinze tronca-capillare diverse dalle attuali
- 4. Guarnizioni in gomma adatte ai loro raccordi per la tenuta capillare
- 5. Gascromatografo: modello e offerta
- 6. Proposta di licenza per la produzione di termostati Ministat ATEA Modelli N2-S2 / C2-C3 per frigoriferi a 1 e 2 porte.

CONCLUSIONE:

- ◆ Per quanto riguarda il gas di carica dei tre modelli di termostato SADU si definisce quanto segue:

⇒ Mod. T3H passa da R22 a PROPANO C3H8

⇒ Mod. T4H passa da R12 a PROPANO C3H8

⇒ Mod. T5H passa da R12 a PROPANO C3H8

Si può quindi unificare l'utilizzo di 1 solo tipo di gas variando solo le pressioni di carica in funzione delle temperature di taratura dei vari modelli.

- ◆ Per caricare con Gas Propano non è consigliabile l'impiego dell'impianto di carica nelle attuali condizioni, in quanto non ha le sicurezze antideflagranti. Si consiglia di modificare l'impianto attuale oppure di sostituirlo con altro impianto più razionale.

**STUDIO PER L'ELIMINAZIONE DEI FLUIDI
REFRIGERANTI (FREON)**

CFC CLOROFLUOROCARBURI R12

HCFC IDROCLOROFLUOROCARBURI R22

**NEL SETTORE DELLA CLIMATIZZAZIONE
DOMESTICA (THERMOSTATI PER FRIGORIFERI
E CONGELATORI) E SOSTITUZIONE CON
NUOVI PRODOTTI CHE NON CONTENGONO
CLORO.**

**QUESTI NUOVI FLUIDI REFRIGERANTI PURI
SONO DENOMINATI:**

HFC IDROFLUOROCARBURI 134A e C3H8.

**QUESTI PRODOTTI COSTITUISCONO
SOLUZIONI DEFINITIVE IN QUANTO, IN
ASSENZA DI CLORO, HANNO UN POTENZIALE
DI IMPOVERIMENTO DELL'OZONO UGUALE A
ZERO.**

14 dicembre 1997

SCELTA DEL GAS DI CARICA PER OGNUNO DEI TRE MODELLI DI THERMOSTATO.

MODELLO T3H - PER FREEZER

Attualmente viene caricato con Freon 22 HCFC. Il modello T3h viene normalmente impiegato nella produzione dei Freezer.

Questi apparecchi possono raggiungere temperature di distacco sull'evaporatore, luogo dove viene posizionato il capillare del termostato, che raggiungono i -32°C.

Il gas con caratteristiche che si avvicinano di più al Freon 22 è il C3H8 PROPANO. Verificando i valori temperatura/pressione risulta:


| | FREON R22 | C3H8 PROPANO |
|----------|--------------|--------------|
| a 0°C | = 3.9759 bar | = 3.7414 bar |
| a - 32°C | = 0.5011 bar | = 0.5420 bar |

GRADO DI PUREZZA RICHIESTO = 99.9 %

Le tabelle di conversione temperatura/pressione forniscono i dati delle forze in gioco da considerare nella procedura di calcolo dei termostati.

**COME SI DETERMINA LA PRESSIONE DI CARICA DEL GAS
PER IL THERMOSTATO T3H CON GAS DI CARICA C3H8
PROPANO**

Per avere un corretto funzionamento del termostato nel congelatore, la pressione di carica del gas deve corrispondere a circa 9-10°C di valore in pressione, superiore alla temperatura di attacco più calda:



In questo caso la temperatura da considerare è -15,8°C in posizione WARM.

Aggiungendo 10°C si arriva a -5°C circa che, dalla tabella di conversione temperatura/pressione, corrisponde ad una pressione di 3 bar.

Aggiungendo un ulteriore limite di sicurezza nei casi di valori di temperatura fino a 0°C, si può definire che la pressione di carica venga fissata a 4 bar.

Verificare praticamente, montando 4 soffietti caricati in Italia con propano a 4 bar.

MODELLO T4H - PUSH BOTTON PER FRIGO A 1 PORTA

Attualmente viene caricato con Freon 12 HCFC.

Il modello T4H viene normalmente impiegato nella produzione di frigoriferi ad 1 porta con sbrinamento semiautomatico.

Questi termostati hanno un campo di regolazione che va da +10°C a -20°C.

L'utilizzo del Freon 12 come gas di carica era compatibile, come rapporto temperatura/pressione.

Per il termostato T4H, visto che la temperatura di distacco arriva a $-24^{\circ}\text{C} \pm 1 = -25^{\circ}\text{C}$, abbiamo:

| | R12 | R134A | C3H8 |
|-------------------------|------------|------------|------------|
| a -25°C | 0.2368 bar | 0.0650 bar | 1.0246 bar |

Secondo la nostra esperienza, questo termostato caricato con Freon 12 non dà molte garanzie di ripetibilità e precisione del valore di taratura $-24^{\circ}\text{C} \pm 1$.

Caricato con R134A ancora meno, in quanto la spinta del gas a -25°C è praticamente zero.

Pertanto si deve utilizzare come gas di carica per i termostati T4H con temperature di distacco freddo, il propano C3H8 dove le spinte a -25°C sono decisamente favorevoli.


E' buona regola quindi usare come gas di carica

R134A: *FINO A TEMPERATURE DI DISTACCO DI
-20/-21°C*

C3H8: *CON TEMPERATURE DI DISTACCO PIU' FREDDE
DI -20/-21°C*

**COME SI DETERMINA LA PRESSIONE DI CARICA DEL GAS
PER IL THERMOSTATO T4H CON GAS DI CARICA C3H8
PROPANO (ex R22)**

Per avere un corretto funzionamento del termostato nel frigorifero, la pressione di carica del gas deve corrispondere a circa 9-10°C di valore in pressione, superiore alla temperatura di attacco (cut in) più calda:



+7°C (attacco defrost).

Aggiungendo 10°C, arriva ad una temperatura di +17/+18°C che corrisponde ad una pressione di carica di 6.7 bar.

Pertanto la pressione di carica con C3H8 per questo modello sarà di 7 bar.

Verificare preticamente il risultato, montando termostati T4H con soffietti caricati in Italia con C3H8 a 7 bar.

MODELLO T5H - PER FRIGO A 1 STELLA

Attualmente viene caricato con Freon 12 HCFC.

Il modello T5H viene normalmente impiegato su piccoli frigoriferi senza sbrinamento.

Questi termostati hanno un campo di regolazione abbastanza limitato.

Il distacco a freddo non va oltre i -21°C.

L'utilizzo del Freon 12 come gas di carica era il più adatto, come rapporto temperatura/pressione.

In questo tipo di termostato, la temperatura di distacco in posizione Cold raggiunge i -21°C; il gas che si avvicina di più al Freon 12 come rapporto temperatura/pressione è il 134A:


| FREON R12 | R134A |
|-----------|--------------|
| a -21°C | = 0.2750 bar |

E' comunque un limite di temperatura fredda da non superare con questo gas.

Le tabelle di conversione temperatura/pressione forniscono i dati delle forze in gioco da considerare nella procedura di calcolo dei termostati.

**COME SI DETERMINA LA PRESSIONE DI CARICA DEL GAS
PER IL THERMOSTATO T5H CON GAS DI CARICA HFC 134A**

Per avere un corretto funzionamento del termostato nel frigorifero, la pressione di carica del gas deve corrispondere a circa 9-10°C di valore in pressione, superiore alla temperatura di attacco (cut in) più calda:



In questo caso la temperatura di attacco da considerare è -2.8°C (attacco WARM pos.).

Aggiungendo 10°C, arriva ad una temperatura di +8°C che, dalla tabella di conversione temperatura/pressione, corrisponde ad una pressione di carica di circa 3 bar.

Aggiungendo un ulteriore limite di sicurezza, si può fissare una pressione di carica a 4 bar.

Verificare praticamente il risultato, montando termostati T5H con soffietti caricati in Italia con 134A a 4 bar.

**ANALISI ESEGUITA SUI CAMPIONI DI
TERMOSTATI T3H - T4H - T5H**

- Lettura valori di temperatura
- Analisi gascromatografica dei soffietti (5) caricati in R22 e R134A
- Analisi gascromatografica dei gas di carica dei soffietti montati sui termostati campioni ricevuti T3H - T4H - T5H
- Esame della tenuta delle punte sotto goccia di stagno
- Ricarica di:
 - * 2 soffietti con C3H8 4 bar per T3H
 - * 3 soffietti con C3H8 7 bar per T4H
 - * 2 termostati completi T4H 7 bar C3H8 (ex R12)
 - * 2 termostati completi T5H 4 bar R134A (ex R12)
 - * 3 termostati completi T3H 4 bar C3H8 (ex R22)

Tutti questi campioni sono da esaminare in Romania con i loro mezzi per quanto riguarda:

- valori di temperatura dopo la ricarica (IT)
- montaggio dei soffietti caricati in Italia e controllo risultati in temperatura

I VALORI NOMINALI possono variare. Per i VALORI DI TARATURA occorre aggiornarli durante l'operazione di taratura. Per i valori di CAMPO occorre variare gli elementi di calcolo molla/incremento camma in funzione delle pressioni di spinta dei nuovi gas (vedi tabelle di conversione temperatura/pressione).

T3H

Customer

Customer Therm. Code No.

Measured individual values

| Sample No. | Ts min C° | Ta min C° | Ts max C° | Ta max C° | Lungh. capill. mm. |
|------------|-----------|-----------|-----------|-----------|--------------------|
| 1 | -15,9 | -11,8 | -29,5 | -24,1 | 1000 |
| 2 | -13,9 | -10,4 | -28,5 | -23,9 | 1040 |
| 3 | -18,1 | -12,6 | -33,8 | -25,3 | 1000 |


T4H

| Sample No. | Ts min C° | Ta min C° | Sbr. min. C° | Ts max C° | Ta max C° | Sbr. max C° | Lungh. capill. mm. |
|------------|-----------|-----------|--------------|-----------|-----------|-------------|--------------------|
| 1 | -14,2 | -5,3 | 10,6 | -24,9 | -13,7 | 7,7 | 480 |
| 2 | -15,6 | -6 | 9,2 | -27,1 | -14,9 | 7,5 | 470 |
| 3 | -16,4 | -6,7 | 9,7 | -27,4 | -14,1 | 8,3 | 500 |

T5H

| Sample No. | Ts min C° | Ta min C° | Ts max C° | Ta max C° | Lungh. capill. mm. |
|------------|-----------|-----------|-----------|-----------|--------------------|
| 1 | -3 | -0,3 | -14,1 | -8,8 | 950 |
| 2 | -0,7 | 2,1 | -15,2 | -8,6 | 910 |
| 3 | -0,4 | 1,2 | -13,9 | -8,7 | 940 |

1° CAMPIONE




ANALISI OK (AL LIMITE)

1 QUADRETTO = 20 ppm.

RISULTATO: ~ 70 ppm.

LIMITE AMMESSO 100 ppm.


2° CAMPIONE



RISULTATO: ANALISI OK 50 ppm

(LIMITE AMMESSO 100 ppm)


1° CAMPIONE



RISULTATO: ANALISI OK 40 ppm.


1 QUADRATTO = 20 ppm LIMITE AMMESSO 100 ppm.

2° CAMPIONE




RISULTATO: ANALISI DI 15 ppm. ~

1 QUADRATTO = 20 ppm. LIMITE AMMESSO 100 ppm.



RISULTATO : NEGATIVO


QUESTO SOFFIETTO PRESENTA UNA ENORME QUANTITÀ DI
GAS DI CARICA CHE NON È FREON 22. (CARICA INQUINATA)
ARIA - FREON 23 FREON 12
DOVUTO AL CAMBIO DEL GAS ? (CAMBIO BOMBOLA?)



RISULTATO : NEGATIVO


QUESTO SOFFIETTO PRESENTA UNA QUANTITÀ ECESSIVA (500 ppM) DI GAS DI CARICA CHE NON È FREON 22 (CARICA INQUINATA)

FISONS INSTRUMENTS - S.P.A. Cod. 352.750.00



RISULTATO : ANALISI OK 20 ppm.

LIMITE AMMMESSO 100 ppm.



Analisi di FREON

Condizioni sperimentali

Campione: Clorodimetilfluorometano (Freon 22)
 Fractovap tipo: ATC/I con rivelatore a filamenti
 Colonna tipo: In acciaio 5 m Ø 6x5 con 20% di Tergitol NPX su Chromosorb P 30-60 mesh
 Temperatura colonna: 95°C
 Temperatura evaporatore: 180°C
 Temperatura rivelatore: 95 °C
 Carrier: Elio 60 cc/min.

Dati tecnici sulla fase stazionaria

Denominazione: Tergitol NPX
 Polarità: alta (+++)
 Temperatura max. di esercizio: 100°C
 Temperatura min. di esercizio: temperatura ambiente
 Solubilità: Cloroformio

Note

Le colonne preparate con Tergitol NPX trovano un impiego specifico per l'analisi del Freon. Per una ricerca di impurezze del prodotto industriale è necessario usare colonne lunghe da 4 a 6 metri. L'analisi esposta mostra l'analisi del Freon 22 e le sue impurezze costituite da altri Freon.

Sono state esaminate le punte dei capillari pinzate meccanicamente e ricoperte dalla goccia di stagno.

Su un totale di 12 pezzi controllati (tolto lo stagno immergendo la punta stagnata in un crogiolo con stagno fuso) nr 2 pezzi presentavano perdite di tipo grossolano: i termostati si sono scaricati in pochi minuti.

Vedere operazione di pinzatura, metodo di controllo delle perdite prima e dopo la stagnatura della punta (stagionatura?); vedere difettosità attuale in produzione e i ritorni dal Service.

ANNEXE 1

**THE RESULTS OF THE TESTS FOR THE THERMOSTATS
CHARGED WITH PROPANE AT RIVIERA**

THERMOSTAT T4H
REFRIGERANT C₃H₈ (7 BAR)

Tabel 1

| Sample no. | T _a max [°C] | T _d max [°C] |
|------------|---------------------------|---------------------------|
| 1. | -31 | doesn't work |
| 2. | -32 | doesn't work |

REMARK: When the temperature in the test bath is -40 °C the two samples don't work.

THERMOSTAT T5H
REFRIGERANT R 134 a (4 BAR)

Tabel 2

| Sample no. | T _a max [°C] | T _d max [°C] |
|------------|---------------------------|---------------------------|
| 1. | -8.1 | -11.9 |
| 2. | -8.0 | -12 |

THERMOSTAT T4H
REFRIGERANT C₃H₈ (7 BAR)

Tabel 3

| Sample no. | T _a max [°C] | T _d max [°C] | T _s [°C] |
|------------|---------------------------|---------------------------|-----------------------|
| 1. | -27.5 | -32.6 | -20.6 |
| 2. | -26.8 | -31.4 | -20.4 |
| 3. | -26.8 | -33.4 | -19 |

| | | |
|----|-------|-------|
| 1. | -17.5 | -26.9 |
| 2. | -17.6 | -27.6 |
| 3. | -15.9 | -27.6 |

✓ 2

THERMOSTAT T3H
REFRIGERANT C₃H₈ (4 BAR)

Tabel 5

| Sample no. | T _a max [°C] | T _d max [°C] | T _s [°C] |
|------------|---------------------------|---------------------------|-----------------------|
| 1. | -24.2 | -29.3 | -14.8 |
| 2. | -26.6 | -31 | -15 |

WHERE: T_a -coupling temperature
 T_d -decoupling temperature
 T_s -signalisation temperature

✓ 2



PROPANO C₃H₈
GRADO DI PURITÀ 99.9%

Settala hydrocarbon pure gases

Propane - N. Butane - Isobutane

Combining experience and modern technology, we have for several years devoted a great deal of time and effort to obtain pure gases. Sulphur is removed by absorption on molecular sieves and unsaturated hydrocarbons are removed by acid polymerisation followed by distillation.

With the installation of a 35 - meter high fractionated distillation column, besides the normal production purities of 99 (2.0) - 99.5 (2.5) - 99.9 (3.0) - 99.95 (3.5), we have now obtained an experimental gas with overall impurities of less than 100 ppm that is a gas which is more than 99.99 (4.0) pure.

Obviously monitoring is done with process gas chromatographic equipment and laboratory gas chromatographic apparatus, connected to a sophisticated recorder - integrator which supplies analysis results without any operator intervention.

We are also able to detect traces of organic sulphur down to few p.p. billion using a special gas chromatograph equipped with a flame photometric detector.

Our laboratory is also equipped with an electrolytic cell moisture - monitor which reveals traces of water in the gas to within a few ppm.

PROPANE

| PURE GRADE | 99% | 99.5% | 99.9% | 99.95% RESEARCH GRADE |
|----------------------------------|--------|--------|-------|-----------------------|
| Max content of impurities | vol. % | vol. % | ppm | ppm |
| Ethane | 0.02 | 0.01 | 100 | 50 |
| Propylene | 0.02 | 0.02 | 150 | 100 |
| Isobutane | 0.85 | 0.4 | 800 | 400 |
| N. Butane | 0.2 | 0.1 | 200 | 100 |
| Total unsaturated C ₄ | 0.01 | 0.01 | 100 | 50 |
| Sulphur | 0.0002 | 0.0002 | 1 | 1 |
| H ₂ O max | 0.0012 | 0.0012 | 10 | 10 |
| O ₂ max | 0.0015 | 0.0015 | 10 | 10 |
| CO ₂ | 0.001 | 0.001 | 10 | 10 |

Of course in our pure gases the total sum of impurities meets the specifications.

**CORREZIONE BAROMETRICA A 740 mmHg
per C3 H8**

(Barometric Correction at 740 mmHg for C3 H8)

| | 710 | 714 | 720 | 724 | 730 | 734 | 740 | 744 | 750 | 754 | 760 |
|-------|--------|--------|--------|--------|--------|--------|-----|--------|--------|--------|--------|
| + 5° | + 0,30 | + 0,20 | + 0,20 | + 0,10 | + 0,10 | = | 0,0 | = | - 0,10 | - 0,10 | - 0,20 |
| + 0° | + 0,30 | + 0,30 | + 0,20 | + 0,20 | + 0,10 | = | 0,0 | = | - 0,10 | - 0,10 | - 0,20 |
| - 5° | + 0,30 | + 0,30 | + 0,20 | + 0,20 | + 0,10 | - = | 0,0 | = | - 0,10 | - 0,10 | - 0,20 |
| - 10° | + 0,30 | + 0,30 | + 0,30 | + 0,20 | + 0,10 | + 0,10 | 0,0 | - 0,10 | - 0,10 | - 0,20 | - 0,20 |
| - 15° | + 0,40 | + 0,30 | + 0,30 | + 0,20 | + 0,10 | + 0,10 | 0,0 | - 0,10 | - 0,10 | - 0,20 | - 0,30 |
| - 20° | + 0,40 | + 0,40 | + 0,30 | + 0,20 | + 0,10 | + 0,10 | 0,0 | - 0,10 | - 0,10 | - 0,20 | - 0,30 |
| - 25° | + 0,50 | + 0,50 | + 0,40 | + 0,30 | + 0,20 | + 0,10 | 0,0 | - 0,10 | - 0,10 | - 0,20 | - 0,30 |
| - 30° | + 0,60 | + 0,50 | + 0,40 | + 0,30 | + 0,20 | + 0,10 | 0,0 | - 0,10 | - 0,20 | - 0,30 | - 0,40 |

ESEMPIO

pressione 710 Temperatura ST -30°

lo stacco risulta -30,6°

in realtà è -30° perchè c'è + 0,6° di correzione

Example

pressure 710 cut out temperature - 30°

Cut out results - 30,6°

really it is - 30° because there is + 0,6° for correction

ESEMPIO

pressione 760 Temperatura ST -30°

lo stacco risulta -29,6°


in realtà è -30° perchè c'è - 0,4° di correzione

Example

pressure 760 cut out temperature - 30°

Cut out results - 29,6°

really it is - 30° because there is - 0,4° for correction



N.B. QUESTO IMPIANTO POSTO LONTANO DALLA FABBRICA IN BOX DI CEMENTO ARMATO SERVE COME DEPOSITO PER LE BOMBOLE DI PROPANO CHE ALIMENTANO LA MACCHINA DI CARICA IN REPARTO. TUTTO QUESTO IMPIANTO DEVE FUNZIONARE SENZA ALCUNA APPARECCHIATURA ELETTRICA.

OPERAZIONI DI MANOVRA PER CAMBIO BOMBOLA GAS PROPANO

- 1 VALVOLE A-B-C CHIUSE
- 2 APRIRE VALVOLA C. IL TUBO FLESSIBILE SI RIEMPIE DI GAS, L'ARIA SI CONCENTRA NEL POLMONE.
- 3 APRIRE VALVOLA A PARZIALMENTE E SCARICARE GAS E ARIA IN ATMOSFERA PER 30"
- 4 PARZIALIZZARE VALVOLA C CON VALVOLA A APERTA
- 5 CHIUDERE VALVOLA A
- 6 APRIRE VALVOLA B

1 10
PLANE

- VISIT AND TRAINING OF
THE COUNTERPARTS'
STAFF IN ITALY

13 - 20. 09. 98

VISIT AND TRAINING OF COUNTERPART'S

**RELAZIONE SULLA VISITA DEI RAPPRESENTANTI
SADU A RIVIERA ITALIA DAL 13 AL 20.09.98**

STAFF FROM 13 TO 20.09.98, IN ITALY.

In conformità agli accordi bilaterali tra Riviera Italia e U.M.Sadu, con riferimento al contratto Unido 97/106/VK, riguardante l' eliminazione dei gas CFC dalla produzione della suddetta U.M.Sadu, i rappresentanti

| | |
|-------------------------|------------|
| Sig. Lazarescu Valentin | Ingegnere |
| Sig. Panisoara Cornel | Ingegnere |
| Sig.ra Hoara Iuliana | Interprete |

hanno preso parte, durante la settimana sopracitata ad una serie di attività relative al contratto in oggetto e riguardanti l' addestramento e aggiornamento tecnico, sopralluogo e controllo dello stato di costruzione dei macchinari facenti parte dello "scope of supply" del contratto stesso, nonchè la visita ad alcuni produttori di elettrodomestici, macchinari e componenti dell' area nord-Italia.

In particolare, si sono svolte le seguenti attività e si sono stabiliti i seguenti punti :


- 1- E' stata fornita ai Sigg. Rappresentanti U.M.Sadu la lista completa e definitiva delle attrezzature e macchinari facenti parte del contratto.
- 2- Sono state fornite indicazioni di massima per la ottimizzazione del processo produttivo attraverso dei suggerimenti di Riviera Italia che la U.M.Sadu si riserva di porre in atto.
- 3- Si sono stabiliti i modi e i tempi della spedizione dei sopracitati macchinari da Riviera Italia a U.M.Sadu. Tale spedizione comprenderà anche i campioni di frigoriferi della U.M.Sadu (180 e 240 litri) che sono stati oggetto delle prove e delle modifiche e che sono attualmente presso i magazzini Riviera.
- 4- Sono stati visitati i laboratori Riviera e si sono discussi ed approfonditi i risultati delle prove di cui al punto (3).
- 5- Sono stati visionati tutti i macchinari (macchine di schumatura, serbatoi da 3000 e 10000 litri con relativi piping ed accessori) di produzione del sub-fornitore Impianti OMS di Milano, quasi completamente pronti per essere spediti a U.M.Sadu.
- 6- Impianti OMS ha consegnato ed illustrato ai rappresentanti U.M.Sadu una serie di disegni costruttivi degli impianti ed anche riguardanti indicazioni sulla parte elettrica degli stessi, nonchè suggerimenti per la preparazione finale delle aree interessate all' installazione.

- 7- Il funzionamento di impianti analoghi a quello in fase di consegna è stato visionato dai rappresentanti U.M.Sadu durante la visita agli stabilimenti IAR-Siltal di Casale Monferrato (Alessandria)
- 8- Le attrezzature che Riviera fornirà direttamente a U.M.Sadu sono già imballate e pronte per la spedizione e, pertanto, non è stato possibile visionarle direttamente.
- 9- Una delegazione mista Riviera-Impianti OMS visiterà U.M.Sadu entro le prossime 3 settimane per un sopralluogo alla fabbrica ed ai lavori di preparazione delle aree interessate all' installazione dei nuovi macchinari.
- 10- Sono state effettuate visite di approfondimento tecnico anche alla Direzione Commerciale Whirlpool Europe di Comerio, alla fabbrica di termostati Atea di Bardello, all' industria di stampaggio componenti in plastica Roverplastic di Groppello di Gavirate ed alla salderia meccanica SimMeccanica di Ternate.
- 11- Eventuali ed ulteriori informazioni e documentazioni tecniche, che non fossero state raccolte direttamente dai rappresentanti U.M.Sadu verranno consegnate durante l' imminente visita dei rappresentanti Riviera-Impianti OMS
- 12- Riviera Italia potrà fornire collaborazione e consulenza diretta alla U.M.Sadu per l' acquisto di nuovi macchinari, componenti e tecnologie dall' Italia.
- 13- Riviera Italia potrà fare, su richiesta della U.M.Sadu, una proposta tecnica e commerciale per lo spostamento delle operazioni di vuoto e carica direttamente sulla linea di produzione frigoriferi della U.M.Sadu.
- 14- Riviera Italia potrà fornire collaborazione per lo studio e la realizzazione di nuovi modelli di frigoriferi che la U.M.Sadu volesse proporre sul mercato.
- 15- Riviera Italia potrà fornire assistenza per l' eventuale commercializzazione in Italia di frigoriferi ad assorbimento di produzione della U.M.Sadu.

Milano, 20.09.98


U.M.Sadu

Ing. Valentin Lazarescu



Riviera Italia S.r.l.

Antonio Forni - Projects' coordinator



- RE- VIEW OF SITE
CONDITIONS AND
CIVIL WORKS

JUNE 1998



21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 282984 - telefax 0332 / 240309 - telex 325126
Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

Varese, li 22.05.98
vs. rif.
ns. rif.
Fax no. 781

Messrs.
Arsenalul Armatei - Bucuresti
Uzina Mecanica Sadu

Ref. Contract 97/106/VK - visit of our officers

Dear Sirs,

Please find herebelow details of our two delegates :

Mr Antonio Forni - Projects' coordinator - Riviera - Pass. no. **746488L**

Mr Paolo Calderini - Technician - **Impianti OMS** (sub-supplier for the foaming section) - Pass. no. will be informed at a later date.
resident of Albiate Brianza (Milano), via Giovanni XXIII
Born in Carate Brianza (Milano) on 25.03.1960

Subject to Your approval, our provisional travelling schedule would be as follows :

Monday, **01.06.98** - Milano dep. 10.00. - **Bucuresti** arr. **13.15** - Flight **AZ 504**

Thursday, **04.06.98** - Bucuresti dep. **14.05** - Milano arr. 15.30 - Flight **AZ 505**

Awaiting Your reply, we thank You and pass our best regards.

WE CONFIRM OUR VISIT
AS PROGRAMMED ABOVE
LOOKING FORWARD TO
SEEING YOU, SOON
BEST REGARDS. 28/05/98

Yours faithfully,
Riviera S.r.l.
Antonio Forni
Projects' coordinator

Contract 97/106

Conversion of U.M. Sadu
factories of Bumbesti Jiu, Romania
to phase-out the use of CFC-11 and 12
in the production of domestic appliances.

The specifications and list of all civil and preparatory works, to be done by the Counterpart before the installation of the equipments in the factory, were given to the Responsible staff, leaving them a more than reasonable period of time to complete them.

After receiving a written confirmation on the execution of these works, we visited the Project Site in june '98 to approve all above. We found all works had been carefully executed, therefore we agreed to proceed with the shipment of all machineries.

In particular, all previously used machineries had been removed from the installation areas, although still in use in different areas until the completion of the installation works.

Supports for the external piping (some 300 meters) had been manufactured.

All utilities were available (electricity, water, air etc..)

All electrical terminal boards had been removed from the foaming areas.

All electrical connections had been re-done with a higher safety level.

The concrete structure for the 3000 liters tank basin had been constructed.

A general higher level of cleanliness, dust removing etc.. was be kept until the installation started.

- SHIPMENT, INSTALLATION
OF ALL EQUIPMENTS,
TRAINING
- CERTIFICATE OF ACCEPTANCE
OF WORKS

OCT/NOV 1998

Riviera

WEIGHT CERTIFICATE AND PACKING LIST PER CONTAINER

THE HI LIFE PRODUCTS

CONTRACT 97/106

FICATE OF ORIGIN NO. C/00677117

ING MARKS: RIVIERA/OMS 1-4+8/KLIMAX 7/GALILEO 10+20 MADE IN ITALY CONTRACT UNIDO 97/106

MECANICA SADU ROMANIA

CK FROM VARESE ITALY TO BUCHAREST ROMANIA

BUMBESTI JIU

MESSRS. SADU.

THE UNITED NATIONS

DEVELOPMENT PROGRAMME

RESIDENT REPRESENTATIVE (UNDP)

16,AUREL VLAICU STR.

79362 BUCHAREST ROMANIA

(ORIGINALS WILL FOLLOW
BY DHL.)

PMENT FOR DOMESTIC APPLIANCES PRODUCTION

UNIDO CONTRACT 97/106

TOTAL AMOUNT USD. 435.640.-

INVOICE NO. 23/EX

| K NO. | MM05BTJ/MM85BTJ | | TOTAL PACKAGES NO. | 9 | TOTAL GROSS WEIGHT KGS. | 9.180.- | TOTAL GROSS WEIGHT KGS |
|-------|-----------------|-------|--------------------|--|-------------------------|---------|------------------------|
| | PACKAGES | P C S | | | | | |
| EO 10 | 1 CASE | 1 | 1 | REFRIGERANT CHARGING MACHINE FOR 134a | 720X1070X1750 | 170 | 250 |
| EO 20 | 1 CASE | 1 | 1 | CHARGING STATION WITH VACCUM PUMP AND CYLINDER | 470X1720X750 | 120 | 170 |
| X 7 | 1 CARTON | 2 | 2 | LEAK DETECTOR FOR HFC-134a | 690X470X700 | 50 | 60 |
| | | 2 | 2 | SETS OF MAINTENANCE AND SPARE PARTS | | | |
| | | 1 | 1 | MANIFOLD SET | | | |
| | 1 CRATE | 1 | 1 | ELECTRIC BOARD FOR PENTAFOAM HP40/20 | 3300X2100X2430 | 2.000 | 2.470 |
| | | 1 | 1 | ELECTRIC BOARD FOR PENTAFOAM HP100/50 | | | |
| | | 1 | 1 | ELECTRIC BOARD FOR SENSORS + ALARMS | | | |
| | | 1 | 1 | FOAMING AREA | | | |
| | | 1 | 1 | ELECTRIC BOARD FOR SENSORS + ALARMS | | | |
| | | 1 | 1 | DOOR/CABINET JIGS | | | |
| | | 1 | 1 | CHILLER TYPE 5 - 15000 Fr/H | | | |
| | | 1 | 1 | ELECTRIC BOARD FOR 3000 LTS TANK | | | |
| | | 1 | 1 | CYLINDER DE-COMPRESSION GROUP | | | |
| | | 1 | 1 | FITTING FOR CP TRUCK-TANK EARTHING | | | |
| | | 1 | 1 | + BASE | | | |
| | | | | | | | |

RIVIERA s.r.l.

00 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 281659 - telex 325126

tità IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

| | | | | | | INVOICE NO. | 23/EX |
|---------------------------|--|----------------------|-----------|---|----------------|----------------------|------------------------|
| TRUCK NO. MM05BTJ/MM85BTJ | | TOTAL PACKAGES NO. 9 | | TOTAL GROSS WEIGHT KGS. 9.180.- | | | |
| PACKAGE NUMBERS | QUANTITY | | TOTAL PCS | DESCRIPTION OF THE GOODS | DIMENSIONS MM | TOTAL NET WEIGHT KGS | TOTAL GROSS WEIGHT KGS |
| | PACKAGES | PCS | | | | | |
| OMS 2 | 1 CRATE | 1 | 1 | PENTAFOAM HP100/50 HIGH PRESSURE SYSTEM | 3300X2100X2440 | 2200 | 2.690 |
| OMS 3 | 1 CRATE | 1 | 1 | PENTAFOAM HP40/20 HIGH PRESSURE SYSTEM | 3300X2100X2440 | 2200 | 2690 |
| OMS 8 | 1 CASE | 12 | 12 | SFERICAL STAINLESS VALVES DN 20 | 1100X600X570 | 295 | 310 |
| | | 800 | 800 | LOCK BANDS FOR CABLES | | | |
| | | 2 | 2 | ANTI-EXPLOSION CERAMIC FIBER PACK. | | | |
| | | 2 | 2 | ANTI-EXPLOSION MATERIAL PACKAGES | | | |
| | | 40 | 40 | ANTI-EXPLOSION CONNECTIONS | | | |
| | | 16 | 16 | STAINLESS FLANGES DN65 | | | |
| | | 16 | 16 | ALLUMINIUM BY-PASS SOCKETS | | | |
| | | 6 | 6 | SFERICAL STAINLESS VALVES 1/2" | | | |
| | | 1 | 1 | SET FOR VARIOUS MECHANICAL CONNECTIONS | | | |
| | | 4 | 4 | STAINLESS FLANGES DN20 | | | |
| | | 1 | 1 | PRESSURE METER | | | |
| | | MT.210 | | 50X50RUN-CHANNEL FOR FOAMING AREA PENTANISATION | | 2400X800X500 | 520 |
| | 2 PALLETS | | | | | | 540 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | 3 CRATES 3 CASES 1 CARTON 2 PALLETS | | | | | 7.555 | 9.180 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 281659 - telex 325126

Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

RIVIERA s.r.l.



WEIGHT CERTIFICATE AND PACKING LIST PER CONTAINER

THE HI LIFE PRODUCTS

UNIDO CONTRACT 97/106

CERTIFICATE OF ORIGIN NO. C/00677117

SHIPPING MARKS: RIVIERA/OMS 1-4+8/KLIMAX 7/GALILEO 10+20 MADE IN ITALY CONTRACT UNIDO 97/106

UZINA MECANICA SADU ROMANIA

1 TRUCK FROM VARESE ITALY TO BUCHAREST ROMANIA

C & F BUMBESTI JIU

THE UNITED NATIONS

DEVELOPMENT PROGRAMME

RESIDENT REPRESENTATIVE (UNDP)

16,AUREL VLAICU STR.

79362 BUCHAREST ROMANIA

EQUIPMENT FOR DOMESTIC APPLIANCES PRODUCTION

REF. UNIDO CONTRACT 97/106

TOTAL AMOUNT USD. 193.000,-

INVOICE NO. 23/EX

TRUCK NO. MM10GXE/MM08DDU

TOTAL PACKAGES NO.

21

TOTAL GROSS WEIGHT KGS.

7.333,-

| PACKAGE NUMBERS | Q U A N T I T Y | | TOTAL P C S | DESCRIPTION OF THE GOODS | DIMENSIONS M M | TOTAL NET W E I G H T K G S | TOTAL GROSS W E I G H T K G S |
|--------------------|-------------------|---------|----------------|---|-------------------|--------------------------------|----------------------------------|
| | PACKAGES | P C S | | | | | |
| OMS 4 | 1 CRATE | 2 | 2 | EXHAUST AND VENTILATION SYSTEMS SAFETY PACKAGE WITH GAS DETECTION SYSTEM | 5720X2220X2300 | 3500 | 4360 |
| | | 2 | 2 | CONNECTION PIPING (FOAM.SYST.TO MIX HEADS) | | | |
| | | MT.20 | MT.20 | CONNECTION PIPING (FOAM.SYST.TO MIX HEADS) | | | |
| | 1 TANK 1 LOOSE | MT.20 | MT.20 | STORAGE TANK FOR C-PENTANE 3000LTS TRANSFER PUMP GROUP FROM CP TANK PENTAFOAM 40/20 | 1200X600X600 | 858 | 858 |
| | | 1 | 1 | RIGID PIPING CP TANK-PENTAFOAM40/20 | | | |
| | 8 CARTONS | MT. 24 | MT. 24 | ROCK WOOL INSULATING MATERIAL | 1060X640X1180 | 100 | 100 |
| | | MT. 25 | MT. 25 | ROCK WOOL INSULATING MATERIAL | | | |
| | 2 CARTONS | MT. 360 | MT. 360 | PROTECTION TUBE FOR ROCK WOOL | 96 | 144 | 160 |
| | | MT. 360 | MT. 360 | PROTECTION TUBE FOR ROCK WOOL | | | |
| | 1 BUNDLE | MT.25 | MT. 25 | DISTRIBUTION PIPING (CP TANK TO PREMIX) | .../... | 670 | 670 |

21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 281659 - telex 325126

Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

RIVIERA s. r.l.

INVOICE NO. 23/EX

| | | | | | | INVOICE NO. 23/EX | |
|----------------------------|--|--|--|---|------------------------------|--------------------------------------|--------------------------------------|
| TRUCK NO. MM10GX/E/MM08DDU | | TOTAL PACKAGES NO. 21 | | TOTAL GROSS WEIGHT KGS. 7.333.- | | | |
| PACKAGE NUMBERS | QUANTITY | | TOTAL P C S | DESCRIPTION OF THE GOODS | DIMENSIONS MM | TOTAL NET WEIGHT KGS | TOTAL GROSS WEIGHT KGS |
| | PACKAGES | P C S | | | | | |
| | 1 BUNDLE 1 BUNDLE 1 ROLL 1 ROLL 1 PALLET 1 PALLET | MT.20 MT.30 MT.1500 MT.500 1 MT.300 | MT.20 MT.30 MT.1500 MT.500 1 MT.300 | STAINLESS TUBE DIA. 22 STAINLESS TUBE DIA. 35 CABLE 5X5.1 CABLE 4X2.5 SET OF RUN-CHANNEL CABLE 3X1 SET OF ELECTRIC CONNECTION CABLES ELECTRIC BOARDS-MACHINES SET BOLDS SET PF CABLE SET OF PIPE HANGER | 2400X800X500 1200X800X500 | 60 130 425 54 140 196 | 60 130 425 54 150 206 |
| | 10 CARTONS 1 CRATES 2 PALLETS 4 BUNDLES 2 ROLLS 1 TANK 1 LOOSE | | | | | 6.433 | 7.333 |
| | | | | | | ===== | ===== |

21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 281659 - telex 325126

Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

RIVIERA s.r.l.

Riviera S.r.l.

Unido Contract 97/106 - Uzina Mecanica SADU - Romania

General Packing list (please refer to our offer 557/97 and further amendment)

2. Conversion of the assembly line for the refrigeration cycle

| Galileo | no. 2 cases | Quantity |
|--|----------------------|-----------------|
| Digifill B 150 F1 charging machine for R134a | | 1 |
| vacuum valve | | 1 |
| refrigerant valve | | 1 |
| quick coupler 1/4" for filler | | 1 |
| temperature sensor | | 1 |
| pirani head OG915 | | 1 |
| inox start button for filler | | 1 |
| valve maintenance kit | | 1 |
| metering device maintenance kit | | 1 |
| transfer pump RP1 | | 1 |
| gasket kit for refrigerant gas cylinder | | 1 |
| maintenance kit for refrigerant gas cylinder | | 1 |
| gasket for air cylinder | | 1 |
| Rotoil oil (can of 5 liters) | | 1 |
| Klimax | no. 1 pallett | Quantity |
| H10N leak detector for R134a | | 1 |
| set of maintenance and spare parts | | 1 |

3/4. Conversion of foaming for compression and absorption lines

| OMS | no. 1 cage cms 330x212x245 | Quantity |
|---|-----------------------------------|-----------------|
| Pentafoam HP 100/50 two-speed high pressure system complete with polyol/pentane line + Isocyanate line + tanks of 250 liters and cabin for polyol/pentane line + no. 2 catalytic sensors | | 1 |
| no. 1 cage cms 330x212x245 | Quantity | |
| Pentafoam HP 40/20 two speed high pressure system same features as above | | 1 |
| no. 1 cage cms 330x192x237 | Quantity | |
| electric board for Pentafoam HP 40/20 | | 1 |
| electric board for Pentafoam HP 100/50 | | 1 |
| electric board for sensors and alarms - foaming area | | 1 |
| electric board for sensors and alarms - door/cabinet jigs | | 1 |
| chillers - type 5 - 15000 Fr/h | | 2 |
| electric board for 3000 liters tank | | 1 |
| cylinders de-compression group | | 1 |
| fitting for CP truck-tank earthing + base | | 1 |

| <u>no. 1 cage cms 570x212x223</u> | <u>Quantity</u> |
|---|-----------------|
| boomer for injection heads - HP 40/20 | 1 |
| boomer for injection heads - HP 100/50 | 1 |
| aspiration groups for foaming machine cabins | 2 |
| aspiration group for foaming area cabin w/base and devices | 1 |
| aspiration group for cabinet area cabin w/base and devices | 1 |
| aspiration group for jigs area cabin w/base and devices | 1 |
| 250 liters service tank for pure polyol | 1 |
| transfer pumps groups from tanks to foaming machines | 2 |
| electric run-channels set | 1 |
| pneumatic charging pumps | 2 |
| catalytic sensors | 11 |
| injection heads w/8 meters pipings and nitrogen injectors | 4 |
| balance lead cables and weights for boomers/heads | 7 |
| <u>various materials to be loaded on trucks</u> | <u>Quantity</u> |
| 3000 liters tank with anti-corrosion external coating and double jacket, with capacity meter, probe, pressure meter and safety valve. | 1 |
| transfer pump group from cp tank to Pentafoam 40/20 | 1 |
| rigid piping cp tank - Pentafoam 40/20 | meters 24 |
| rock wool insulating material | meters 25 |
| alluminium by-pass sockets | 4 |
| sferical stainless valves 1/2" | 6 |
| rigid piping cp tank - Pentafoam HP 100/50 | meters 360 |
| rock wool insulating material | meters 300 |
| protection tube for rock wool | meters 300 |
| 4" sleeves for tubes mounting | 100 |
| alluminium by-pass sockets | 12 |
| sferical stainless valves DN 20 | 12 |
| stainless tube diam 22 | meters 20 |
| stainless tube diam 35 | meters 30 |
| stainless flanges DN 65 | 6 |
| bolts set for flanges coupling | 1 |
| set for various mechanical connections | 1 |
| connection piping Penta HP 100/50 - injection heads | meters 10 |
| connection piping Penta HP 40/20 - injection heads | meters 10 |
| 50x50 run-channel for foaming area pentanization | meters 210 |
| cable 5x1,5 | mts 1500 |
| cable 4x2,5 | mts 500 |
| cable 3x1 | mts 300 |
| set of electric connection cables electric boards-machines | 1 |
| anti-explosion connctions | 40 |
| anti-explosion ceramic fiber packages | 2 |
| anti-explosion material packages | 2 |
| lock bands for cables | 800 |

6. Development of the servicing and repair technology

| Klimax | Quantity |
|-------------------------------------|-----------------|
| Tif 5650 leak detector for service | 1 |
| set of repair and maintenance parts | 1 |
| manifold set | 1 |



R.A. ARSENALUL ARMATEI - UZINA MECANICA SADU
Str. PARANGULUI Nr. 1 , BUMBESTI - JIU, Jud. GORJ, ROMANIA
Tel: 040 - 53 - 463859 , 463201 fax: 040 - 53 - 463873, 463863

Messrs.

RIVIERA S.R.L.

VIA SANVITO SILVESTRO , 60
21100, VARESE - ITALY

During the visit of your technicians - Mrs. Perego, Pedroni, Cavalleri and Forni - at our plant the following activities have been performed:

- Installation of Digifill B150 F1 charging machine for R 134a.
Relevant working tests with positive outcomes.
- Installation of Pentafoam HP 100/50 two-speed high pressure system complete with polyol/pentane line + Isocyanate line + tanks of 250 liters and cabin for polyol / pentane line + no. 2 catalytic sensors.
Relevant working tests with positive outcomes.
- Installation of Pentafoam HP 40/20 two-speed high pressure system same feature as above.
Relevant working tests with positive outcomes.

WE DECLARE THAT OUR FACTORY IS PROPERLY WORKING AND IS IN POSITION TO
PERFORM ALL OUR PRODUCTION ACTIVITIES BY EMPLOYING CFC-FREE
TECHNOLOGY.

The present statement will be considered as CERTIFICATE OF ACCEPTANCE for the plant subject of Contract no. 97/106.

In faith ,

Manager

Eng.

PANOIU POMPILIU

- TÜF REPORT
AND ACCORDING MEASURES

19/20. 11. 98

REPORT

on Technical Plant Inspection

Plant:

1. Pentane-Tank, above ground.
2. Pentan-Tank, underground
3. Pentafoam 100/50
4. Pentafoam 40/20

**Bau und
Betrieb**

Dates of inspection:

19. / 20. November 1998

Niederlassung Ulm
Dampf und Druck

Kind of inspection:

Safety inspection

plant location:

Ratmil / Romania

Benzstraße 17
D-89079 Ulm
Telefon (07 31) 49 15-2 30
Telefax (07 31) 49 15-2 80
Internet www.tueva.de
E-mail:
[Karl-Josaf.Richardt
@tuevsaed.de](mailto:Karl-Josaf.Richardt@tuevsaed.de)

Experts:

Dipl.-Ing. Richardt
TÜV Süddeutschland, NL-Ulm/BB

Ulm, 1999-02-02
BB-ULM-R/IMa
File-No.: OMS/Rat-RUM/01/69

Participant on location:

Mr. Carlo Candiani - OMS

TÜV Süddeutschland ~
Bau und Betrieb GmbH
Aufsichtsratsvorsitzender:
Karsten Püssl
Geschäftsführer:
Roland Ayz (Sprecher)
Dr. Roland Ballier
Michael Hahn
Ingo Schröter
Peter Schubert
Dr. Kurt Vinzens
Sitz: München
Amtsgericht München
HRB 96 869

Date:

20 January 1999



1. Preliminary remark

The OMS company builds and delivers PU-foaming plants for both factories of the Project of UZINA Mecanica Sadu in Romania.

These plants are going to use Cyclopentane as foaming agent.

The main contractor and OMS have agreed to build these plants in accordance with the TÜV-safety requirements. The aim of the TÜV inspection is to prove the measures against fire and explosion hazard.

Following parts belong to the 2 Factories related to the PU Plant:

- Machine 1 Factory 1

- 1 x Underground tank 10.000 l
- 1 x Mixing unit with machine tank and HP Pump (100 kg machine)
- 1 x Cabinet Carousel with 1 Mixing head
- 1 x Door Plant with 1 Mixing head Pipes will be above ground approx. 300m
- 1 x Inertisation for cabinet and doors via mixing head.

- Machine 2 Factory 2

- 1 x Storage tank aboveground tank 3.000 l
- 1 x Mixing unit with machine tank (250l)and HP Pump (40 kg machine)
- 1 x Cabinet Carousel with 1 Mixing head
- 1 x Door Plant with 1 Mixing head
- 1 x Inertisation for cabinet and doors via mixing head.

2 DOCUMENTS USED AS A BASIS FOR THIS PLANT EVALUATION

2.1 Technical regulations

This plant evaluation is based on international, European and national regulations - in that order - as far as these are available and applicable.

These include the following essential regulations:

- international standards (ISO, IEC)
- Ordinance Regulating Facilities for Storing, Racking and Transporting combustible Liquids - Germany: VbF
- Decree for electrical plants in explosion dangerous areas, Germany: EleXV
- Decree for pressure vessels, Germany DruckbehV (pressure vessels)
- Law for immission protection: Germany BlmSchG
- Law for water protection: Germany WHG (protection against water-polutution)
- Electrotechnical regulations: International: IEC / European: EN / National: DIN VDE e.g. IEC 60073, IEC 439-1/A2, IEC 204-1, IEC 1310-2, EN 50054, EN 50013, EN 50020, EN 50081, EN 60529, pr. EN 1050, DIN VDE 0165, EN 349, EN 418, EN 294
- Fundamental safety aspects to be considered for measurement and control equipment: Germany DINV 19250
- Safety requirements for automated manufacturing systems: Germany VDI 2854
- personal protection regulations / accidents prevention - European: EN..EC / Germany: UVV/ZH
e.g. VBG 1, VBG 5, VBG 61, ZH 1/200, ZH 1/255, ZH 1/8, ZH 1/10

- Technical regulations for combustible liquids and for gases: Germany TRbF / TRG e.g. TRbF 100, 110 / TRG 280
- Ex-proof / spark-proof for ventilators: Germany VDMA-24169 part 1
- Homologation of technical plant and equipment - European: conformity certificates (e.g. PTB, Cesi, Damko)
- EN 378, Refrigerating systems and heat pumps, Safety and environmental requirements
- pr EN 1612-2 Reaction molding machines
- EG machine directive (89/392/ESG, revised edition 91/368/EEC)
- CEI/IEG 335-2-24, Safety of household and similar electrical appliances
- IEC 79-10/EN 60079-10/VDE 0165 Part 101: Electrical apparatus for explosive gas atmospheres - classification of hazardous areas.

2.2 Documentation of the PU plants and the peripherals

- Storage tank Type 10.000 l / 3.000 l
Work order 35/98M
100/98
Commissioning and Conformity Certificates
- Storage tank Type 10.000 l / 3.000 l
Work order 35/98M
100/98
Technical documentation Item Lists and drawing
- Machine Pentafoam HP 100/50
Work order 35/98B
Serial Number 0835
Technical documentation
- Machine Pentafoam HP 100/50
Work order 35/98B
Serial Number 0835
Instruction for Equipments composing the plant

- Machine Pentafoam HP 100/50
Work order 35/98B
Serial Number 0835
Testing and Conformity Certificates
- Machine Pentafoam HP 100/50
Work order 35/98B
Serial Number 0835
Directions for use
- Machine Pentafoam HP 40/20
Work order 35/98B
Serial Number 0834
Item lists and Drawings

3 Short description of the inspected plants

3.1 Plant for factory 1

3.1.1 Pentane Storage Tank (underground tank) according to drawing 1078/98 No.:820

a) Dates according to type plate:

Producer: C:I:S
No.: 98-317 271 MI
Volume: 10.000 l for Jacket 1000 l
Double walled

b) Important Safety Equipment:

- 2 x Pressure Gauge
1 x for N₂-pressure inside the tank room,
1 x for N₂-Pressure inside the jacket
- Safety relief valve Type SMIFN Nr.:981565 checked by ISPESL (set point 1.5 bar)
- Liquid level switch (super, max) Type: Nivelco,
Cert-TÜV-A-Nr. Ex 97.D014.X
- Automatic-Valve, Type Air Torque
- Automatic-Valve, Type Bremer, GTXN 92 x 90 NP 17A
- Level indicator, Type VEGA-EL 21Ex, PTB No. Ex-95.D.2097
- Pump/Motor:
Motor F.I. M.M., EEx II b T 4, CESI-CERT-AD-01.119
Magnetic coupling made by Burgmann
Pump: ANAR TIPO 1C25 TMG (set point of pump protection is 6 bar)

- Electro Panel: Mod. Stocc. Pent., Matr. 002 106
Cod. A 00.360, Data 7/10/98

3.1.2 Pentafoam 100 (Wetpart)

a) Dates according to type plate:

Producer: OMS

No. of Day Tank: 98-314 541 MI / 806

b) Equipment:

- Polyol / Pentane-Mixing unit: (automatic entrance valve, flow meter, Pump/Motor)
- Polyol / Pentane Tank No. 806
(Temperature -10°C / +90°C, automatic Valves, Overfilling switch, filling detection system, Stirrer, Stirrer motor, Leakage control system, pressure gauge for N₂, electrical heater, PT 100, Thermostat, approved safety relief valve)
- HP Pump (Motor, Leakage control system, Filter, Automatic valve)
- Gas sensors (2 x)
- Leakage- Sensor
- Technical ventilation (2 fans, Flow-switch)
- N₂-System for door/cabinet-inertisation: (pressure switch, flow-meter including flow-switch)
- Complete enclosure of the Pentafoam 100 including door control system
- The Iso-part is outside the enclosure,
- Electro panel for machine: CEROM, CE, Part. No. 002090

3.1.3 Safety-Panel

a) Dates according to type plate:

CEROM, 400 V, Part-No. 002134, diagram A 00364

b) Components:

- Gas alarm system (MSA 9020, Sensors EEx-d II C T6. CESI Ex 90050 X)
- Safety switch devices Type. Siemens 3 TK 2893, BIA No. 94 0080
- Control system for technical ventilation.

3.2 Plant for factory 2

3.2.1 Pentane tank (above ground) according to drawing 1077/98 No.:821

a) Producer: C.I.S.
No. 98. 317 972 MI No:821
Volume: 3.000 l
Single walled

b) Equipment:

- Pressure Gauge (for N2 inside the tank)
- Level switch (super-max.), Type. Nivelco,
Cert. TÜV-A-No. Ex 97.014.X
- Automatic-Valve, Type. Air Torque
- Pneumatic membrane pump, (Type. Capitanio) in particular pit
- Pipe to the Mixing room:
Pipe will be flanged
Material of pipe. Stainless steel 1.4301
Flange. PN 10/16 UNI 6092-93 304I
Gasket: armed (metal ring) Teflon were no explosion zone is possible in
the other parts only normal Teflon.
- Electro Panel: Mod. Stocc.Pent, Matr. 002 107, Cod. A 00 359, Data
07/10/98

3.2.2 Penta foam 40 (Wet part)

a) Dates according to Type plate.
Producer: OMS
No. of Day Tank: 98-314 539 MI / 804

b) Equipment:

- Similar like. part in 2.1.2 b
- Electro panel for Machine: CEROM, CE, Par. No. 002 033

3.2.3) Safety Panel

a) Dates according to type plate:
CEROM, 400 V, Part. No. 002 133, Diagram A 00 363

b) Equipment:

- Similar like. part in 2.1.3 b

**4. Results of the inspection
at the plants for Project UZINA Mecanica Sadu Factory 1,
Romania**

| | Remarks |
|--|--|
| 4.1 Pentane-Tank | |
| 4.1.1 General | <p>Concerning the used materials and the safety related equipment the tank meets the required technical standards</p> <p>The approval of the TÜV inspection is restricted to the present equipment which was available during the inspection.</p> |
| | <p>The present documentation is sufficient and meets the technical requirements (See additional Chapter 4.1.2)</p> |
| 4.1.2 Following measures are necessary: | |
| a) Documentation | <ol style="list-style-type: none">1. Super-max. level device: The certificates must be available2. A plan shows the explosion zones must be available,3. MSA-Tankgard I: The Certificate of conformity CESI Ex-91.C.126 X must be available.4. The set points of the pressure gauges and thermometers must be inside the documentation.5. The pressure limit switch of Schubert und Salzer is not in the documentation |
| b) Electrical control panel for Pentane tank: | <ol style="list-style-type: none">1. In the power circuit of the Super-max-levels the relay KA 4 is not as reliable as requested. (Must be one failure safe) |

4.2 Pentafoam 100

4.2.1 General

The safety system against fire and explosion hazard at all is according to the technical standards and the state of the art.

The present documentation is sufficient and meets the technical requirements.
 See additional Chapter 4.2.2)

4.2.2 Following measures are additional necessary:

1. The signals must be transmitted to an central place where a competent staff is always available.
2. The situation in the factory in case the electrical power brakes down must be clarified finally. The specific situation of the company must be considered.
3. The necessary function coupling to other safety relevant parts of the factory (e.g. the fire detection equipment) must be approved by experts in relation to the particular situation.

5 Results of the inspection at the plants for Project UZINA Mecanica Sadu Factory 2, Romania

5.1 Pentan-Tank

5.1.1 The results are same like in chapter 4.1.1.

5.1.2 Following measures are additional necessary:

a) Documentation

1. The technical documentation of the flexible Pentane pipes are available but in the present documentation it is not visible which kind of pipes will be used and whether the pipe is suitable for pentane or flammable liquids..
2. Operator instructions, e. g. Filling of the tank.
3. Pump

In the documentation of the Capitanio pump is not recognizable whether the pump is suitable for flammable liquids.

Remarks

b) Tank / Unloading place

1. Basin

the basin for the tank will contain more than 3 m³
It is planned to use concrete without cracks and it will be
painted with anti electrostatic paint.

2. Overfilling sensor

The sensor must be adjusted that the tank can not be
filled for more than 95%.

5.2 Pentafoam 40 and Safety-Panel

5.2.1 Concerning the documentation are this parts similar as the
parts mentioned in chapter 4.2

6 Measures, Function tests

During the inspection following measures and function tests has been carried out:

| Measures/ Function tests | Result | Function according to the Matrix | | Remark |
|--|------------------------------|-------------------------------------|----|--------|
| | | yes | no | |
| 1. Storage tanks | | X | | |
| 2. Penta foam | | | | |
| 2.1 Measures: | | | | |
| a) Potential equalisation / PE-connection | ≤ 0,3 Ohm | | | |
| b) Electrostatic/ Field Intensity: - Tank insulant „Keimannflex“) - Glass of the enclosure • Friction with Mohair • without Friction | 0 kV/m 100 kV/m 0 kV/m | | | |
| 2.2 Function tests | | | | |
| a) Gas alarm system - Power from Battery - Gas alarm 15% - Gas alarm 30% | | X X X | | |
| b) Ventilation - Function | | X | | |
| c) Super max-level | | X | | |
| d) N ₂ -Inertisation | | X | | |
| e) Leakage control system (control of seals) | | X | | |
| f) Leakage control system (Basin) | | X | | |
| g).Door control switch | | X | | |

7 Conclusion

Trial operation requires a constant supervision of the plant by expert technical personnel. Furthermore, the organisational aspects of plant operation must also be constantly monitored.

In the opinion of the TÜV experts, operation with pentane can be started after the measures mentioned in the report.

The experts



K.J. Richardt



E. Mack

Contract 97/106

Conversion of U.M. Sadu
factories of Bumbesti Jiu, Romania
to phase-out the use of CFC-11 and 12
in the production of domestic appliances.

According to enclosed TUF report, after their inspection of 19 and 20.11.98,
as per their advice, the following measures have been taken :

Page 8 Point 4.1.2

- a) 1- Certificates are available
 2- A plan has been supplied and kept with the whole documentation.
 3- Certificate is available
 4- A drawing showing such points has been supplied.
 5- Documentation has been supplied.
- b) 1- The tank has been operating with the supplied relay without any problem, however the technician that will visit the Counterpart in the first weeks of next year will replace it

Page 9 Point 4.2.2

- 1- Alarms and signals are efficient and constantly monitored by the pertaining staff. Even when the lines are not operating, i.e. at night and week-ends, staff is available inside the factory in case of emergency.
- 2- There is a private power station serving the whole industrial complex of U.M. Sadu, therefore the risk of break-downs is practically non-existent.
- 3- We were informed that, due to the Public nature of the factory and the type of products, other than refrigerators, being produced inside the whole industrial complex, government experts are constantly monitoring such aspects.

Page 9 Point 5.1.2

- a)
 - 1- The documentation used by OMS is a standard and widely accepted one, the nature of the piping used is, also, standard and suitable for use with highly-flammable liquids.
It doesn't describe the chemical composition of the materials used in manufacturing the piping, which can be examined on site, if necessary. The documentation provided consists of instructions on mounting and maintenance.
 - 2- Instructions on filling the tank were given to the pertaining staff. Normally, it's the supplier of c-pentane's operator(s) that carries out the filling operations.
 - 3- same as point 1, above.
- b)
 - 1- The basin is suitable to contain the 3000 liters tank, it is made in strong concrete and has been painted with anti-static paint after the TUF report had been issued.
 - 2- There is no need of such device, as the tank is normally filled at 70/75% of its capacity, allowing the line to operate for months.

The lines are operated only by personnel of U.M. Sadu with, at least, a decade of experience in handling foaming equipments and supervised by a team of engineers.

- VISIT TO THE PROJECTS
SITE, 6 MONTHS
AFTER INSTALLATION
JULY 1999

- FURTHER ACTIVITIES
UP TO DEC. 1999

Contract 97/106

Conversion of U.M. Sadu
factories of Bumbesti Jiu, Romania
to phase-out the use of CFC-11 and 12
in the production of domestic appliances.

We visited the Project's site at the end of July, 1999 to re-view the situation of the two lines that were operating efficiently.

The assigned operators and staff were carrying out their job, smoothly.

After a few months, as agreed, we despatched a number of spare parts as per enclosed OMS' proforma invoice 82/99, at the Counterpart's request.

Due to the rigid ambient conditions, the Counterpart decided to stop the two lines, temporarily, over December and the Holiday Season, to resume activities early next year at the presence of one technician from our side.

Instructions on how to empty the machines and fill them with proper liquids, in order to prevent corrosion and damages, have been given as per enclosed fax dated 02.12.99



21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332/282984 - telefax 0332/240309 - telex 325126
Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

Varese, li
vs. rif.
ns. rif.

07.07.99

Messrs.
Uzina Mecanica SADU
Bumbesti Jiu
c.c. **Arsenalul Armatei**
Bucuresti
ROMANIA

Object : Contract 97/106

Dear Sirs,

please note that, due to unexpected personal engagements, OMS technician, Mr Cannata, will have to be replaced by Mr Tiziano Perego. However, due to this change, we regret informing You that our group will arrive in Bucuresti on 20.07.99 and will perform its activities at Your factory until 23.07.99.

Our delegation will be composed as follows :

Mr GIAMPIERO PEDRONI - Riviera technical manager - pass. no. 773596A

Mr ROLANDO TEDIOLO - Riviera technician - pass. no. 747896L

Mr TIZIANO PEREGO - OMS technician - pass. no. 025360T

Mr ANTONIO FORNI - Riviera projects' coordinator - pass. no. Y006559

Flight details will be informed at the beginning of next week.

We are sorry for the inconvenience and we trust in Your understanding.

Thank You for Your attention and best regards.

Yours faithfully,
Riviera S.r.l.
Antonio Forni
Projects' coordinator

A handwritten signature in black ink, appearing to read "Antonio Forni".

**Impianti OMS Spa**

Via Sabbionetta 4
20050 Verano Brianza (Mi) Italy
Tel. +39-0362-983.1
Fax +39-0362-983217
internet: www.omsgroup.it
e-mail: impianti.oms@omsgroup.it



Verano Brianza, 28.10.99

Vs. rif.

Ns. rif.

UZINA MECANICA SADU
STR. PARANGULUI NR. 1 BUMBESTI JIU
1435 JUD. GORJ
ROMANIA

PROFORMA INVOICE N° 82/99

OGGETTO:

| QTY | DESCRIPTION | CODE | UNIT PRICE USD. | UNIT NET WEIGHT KG. | CUSTOMS CODE |
|-----|---|-----------|-----------------|---------------------|--------------|
| 2 | SELF-CLEANING FILTER ½" MOD. 25 | 921000124 | 10 | 1 | 84779010 |
| 2 | 2-WAYS LP BALL VALVE ¼" | 920900308 | 1 | 1 | 84779010 |
| 2 | OUTPUT REGULATOR ¼" | 920505557 | 1 | 2 | 84779010 |
| 2 | CALIBRATOR CARTRIDGE GROUP 1" | 133121002 | 5 | 2 | 84779010 |
| 2 | BALL VALVE 2V MVZ 1"1/2 | 920900304 | 5 | 2 | 84779010 |
| 4 | PRESSURE GAUGE HOLDER DIAM. 18 | 134173016 | 2 | 0,5 | 84779010 |
| 1 | PRESSURE GAUGE 0-20 1 CONTACT ½" DN100 | 920100139 | 10 | 2 | 84779010 |
| 1 | AMPLIFIER FOR LEVEL SENSORS | 930100124 | 10 | 1 | 84779010 |
| 2 | HYDRA-CELL VOLUMETRIC PUMP | 902200300 | 30 | 8 | 84779010 |
| 2 | ADDING BASE | 134203002 | 5 | 5 | 84779010 |
| 2 | COUPLING TRASCO28-38 24-7/8 | 134203001 | 2 | 1 | 84779010 |
| 2 | TANK LT 0,5 ¼" | 920800314 | 1 | 0,5 | 84779010 |
| 2 | LEVEL INDICATOR IEG 1P-100W | 930100119 | 1 | 0,2 | 84779010 |
| 2 | P&F BARRIER | 930401706 | 10 | 0,5 | 84779010 |
| 4 | O-RING 4081-75 SHORE VITON | 920200812 | 1 | 0,1 | 84779010 |
| 2 | LIP SEAL SAFCO AR 600258 | 920200303 | 1 | 0,1 | 84779010 |
| 2 | O-RING 4750-75 SHORE VITON | 920200838 | 1 | 0,1 | 84779010 |
| 2 | LIP SEAL 52-40-7 VITON | 920200448 | 1 | 0,1 | 84779010 |
| 2 | O-RING 162-75 SHORE VITON | 920200807 | 1 | 0,1 | 84779010 |
| 2 | NON RETURN VALVE TYPE CA38/4 COUPLING 1-1/2" | 920404040 | 1 | 0,5 | 84779010 |
| 2 | UNION E302-22L | 920401706 | 1 | 0,5 | 84779010 |
| 2 | UNION E222-22L | 920401407 | 1 | 0,5 | 84779010 |
| 2 | UNION E221-22L | 920401207 | 1 | 0,5 | 84779010 |
| 2 | UNION E231-222L | 920400907 | 1 | 0,5 | 84779010 |

16. NOV. 1999 16:30

IMPIANTI OMS
IMPIANTI OMS

NA. 1210



| | | | | | |
|-----------------------------------|-----------------------------------|-----------|----|-------------------|----------|
| 2 | UNION E412-122L | 920402105 | 1 | 0,5 | 84779010 |
| 2 | UNION E281-222L | 920401107 | 1 | 0,5 | 84779010 |
| 2 | UNION E502-22-18L | 920402502 | 1 | 0,5 | 84779010 |
| 2 | UNION E222-18L | 920401406 | 1 | 0,5 | 84779010 |
| 2 | UNION E412-118L | 920402104 | 1 | 0,5 | 84779010 |
| 2 | UNION E402-112L-G1/2" | 920402316 | 1 | 0,5 | 84779010 |
| 2 | UNION E211-212L | 920400805 | 1 | 0,5 | 84779010 |
| 2 | UNION E422-1/4"-3/8" | 920402203 | 1 | 0,5 | 84779010 |
| 2 | UNION E412-108L | 920402101 | 1 | 0,5 | 84779010 |
| 2 | UNION E281-212L | 920401105 | 1 | 0,5 | 84779010 |
| 4 | UNION E211-208L 1/4" | 920400803 | 1 | 0,5 | 84779010 |
| 2 | UNION E412-108L | 920402101 | 1 | 0,5 | 84779010 |
| 2 | REDUCTION AIR UNION RA014 1/2-1/4 | 920500405 | 1 | 0,2 | 84779010 |
| 2 | REDUCTION RA 014 3/8-1/2 | 920500406 | 1 | 0,2 | 84779010 |
| 2 | UNION E211-212L | 920400805 | 1 | 0,2 | 84779010 |
| 2 | UNION E502-18-12L | 920402501 | 1 | 0,2 | 84779010 |
| 2 | UNION E211-218L | 920400806 | 1 | 0,5 | 84779010 |
| 2 | UNION E412-142L | 920402108 | 1 | 1 | 84779010 |
| 2 | CONICAL CAP 105811-28L -DISEM | 920407102 | 1 | 0,5 | 84779010 |
| 2 | UNION E222-18L | 920401406 | 1 | 0,5 | 84779010 |
| 2 | UNION E221-18L | 920401206 | 1 | 0,5 | 84779010 |
| 2 | UNION E231-208L | 920400903 | 1 | 0,2 | 84779010 |
| 2 | UNION E211-208L | 920400803 | 1 | 0,2 | 84779010 |
| 1 | SET OF ELECTRIC MATERIAL | | 20 | 9 | 84779010 |
| 2 | BATTERY SIAC LC15 12V 15AH | | 20 | 13 | 84779010 |
| TOTAL VALUE ONLY FOR CUSTOMS..... | | | | NET W. KG. 114 | |

– Goods without value, under guarantee

– Goods rendered CIF

Goods of ITALIAN origin

N. 2 PACKAGES:

1) CM. 112x55x49

2) CM. 42x27x34

Total net weight kg. 114

Total gross weight kg 134

MARK: UZINA MECANICA SADU

1435 BUMBESTI JIU - JUD. GORJ (ROMANIA)

Customs code: 84779010



21100 Varese (Italy) - Via Silvestro Sanvito, 60 - tel. 0332 / 282984 - telefax 0332 / 240309 - telex 325126
Partita IVA 02149680122 Capitale Sociale L. 20.000.000 Reg. Soc. 20485 Tribunale di Varese - C.C.I.A.A. 234056

02.12.99

Varese, li

vs. rif.

ns. rif.

Messrs.
Uzina Mecanica SADU
Bumbesti Jiu
ROMANIA
k.a. **Eng. Panoiu**
Eng. Lazarescu

Object : Contract 97/106

Dear Sirs,

in order to preserve the two foaming lines until Mr Perego's visit, please note we advice You to purchase, *at least*, kgs 200 of Mesamoll.


In case You would like us to provide it, please note our retail price is Itl. **5.500 per kilo**, equal to **2,85 Euro**, ex-our warehouse in Varese, Italy, and that it comes in drums of kgs 220 each.

Therefore, the total cost, for 1 drum, would be Itl. 1.210.000 or Euro 627 and we would prefer if You arrange the shipment, Yourself, by sending a courier to our warehouse.

Afterwards, You should proceed as follows :

- a- descharge all chemical components from the tank(s)
 - b- fill the tank with Mesamol cleaning agent (about 15-20 liters)
 - c- by using the valve on the filter, descharge this quantity of Mesamol at about 0,5 bar pressure in the tank.
 - d- repeat points (b) and (c) two or three times.
 - e- fill the tank with Mesamol, again (this time about 30 liters)
 - f- disconnect the tank's feed-back tubes (2-3 bars)
 - g- give pressure to the tank
 - h- place a collecting container in correspondance of the disconnected tube.
 - i- push "Start pompe" for about 10 seconds, then stop the pumps.
 - l- with selector in "recycle" position ("taratura iniettori") push the injection button and descharge all the Mesamol completely (make sure the high pressure pump does not work without material inside the tank)
 - m- repeat operations from (e) to (l) two or three times.
 - n- stop the machine and leave it with about 20 liters of Mesamol in the tank.
- Thank You and warmest regards.

Yours faithfully,
Riviera S.r.l.
Antonio Forni
Projects' coordinator



RIMANTO C-PENTANO 168071401
VSFER PIPING


ADI ACCESSO

ZONA SCHIUMATURA ARRADI
160071501
CABINETS FORMING AREA

ZONA SCHIUMATURA PORTE
168071501
DOORS FOAMING AREA



La Impianti OMS S.p.a. si riserva a termine di legge la proprietà del presente disegno con diritto di riprodurlo o comunque senza la sua autorizzazione.



| DATA | MODIFICA |
|--|---|
| SCOSTAMENTI AMMESSI PER QUOTE SENZA TOLLERANZA SECONDO UTN D02 | |
| Campi dimensioni nominali | >0.5 ±3 ±6 ±30 ±120 ±315 ±1000 ±2000 |
| Scostamento grado grossolano | 0.15 0.2 0.5 0.8 1.2 2 3 |
| Scostamento grado medio | 0.10 0.1 0.2 0.3 0.5 0.8 1.2 |



DESCRIPTION *

SCHEMA DI FLUSSO REPARTO STOCCAGGIO

* STORAGE AREA FLOW-DIAGRAMM

REPLACE DRW.
*

REPLACED DRW.
*

DATE 30-04-98
MACHINED *

SIGNATURE CP
SCALE 1:10

DRAWING 168075301

| DATA | MODIFICA |
|--|---|
| SCOSTAMENTI AMMESSI PER QUOTE SENZA TOLLERANZA SECONDO UTN 002 | |
| Campi dimensioni nominali | >0.5 >3 >6 >30 >120 >315 >1000 ±3 ±6 ±30 ±120 ±315 ±1000 ±2000 |
| Scostamento grado grossolano | 0.15 0.2 0.5 0.8 1.2 2 3 |
| Scostamento grado medio | 0.10 0.1 0.2 0.3 0.5 0.8 1.2 |

CASSETTA ANTIINFLAMMABILE PER
CONTENIMENTO ELETTRONAVOLE
FLAMEPROOF BOX FOR SOLENOID VALVE

PINZA DI MESSA A TERRA
GROUNDING PLIERS



CONNECTION TANK-TRUCK FOR LOADING TANK
ATTACCO AUTOBOTTE PER CARICO SERBATOIO



ATTACCO AUTOBOTTE PER RACCOLTA GAS
CONNECTION TANK-TRUCK FOR GAS COLLECTION

FORNITURA CLIENTE
CUSTOMER'S SUPPLY


LINER AZOTO 4-8 Bar
Nitrogen line

ARIA COMPRESA 4/8 Bar
GRUPPO TRATTAMENTO ARIA
COMPRESSED AIR
TREATMENT AIR GROUP

HANDATA PENTANO
PENTANE FEEDING



| OMS Group Polyurethane Evolution | REPLACE DRW. * | DATE 25-05-98 | MACHINED * |
|--|--|------------------|----------------------|
| REPLACED DRW. * | SIGNATURE CP | SCALE 1:10 | DRAWING 168065301 |
| DESCRIPTION * | * SCHEMA E MONTAGGIO ACCESSORI SU SERBATOIO STOCCAGGIO | | |
| | * DIAGRAM AND ACCESSORIES FOR TANK STORAGE | | |



| DATA | MODIFICA |
|--|---|
| SCOSTAMENTI AMMESSI PER QUOTE SENZA TOLLERANZA SECONDO UTN 002 | |
| Campi dimensioni nominali | +0,5 +3 -6 -30 +120 +315 +1000 +2000 |
| Scostamento grado grossolano | 0,15 0,2 0,5 0,8 1,2 2 3 |
| Scostamento grado medio | 0,10 0,1 0,2 0,3 0,5 0,8 1,2 |

OMS
GROUP
Polyurethane Evolution

DESCRIPTION *

PIPING TRASFERIMENTO C-PENTANO

* C-PENTANE TRANSFER PIPING

REPLACE DRW.

REPLACED DRW.
#

DATE
03-07-98
MACHINED
SIGNATURE
CP
SCALE
1:1

DRAWING
168061401

CONNECTION TANK-TRUCK FOR LOADING GAS
ATTRACCO AUTOBOTTE PER CARICO SERBATOIO

ATTRACCO AUTOBOTTE PER RACCOLTA GAS
CONNECTION TANK-TRUCK FOR THE DRAINING


FORNITURA CLIENTE
CUSTOMER'S SUPPLY
LINEA AZOTO 4-8 Bar
Nitrogen line

SCHEMA DI FLUSSO IMPIANTO STOCCAGGIO 1680
STORAGE PLANT FLOW-DIAGRAM

(E1)

SCHEMA DI
FLUSSO IMPIANTO
STOCCAGGIO 168075301

OLTA GAS
CIRCUITO



SCHEMA DI FLUSSO IMPIANTO STOCCAGGIO 168075301
STORAGE PLANT FLOW-DIAGRAM

LINEA ALIMENTAZIONE POLIOL
POLYOL FEEDING LINE

LINEA ALIMENTAZIONE ISOCIANATO
ISOCYANATE FEEDING LINE



IMPIANTO PORTE
DOORS PLANT


FICM
MACCI
13297

(E2)

| ITEM | NUMBER | REF. | QTY | UNIT |
|------|--------|------|-----|------|
| ITEM | NUMBER | REF. | QTY | UNIT |
| ITEM | NUMBER | REF. | QTY | UNIT |
| ITEM | NUMBER | REF. | QTY | UNIT |


E POLIOL

ISOCIANATO
INE



FORMING MACHINE
MACCHINA "PENTAFORM HP100"
132971001

IMPIANTO ARMADI
CABINETS PLANT



FORNITURA CLIENTE
COSTONEP'S SUPPLY
LINER AZOTO 4-8 Bar
Nitrogen line


E3

OMG
GOUD
Polyurethane Evolution

SCHEMA DI FLUSSO IMPIANTO

| | | | | | |
|-----------|------------|-----------|----------|--------------|----------|
| PROGETTO | PROGETTO * | DATA | 11-05-98 | VISUALIZZATO | * |
| PROGETTO | PROGETTO * | SIGILLATO | CP | DATA | 11-05-98 |
| SCHEMI | SCHEMI * | DATA | 11-05-98 | VISUALIZZATO | * |
| 168075101 | | | | | |

ESECUZIONE DI DIBETONE
DI ESECUZIONE SUL POSTO



STOCCAGGIO C-PENTANO
10 m³

ESECUZIONE DI TUBAZIONE
DI ESECUZIONE SUL POSTO

TUBO COIBENTATO : diam. 35 sp3
ecc. inox
(ESEGUIRE N. 4 tubi di lunghezza 5mt.
come disegno N. 1337300)


F

Sostegni per siringa (Fornitura clienti)

1

13

-
17



F2

21 1

MACCHINA SCHIUMATRICE

TUBO ELETTRONICO diam. 32 sp3

Elettronica per comando
valvola a due posizioni
(Posizionate sulla macchina)

SPECZIONE DI TUBAZIONE
DA ESEGUIRE SUL POSTO

3200

16 13 12 11 10

SCARICO DA ADATTARE SUL POSTO
SECONDO INCLINAZIONE PIPING

135000

TUBO COIBENTATO diam. 35 sp3
acc. inox
ESEGUIRE N. 22 tubazioni L=6mt.
come disegno N. 168072001

TUBAZIONE DISTRIBUZIONE C-PENTANO
INCLINAZIONE 0,5% (Verso il serbatoio stoccaggio)
PRESSIONE MAX. 15Bar
PIPE FOR C-PENTANE DISPENSING
INCLINATION 0,5%. Storage tank side
MAX. PRESSURE

NB: TUTTE LE TUBAZIONI DEVONO AVERE
IL COLLEGAMENTO DI MESSA A TERRA
REMEMBER ALL PIPING SHOULD HAVE EARTHING
CONNECTIONS

F3



REPLACED BY:

DATE: 07-07-98

*
REPLACED BY:

SIGNATURE:

1:1,


CP

*


PIPING TRASFERIMENTO C-PENTANO

168071401

* 168071401




G1




G2

| DATA | MODIFICA |
|--|-------------------------------|
| SCOSTAMENTI ANNESSI PER SCUTE SENZA TOLLEGENZA | |
| Campi dimensioni nominali | 0,5 -3 -6 30 +3 +6 +30 +30 |
| Scostamenti grado pressoché | 0,18 0,2 0,5 0,8 |

E AZOTO 4/8 Bar
TATR 100L/min
OPEN LINE



REPARTO SCHIUMATURA PRODOTTO
68061501
PRODUCT FORMING AREA



POTENZA ELETTRICA
400Vac - 50Hz - 3Fasi
ELECTRICAL POWER
400Vac - 50Hz - 3ph

● SENSORI GAS
GAS DETECTOR

Ec E ESTINTORE
FIRE EXTINGUISHER

○ RETE AZOTO
NITROGEN LINE

○ RETE ARIA COMPRESSA
COMPRESSED AIR LINE

○ LINEA ACQUA DI RETE
ATTACCO 1'Gas
TAP WATER LINE
CONNECTION

| INDIFESA | | | | | | |
|---|-------|------|------|------|------|-------|
| PIANTE INGRESSO PEP. SOUPE SENZA TOLLEGANZA SECONDO UTM 002 | | | | | | |
| dimensioni nominali | 0.5 | 3 | 6 | 30 | 120 | 315 |
| dimensioni nominali | ±3 | ±6 | ±30 | ±120 | ±315 | ±1000 |
| entro grado pressione | 0.15 | 0.2 | 0.5 | 0.8 | 1.2 | 2 |
| entro grado pressione | ±0.15 | ±0.2 | ±0.5 | ±0.8 | ±1.2 | ±2 |

OMG
GROUP
Polyurethane Evolution

DESCRIPTION *

IMPIANTO SCHIUMATURA ARMADI E PORTE

* CABINETS AND DOORS PLANT LAYOUT

| | | | | |
|---------------|---|-----------|-----------|---------|
| REPLACED DPN. | * | DATE | 27-04-98 | MACHINE |
| REPLACED DPN. | * | SIGNATURE | CP | SCALE |
| | | | | 1: |
| | | DRAWING | | |
| | | | 168061001 | |

CONNECTION TRAILER -> FCB LOADING TANK
ATTACCO AUTOBOTTE PER CARICO SERBATOIO

ATTACCO AUTOBOTTE PER RACCOLTA GAS
CONNECTION TRAILER -> FOR GAS COLLECTION


FORNITURA CLIENTE
COSTOMEPS SUPPLY
LINER AZOTO 4-8 Bar
Nitrogen line

SCHEMA DI FLUS.
STORGE FLOR-D.


GRUPPO
POLY...

GRUPPO POMPA PNE
PNEUMATIC PUMP


H1



**SCHEMA DI FLUSSO STOCCAGGIO 168065301
STORAGE FLOW-DIAGRAM**




PINZA DI MESSA A TERRA
KIRNDING PIASTRE



PIPING MANDATA C-PENTANO 168061401
C-PENTANE FEEDING PIPING


**TUBO DIAMETRO 28
EXTERNAL PIPE**




FORNITURA CLIENTE

CUSTOMER'S SUPPLY


LINER AZOTO 4-8 Bar
Nitrogen line



| | | | |
|---|---------------|-----------|----------|
|  Group Polyurethane Evolution | PERFECT DPW. | DATE | REVISION |
| | * | 09-05-98 | * |
| | REPLACED DPW. | SIGNATURE | SCALE |
| | * | CP | 1:7 |
| DESCRIPTION * | | DRAWING | |
| SCHEMA DI FLUSSO IMPIANTO | | 168065101 | |
| * PLANT FLOW-DIAGRAM | | | |



POZZETTO (300x300) PER PILOTA
MESSA A TERRA
PIT FOR GROUNDING ROD




PIT FOR TANK GROUNDING ROD
POZZETTO PER PALINA DI MESSA
A TERRA SERVATARIO



POSIZIONE ATTACCHI PER AUTOBOTTE
CONNECTIONS FOR TANK-TRUCK

POZZETTO PER PALINA DI MESSA
PER PINZA AUTOBOTTE
PIT FOR TANK TRUCK
GROUNDING ROD

1000



ESTRAZIONE CARRELATO
(FORNITURA CLIENTE)

EC


STOCCAGGIO BOMBOLE AZOTO
RETE AZOTO 0/8 Bar
PORTATA 100 NL/min
NITROGEN STORAGE BOTTLES
NITROGEN LINE

RETE ARIA COMPRESSA
4/8 Bar 50 NL/min
COMPRESSED AIR LINE


NB: tutte le strutture e masse metalliche
devono essere collegate alla rete di
messaggio a terra con bulloni e/o saldature

REMARK: ALL THE STRUCTURES AND METALLIC PARTS
MUST BE CONNECTED TO THE EARTHING
SYSTEM WITH BOLTS AND/OR WELDINGS

12



RETE AZOTO 4/8 Bar
PORTATA 100NL/min
NITROGEN LINE
OUTPUT



3500

5000

La Impianti OMS s.p.a. si riserva a termine di legge la proprietà del presente disegno con diritto di riprodurla o comunque carico senza la sua autorizzazione.

RIEMPIRE LA FOSSA ATTORNO AL SERBATOIO CON SABBIA
FILL THE DITCH AROUND THE TANK WITH SAND

POZZETTO (300x300) PER PALINA DI MESSA A TERRA SERBATOIO
PIT FOR TANK GROUNDING ROD

H=3000
ESALAZIONE GAS
GAS SCAVENGING

1900x2260

1280x1640

SG1

ESEI
CARF

400 600 4910 6110 2070 600

500
865
350

Pavimento in cemento

115021301
GRUPPO CENTRALINA DI ASPIRAZIONE
UNIT FOR EXTRACTION GROUP


POSIZIONE ATTACCHI PER AUTOBOTTE
CONNECTIONS FOR TANK-TRUCK

15400



RETE ARIA CI
PORTATA 100
COMPRESSED AIR

3 PIRANTANA SOS
POSITION OF
HOLDER BOX


6




51



ATTACCO PER MESSA A TERRA
GROUNDING CONNECTION




SOLUZIONE '1'




PENDENZA 1%
SLOPE
(CON FORO DI DRENAGGIO)
(DRAIN HOLE)

EXCAVATION TO BE CARRIED OUT
AFTER THE POSITIONING OF COLUMN
SCAVO DA ESEGUIRE IN OPERA
DOPO IL POSIZIONAMENTO DELLA
PIANTANA



NB: TUTTI
DEVOI
MESSI

REMARK: ALL TH
MUST E
SYSTEM



J2

| | |
|--|--------|
| OMS Group Polyurethane Evolution | REPLAC |
| DESCRIPTION * | REPLAC |
| DISPOSIZIONE REPARTO STOCCAGGI | REPLAC |
| * C-PENTANE STORAGE LAY-OUT | REPLAC |

