



**TOGETHER**  
*for a sustainable future*

## OCCASION

This publication has been made available to the public on the occasion of the 50<sup>th</sup> anniversary of the United Nations Industrial Development Organisation.



**TOGETHER**  
*for a sustainable future*

## DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

## FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

## CONTACT

Please contact [publications@unido.org](mailto:publications@unido.org) for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at [www.unido.org](http://www.unido.org)

16910-E

Distr.  
RESTRICTED

UNIDO/IO/R.250  
7 July 1988

UNITED NATIONS  
INDUSTRIAL DEVELOPMENT ORGANIZATION

ORIGINAL: ENGLISH

Workshop on Hazardous Materials/Waste  
Management, Industrial Safety in  
Chemical Industry and Emergency  
Planning: Guidelines for Governments  
and Industries - A Plan of Action for  
UNIDO.

Vienna, 22-26 June 1987

WASTE DISPOSAL AND WATER TREATMENT  
IN SELECTED PRESERVED FOOD INDUSTRIES IN EGYPT\*

by

Makio Nakashio  
UNIDO Consultant

473

---

\* The views expressed in this paper are those of the author and do not necessarily reflect the views of the Secretariat of UNIDO. This document has been reproduced without formal editing.

CONTENTS

	<u>Page</u>
Acknowledgement	3
Summary	4
Introduction	5
Project Background	11
Recommendations	19
Section 1. EGYPTIAN BOTTLING CO. "Pepsi-Cola" (Sohag-City)	
Section 2. EDFINA CO. for PRESERVED FOOD (Alexandria-City)	35
Section 3. EL NASR CO. FOR PRESERVED FOOD "Kaha" (Kaloubia, Kaha)	45
Section 4. EL NASR CO. FOR PRESERVED FOOD "Kaha" (Badrashin)	62
Conclusion	81
Annexes	82

ACKNOWLEDGMENTS

This report has been prepared in cooperation with GOPI, (1) EGYPT, at the request of UNIDO, (2) Vienna.

The author "Makio Nakashio" wants to express his gratitude to the help of Dr. Ahmed Amin Ibrahim (3) GOPI as well as of Mr. Stharwat Sabry (4) of the UNDO Cairo .

The author also thanks the staff of the Bureau of Industrial development Managment. GOPI as stated in annex

- 
- 1) GOPI - General Organization of Industrialization  
6, Khalil Agha Street, Garden City-Cairo EGYPT.
  - 2) UNIDO- United Nations Industrial Development  
Organization, Vienna, Austria.
  - 3) Engr. Dr. Ahmed Amin Ibrahim  
Head of Central Department of Industrial  
construction  
Bureau of Industrial Enviromental Management,  
GOPI, EGYPT
  - 4) Mr. Tharwat Sabry,  
UNITED NATIONS DEVELOPMENT PROGRAMME  
ZAMALEK 29, DR. TAHA HUSSEIN STREET, EGYPT.

SUMMARY

This project was supported in part by the UNIDO, Vienna and UNDP, Cairo. The work reported here represent a joint effect on the part of GOFI, Egypt.

In brief, it can be said that the overall efficiency of manufacturing food factory waste water treatment plants depends upon these design, application and operation.

- (1) All the industrial waste water from the food factory was passing untreated into the river Nile and the nearest river or streams.
- (2) It does not have data of water quality chemical analysis investigation (BOD, COD, SS, oil and grease, etc.) result table industrial waste water of Government enterprise factory and it has no chemical analysis operation and analysis ability of water quality chemical analysis items.
- (3) For this project samples were taken from each factory (four companies).
- (4) An important and major part of the programme in this area is on-going grant with the city Cairo, river Nile from its southern Egyptian border to the Delta barrages.

A list of completed and on-going projects is presented in the appendix to give the reader an overview of the activity in this area.

### INTRODUCTION

There are about 200 governmental industrial Factories in EGYPT along the river Nile & its branches .

In the past, little has been carried out to treat sewage and industrial waste water effluent .

The existing state of the art had caused water pollution to the river Nile.

This GOFI project consists of four Preserved food Factories with definite plan of measure against pollution at urgently. They are :-

1. EGYPTIAN BOTTLING CO.  
"Pepsi Cola" (Sohag- City)
2. EDFINA PRESERVED FOOD CO. (Alexandria- City)
3. EL NASR CO. FOR PRESERVED FOOD  
"Kaha" (Kaloubia - Kaha)
4. EL NASR CO. FOR PRESERVED FOOD  
(Giza-Badrashin)

In these industrial activity, the water quality of industrial waste water is generally characterized with "BOD" heigher (bigger) than "COD" But, these four food factories have something in common : BOD is lower (smaller) than "COD"

the result of actual water quality chemical analysis was as follows :

1.	Pepsi cola Co.	BOD 360 ppm	COD 771 ppm
2.	EDFINA Co.	BOD 640 ppm	COD 820 ppm
3.	Kaha Co.	BOD 385 ppm	COD 496 ppm
4.	Badrashin Co.	BOD 2.452 ppm	COD 2.728 ppm

The chemical treatment Methods include coagulation followed by sedimentation must be used .

The biological treatment is achieved by using Controlling Tank (Storage tank) one day capacity size (water volume per day) which is necessary for feeding Bacteria Hiroagh Friday to Saturday, as the Factory is closed Friday .

The waste water discharge of governmental enterprises EGYPT's is a mix of industrial waste water (from manufacturing Process) and Domestic sewage (As countermeasure it is needed to use cl sterilizing Tank (3-8 ppm injection liquified chlorine gas) of all volume (m3/day) as effluent treated water . . liquified chlorine gases soluble in effluent water chlorine is effective in killing both "Escherichia Coli" and "viruses".

The problem of recycling of effluent treated water not considered because of low price of water.

Industrial waste water and domestic water are separated in the Pepsi Cola Factory Co. only. Pepsi Cola Factory had all machines and process from Germany .

The factory was very fine and maintenance management is according to Germany's modern style .

But. Kaha Factory, Badrashin Factory and EDFINA Factory are old factories 30 to 40 years ago/ The pipe lines and pits are joined up for both sewerage and industrial water which is impossible to separate inside Factory .


The problem is a discussion on the alternative processes that have been developed and their general standing in regards to immediate and future application.

Recycling of Effluent treated water:

The recycling of effluent treated water is used for in follow Diagram as a tertiary treatment stage.

..... next page





This technology has a high initial cost for the design and operation Activated carbon system. The running cost (in Japan case) is 150 - 200 Y/m<sup>3</sup> =(1.87 - 2.5 LE/m<sup>3</sup>).

At present time the conditions of Cairo-City is very cheap in comparison with other foreign countries, e.g. Cairo-City Tap-water is equal to : m<sup>3</sup> 0.1 LE/m<sup>3</sup> (10Piasters/m<sup>3</sup> , 0.05\$/m<sup>3</sup> ) In Japan case fresh water price is :25 Y/m<sup>3</sup> (0.31 LE/m<sup>3</sup>) that is about 3 times.

According to this recycling of water was not taken in consideration while making for effluent waste water .

In the future this is a problem to deal with at the Ministry of Industry and at the Ministry of Development, EGYPT.

I like to consider also the possibility of effective utilization of factory waste instead of disposing them through burning in an incinerator .

This will lead to recovery and recycling of waste.

Along a line of thinking about biomass . I propose to direct this reutilization to convert the waste to fertilizer and fodder (animal food).

First, Drainage channel flow in effluent from manufacturing process line at inside Factory. That is small pieces of fresh fruits, fresh Vegetables and fish etc.

These are taken out to segregated in side Factory and is given as animal food (cow, sheep, chicken) feeder.

It makes a profit place on the market at a growth period . For example, in Japan was to depreciation at three years proceeds.

The situation of equipment is described in the following page (Photograph No 1,2 ) . Page 48.

Second, It has been shown in other parts of this report that excess sludge in biological treatment (Activated sludge method).

It was necessary for the sludge disposal problem in that it must either be taken away to a suitable disposal site or applied to sand beds which must eventually be dried using solar heat . substance used as fertilizer for Agriculture.

#### PROJECT BACKGROUND

The problem in the food industry lies in the waste it produces it need much water e.g. when producing one ton of tomato Juice (as product), 10 Tons of fresh water is required to sterilize a cleaning water-tank for raw material.

It varies depending upon the season in analysis, deepness and volume of the water required treatment.

Because of the differences on each harvest season on fresh fruits, vegetables and fish etc, the produced items are also not the same during a year, consequently composition and density as well as volume of industrial waste water are fluctuating remarkably.

The detergent and fungicide cause bad effect on efficiency of waste water treatment by biological treatment process.

The pollution loading amount (total BOD:kg-BOD/day) of these four food Factory correspond to the scale of city sewage treated matter for person if converted to population equivalent on city sewage, as follows:-

1.	EGYPTIAN BOTTLING CO. Pepsi Cola	
	Total BOD 864 (Kg-BOD/day) equivalent	21.600 persons
2.	EDFINA Co.	
	Total BOD 1.280 Kg-BOD/day	32.000 persons
3.	ELNASR Co. "Kaha"	
	Total BOD 862 Kg-BOD/day	21.500 persons
4.	ELNASR CO. "Badrashin"	
	Total BOD 2.746 Kg-BOD/day	86.600 Persons

**NOTE:**

The daily water consumption of one person, sewage, 200 ppm-BOD multiplied by 200L/man.day 40 g -BOD/man.day for example, 864 kg-BOD/day divided by 40g-BOD/man.day=21.600Persons

In a comparison between EGYPT and other countries as :-America, Germany, England and Japan, the investment cost of economical treatment plant is important and, running cost is cheap too. This reason are:-

(in Egypt case) (in Japan case)

- 1- City Tap-water 0.1 LE/m<sup>3</sup> = (0.05\$/m<sup>3</sup>) 25Y/m<sup>3</sup> = 0.31LE/m<sup>3</sup>
- 2- Electric 0.2 LE/KWH = (0.1\$/KWH) 20Y/KWH = 0.25LE/KWH
- 3- Personal (labor) expenses per Year/man  
1.500-2.000 LE/man/year =  
(750-1000\$/man.year)


Regarding the volume and concentration of industrial waste water which has to be influent before treatment at last, water quality has been analyzed and taken as reference for designing of an economical treatment plant.

Items of waste water chemical analysis were:

PH (Hydrogen ion concentration) ( $-\log H^+$  concentration)  
BOD (Biochemical Oxygen Demand)  
COD (Chemical Oxygen Demand )  
SS (Suspended Solids)  
T-N (Total Nitrogen)  
Oil and grease

I draw up the flow- sheet. The plan course of action is shown in Fig.1. (next page)

Fig.1 A Technique of make up flow-sheet



Next, Selection of treatment equipment depends upon the calculation sheet (a statement of accounts) on such as performance of the equipment, size of the Tank and other dimensions, (W), (L), (H), Diameter, pipe laying, motor etc . Fig.2. shows an example of selection of treatment method and a plan (working Drawing) based on design conditions.

**NOTE:**

(next page)

**Fig.2. "Flow-Diagram of waste water Treatment"**

**quote from a specialized book**


**(The Activated sludge Treatment of waste water)**

**Page 102, 4ed, 1986. NAKASHIO.**



Fig. 2

Book: The Activated Sludge Treatment of Waste Waters, 1st Edition  
NAKASHIO




## RECOMMENDATIONS

### General

In view of the many factories presentd in this report and considered by the GOPI, the following recommendations are made :

1. Place of the Factory on the map



1. Edfina Company (Res-El soda - (Alexandria)
2. Kaha company ( kalowbia)
3. Kaha company ( Badrashin)
4. Egyptian bottling company - peysicola ( sohag )

2. Purpose of the Project

To assist the General Organization for Industrialization (GOPI) in identifying the terms of reference for sub-contracting of detailed engineering and civil design work and monitoring and supervising the contractor's work in installation in waste disposal and water treatment of the food industries.

3. Effluent Standard of irrigation drain. The law and regulations has been made to meet local condition. Law name is as shown below:

(LAW 48-1982, REGARDING THE PROTECTION OF THE RIVER NILE & WATERWAYS FROM POLLUTION)

In application of this law, the Factory are the following

Parameter	Pepsi Cola Co.	EDFINA Co.	in Kaha KAHA CO.	Kaha Co. BADRASHIN
PH	6-9	6-9	6-9	6-9
BOD	30ppm	60ppm	20ppm	20ppm
COD	40ppm	100ppm	30ppm	30ppm
SS	30ppm	60ppm	30ppm	30ppm
Oils & grease	5 ppm	10ppm	5 ppm	5 ppm
Total Coliform (MPN/100ml)	2500/ 100ml	2500 100ml	2500 100ml	2500 100ml

NOTE:

1 All Standards in ppm unless otherwise noted .


**Section - 1 PEPSI COLA Factory at Sohag**

**Site Visit :**

1. **Place of Factory :**  
**EGYPTIAN BOTTLING CO. "PEPSI COLA"**  
**Sohag-Factory - AGhmiem Sohag City**
  
2. **The technical meeting hold a two days visits on site on 25,26 November 1986, detail and plans were presented by factory personel .**
  
3. **GOFI Visitors**  
**Engr. Mohamed A. Eweiss**  
**Egnr. Ali El Sisi**  
**----- Makio Nakashio (Japanese)**
  
4. **Company Personel**
  - 1) **Engr. Mr. Taha abo Eldahab**  
**(General Managerment Chief)**
  - 2) **Factory manager : Engr. Mr. Mohammed Aly Othman**
  - 3) **Person in charge: Engr. Mr. Mohammed El Nezany**  
**(Quality company manager)**
  - 4) **Laboratory chief Engr. Mr. Talal EL Abd**

Pepsi Cola Co. (Sohag-City)

A Sketch map of Factory



Reduced scale : free

Pepsi Cola Co. (Sohag-City)

A Sketch map of Factory

reduced scale:Free

The RIVER NILE

underground  
pipe line  
(about. 1 km)

waste water  
Effluent


Gate

material place 60m (empty area) 1.200m <sup>2</sup>	pits 20m	Security office
-----------------------------------------------------------------	-------------	--------------------

ware house	manufacturing process factory (building)
---------------	------------------------------------------------

CO <sub>2</sub> gas produce equipment	loading house (employees rest) plase
---------------------------------------------	--------------------------------------------

River  
Nile



Effluent of the present

Photo : 1. Final Point of discharge to the river Nile.



Photo:2. Settling time for the suspended matter on  
the site



Photo: 3.        Settling time for the total suspended solid  
                  of waste water and see colour on the site.



Photo: 4.        Upper view of all Pepsi-Cola Factory.



Description of Process (flow-sheet)

1. Planning establish terms

(1) The basis for planning

1) Volume of industrial wast water.

summer season: (6month).24hrs/day.. work operation  
100m3/hrs. 24hrs. = 24.000 m3/day

winter season: (6month) 12hrs/day. work operation  
100m3/mr x12hrs= 12.000 m3/day

I shall establish treatment unit according to the maximum discharge volume (2.400m3/day)

2) The domestic discharge can be transported away by trucks from the industrial waste water.

3) The number of workers(employees) 150 men

(2) waste water quality of industrial

1) Effluent Standard

PH	11.7	PH	6-9
BOD	360 ppm	BOD	30ppm
COD	771 ppm	COD	40ppm
SS	284 ppm	SS	30ppm
Oil & grease	0	Oil & grease	5

2) A unit cost of City tap-water 0.03 LE/m3 (3piasters/m3)

3) The empty area, about 1.200m2 (20mx60m)

NOTE: (LE. is a abbreviation of EGYPT POUND .

2. **Plant Description (Major Equipment specification)**  
The flow-sheet diagram of the economical treatment plant is shown in figure 1. (Annex)

2-1. **Controlling Tank**

Controlling tank have following object

- 1) It will give us uniform concentration of the influent waste water.
- 2) We shall get rid of the volatile matter, this will cause the decrease of the BOD 10-15% by aeration agitation condition .
- 3) It will act as storage tank as the factory is closed on Friday which is necessarily for feeding bacteria (for Biological treatment : Activated Sludge method).
- 4) Also for adjustment of the pH value of the waste water(which is 11.7)to base condition for Activated sludge method,(which is 7) by using 20% NaOH solution.

**Specification of Controlling Tank**

Components Item	Type Material	Dimension(m)			Capacity (m3)	Space requirement(m2)
		(W)	(L)	(H)		
Controlling tank body	Aeration- Agitation concrete	20	36	5	1800	720

Retention time : 18 Hr

\* **Attachments**

1. Air diffuser : Air distribution pipe : 2 1/2 inch  
Sparger  
Blower (Air-compressor)

- 2. 20% H2 SO4 Storage Tank

Capacity 20m<sup>3</sup> (in side Tank Rubber Coating) one set.  
 .Dimention 2.7m x 3.5 (H)  
 material steel sheet  
 space requirement 6m<sup>3</sup>

3. Instrumentation

Type (Pn1C) jutomatic control system, one set (PH indicate control)

2-2 Coagulation and Sedimentation Tank

Components Item	Type Material	Dimension(m)	Capacity (m <sup>3</sup> )	Space requirement(m <sup>2</sup> )
		(W) (L) (H)		
Coagulation tank	Concrete	2.5x10x2	50	25
Sedimentation tank	concrete	2.5x13x3	100	33

\* Attachments

1. Agitation : 1) quick agitation, 120 r.p.m.(1.5 m/sec. speed)  
 MOTOR: reduce speed of a machine,  
 3HP retention time : 5 minutes
- 2) Slow agitation, 30 r.p.m.(30 m/sec. speed)  
 MOTOR: reduce speed of a machine,  
 5HP retention time :25 minutes

2. FeSO<sub>4</sub> storage Tank (coagulant)

Capacity 10m<sup>3</sup>  
 Dimension 2.1 m x 3.05m (H)  
 material Steel sheet  
 space requirement 5m<sup>2</sup>

3. PAC (Polymer coagulant aids) - - - concentration of use 5-10 ppm

Capacity one m<sup>3</sup> one set  
 Dimension one m x one m (H)  
 material steel sheet  
 space requirement one m<sup>2</sup>

2-3 Neutralization Tank

Neutralization tank is the PH adjustment for Activated Sludge process of next step using 10% H<sub>2</sub>SO<sub>4</sub>

Item	components Type Material	Dimension(m)	Capacity (m <sup>3</sup> )	Space requirement(m <sup>2</sup> )
		diameter(H)		
Neutralization tank	Concrete	D=5m x 2.5	50	25

Retention time : 30 min

\* Attachments

1. 10% H<sub>2</sub>SO<sub>4</sub> Storage Tank

Capacity 20m<sup>3</sup> (in side tank rubber coating)  
 Dimension D = 5m x 2.5m (H)  
 Material Steel Sheet  
 Space requirements 25m<sup>2</sup>

2. Agitation : 50-80 r.p.m Agitator one set  
MOTOR : reduce speed of a machine

**2-4 Aeration Tank**

Incoming raw concentration waste water is fed to Aeration Tank where it is treated biologically by microorganisms.

components Item	Type Material	Dimension(m)			Capacity (m3)	Space requirement(m2)
		(W)	(L)	(H)		
Aeration tank	Aeration- Agitation concrete	* 16x23.5x4			1500	376
				* 8mx2 =	16m	

1. Bod loading : 0.7 kg-BOD/m3.day
2. incoming waste water quality : BOD 240 ppm
3. Total-BOD 0.24kg-BOD/m3x2.400m3/day=576kg-BOD/day  
576kg-BOD/day = 0.7 kg-BOD/m3day

V

$$V = 822m^3$$

4. Return sludge rate as 30%  
2400m3/day x 0.3 = 720m3 (30m3/hrs)  
822m3 + 720m3 = 1500 m3 - - - Aeration Tank
5. Retention time :(1500m3 :- 100m3/hrs) = 15 hrs

**\* Attachments**

1. Air diffuser : Air distribution pipe 2.5 inch sparger

2. Blower: Volume of the compressed air.
- 1) Controlling tank 22m<sup>3</sup>/min
  - 2) Aeration Tank 24m<sup>3</sup>/min
- 1)+2) 21m<sup>3</sup>/min+24 m<sup>3</sup>/min=45m<sup>3</sup>/min  
 (Volume) : 45m<sup>3</sup>/minx1.4 (Efficiency)= 63m<sup>3</sup>/min

Type: Turbo-type Blower  
 one side in . 5 step, moter-direct  
 suction presure.- 200mm/ag  
 revolution per minutes, 2000-3000 r.p.m  
 Motor,: 100kw (3.000volt)

3. Instrumentation  
 Type PH1- automatic contral system, one set  
 (PH indicate)

2-5 Settling Tank

components Item	Type Material	Dimension(m)	Capacity (m <sup>3</sup> )	Space requirement(m <sup>2</sup> )
		(Daimeter)(H)		
Settling tank	Sludge collector concrete	D=16m x 2	400	256

Retention time : 4 hrs(100m<sup>3</sup>/hrs)

\* Attachments

1. Sludge collector : scraper - type
2. reduction gear included machine-Motor  
 reduce speed, 1 revolution per 30 minutes

3. Return Sludge Pump

(30m<sup>3</sup>/hrs) 0.5 m<sup>3</sup>/min caliber (Diameter)  
(4inch)-100mm 3.7kw x 2set, 3.7KW x 2set Head 15m

2-6 Sludge Tank (Precipitator)

\* The accounts of Excess sludge Volume

BOD, removal rate 93% 284 ppm 20ppm/BOD

$2400 \times 284 \times (1 - 0.3) \times 0.93 \times 10^{-6} = 0.443 \text{ ton/day-dry matter}$

Return sludge concentration value :

$\frac{0.443 \times 10^6}{7500} = 59 \text{ m}^3/\text{day wet}$

7500

According to need sludge tank capacity 60m<sup>3</sup>

1) (W) (L) (H) material: concrete

4 x 5 x 3m

2) Space requirement 20m<sup>2</sup>

3) Retention time : One day (Settling)

2-7 Sludge disposal

Sludge transfer pump 1 set

truck away to drying solar heat bed

.....next page  
photo 5

(W) (L) (H)

- Sand bed Size 6m x 12m x 0.5-0.7m, 10set  
(sand)

Space requirement 72m<sup>2</sup> x 10set = 720m<sup>2</sup>

- weight ton of sludge produced annually

0.44ton/day.dry x 360day/year = 158.4ton/year

(used as fertilizer.)

**2-8 Holding Tank (Effluent treated water)**

**2,400m<sup>3</sup>/day, 1.66m<sup>3</sup>/min, retention time: 15minutes**

**Capacity 25m<sup>3</sup>**

**(W) (L) (H)**

**Dimension 3 x 4 x2m**

**material concrete**

**space requirement 12m<sup>2</sup>**



**Photo : 5.**

For example, drying solar heat bed in the Philippines



Arrangement of Building area

No	Item	Site	Space requirement (m <sup>2</sup> )
1.	Controlling	Tank	720
2.	Coagulation and sedimentation	Tank	25 } 33 }
3.	Neutralization	Tank	
4.	Aeration	Tank	376 }
5.	Settling	Tank	256 }
6.	Sludge	Tank	30
7.	Holding steel sheet etc.	Tank	12
8.	(total)	Tank	18

Total 1.470m<sup>2</sup>

Way + 130

Building area- - - - 1.600m<sup>2</sup>

Initial cost (construction cost)

	Economical plant Item	Capacity	LEX
1.	Concrete Tank	3.985m <sup>3</sup>	427.750
2.	Steel sheet etc Tank	51m <sup>3</sup>	55.000
3.	Instrumentation contented wiring work	(PHIC 1set) (PHI 1set)	72.500
4.	Pipe laying	(4inch SGP153m) (3inch PVC 50m) (2.5inch PVC 140m)	50.000
5.	Pump and Motor	24 KW	11.500
6.	Motor & reduce speed a mashine	38HP	30.700
7.	Blower	1set	175.555

It Sums up to - - - - 1.022.450 LE

NOTE: 1 U.S.\$=1.35 LE Total - - - - U.S.\$ 757.370

**Running Cost**

Item	component	consumption A Unit price	weigh or volume (day)	day per operating expenses LE/day	annual operating expenses LE/year. (360 day)
1. Power (Electric)		0.2LE/KWH	1312KWH	263LE	95.000LE
2. Chemical					
	H2SO4	300LE/ton	0.5ton	150	24.000
	FeSO4	262LE/ton	0.24ton	63	22.680
	PAC(polymer)	19LE/KG	12kg	228	82.080
3. Labor		2000LE/year	5men	30	10.000
Total - - - - 734 LE/day					263.760 LE/Year

**NOTE:** no use utility (fresh water, gas, steam)

\*Average daily amount of wast water treated valume 2.400 m3/day

- (1) One day per running cost                      734 LE/day
- (2) Year per running cost                            263.760 LE/year  
(Treated waste water)
- (3) BOD kg per operating expenses              0.85 LE/BOD kg
- (4) Waste water m3 per operating expenses      0.3 LE/m3

Investment Cost (Total)

1. Building area	way + 130m <sup>2</sup> - - - 1.600 m <sup>2</sup>		
2. Construction Cost		1.022.450 LE	
		( US\$ 757.370)	
3. Running Cost			
One day per running cost		734LE/day.	\$543/day
Year per running cost		263.760LE/day	\$195.377/day
BOD Kg per operating expenses		0.85LE/BOD-kg	\$0.62/Kg-BOD
Waste water m <sup>3</sup> per operating expenses		0.3LE/m <sup>3</sup>	\$ 0.22/m <sup>2</sup>

NOTE: 1 U.S.\$ = 1.35 LE

Section - 2. EDFINA CO.

Site Visit

1. Place of Factory :

EDFINA CO ALEXANDRIA . EGYPT  
City Alexandria

2. Day of site visit

10, 11 December 1986  
to City Alexandria . EGYPT

3. GOPI visitors

Engr. Mohamed A. Eweiss  
Engr. Ali EL Sisi  
---- Makio Nakashio (Japanese)

4. Company Personnel

- 1) Factory manager : Engr. Mr. ADEL E. ELSAMAHY
- 2) Head technical Sector: Mr. Khalid Hassen gouda
- 3) Person in charge :Engr. Mr. Kamal Azmy

Description of Process (flow-sheet)

1. Planning establish terms

(1) The basis for planning

1) volume of industrial waste water

V = 2.000 m<sup>3</sup>/day (83.3 m<sup>3</sup>/hrs)

2) work operation 24hr (continuous operation)

Friday is a holiday

3) on a three-shift- a - day basis (one shift 1.100 workers) a day , 3.300 wokers

(2) Analysis of water quality of industrial waste water

1)

Effluent Standard

PH 5.5 -6

PH 6-9

BOD 640 ppm

BOD 60ppm

COD 820 ppm

COD 100ppm

SS 200-500 ppm

SS 60ppm

Oil & grease 800-1.000

Oil&grease 10ppm

2)A unit cost of city tap-water,0.1LE/m<sup>3</sup>(10Piasters/m<sup>3</sup>)

" Electric 0.026LE/KWH(106Piasters/m<sup>3</sup>)


" NaOH 300 LE/Ton

3) Personnel (Labor) expenses per year 2000LE/year

4) The empty area, about 800 m<sup>2</sup>

### EDFINA FACTORY

The map of Factory



**EDFINA COMPANY  
FOR PRESERVED FOODS**

**Reduced Scale 1/800**




Photo : 1. Gate out side view of Edfina Company from the Eastern corner of the site




Photo: 2. Settling time of suspended solid - colour observation of waste water.



Photo:3. The end discharge point of waste water for the whole factory




Photo : 4. Another view for the final discharge point with a cylinder containing a portion of the effluent.



## 2. Plant Description


### **Edfina Company Flow-sheet:**

In the supposed project we find the following observations.

- (1) Sedimentation needs a very big area which is not the case in the plant.
- (2) Neutralization is carried out in separate tank which can be done in the same controlling tank .  
This flow-sheet is not right for the following reason.
- (3) This company produce food material and this is treated usually biologically.
- (4) The retention time is 24 Hr in the Sedimentation Tank and this case decomposition which leads to the elevation in BOD and COD.
- (5) The temperature in EGYPT is 25-35 C° average and this is too high leading to decomposition.
- (6) Inside the sedimentation Tank, sludge will be collected which needs the use of a sludge collector.

This supposed project is appreciated by Engr. Mr. Eweiss (General Manager . Constructor, GOPI).

I will try only to carry out materialistic incoming and effluent of calculation of the treatment process by using controlling Tanks as shown in the following sheet.



The flow-sheet diagram of the industrial treatment plant is shown in Fig 2:

Major Equipment Specification

Compon-ntes Item	Material	Dimension (m)		Capacity (m3)	space require- ment (m2)	Remarks (Attach- ments)
		(W)	(L) (H)			
1. controlling Tank	concrete	10X	36x 5	1800	360	10%NaOH Strage tank PHIC Aeration Agitation
2. Coagulation Tank	concrete	2x	10 x 2	40	20	Al2(50)3Strage tnak PAC strage tank motor 2 set
3. Compressed -Air Floatation	Steel sheet	1.5x	9 x 2	27	25	Sludge collector compressed-Air water pressure pump Air Tank, valve
4. Aeration Tank	concret	16x26.5x4 (8x2)		1700	425	Aeration Agitation (PHI) Blower
5. Settling Tank	concret	15m	x2	350	225	Sludge collector Retun sludge pump
6. Holding Tank (Domestic treatment)	concret	2x	5 x 2	20	10	
7. Digester Chamber	concret	600 people	Tnak	300	100	I. sterilizing Tanl

concret 4210m3

1.165m2

Initial Cost (Construction Cost)

Economical plant Item	Capacity	LE/cost
1. concrete Tank	3910m3	500.000
2. Steel sheet etc Tank sludge collector	51 m3	27.000
3. Instrumentation	(PHIC)(PHI)	175.000
4. Comperssed-Air floatation		443.000
5. Blower		75.000
6. Pump and Moter	73.4KW	11.500
7. Moter and reduce speed a machine	33 HP	22.500
8. Blower (Ain-Compressor)		75.000
9. digester chamber	300m3	75.000
		<b>1.376.000 LE</b>

Running Cost

Item	component consumption A Unit price	weigh or valume	day per operating expenses LE/day	annual operating expenses LE/year. 360 day
1. Power (Electric)	0.016LE/ KWH	1450KWH/ day	25 LE	9.000
2. Chemical				
NaoH	300LE/ton	2ton	60	21.600
PAC	19LE/KG	18.7kg	355	27.800
3. Labor	2000LE/year	5men	30	10.000
4. digestor				
- Chamber Electric	0.016LE/KW	45KWH	6	2.160
I liquid	1.25LE/Kg			
			<b>476 LE/day</b>	<b>170.560 LE/Year</b>

\* Average daily amount of waste water treated valume

V=2.000 m3/day

- |                                           |                |
|-------------------------------------------|----------------|
| (1) one day running cost                  | 476LE/day      |
| (2) Year running cost                     | 170.560LE/year |
| (3) BOD Kg per operating expenses         | 0.38LE/Kg-BOD  |
| (4) waste water m3 per operating expenses | 0.27LE/m3      |

Investement Cost (Total)

1.	Building area	way+119m2--1.300m2
2.	Construction cost	1.376.000LE
3.	Running Cost	
	one day per running cost	476 LE/day
	Year per running cost	170.560 LE/year
	BOD Kg operating expenens	0.38LE/Kg-BOD
	Waste water m3 per expenses	0.27LE/m3

Section-3. In Kaha "Kaha" Co.

Site visit

1. Place of Factory:  
AL NASR CO. FOR PRESERVED FOOD "Kaha"
2. Site visit of day:  
1st: 6 November 1986  
2nd: 17November 1986
3. GOPI visitors:  
Engr. Ali El Sisi  
Engr. Hoda William  
Engr. Eglal Moustafa  
\_\_\_\_ Makio Nakashio (Japanese)
4. Company Person:  
1) Factory Manager : Engr. Mr. Hussam Zaher  
2) Person in charge : Engr. Mr. Yousry Moustafa

Description of Process (flow-sheet)

1. Planning establish terms

(1) The basis for planning

1) volume of industrial waste water

V = 2240 m<sup>3</sup>/day (140 m<sup>3</sup>/Hr)

2) work operation 16hrs

Friday is a holiday

3) on a two-shift- a - day basis

(2) Water quality of industrial waste water

		<u>Effluent Standard</u>	
PH	6.1	PH	6-9
BOD	385 ppm	BOD	20ppm
COD	496 ppm	COD	30ppm
SS	130 ppm	SS	30ppm
Oil & grease	180ppm	Oil	5ppm


2) A unit cost of city tap-water 0.1LE/m<sup>3</sup>

" Electric 0.2 LE/KWH

3) Personnel (Labor) expenses per year  
2000LE/year

4) The empty area, about 2800 m<sup>2</sup>


**Kaha Factory (Kaloubia)**  
**A Sketch map of Factory**








**Photo: 1. Outside view of Kaha Company at Kaloubia**




**Photo: 2. Inside view of Kaha Company at Kaloubia**




**Photo:3. Four samples taken from four discharging points for industrial waste water - to make a compariason in color between each other**



**Photo: 4. The above four samples after putting in Beakers at the company lab to make the color comparaisn test.**



**Photo:5. Collecting tank for industrial waste water**



**Photo: 6. Existing waste water transfer pump .**

**2. Plant Description (Major Equipment Specification)**

The flow-sheet diagram and the material inlet and effluent of calculation is shown in Fig. 3.

**2-1 Bulky refuse recovery equipment (in side the Factory)**


**First.** the solids (small pieces, cubes, grate, para etc) is removed after the Jam and Juice manufacturing process.

**Second.** There are bulky refuse (fruits, vegetable, fish,etc) is used for animal food,(cows sheep and chicken) making a good profit .


In case that the scale is 500m<sup>3</sup>/day waste water or more, the brief specification for this equipment are as shown in photo 1.2. (see photogograph)

expect removal rate

SS 180 ---72%--- 50ppm



**Photo: 1. Bulky refuse recovery equipment**



**Photo: 2. Bulky refuse recovery equipment**

## 2-2 Compressed-Air Flotation Tank

The object of this equipment is the removal of oil and grease from waste water. This Factory is in the effluent standard of irrigation drain 5ppm It is severe standard for needed this Flotation separation Tank .

- 1) The effluent waste water oil and grease 180ppm, SS 130ppm
- 2) Waste water volume 2240m<sup>3</sup>/day 140m<sup>3</sup>/hrs. 16Hr work operation
- 3) Presupposition terms of compressed-Air Flotation method

- (1) A/s Air per solids rate: 0.03 Kg-Air/Kg-Oil/SS
- (2) Water surface loading : 90-220m<sup>3</sup>/m<sup>2</sup>.day
- (3) Solids loading: 100-150Kg/m<sup>2</sup>.day

(calculation)

effluent waste water solid (oil and SS) volume

$$0.18\text{Kg/m}^3 \times 2.240\text{m}^3/\text{day} = 403.2\text{Kg}/\text{day}$$

Required Air 0.03Kg/Air/Kg-Oil.SS x 4D3 Kg/day=12Kg-Air/day

Solubility of Air is by Henry's Saw pressure water 5Kg/cm<sup>2</sup>

$$20 \text{ deg } 1\text{Kg}/\text{cm}^2 \text{ -- } 0.024 \text{ Kg-Air/ m}^3 \text{ water } \left. \vphantom{\begin{matrix} 20 \text{ deg } 1\text{Kg}/\text{cm}^2 \\ 20 \text{ deg } 5\text{Kg}/\text{cm}^2 \end{matrix}} \right\} \text{Air-}$$

$$20 \text{ deg } 5\text{Kg}/\text{cm}^2 \text{ -- } 0.02 \text{ Kg-Air/ m}^3 \text{ water } \left. \vphantom{\begin{matrix} 20 \text{ deg } 1\text{Kg}/\text{cm}^2 \\ 20 \text{ deg } 5\text{Kg}/\text{cm}^2 \end{matrix}} \right\} \text{Solubility}$$

Air Tank (Saturated Air Solution) of forming Air rate as,

70% Producted forming Volume:

$$(0.12 - 0.024) \times 0.7 = 0.067\text{Kg-Air}/\text{m}^3 \text{ water}$$

Requried pressure water valume = 12 = 178.57-180m<sup>3</sup>-water/day

$$0.067$$

Air Saturated recycle rate :  $\frac{180}{2.240} = 0.08 = \text{as. } 1$

Solids Loading 100Kg/m<sup>2</sup>day (adaptation of planning)

Separate space :  $\frac{430\text{Kg}}{100\text{Kg}} = 4.03\text{m}^2 = \text{as. } 6\text{m}^2(\text{a})$

Components Item	Type Material	Dimension(m)	Capacity (m <sup>3</sup> )	operating pressure	Space requirement (m <sup>3</sup> )
		(W) (L) (H)			
Compressed- Air Floatation Tank	Scum collector steel sheet	1 x 6x2.5m	15	5Kg/cm <sup>2</sup>	6

Retention time :  $\frac{15\text{m}^3}{(2240+2240 \times 1)/1440\text{min}} = 4.83\text{min} = 5\text{minutes}$

\* Attachments

- |                             |                                                                        |
|-----------------------------|------------------------------------------------------------------------|
| 1. Scum collector           | one set                                                                |
| 2. Compressed-Air machine   | } Space<br>} requirement<br>} CM <sup>2</sup> 6m <sup>2</sup> (b)<br>} |
| 3. Compressed-Air Pump      |                                                                        |
| 4. Air Saturated Water Tank |                                                                        |
| 5. Back pressure valve      |                                                                        |
| 6. Incinerator of Scum      |                                                                        |
| Total (a) + (b)             |                                                                        |

expect removal rate

Oil and grease	180ppm	<u>94%</u> 10 ppm
SS	50ppm	<u>40%</u> 30 ppm
BOD	385ppm	<u>10%</u> 347ppm
COD	496ppm	<u>15%</u> 421ppm

Components Item	Type Material	Dimension(m)			Capacity (m3)	Space requirement(m2)
		(W)	(L)	(H)		
Controlling Tank	Aeration- Agitation concrete	20x22x5m			2200	440

Retention time : 23.6 Hr

**\*Attachments**

1. Air diffuser: air distribution pipe 3 inch  
sparger 75 mm  
Blower (Air-compressor)
  
2. 10% NaOH Storage Tank 1 set  
Capacity 20m3 (in side tank resin trated coating)  
Dimension(D=2.7m x(H= 3.5m)  
Material : steel sheet  
space requirement 8m2
  
3. Instrumentation  
Type (PHIC) automatic contral system one set  
(PH indicate contral)

**2-4 Aeration Tank**

Components Item	Type Material	Dimension(m)			Capacity (m3)	Space refuirement(m2)
		(W)	(L)	(H)		
Aeration Tank	Aeration- Agitation concrete	16 x28 x 4			1800	450



- 1) BOD loading 0.6 Kg-BOD/m<sup>3</sup>. day
- 2) incoming waste water quality : BOD 300ppm
- 3) Total BOD 0.3Kg-BOD/m<sup>3</sup> x 2.240m<sup>3</sup>/day = 672Kg-BOD/day  
672Kg-BOD/day = 0.6 Kg-BOD/m<sup>3</sup>.day

V

$$V = 1120 \text{ m}^3$$

- 4) Return sludge rate as, 30%  
2400 m<sup>3</sup>/day x 0.3 = 672 m<sup>3</sup>/day  
26m<sup>3</sup>/Hr  
1120m<sup>3</sup>+672m<sup>3</sup> = 1.792m<sup>3</sup>=1800m<sup>3</sup>--Aeration Tank Capacity

- 5) Retention time:  
2240m<sup>3</sup>/day -- 24 Hr = 9303 m<sup>3</sup>/Hr = 94 m<sup>3</sup>/Hr  
1800 m<sup>3</sup> -- 94m<sup>3</sup>/Hr = 1901 = 19Hr

\* Attachments

1. Air diffuser : air distribution pipe sparger

2. Blower :

Volume of the air (compressor-Air)

- 1) controlling Tank 20m<sup>3</sup>/min
  - 2) Aeration Tank 30m<sup>3</sup>/min
- 1) + 2) 20m<sup>3</sup>/min + 30m<sup>3</sup>/min = 50 m<sup>3</sup>/min  
50m<sup>3</sup>/min x 1.4 = 70 m<sup>3</sup>/min

(Dimension)

- Type: Turbo-type Blower

One side in 5steps, motor-direct

Suction pressure - 250mm/Hg

revolution per minutes 2000-3000 r.p.m

Motor: 120 KWH x 3000 volt

3. Instrumentation

Type : (PHI). automatic control system 1set

2-5 Settling Tank

Components Item	Type Material	Dimension(m)	Capacity (m3)	Space requirement(m2)
		Diameter(H)		
settling Tank	sludge collector concrete	(D=16.2m) x2	400	200

Retention time : 4.2 hrs( 94m3/Hr)

\* Attachments

1. Sludge collector : Scraper - type
2. reduction gear included machine-Motor  
reduce speed, 1 revolution per 30 minutes

2-6 Sludge Tank

Components Item	Type Material	Dimension(m)	Capacity (m3)	Space requirement(m2)
		(W) (L) (H)		
sludge Tank	concrete	4 x 5 x 3	60	20

retention time one day--sludge of by-product(excess sludge)

**\*Attachments (Sludge disposal)**

1. Sludge transfer pump 1set
2. truck away ---- drying solar heat bed  
(W) (L) (H)
3. sand bed size : 6m x 12m x 0.5-0.7m 10set
4. weight ton of sludge produced annually  
044ton/day.dry x 360day/year = 158.4 ton / year  
(fertilizer for Agriculture)

**2-7 I. sterilizing Tank**

Components Item	Type Material	Dimension(m)			Capacity (m3)	Space requirement(m2)
		(W)	(L)	(H)		
sterilizing Tank	chlorine gas concrete	2	6	2	24	12

Retention time 15 minutes

**\*Attachments**

1. (5 bottle) I liquied cylinder to contain 5-7 ppm
2. Sparger (for cholrine gas) one set

Liquified chlorine gas ( Subsequently referred to as chlorine ) is soluble in water. The reason of used the Dominance waste water is that practically all waste water contains ammonia and most of the chlorine applied is very rapidly converted to chlorine gas at waste water PH of slightly above 7.0 .

Arrangement of Building area

No	Item	Site	Space requirement (m <sup>2</sup> )
1.	Compressed-Air flotation	Tank	12
2.	Controlling	Tank	440
3.	Aeration	Tank	450
4.	Settling	Tank	200
5.	Sludge	Tank	20
6.	sterilization	Tank	12
7.	steel sheet etc (total)	Tank	8

Total 1.470m<sup>2</sup>

Wag + 158

Building area- - - - 1.300m<sup>2</sup>

Initial cost (construction cost)

No	Economical plant Item	Capacity etc	LE/cost LE
1.	Concrete Tank	4.484m <sup>3</sup>	452.600
2.	Steel sheet etc Tank sludge collector	20m <sup>3</sup> 1set	18.000
3.	Instrumentation electric	PHIC 1set PHI 1set	155.000
4.	Piping	D: 150mm SGP 100m D: 125mm SGP 70m D: 65 mm PVC80m D: 125mm PVC200m	70.000
5.	Pump and Motor	39 KW	16.500
6.	Motor & reduce speed a machine	16tp	10.500
7.	Blower		600.000

It Sums up to - - - - 1.710.500 LE

Total - - - - U.S.\$ 1.267.037

**Running Cost**

Item	component	consumption		day per operating expenses LE/day	annual operating expenses LE/year. 360 day LE
		A Unit price	weigh or volume (day)		
1.	Power (Electric)	0.2LE/KWH	1300KWH	260LE	93.600
2.	Chemical		10% NaOH		
	NaOH(conc)	360LE/ton	as2ton	72	25.000
	CL2 liqured	1.25LE/Kg	11.2kg/day	14	5.040
3.	Worker	2000LE/year	5men	17	6.000
				363 LE/day	130.560 LE/Year

**NOTE:** no use Utility (fresh water, gas, steam)

\*Average daily amount of waste water treated volume 2.240 m<sup>3</sup>/day

- (1) One day running cost 363 LE/day
- (2) Year running cost 130.560 LE/year
- (3) BOD kg operating expenses 0.45 LE/kg-BOD
- (4) Waste water m<sup>3</sup> per operating expenses 0.16 LE/m<sup>3</sup>

Investment Cost (Total)

1. Construction area	way + 158m2 - - - 1.300 m2		
2. Construction Cost	1.022.450 LE		
	( US\$ 757.370)		
3. Running Cost			
One day running cost	363LE/day,	\$268/day	
Year running cost	130.560LE/day	\$76.711/year	
BOD Kg operating expenses	0.45LE/kg-BOD	\$0.33/Kg-BOD	
Waste water m3 per operating expenses	0.16LE/m3	\$ 0.118/m3	

NOTE: 1 U.S.\$ = 1.35 LE

**Section - 4 Kaha CO. Badrashin**

**Site Visit :**

**1. Place of Factory :**

**EL NASR CO. FOR PERSERVED FOOD "KAKA" Badrashin**

**2. Site Visit of day :**

**1st: 9 November 1986**

**2nd: 16 November 1986**

**3rd 19 November 1986**

**3. GOPI Visitors**

**Egnr. Ali El Sisi**

**Engr. Hoda Willian**

**Engr. Eglal Moustafa**

**Engr. Mr. Abd EL KADER(EL NASR COMPANY FOR**

**MANUFACTURING COKE**

**AND CHEMICALS**

**----- Makio Nakashio (Japanese)**

**4. Company Personel**

**1) Factory manager : Engr. Mr. Said shalaby**

**2) Person in charge: Engr. Mr. Mohammed Abdel**

**Hamid Kharib**

Description of Process (flow-sheet)

1. Planning establish terms

(1) The basis for planning

1) volume of industrial waste water

V = 1120 m<sup>3</sup>/day (70 m<sup>3</sup>/Hr)

2) work operation 16hr

Friday is a holiday

3) on a two-shift- a - day basis

(2) water quality of

i) industrial waste water

1.

Effluent Standard

PH 7.5

PH 6-9

BOD 2.142 ppm

BOD 30ppm

COD 2.728 ppm

COD 30ppm

SS 281 ppm

SS 30ppm

Oil & grease 160ppm

2) A unit cost of city tap-water 0.1LE/m<sup>3</sup>

" Electric 0.2LE/KWH

3) Personnel (worker) expenses per year


2000LE/year

4) The empty area, about 6000m<sup>2</sup>



### Badrashm Factory (Cairo-City)

#### A Sketch map of Factory



reduced Scale : free

**Badrashin Factory (Cairo-City)**

**A Sketch map of Factory**

**Holding  
Tank**

**empty  
area**

**5976m2**

**36m**

**manufacturing  
process factory  
(building)**

**Boiler  
room**

**Filter  
room**

**2F**

**Administration**

**Church**

**security office**

**reduced scale:Firee**




Photo: 1      outside view for the kaha Factory at  
                 badrashine





Photo:2.      Available area suitable for the futur  
                 treatment plant.



**Photo: 3. one point of industrial waste water discharge**



**Photo: 4. sedimentation test- samples taken to make analysis in the lab of coke company**



Photo: 5. side view of the wall of the chambers of pickling



Photo: 6. many chambers where olives is pickled.



Photo : 7.      Outside view of one chamber where olives is  
pickled




Photo:8.      Final discharged point of industrial waste  
water to the drain

2. Plant Description (Major Equipment specification)

The flow-sheet diagram and the material inlet and effluent of calculation is shown in Fig .

2-1. Bulk refuse recovery equipment (in side the Factory)

This equipment consists of "Kaha" Factory same one . see Photo 1 and 2 (page 48)

2-2. Mixture Tank

Components Item	Type Material	Dimension(m)	Capacity (m3)	Space requirement(m2)
		(W) (L) (H)		
Mixture tank	empty concrete	2 x 5 x 2m	20	10

Retention time : 15 minutes

2-3. Coagulation Tank

Components Item	Type Material	Dimension(m)	Capacity (m3)	Space requirement(m2)
		(W) (L) (H)		
Coagulation tank	concrete	1.5x12 x 2m	35	18

Retention time : 30 minutes

\* Attachments

1. Agitation :

- 1) quick agitation, 120 r.p.m (1.5 l sec. speed) Motor : reduce speed of a machine 3HP Retention time 5 minutes
- 2) Slow agitation, 30 r.p.m (30cm/sec. speed) Motor : reduce speed of a machine 5HP Retention time 25 minutes

2. Al<sub>2</sub>(SO<sub>4</sub>) Storage Tank (Coaglant)---1.000-1.500ppm/m<sup>3</sup>

Capacity 20m<sup>3</sup>  
 Dimension D =2.7m x3.5m (H)  
 material steel sheet  
 space requirement 8m<sup>2</sup>

3. PAC (polimer, coaglant aids) ---concentration of use

20ppm/m<sup>3</sup>  
 Capacity 1m<sup>3</sup>  
 Dimension D=1m x 1m (H)  
 material steel sheet  
 space requirement 1m<sup>2</sup>

2-4 Sedimentation Tank

Components Item	Type Material	Dimension(m)	Capacity (m <sup>3</sup> )	Space requirement(m <sup>2</sup> )
		Diameter(H)		
Sedimentation tank	Sludge collector concrete	(D=6.7m) x 2	70	50

Retention time: 60 minutes



\* Attachments

1. Sludge collector : Scraper-type
2. reduction gear included a machine-Motor reduce speed, one revolution per 30 minutes
3. incinerater
  - 1) Sludge drow pump one set
  - 2) Sludge incinerator (compact-type)

2-5. Controlling Tank

constructed tank diversion by the Factory

Components Item	Type Material	Dimension(m)			Capacity (m3)	Space requirement(m2)
		(W)	(L)	(H)		
controlling tank	Aeration Agitation Blower	6	70	2.5	1.000	none

Retention time :  $1120\text{m}^3/\text{day} \div 24\text{hrs} = 46\text{m}^3/\text{hrs}$

$1000\text{m}^2 \div 46\text{m}^3/\text{hrs} = 22\text{hrs}$

\* Attachments

1. 20% NaoH Storage Tank  
(in side tank resin treated coating)
  - Capacity : 12m3
  - Dimension : 2.1m x 3.5 m
  - material : steel sheet
  - space requirement : 5m2

2. 20% H<sub>2</sub> SO<sub>4</sub> Storage Tank (in side tank rubber coating);  
 Capacity 12m<sup>3</sup>  
 Dimension 2.1m x 3.5m  
 material steel sheet  
 space requirement 5m<sup>2</sup>

3. Instrucmentation  
 Type (PHIC) automatic control system 1set (PH indicate contral)

4. Airdiffuser: air distribution pipe sparger

2-5 Dilution Tank

Components Item	Type Material	Dimension(m)			Capacity (m <sup>3</sup> )	Space requirement(m <sup>2</sup> )
		(W)	(L)	(H)		
Dilution tank	empty concrete	2	3	2	12	6

Retention time : 15 minutes

weste water : 1.120m<sup>3</sup>/day :- 24Hr = 46.6 = 47 m<sup>3</sup>/Hr  
 47m<sup>3</sup>/Hr x 1/4 = 12 m<sup>3</sup>/Hr

- 1) fresh water (city tap-water) 1120 m<sup>3</sup>/day for dilution
- 2) incoming BOD, 1600 ppm x .5 of BOD 800ppm (send to Aeration tank)
- 3) Retention time 1120m<sup>3</sup>/day + 1120m<sup>3</sup>/day = 2240m<sup>3</sup>/day  
 7.5 minutes  
 2240m<sup>3</sup> :- 24Hr = 93.3 m<sup>3</sup>/Hr = 93 m<sup>3</sup>/Hr

2-6 Aeration Tank

Components Item	Type Material	Dimension(m)	Capacity (m3)	Space requirement(m2)
		(W) (L) (H)		
Aeration tank	Aeration Agitation concrete	22x29.3x4	2600	325
		(11x2)	1300x2	650 325

- 1) BOD loading 0.8 Kg-BOD/m<sup>3</sup>. day
- 2) incoming wast water quality : BOD 800ppm
- 3) Total BOD 0.8 Kg-BOD/m<sup>3</sup>x2.240m<sup>3</sup>/day = 1.792Kg-BOD/day  
1792Kg-BOD/day = 0.8

V

$$V = 2240 \text{ m}^3$$

- 4) Return sludge rate 30%-15%  
 2.240 m<sup>3</sup> + 360 m<sup>3</sup> = 2600 m<sup>3</sup>--Aeration Tank Capacity
- 5) Retention time : 2240m<sup>3</sup>day-- 24hrs= 93m<sup>3</sup>/hrs  
 2600m<sup>3</sup>-- 93m<sup>3</sup>/hrs= 28 hrs

\* Attachments

1. Air diffuser : air distribution pipe  
sparger
2. Blower:  
 Volume of the wind (Compressad-Air)
  - 1) controlling Tank 54 m<sup>3</sup>/min
  - 2) Aeration Tank 74/m<sup>3</sup>/min
    - 1) +2) 45m<sup>3</sup>/min+74m<sup>3</sup>/min= 128m<sup>3</sup>/min
    - 128m<sup>3</sup>/min x1.4 = 180m<sup>3</sup>/min

(Dimension)

Type: Toba-Type Blower 2 set

one side in 5 step Motor-direct

suction pressure - 250mm/Ag

revolution per minuts 2000-3000r.p.m.

Motor : 120 KW x 3.000volt

3. Instrumentation

Type : (PHI) automatic control system, 1set

2-7 Settling Tank

Components Item	Type Material	Dimension(m)			Capacity (m3)	Space requirement(m2)
		(W)	(L)	(H)		
Settling tank	sludge collector	11x 11 x 2			480	121
	concrete				240x2	242 121

Retention time : 480 m3 :- 93 m3/Hr = 5.1 Hr

▸ Attachments

1. Sludge collector : Scraper-type

2. reduction gear included machine-motor

reduce speed, 1 revolution per 30 minutes

2-8 Sludge Tank

Components Item	Type Material	Dimension(m)		Capacity (m3)	Space refuirement(m2)
		Diameter	(H)		
Sludge tank	concrete	(D=2.7m	x 4m	160	52

Retention time : one day ---- sludge of by-product (excess sludge)

**\*Attachments (Sludge disposal)**

1. sludge transfer pump one set
2. truck away --- drying solar heat bed  
(W) (L) (H)
3. sand bed size : 60 x 12 x 0.5-0.7m 20 set
4. weight ton of sludge produced annually  
1.186Kg/day.dryx360day/year = 424.8ton/year  
(fertilizer of Agriculture)

**2-9 I. sterilizing Tank**

Components Item	Type Material	Dimension(m)	Capacity (m3)	Space requirement(m2)
		(W) (L) (H)		
I. sterilizing tank	chlorine gas concrete	2 x 6 x 2	24	12

Retention time : 15 minutes

**\*Attachment**

1. I liquid cylinder( 5-7 ppm)7 bottle
2. sparger (for chlorine gas) one set

**Arrangement of construction area**

No	Item	Site	Space requirement (m <sup>2</sup> )
1.	Mixture	Tank	10
2.	Contralling	Tank	18
3.	Sedimentation	Tank	50
4.	Contolling	Tank	---
<b><u>constructed Tank diversion</u></b>			
5.	Dilution	Tank	6
6.	Aeration	Tank	650    892
7.	Settling	Tank	242
8.	Sludge	Tank	52
9.	Cl Sterilizing	Tank	12
10.	steel sheet etc.	Tank	25
<b>Total</b>			<b>1.065m<sup>2</sup></b>
<b>Wag +</b>			<b><u>135m<sup>2</sup></u></b>
<b>Area- - - -</b>			<b>1.200m<sup>2</sup></b>

Initial cost (construction cost)

Economical plant Item	Capacity	LE/cost
1. Concrete Tank	3401 m3	380.000
2. Steel sheet etc Tank sludge collector	44m3 2 set	51.000
3. Instrumentation contented wiring work	PHIC pne set PHI one set	160.000
4. Pipe laving	D 155mm SGP120m D 150mm SGP100m D 75mm SGP200m D 65mm PVC250m	99.000
5. Pump and Motor	52.5 KW	21.000
6. Motor & reduce speed a machin	25HP	33.700
7. Blower		90.000
8. Bulky refuse recovery equipmnet		75.000
It Sums up to - - - -		909.700 LE
Total -----		U.S.\$ 673.851

Running Cost

Item	component	consumption A Unit price	weigh or value (day)	day per operating expenses LE/day	annual operating expenses LE/year. 360 day LE
1.	Power (Electric)	0.2LE/KWH	4.320KWH	864LE	311.040
	Top-water(city)	0.1LE/m3	1.120m3/	112	40.320
2.	Chemical				
	Al2(SO4)3	875LE/ton	1.7ton	1500	540.000
	PAC	19LE/KG	22.4kg	425	153.000
	20%H 2SO4	Little use	no	--	--
	20%NaOH		calculation		
	Cl2 liquid	1.25LE/Kg	11.2Kg	14	5.040
3.	Labor	2000LE/year	4men	17	6.000
				2.932LE/day	1.055.400 LE/Year

\*Average daily amount of wast water treated volume

V=1120m3/day in the case BOD 2452ppm-Total  
BOD-2746kg-BOD/day

V=2240m3/day in the case BOD 800ppm

(1) running cost per day 2.932LE/day

(2) running cost per day 1.055.400 LE/year

(3) BOD-kg per operating expenses  
2932LE--:2746Kg-BOD/day = 1.067=1Le/Kg-BOD

(4) Waste water m3 per operating expenses  
2932LE/day --: 2240/m3day = 1.308=1.3Le/m3



Investment Cost (Total)

1. Construction	way + 135m2 - - - 1.200 m2
2. Construction Cost	909.700 LE ( US\$ 673.851)
3. Running Cost	
running cost per day	2.932LE/day
running cost per day	1.055.400 LE/day
BOD Kg per operating expenses	1 LE/Kg-BOD
Waste water m3 per operating expenses	1.3LE/m3

CONCLUSION

This project was supported partly by GOFI and by the four food companies.

Perhaps the most important contribution for all the project in the final analysis, has been the demonstration of cooperation in solving the problem of the industrial waste water treatment by all parties concerned .

It is believed that the same methodology which was demonstrated by the present study could be applied in the search for answer to many other problems in this field.

These conclusion are listed in the following result

1. That is not the way to do introduction of foreign techniques from America, Germany and Japan etc for measure against pollution for EGYPT. This techniques do not apply very easy.
2. The investment cost of economical treatment plant in EGYPT is more cheaper in comparison with that in America, Germany, Japan.

3.	(Construction Cost)	(operating expenses )
-	Pepsi Cola Co. 1.022.450 LE	0.85 LE/Kg-BOD
-	EDFINA Co. 1.376.000 LE	0.38 LE/Kg-BOD
-	Kaha(Kaha Co.) 1.022.450 LE	0.33 LE/Kg-BOD
-	Badrashine	
-	(Kaha Co.) 909.700 LE	1.0 LE/Kg-BOD

Annex

EGYPT & THE RIVER NILE

this report is concerned with industrial liquid wastes discharged directly to the River Nile in Egypt- through three production units which are selected by GOFI.

Egypt is located at the north eastern side of Africa. To the north side is the Mediteranean Sea, the east side is the Red Sea, the west side is the Great Sahara Desert. The area of Egypt is 1 million sq. Km. The population is now about 50 million and is expected to reach 65-70 million in year 2000. Only 6% of the land is cultivated land and the rest is desert land. The agriculture and the whole life of Egypt depend on water irrigation from the Nile.

The Nile is one of the longest rivers in the whole world. It is the main source of life for Egypt.

The historian Ephrodite has once stated that Egypt is the gift of the Nile. This is true till now; the Nile is the main source for water resource in Egypt with exception of some rainfall in the Winter.

I was told that the Pharaons used to worship the Nile and for them it was forbidden to pollute it in any way. Also the Pharaone stated in their tenples that they swear before God that they never polluted the River Nile and so they deserved Paradise. For that reason I was surprised to see that the modern Egyptians are disposing of their wastes in the Nile .

Despite the discharge of all wastes to the Nile, the Nile is still in a very good condition compared with other rivers in industrial countries in Europe.

This was due to the fact that the River Nile has a flood in the Summer time each year, washing away all the residuals and cleaning the bed. The amount of water running in the Nile each year amounts to 55 billion cu.m.

#### INDUSTRY IN EGYPT:

The public sector in Egypt is nowadays dominating the industrial activity. 65% belongs to the public sector. Only 35% belongs to the private sector. The public sector is governed mainly by the Ministry of Industry; but, there are some other industrial activities which do not belong to the Ministry of Industry such as production of pharmaceuticals (which belongs to the Ministry of Health), cement and building materials (which belongs to the Ministry of Housing & Reconstruction) and the production of Petroleum and Petroleum products (which belongs to the Ministry of Petroleum & Mineral Wealth). There are 117 public sector companies which belong to the Ministry of Industry; some of these industrial companies have more than one factory located in different sites, the total amounting to more than 500 different production units with a total aggregate investment cost L.E.. 8.5 billion. The total amount of industrial production amounts in fiscal year 85/86 L.E. 7.8 billion.

This industrial production could be divided into the following sectors :

Spinning & Weaving;  
Food;  
Chemical;  
Engineering;  
Metallurgical;  
Small Scale Industries; and  
Mining.

As we see, the food industries represent a major part of the industrial production (25%), which give importance in taking care of the food production units and their disposals.

THE RULES AND LAWS FOR FLUID DISPOSAL OF EGYPT:(As attch'd)

There are some laws & regulations governing the liquid disposal in the sewerage network whether from industrial or municipality sources. There is also regulation for industrial waste discharged to the Nile. In this respect we will restrict ourselves with that of the Nile because the factories under investigation are located and discharging directly to the Nile.

THE LAW OF PROTECTION OF THE NILE FROM POLLUTION:

In the year 1982, Egypt issued a law for the protection of the Nile. Attached to the law are the parameters governing the quality of waste water drained directly to the Nile and its branches. Attached in Annex No. is a translation of the law in English.

According to the law all effluents must be treated before disposal to conform to the law. I was told in GOFI that this law is not applicable because of lack of investment especially foreign component. The industrial companies lack very much in foreign component. GOFI has prepared different plans for the establishing of treating units; yet, these plans were not implemented because of the lack of foreign currency. Also priority was selected from these plans and GOFI is trying to prepare some implementation plans based on local efforts.

### INDUSTRY & LAWS OF WATER PROTECTION

Since the issue of the law for the protection of the River Nile, industry is taking all possible measures to limit pollution caused by factories of the industrial sector, especially those factories using the River Nile and its branches to dispose of their wastes.

Moreover the Ministry of Industry has contacted all the companies to make the preliminary treatments with their available resources such as :

- Eliminating oils and greases
- Neutralising effluent waters
- Removal of floating matter
- Use of cooling water in closed circuit

The Ministry was bale during the survey to identify 188 units disposing of their wastes on waterways requiring total sum L.E. 200 million in foreign currency for treatment processes, of which :

- 32 factories disposing directly to the Rive Nile requiring L.E. 72 million for which the programme of the Ministry of Industry was prepared and approved by the Policies Committee and all executive institutes and it is being taken care of with an allocation of L.E. 14 million for the current year.
- 53 factories disposing on the agricultural lands and plans are currently being set for treatment.
- 58 factories that use the city sewerage networks at present and should apply treatment according to the law 93/1962.
- 45 factories that will use the sewerage systems that will be implemented in the coming plans.



OUTLINE ABOUT IN. SECTOR

The industrial Sector contributes with 65% of the total industrial activity in Egypt and is affiliated to the Ministry of Industry represented in 580 production units concentrated in 330 geographical sites belonging to 117 companies. The production of these units reached L.E. 7.8 billion on the national level as follows:

	<u>No. of Co.</u>	<u>No. of unites</u>	<u>Percentage of prod'n</u>
Food Industries Sector	20	144	22%
Spinning & Weaving Sector	32	193	26%
Chemicals Sector	26	97	19%
Engineering Sector	20	61	18%
Metallurgical Sector	10	49	10%
Ceramics Mining Sector	9	36	5%
			<hr/> 100%





Figure 1. Papsi Cola co. flo



SECTION 1

Pepsi Cola co. flow - Sheet




Materialistic incoming and affluent of Calculation


tion numerical value

coming waste water  $V = 2400 \text{ m}^3/\text{day}$  (100%)

incoming water	→	effluent Standard
PH 11.7	→	PH 6-9
BOD 360 ppm	→	BOD 30 ppm
COD 771 ppm	→	COD 40 ppm
SS 284 ppm	→	SS 30 ppm




Edfima company flow




SECTION 1

# Company flow-sheet



Mabachio's  
B. alternative




22. Dec. 1986  
made up flow-sheet: Eng. Ewalds  
writer: Mabachio



## SECTION 2

# Kaha co. flow-Sheet

( manufacturing process )




( in side Factory )



## SECTION 1

Co. flow-sheet



25. DEC 1986  
Abuhalia

Materialistic incoming and effluent of calculation


○ foundation numerical value

- (1) incoming waste water work operation 16 Hr  $V=2240\text{ m}^3/\text{day}$  ( $140\text{ m}^3/\text{hr}$ )
- (2) water quality

effluent standard

PH 6.1 BOD 385 ppm COD 496 SS 130 oils 180	→ → → →	PH 6~9 BOD 20 ppm COD 30 SS 30 oils 5
--------------------------------------------------------	------------------	---------------------------------------------------


○ Process




25. DEC 1986  
 Mahashia



Badrasken co. flow-sheet



SECTION 1



2. Jan 1987  
*Richard*

Mechanical Treatment and Sludge Collection

