



OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.

TOGETHER

for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as "developed", "industrialized" and "developing" are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact <u>publications@unido.org</u> for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at <u>www.unido.org</u>

RESTRICTED

14744

FEBRUARY 10TH, 1985 ENGLISH

Mexico. TESTING OF POWER CABLES WITH EXTRUDED INSULATION

DP/MEX/82/011/11-54/31.9.C

MEXICO

FINAL REPORT

PPEPARED FOR THE GOVERNMENT OF MEXICO BY THE UNITED MATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION ACTING AS EXECUTING AGENCY FOR THE UNITED NATIONS

DEVELOPMENT PROGRAMME

BASED ON THE WORK OF MANFRED J. HOELZER

UNITED NATIONS INDUSTRIAL DEVELOPMENT OPGANIZATION

VIENN4

1 1

1

I.

ABSTRACT

- Title: CONSULTANT IN TESTING OF POWER CABLES WITH EXTRUDED INSULATION.
- Number of the Project: DP/MEX/82/011/11-54/31.9.C
- Duration: Six months. September 5th, 1984 to Sebruary 24th, 1985
- Duty Station: Cuernavaca, (Morelos province), MEXICO

Purpose of

Project: To assist Instituto de Investigaciones Eléctricas (IIE) in developing skills aimed at promoting quality aspects of locally manufactured electrical power instruments, machinery and associated products.

Main

- Conclusions: 1. In order to increase the quality of the products of the electrical industry -specifically the cable industry- the prompt application of the recommendations would be most advisable, although this seems not to be so easy in the actual given economical situation.
 - 2. Undoubtedly Mexico has the optimal conditions to improve their own raw materials -indispensable for the production of these items- so as to diminish the present import.
 - 3. Glass Fiber Optic Cables. Mexico's biggest company of glass fiber optic cables (CONDUMEX) produces this type of cables with up to 12 numbers of cores with the importation of glass fiber elements, joints and terminations and cutting devices.

With the support of highly specialized field experts, Mexico would be in the position to develop its own technology in the field of glass fiber optic cables.

Main Recommendations: 1. The establishment of a central national cabletesting laboratory for life-time tests and the evolution of aging techniques for a more efficient development of the cable industry.

> When developing a semiconducting compound, it became obvious that the quality of the mexican raw materials have not yet achieved the required level.

To obtain better results in this field in Mexico, it is essential that research and development should be urged for the refinement of mexican raw materials, in order to diminish the expensive importation. As a result, Mexico would count on a higher quality.

3. The potential to raise new generations of specifically trained specialists (preferably trained at the UNIVERSIDAD NACIONAL AUTONOMA DE MEXICO and the INSTITUTO POLITECNICO NACIONAL).

CONTENTS

INTRODUCTION	6
RECOMMENDATIONS	9
I. ASSISTANCE TO THE INSTITUTO DE INVESTIGACIONES ELECTRICAS IN CUERNAVACA	11
A. ASSISTANCE TO THE DEVELOPMENT OF SEMICONDUCTIVE SHIELDS USED IN POWER CABLES	12
B. ASSITANCE TO THE ESTABLISHMENT OF A BASIC LABORATORY FOR AGING TESTS	13
C. CONTRIBUTION FOR THE DESIGN, DEVELOPMENT AND TEST OF A HIGH VOLTAGE CABLE TERMINATION	13
D. CALCULATION AND DEVELOPMENT OF A TUNABLE HIGH VOLTAGE REACTOR	14
E. ASSITANCE FOR THE DEVELOPMENT OF A WALL BUSHING	14
F. QUALITY TESTS OF THE INSULATION OF TRANSFORMER COILS	14
G. PROBLEMS OF KNOWLEDGE IN THE FIELD OF POWER CABLE TESTS	15
H. GENERAL REMARKS	15

т. П

Π.	ASSISTANCE TO INDUSTRIA ELECTRICA SOCIEDAD ANONIMA (IESA), CONDUMEX, CONDUCTORES COYOACAN AND FORRADOS FINOS, INSTITUTO DE FISICA (UNAM)	7
	A. SPECIAL CONSULTATIONS ABOUT DESIGN, MATERIAL AND PROCESSES OF MANUFACTURE OF TRANSFORMER-COILS	8
	B. SEVERAL TALKS ABOUT TEST-METHODS OF CABLES AND TECHNOLOGY OF GLASS FIBER OPTIC CABLES	8
	C. VOLTAGE TESTS OF CABLES PRODUCED BY "CONDUCTORES COYOACAN" (INDUSTRIAS MAC, S.A.) AND "FORRADOS FINOS", S.A. (FOFISA)	9
	D. TALKS ABOUT GLASS FIBER OPTIC CABLES WITH EXPERTS OF THE INSTITUTO DE FISICA (UNAM)	9
III.	ANNEXES	20
	ANNEX 1 JOB DESCRIPTION, WORK SCHEDULE AND A NOTE OF BRIEFING BY THE CONSULTANT	21
	ANNEX 2 A COMPREHENSIVE LIST OF EQUIPMENT ITEMS REQUIRED IN THE CABLE LABORATORY FOR LIFE TESTING	28
	ANNEX 3 SCHEDULE OF LECTURE COURSES	43

1

T.

т т

1

1 I

I.

INTRODUCTION

According to the Job Description DP/MEX/82/011/11-54/31.9.C, the purpose of the project was to assist the Instituto de Investigaciones Eléctricas (IIE) in the development of skills aimed at promoting quality aspects of locally manufactured electrical power instruments, machinery and associated products.

The consultant's assistance at the Institute lasted from September 5th, 1984, to February 14th, 1985.

The consultant had the following duties:

- 1. To assist the envolved staff at IIE developing aging techniques for electric power cables; to stimulate normal operating conditions at an accelerated pace and thus obtain a standard of a usable lifespan of cables as well as of the residual lifespan of the cables in operation.
- To prepare a comprehensive list of equipment items required in the cable laboratory for life testing of power cables. Quality control equipment is to be included.
- 3. To prepare a final report setting out the findings of his mission and listing recommendations for future operations of the cable laboratory.

The main activities of the consultant to perform the foreseen project, were:

- 1. Proposals of measuring equipments and electrical circuits for the evaluation of semiconductive materials.
- Development of local (Mexico) materials for semiconductive shields used in power cables (electrical evaluation of the raw materials as well as the final product - 15 KV class).

- Elaboration of a comprehensive list of equipment items destinated to a laboratory for life testing of power cables.
- 4. Contribution to the design, development and testing of a high voltage cable termination to be used in the 150 KV test circuit for pollution tests in the high voltage laboratory of the Materials Department.
- 5. Calculation and development of a tunable high voltage reactor for aging tests set for power cables (35 KV; 1000 Hz; 50 KVA).
- 6. Essential support at the development of a 35 KV, 2 kA wall bushing for the short circuit laboratory of Salazar (some kilometers to the west of Mexico City); these wall bushings will be manufactured using thermocontractil materials.
- 7. Quality testings of the insulation of transformer coils.
- Lecture courses and seminars on cable technology and test methods (extruded insulations).
- 9. Visits to several factories and institutions, intending the improvement of quality of cables and transformers.

When arriving at the duty station on September 5th, the project was not yet as advanced as expected, which meant that all the above mentioned goals could not be reached during those six months, since there was not yet the necessary technical documentation available for the life-tests of electric power cables and no engineering group ready for cable testing and aging techniques research.

This situation was discussed extensively with the UNIDO JPO in Mexico City, considering the guiding principles of the briefing in Vienna. All activities of the consultant were directed to increase the quality of tests for locally manufactured electrical power instruments, machinery and associated products; especially for power cables and transformers.

During several concentrated talks with Dr. K. B. Wolf (UNIVERSIDAD NACIONAL AUTONOMA DE MEXICO - IIMAS) and Dr. T. Seligman, Dr. M. Berrondo (INSTITUTO DE FISICA - UNAM), it became quite clear that research and development in the field of glass fiber optics in Mexico have to be centralized and intensified.

.....

RECOMMENDATIONS

The recommendations as the result of the work done, are:

1. In Mexico there are 5 cable testing laboratories, i.e., each cable company with one, plus one at the IIE, which do all work independently; it would be advisable not only to have these institutions work together closely, but also to establish a central national cable-testing laboratory for life-time tests and the evolution of aging techniques, for a more efficient development of the cable industry.

Conditions for research:

- 1.1 Indispensable equipments (see list).
- 1.2 Highly qualified specialists (preferably trained at the UNIVERSIDAD NACIONAL AUTONOMA DE MEXICO).
- 1.3 Potential to raise new generations of specifically trained specialists.
- 2. Research in the realization of life-time-tests to improve the quality of cable manufacturing materials.
 - 2.1 Research in the development of new test-methods for an independent efficient cable industry.

3. Better quality. In Mexico there are four cable companies:

- 1) CONDUMEX
- 2) CONELEC
- 3) LATINCASA
- 4) CONDUCTORES MONTERREY

CONDUMEX invited the consultant to conduct a symposium which counted with the assistance of highly interested engineers from all kinds of areas.

During this symposium, the consultant raised the question why cables in Mexico have only a guarantee of one year. Answer: Consumers generally do not make the appropriate use of the cables, as prescribed.

This seems to be a national problem. The recommendation would be a closer control on the usage of electric energy in general.

4. Further Development.

The Instituto de Investigaciones Fléctricas had already obtained the order from Condumex to develop a semiconducting compound for conductor -and insulation- shields to make the country independent from the costly importation from abroad.

When developing these compounds -with the direct involvement of the consultant- it became obvious that the quality of the mexican raw materials has not yet achieved the required level.

To obtain better results in this field in Mexico, it is essential that research and development should be urged for the refinement of mexican raw materials, in order to diminish the expensive importation. As a result, Mexico would count on a higher quality.

CHAPTER I

G

1

ASSISTANCE TO THE INSTITUTO DE INVESTIGACIONES

ELECTRICAS IN CUERNAVACA

1

A. ASSISTANCE TO THE DEVELOPMENT OF SEMICONDUCTIVE SHIELDS USED IN POWER CABLES

The work of the consultant was started under the following conditions:

- The Instituto de Investigaciones Eléctricas had already obtained the order by the mexican company CONDUMEX, to develop a semiconducting compound for conductor -and insulation-shields.
- The results of the so far developed compounds were not hundred per cent satisfactory.
- The equipments available are not the required ones for testing and measuring.
- These conditions made it necessary to concentrate the efforts on the following aims:
 - a) The elaboration of proposals for measuring equipments and electrical circuits for the evaluation of semiconductive materials.
 - b) To support the development of materials in Mexico of several semiconductive compounds.
 - c) To carry out tests of newly developed semiconductive compounds.

During the development of these compounds, it became obvious that the quality of the mexican materials has not yet achieved the required level.

B. ASSISTANCE TO THE ESTABLISHMET OF A BASIC LABORATORY FOR AGING TESTS

- The consultant prepared a comprehensive list of equipment items for a basic laboratory.
- Some equipment items for the basic laboratory were already available, but there was no documentation of testing methods for aging tests.
- The implementation of this laboratory still requires the purchase of some foreign equipment, as well as of some locally made ones.

C. CONTRIBUTION FOR THE DESIGN, DEVELOPMENT AND TESTS OF A HIGH VOLTAGE CABLE TERMINATION

The consultant has contributed to the design, development and proposals for the testing of a high voltage cable termination to be used in the 150 KV test circuit for pollution tests in the high voltage laboratory.

Up to now, the above mentioned development is not yet concluded since some special materials, like-glass fibertubing- for instance, are needed and not yet available.

The IIE is trying hard to get this material, in order to continue the development.

D. CALCULATION AND DEVELOPMENT OF A TUNABLE HIGH VOLTAGE REACTOR

The IIE has asked the consultant to carry out a calculation and development of a tunable high voltage reactor for aging tests set for power cables (35 KV; 1000 Hz; 50 KVA).

After working out during three weeks in the calculation and design, it appeared that the IIE is not able to build up this reactor because, again, it needs special equipment and materials.

Conclusion: It is necessary to purchase this aging test set from a company, which could be HAEFELY, ASEA, or MICAFIL, for instance.

E. ASSISTANCE FOR THE DEVELOPMENT OF A WALL BUSHING

The consultant has given an essential support for the development of a 35 KV, 2 KA wall bushing to be used in the short circuit laboratory.

These wall bushings will be manufactured using thermocontractil materials.

Several tests were carried out with different thermocontractil materials. The results were positives and this development is almost concluded.

F. QUALITY TESTS OF THE INSULATION OF TRANSFORMER COILS

Several quality testings (particularly partial discharge test) of the insulation of dry-type-transformer coils were carried out by the IIE (750 KVA; 500 KVA; 250 KVA; 23 KV/440 V - 250 V; 60 Hz) in the company IESA (INDUSTRIA ELECTRICA SOCIEDAD ANONIMA), and besides in the Instituto de Investigaciones Eléctricas also.

The results were showing that the measured values did not reach the required standard level, due to the quality of the used insulation material, the design and the process of manufacture.

For the further development of dry-type-transformers, this company will work together with the IIE.

G. PROBLEMS OF KNOWLEDGE IN THE FIELD OF POWER CABLE TESTS

In order to fulfil the conditions for adequate research in this field, it is fundamental that all the higher educational institutions (e.g. UNIVERSIDAD NACIONAL AUTONOMA DE MEXICO; INSTITUTO POLITECNICO NACIONAL) review their educational programs and extend them in this direction, if possible, with specialists from abroad.

H. <u>GENERAL REMARKS</u>

The consultant met a very friendly and open atmosphere at the IIE. The engineering staff was very cooperative. On the other hand, the efficiency of the consultant's task might have been higher for several reasons:

As already mentioned in the introduction, the group for cable-testingengineering had not yet been formed and did not have enough technical documentation. If the whole programme had been carefully planned before hand, the consultant's assistance would have been of more use. The suggestion is that in the future, consultants should be informed with all the details concerning background information at the Institute, its work plans, organization, connection with the industry, Mexican Government decisions, etc.

The consultant took the iniciative to visit some industries, other research institutions, universities, etc., as suggested in the job description.

It is also important that the Institute itself should organize seminars for the direct participation of new consultants, so that members of the other departments and divisions may profit from this exchange of ideas with their consultant.

If the future consultants count on a closer cooperation of other staff within the Institute, his job will yield a maximum efficiency.

CHAPTER II

ASSISTANCE TO INDUSTRIA ELECTRICA SOCIEDAD ANONIMA (IESA), CONDUCTORES COYOACAN AND FORRADOS FINOS, INSTITUTO DE FISICA (UNAM)

1

1

1

1 1 1 1

A. <u>SPECIAL CONSULTATIONS ABOUT DESIGN, MATERIALS AND PROCESSES</u> OF MANUFACTURE OF TRANSFORMER-COILS

Several tests of the insulation of transformer-coils have shown that the required standard level has not been reached.

After these tests, the consultant and an expert from the IIE had consultations with the producer of transformers -INDUSTRIA ELECTRICA SOCIEDAD ANONIMA (IESA) - about the design, materials and process of manufacture of transformer-coils.

As a result of these consultations, the company IESA is working hard to improve the quality of insulation of transformer-coils.

Consequently, IIE and IESA are at present working together intensely in this field.

B. <u>SEVERAL TALKS ABOUT TEST-METHODS OF CABLES AND TECHNOLOGY OF</u> GLASS FIBER OPTIC CABLES

CONDUMEX invited the consultant again for several talks about testmethods of cables and the technology of glass fiber optic cables. As mentioned above, Mexico imports almost all materials and equipment for the production of these cables. Up till now, the quantity of the production in this field has been very small (5 Kilometers).

CONDUMEX, being the biggest cable producer of Mexico, is very interested in improving its production and in changing over to the newest technology. It is advisable to import special technology from abroad (e.g. Japan, USA, BRD, DDR).

C. VOLTAGE TESTS OF CABLES PRODUCED BY "CONDUCTORES COYGACAN" (INDUSTRIAS MAC, S.A.) AND "FORRADOS FINOS", S.A. (FOFISA)

In the IIE were carried out several voltage tests of cables and cores produced by "Conductores Coyoacán" and "Forrados Finos" (FOFISA).

The result of these tests were up to the standard level and satisfying.

D. TALKS ABOUT GLASS FIBER OPTICS WITH EXPERTS OF THE INSTITUTO DE FISICA (UNAM)

The consultant had several talks about the research and development of glass fiber optics with Dr. Thomas Seligman and Dr. Manuel Berrondo. During these talks it became quite clear that in Mexico reserach, as well as practice in this field, have to be centralized and intesified.

If Mexico wants to progress up to a high level in this area, it absolutely needs to keep in touch with top class experts abroad (e.g. Japan, USA).

CHAPTER III

A N N E X E S

20

ANNEX 1

JOB DESCRIPTION, WORK SCHEDULE AND A NOTE

OF BRIEFING OF THE CONSULTANT



UNPEDD NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION.

UNIDO

PROJECT OF THE GOVIDUMENT OF MEXICO

DP/MEX/82/011/11-54/31.9.C

JOB DESCRIPTION

• .	•	•	•	-: .

Post title	Consultant in Testing of Power Cables with Extruded Insulation				
•					
Duration	Six months				
Date required	1 July 1934				
Duty station	Cuernavaca (Morelos province), Mexico.				
Purpose of project To assist IIE (Instituto de Investigaciones Electricas) : developing skills aimed at promoting quality aspects of locally manufactured electrical power instruments, muchi-					
Duties	 and associated products. The consultant's duties will be: 1. to assist counterpart staff at HE with developing aging techniques for electric power cables, to stimulate normal operating conditions at an accelerated pace and thus obtain a measure of useful life of unused cables as well as residual life of cables in operation. 				
	 to prepare a comprehensive list of equipment items required in the cable laboratory for life testing of power calles, Quality control equipment is to be included. 				
	3. to prepare a final report setting out the findings of his mission and listing recommunitiess for future operations of the cable laboratory.				
	· · · · · · · · · · · · · · · · · · ·				
	•				

Applicate direct commentations regarding this deb Discours is ventile, we the

.......

. .

1

1 1

I.

Project Personnel Retruitment Castion, Industrial Contrast Division (2010) (2000) Env. 261, ACO10 St. B. S. St. 2010

1

.....

Quel: in .

qualified electrical engineer with long-conding professional experience in the technology of electric power calles in general and their of power calles with extruded deceletion in particular.

Also the condidate should have experience in receiver this aging tests as part of life-cycle analysis of power cables.

In addition, the candidate should have a background in didactics to enable him to undertake training of counterpart personnel.

Language

English and/or Spanish

Background Information

The development of industries which produce electric power equipment and machinery has been accorded high priority in Mexico's industrialization efforts and the requirement that equipment of this kind, produced in Mexico, would be of a quality acceptable worldwide led to the formation of IIE and its laboratories in Cuernavaea.

From this original concept developed a new idea, notably that of establiching an integral system of specialized testing laboratories in Mexico, near industrial area: where electric power equiptent and machinery is being manufactured. The purpose of these specialized testing facilities is to reduce or eliminate problems associated with one central testing organization. The design and development necessary to create the banks for each of these specialized testing facilities is being carried out at the central organization in Cuernavars, where the following research laboratories have been or are in the process of being - established:

- a high voltage laboratory;

- a high power (short circuit) laboratory;

- a laboratory to evaluate finished products;

- a prototype testing laboratory;

- a materials testing laboratory;

- a turbine laboratory;

- a transformer laboratory;

- a laboratory to investigate the operation of circuit breakers, fuses, lightning arrestors;

- a cable evaluation laboratory;

- a rotary electrical machines laboratory.

The principal purpose of their activities is to used the mational investments and co-primation of local local for programmes to avoid duplication and/or overlated to the second The overriding principle which has been established for the these facilities will not carry out routine testion, but wither be echcerned with performance, design as a for the testing of locally - and imported - electrical controls to an importance.

1.

Furthernesses THE environ in discontinuing income some the binds of technology hert putter to Mexico additional as well on the end-under their adoption in the second to detineering inductor in Mexico.

It maintains relations with similar engeninations in the other countries and with academic and research insitutions in Mexico, whose work its own activities are designed to complement.

With regard to the cable laboratory, the work being carried out in this sector is aimed at developing national expertise not only in testing but also in quality control and quality assurance of locally manufactured electric power cables.

1

 $(1,1,\dots,n)$

.....

• • •



MR. J. PETTERSON UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION UNIDO - REPRESENTATIVE (RESIDENT)

MEXICO - CITY.

LEF : EQ/M/GR/061/84

Cuernvaca, Mor., Octubre 4, 1984

Dear Sir,

Regarding the work of Mr. M. H. HOELZER, Field Adviser (Consultant) from UNIDO. We would like to inform you that his WORK-PROGRAMME has been slightly modified given the present situation and needs of our institute.

We are enclosing the proposed new WORK-PROGRAMME, which does include part of the original one, but is considerably different.

Please let us know if you have any objections to these changes, which we regrettably had to make at such a late date.

Looking forward to hearing from you.

I remain.

Sincerely yours,

1 1


ING. GUILLERMO RIVERA NOVA HEAD OF THE MATERIALS DEFT.

11 1

Enclosures : - Proposal of the new WORK-PROGRAMME - JOB DESCRIPTION of the UNIDO for Consultant.

c.c.p. Mr. Hoelzer.

....



WORK SCHEDULE FOR MR. MANFRED J. HOELZER.

- 1. A mexican cable manufacturer is interested in the development of local materials for semiconductive shields used in power cables. This project includes electrical evaluation of the <u>raw</u> materials as well as the final product, a 15 KV class cable, insulated with a polymeric material. To asses the raw materials test cells and adequate procedures that are needed for cable evaluation, prototype tests will be required.
- 2. To prepare a comprehensive list of equipment items for a Dasic laboratory for aging tests of polymer cables. This is required in the IIE. The implementation of the laboratory will require buying some foreign equipment and some locally made.
- 3. Contribution on the design, development and tests of a high voltage cable termination to be used in the 150 KV test circuit for pollution tests in the high voltage laboratory of the Materials Department.
- 4. Assistance at the development of a 35 KV, 2 KA wall bushing for the short circuit laboratory of Salazar, this wall bushings will be manufactured using thermocontractil materials.
- 5. Visits to cable factories, in order to see if improvements can be suggested by him.
- 6. Corriging out lecture courses and seminary of caule terms of and test-methods (extruded insulation).
- Prepare a final report setting out the findings of his massion and listing recommendations for future operations of the value laboratory.

NOTE FOR THE FILE

To Mr. V. Smirnov

From E. Krajenbrink

Ref: Briefing Mr. M.J. Hoelzer - DP/MEX/82/Cll: Post 11-54

Mr. Hoelzer will be attached to the IIE Institute at Cuernavaca (some 200 km. south of Mexico City), where he will provide advice on techniques for ageing of power cables through simulation of normal operating conditions at an accellerated pace.

The Institute at Cuernavaca is in the process of establishing a number of separate R + D laboratories, amongst which the cable evaluation laboratory where Mr. Hoelzer will be working.

Cuernavaca is a good place to work, well away from the pollution and other problems of Mexico City.

The staff at the Institute are highly trained and very dedicated people. Most of them are under 40 years of age. Some excellent results, particularly in the ceramics and plastics sector, have already been obtained, as well as in the test instrumentation lab.

Mr. Hoelzer will meet a colleague from the DDR, who went there about a month ago (Dr. Neumann) to work on turbo generator development.

Visits to cable factories are advisable, to see if improvements can be suggested by him. IIE - people can arrange these visits and transport as part of the Government contribution to the project. A copy of this Note for the File should be given to Mr. Healter.

E. Krajenbrink

26 August, 1984

ANNEX 2

A COMPREHENSIVE LIST OF EQUIPMENT ITEMS REQUIRED IN

THE CABLE LABORATORY FOR LIFE TESTING

1 I I

1. STANDARDS

1.1 INTERNATIONAL ELECTROTECHNICAL COMISSION (IEC STANDARD)

- 38 IEC Standard Voltage
- 60 High-Voltage Test Techniques
- 141 Tests on Oil-Filled and Gas-Pressure Cables and Their Accessories
- 183 Guide to the Selection of High-Voltage Cables
- 228 Conductors of Insulated Cables
- 229 Test on Cable Oversheath which have a Special Protective Function and are Applied by Extrusion
- 230 Impulse Tests on Cables and Their Accessories
- 270 Partial Discharge Measurements
- 287 Calculation of the Continuous Current Rating of Cables (100% Load Factor)
- 332 Tests on Electric Cables under Fire Conditions
- 502 Extruded Solid Dielectric Insulated Power Cables for Rated Voltages from 1 KV up to 30 KV
- 540 Test Methods for Insulations and Sheaths of Electric Cables and Cords (Elastomeric and Thermoplastic Compounds)
- 541 Comparative Information on IEC and North American Flexible Cord Types
- 754 Test on Gases Envolved during Combustion of Electric Cables

1.2 VDE - STANDARDS (in English available)

- VDE 0207 Isolier-und Mantelmischungen für Kabel und isolierte Leitungen - VPE - Isoliermischungen
- VDE 0209 Bestimmungen für Isolierhüllen und Mäntel aus thermoplastischem Isolierstoff
- VDE 0250 Bestimmungen für Isolierte Starkstrom Leitungen
- VDE 0271 Bestimmungen für Kabel mit Isolierung und Mantel aus Kunststoff auf der Basis von PVC
- VDE 0272 Kabel mit Isolierung aus vernetztem Polyäthylen

- VDE 0273 Kabel mit Isolierung aus thermoplastischem oder vernetztem Polyäthylen
- VDE 0472 Leitsätze für die Durchführung von Prüfungen an isolierten Leitungen und Kabeln
- 1.3 BRITISH STANDARDS (BS)
 - BS 5467 Armoured Cables with Thermosetting Insulation for Electricity Supply
 - BS 5468 Cross Linked Polyethylene Compounds
 - BS 5469 Hard Ethylene Propylene Rubber Compounds
 - BS 6746 BS 6791 BS 1442 and BS 4066

1.4 ASTM - STANDARDS (AMERICAN SOCIETY FOR TESTING AND MATERIALS)

- D 149 Tests for Dielectric Breakdown Voltage and Dielectric Strength of Electrical Insulating Materials at Commercial Power Frequencies
- D 257 Tests for D-C Resistance or Conductance of Insulating Materials
- D 471 Test for Rubber Property Effect of Liquids
- D 573 Test for Rubber-Deterioration in an Air Oven
- D 638 Test for Tensile Properties of Plastics
- D 1248 Specification for Polyethylene Plastics Molding and Extrusion Materials
- D 2436 Specification for Forced-Convection Laboratory Ovens for Electrical Insulation
- D 2633 Thermoplastic Insulations and Jackets for Wire and Cable
- D 3755 Test for Dielectric Breakdown Voltage and Dielectric Strength of Solid Electrical Insulating Materials Under Direct Voltage Stress

1.5 <u>ICEA/NEMA - STANDARDS (INSULATED CABLE ENGINEERS ASSOCIA-</u> TION/NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION)

- WC 7-1982 Cross-Linked-Thermosetting-Poyethylene-Insulated Wire and Cable for the Transmission and Distribution of Electrical Energy
- WC 8-1976 Ethylene-Propylene-Rubber-Insulated Wire and (R-1982) Cable for the Transmission and Distribution of Electrical Energy
- S-19-81 Rubber-Insulated Wire and Cable for the
- WC 3-1980 Transmission and Distribution of Electrical Energy
- 1.6 IMPORTANT RESEARCH PEPORTS
 - Electric Power Research Institute (EPRI) USA
 EPRI EL-3154
 Project 1357-1
 Final Report: January 1984
 Estimation of Life Expectancy of Polyethylene-Insulated Cables
 - EPRI EL-3415
 Contract WS 80-165
 May 1984
 Workshop Proceedings: Electrical Testing of
 Extruded-Dielectric Power Transmission Cables
 - EPRI EL-619
 Project RP 671-1
 Cable Neutral Corrosion
 Selection and Evaluation of Semiconducting
 Thermoplastic Jacket Compounds for Concentric
 Neutral URD Primary Cables

- EPRI EL-3333
 Project 1519-1
 February 1984
 Maximum Safe Pulling Lengths for Solid Dielectric
 Insulated Cables
- And all new publications of EPRI-Reports in the field of Life-Time-Tests
- ALCOA LABORATORIES, Marshall, Texas
 81 WM 115-5
 An Accelerated Life Test for Evaluating Power
 Cable Insulations
- IEEE Transactions on Electrical Insulation
 Vol.; Canada, NRC
 EI-15 No.4, August 1980
 Toward a Credible Aging Test for Extruded Cable
- IEEE
 EI-16 No.4, 1980
 The Voltage Breakdown Characteristics of Miniature XLPE-Cables Containing Water Trees
- IEEE
 EI-16 No.6, 1981
 Environmental Effects on the Rate of Aging of
 EP-Insulated Power Cable

2. EQUIPMENTS

2.1 FOR ROUTINE TESTS

- Precision measuring bridge (Thomson) Measuring range: $1m \ \Omega$ up to $1k \ \Omega$
- Electronic galvanometer (Type EG 01)
 Measuring range: 5µV up to 50V
- D.C. Voltage regulator (Type 3217)
 Tunable voltage: 0.05 V up to 30 V
 Tunable current: 0.05 A up to 10 A
- Temperature-printer (Type DMKV 101)
- Ohmmeter
- A.C. Voltage-test-equipment (Type WP 500/100/4-1) 500 KVA; 0.4/50 KV
- A.C. Voltage-test-equipment 330 KVA; 0.4/6 KV
- Insulation indicator (inductor)
- Test time watch
- Water tank $(3m \times 3m \times 2m)$ to be heated up to 90°C
- Cable Eault locator (P.D. faults) for H.V. cables (Type KF 01)
 Test cable length: 20....3000 m

Input voltage:

Operating value $U_{E_{min}} \ge 0.1 \text{ V at}$ $t_h \ge 50 \text{ ns}$ $t_A \ge 100 \text{ ns}$ Maximum value $U_{E_{max}} \le 5 \text{ V at}$ $t_h \ge 200 \text{ ns}$ $t_A \ge 300 \text{ ns}$ Dynamic input resistance $R_E \ge 10 \text{ k} \odot$ Time resolution: Minimum time between impulses $t_{A_{min}} \ge 50 \text{ ns at } t_h \ge 20 \text{ ns}; U_E \ge 0.2 \text{ V}$ Maximum time between impulses

 $t_{A_{max}} \leq 10 \ \mu s \ at \ t_h < 100 \ ns; \ U_E > 0.2 \ V$

Max measuring error:

 $\Delta l = \pm (0.005 l_k + 5m)$ $l_k - \text{ length of cable}$

Output signals:

1 I I

for observation by oscilloscope
for triggering of oscilloscope
for detector of direction

Partial discharge measuring unit (Type MTE 3)
 Measured quantities:

Impulse duration: t; = 30....3000 nsmode of evaluation "short" $t_i < 300 \text{ ns}$ mode of evaluation "long" $t_i > 300 \text{ ns}$

```
Mode of evaluation "short":
         Minimum operating charge
         (indication by means of external oscilloscope
         at the input of the measuring unit R_{_{\rm F}}~\simeq~350~\Omega_{\text{s}}
         cable not terminated)
         0.05 pC
         0.15 to more than 1000 pC
         t_i = 60....75 \text{ kHz}
         t_i = 30....60 ns; 75....100 kHz
Mode of evaluation "long":
         Minimum operating charge
         (external oscilloscope)
         R_{\rm E} \approx 350 \ \Omega, cable not terminated
         0.13 pC
         0.4....2500 pC
         t_i = 300...1750 \text{ ns}
         t_{i} = 1750...3000 \text{ ns}
Range of repetition rate:
         < 10 kHz
         Measurble p.d. with indicating instrument or
         with external equipment: 2....20000 pC
         Pulse repetition rate: without disturbance
         suppression: single imp.up to 200000 s<sup>-1</sup>
         Pulse repetition rate: with disturbance
         suppression: single imp.up to 100000 s<sup>-1</sup>
Mains supply:
         supply voltage
                            220 V ± 10%
                             50 to 60 Hz
         frequency
         input power
                             35 KVA
```

Application:

A.C. Test voltage: 16 to 500 Hz
(up to 1200 Hz on special requested)
D.C. voltage: Switching impulse voltage

Amplifier/integrator:

Amplification: 55 dB Rise time with rectangular pulse: 80 ns (corresponding upper limiting frequency 4 MHz) Minimum time distance between p.d. impulses: - without disturbance suppression: 10 us - with disturbance suppression: 100 µs

Internal calibrator:

Synchronized rectangular impulses: 0.001 to 10 V Rise time < 50 ns Decay time < 50 ns Duration impulse - with frequency of testing voltage: f<80 Hz:1ms - without frequency of testing voltage: f<30 Hz:0.1ms

Measuring impedance (Type H 253) Load current at 50 Hz: 10 A Rise time with rectangular pulses: < 50 ns Impulse duration: 3 μs Wave impedance: 75 Ω

- External calibrator (Type PET 2)	
Impulse charge:	5; 25; 50; 250 pC
Polarity:	negative
Rectangular voltage decay time:	<50 ns
Amplitude:	≈u _b - 0.5 V
Repetition rate:	100 Hz
Voltage of the battery:	4.3 to 4.8 V

- Dual-bean oscilloscore (Type EO 213)
 Frequency range 0 to 12 MHz
 Input impedance 1 M Ω/32 pF
 Accelerating voltage 3 KV
 (additional voltage component to increase signal brightness)
 Sensibility 10 m V/cm to 10 V/cm
 Time-base deflection 0.2 µs/cm to 100 ms/cm
- Coordinate plotter (Type "endim" 620.02)
 Plotting area 270 mm x 400 mm
 Max. plotting speed X 45 cm/s
 Max. plotting speed Y 35 cm/s
 Measuring ranges 0.1 m V/cm to 10 V/cm
- Universal voltage measuring equipment (Type MU 9) Suitable for measuring D.V. voltage (arithmetic mean values) and A.C. voltage (peak value) with digital display D.C. voltage: range 120/60/30 V input resistance 5 M %
 A.C. voltage: range 100/50/25 V (r.m.s.) Frequency of voltage to be measured: 15 to 500 Hz Input capacitance: 24 nF
- Combination of coupling capacitor with blocking impedance (Type WMCF) and cable termination (Type EKP)

1)	WMCF 8000/50 sp:	$U_n = 50 \text{ KV}$
		$C_{k} = 8000 \text{ pF}$
	EKP 50	$U_{n} = 50 \text{ KV}$
2)	WMCF 1000/100 sp:	U _n = 100 KV
		$C_{k} = 1000 \text{ pF}$
	EKP 100	$U_{n} = 100 \text{ KV}$

3) WMCF 4000/100 sp	$U_n = 100 \text{ KV}$	
	$C_{k} = 4000 \text{ pF}$	
EKP 100	U _n = 100 KV	
Screened measuring cabin		
Dimensions 5m x 5m x 3m		
Divided in two parts: test	room and control room	

- Filters:
 Control filter
 Supply filter
 High-current filter for low frequency
 High-voltage filter for P.D. Measurment
 (Type TEF 60/5)
- High-voltage testing equipment 60 KV; 300 KVA
 High-voltage test transformer (Type TMZ 12)
 Rated voltage 0.38/15/30/60 KV
 Rated current 15 A at 60 KV
 10 A at 30 KV and 15 KV
 Compensation reactors 60 + 120 + 240 K Var
 Regulating transformer 60 KVA
 Peak voltmeter (Type 53 or MU9)
- Analysis-balance (division scale: 0.0001 g)
- Laboratory-press (Type 300 S)
- For mechanical testing: INSTRON
 Instruments and Systems for Advanced Materials Testing
 Model 1125 - Universal Testing Instrument
 0.1 to 100 KN
 0.05 to 1000 mm/min (± 0.1%)

2.2 FOR SPECIAL TESTS

- High-resistance-measuring-equipment (Type 6202)
- Climate-thermo-light-chamber (Type KTLK 1250)
- Staff of insulation material 17 cm long Diameter in mm: 6; 6.5; 7.5; 8; 9; 9.5; 10; 11; 12 13; 14; 15; 16; 17; 19; 20; 21; 23 24; 27.
- Heating-equipment for water bath
 20....90°C
- A.C. Test-voltage regulator
 0....35 KV
- D.C. Test-voltage regulator
 0...10 KV
- Measuring-microscope (10 times; scale divisio: 0.01 mm)
- Mechanical measuring equipments (division of scale 0.01 mm)

2.3 FOR TYPE TESTS

1

1 11

Air oven (Type WSU 100)Range of temperature:30 up to 300°CTime for heating up:Apprx.25 min.Duration for one completeApprx.5s (with max.air change:air supply)Max. supply of air:70 m³ per hourNominal contents:100 L

1 1

T.

- Flowmeter for air-flow control in air oven:

A calibrated capillary tube with an internal calibrated diameter of about 2mm and a calibrated lenght of about 70 mm.

- Stop watch.
- Voltmeter (for measuring of mains supply)
- Amperemeter (power consumption)

$$V = 3590 \frac{(P1-P2)}{d (t_2-t_1)}$$

- Stop-watch
- Equipment (press) for cutting of the cumb-bell test pieces according to IEC-Standard 540, figure 7, page 105.

Single screw laboratory extruder:
 Screw 3/4" (19.05 mm) or 1" (25.40 mm)
 Temperature range up to 400°C
 Lenght/diameters 10:1
 20:1
 25:1
 with a complete line of standard dies.

- Laboratory mixer: Single batch and continuous

Chamber bor diameter apprx. 40 mm Chamber length approximately 48 mm Bowl capacity 125 mL Maximum temperature 400 °C

- Process Monitor and controller

1.1.1

- Multi-strand
- Laminating and coating equipment
- Pelletizer
- Tape, sheet and ribbon equipment
- Measuring microscope: A reading of 0.01 mm and an estimated reading to three decimal places. Magnification power of at least 10.
- Cold-bend test apparatus: It is represented in IEC-Standard 540, page 110, figure 15.
- Impact-test apparatus: It is represented in IEC-Standard 540, page 111, figure 16.
- Hydrometer: Calibrated at 23°C
- Thermometer: 0.1 degree Celsius divisions
- Balance: With a precision of 0.1 mg
- Pan straddle or other stationary support
- Pycnometer: 50 mL capacity
- A liquid bath provided with a thermostatic control
- Apparatus for determining melt flow index: It is represented in IEC-Standard 540, p.112, fig.17 and 18.
- Apparatus for ozone resistance test: It is represented in IEC-Standard 540, p.113, fig.20.

1 1

- Electronic ozonometer: See IEC-Standard 540, p.114, figure 21.
- Indentation device: See IEC-Standard 540, p.108, figure 11.
- Desiccator: Range of Temperature -70 to 180°C ± 0.5 K
 Deep = 965 mm
 Breath = 1050 mm
 Height = 1000 mm

2.4 FOR LIFE-TIME-TESTS

-	Motor generator set:	Motor 6.6 KVA; 440 V/60 Hz 3-ph Generator 6.6 KVA; 440 V/1000 Hz 15A; 1-ph
	Voltage regulator:	0 to 440 V
-	Exciter transformer.	
-	Tunable high voltage reactor:	0 to 35 KV 1.66 A 1000 Hz

I.

1

- Control unit.

ANNEX 3

SCHEDULE OF LECTURE COURSES

1. INSULATING COMPOUNDS

- 1.1 Thermoplastic
- 1.2 Elastomeric or Thermosetting
- 1.3 Applications and Properties

2. XLPE - CABLES

- 2.1 Technology and Equipments
- 2.2 Testing

3. TEST-METHODS FOR POWER CABLES AND MATERIALS

- 3.1 Test Conditions
- 3.2 Routine Tests
 - General
 - Electrical resistance of conductors
 - Partial discharge test
 - Voltage test

3.3 Special Tests

- General

- Frequency of special tests
- Repetition of tests
- Conductor examination
- Measurement of thickness of insulation and of non-metallic sheath

- Measurement of thickness of lead sheath
- Measurement of armouring wire and tapes
- Measurement of external diameter
- Voltage tests for 4h
- Hot set tests for EPR and XLPE insulation and sheaths of SE1

3.4 Type Tests

- 3.4.1 Electrical
 - Cables insulated with PE or XLPE and PVC or EPR
 - Sequence of tests (pd-test; bending-test; tan ⁶ measurement; heating cycle test; impulse withstand test; high-voltage-ac-test)
 - Special provisions
 - Insulation resistance measurement
- 3.4.2 Non-Electrical
 - Measuring of thickness of insulation and sheath
 - Tests for determining the mechanical properties of insulation and sheaths before and after aging
 - Additional aging test on pieces of completed cables
 - Loss of mass test on PVC sheaths of type ST₂
 - Tests for the behaviour of PVC insulation and sheaths at high and low temperatures
 - Test for resistance of PVC insulation and sheaths to cracking (heat shock test)
 - Measurement of melt flow index of PE insulation and sheaths
 - Ozone resistance test for EPR insulation
 - Hot set test for EPR and XLPE insulation and sheaths of SE1

. . . .

- Oil immersion test for elastomeric sheaths
- Water absorption test on insulations

- Flame retardance test
- Measurement of carbon black content of PE sheaths
- Shrinkage test for PE and XLPE insulation
- Special bending test
- Thermal stability test for insulation of PVC/B
- 3.5 Electrical Tests After Installation
- 3.6 Aging-Test-Methods

4. LIFE - TIME - TESTS

- 4.1 High-Voltage
- 4.2 High-Frequency and High-Voltage
- 4.3 Electrochemical

1 I.




DIAGRAM FOR 1000 Hz AGING TEST SET (LIFE-TIME-TESTS)