



**TOGETHER**  
*for a sustainable future*

## OCCASION

This publication has been made available to the public on the occasion of the 50<sup>th</sup> anniversary of the United Nations Industrial Development Organisation.



**TOGETHER**  
*for a sustainable future*

## DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

## FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

## CONTACT

Please contact [publications@unido.org](mailto:publications@unido.org) for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at [www.unido.org](http://www.unido.org)

RESTRICTED

DP/ID/SER.A/1392  
26 September 1990  
ORIGINAL: ENGLISH

18607

INDUSTRIAL ADVISORY SERVICES AND TRAINING

DP/EGY/88/032

EGYPT

Technical report: Manufacturing and testing of medium tension power cables\*

Prepared for the Government of Egypt  
by the United Nations Industrial Development Organization,  
acting as executing agency for the United Nations Development Programme

Based on the work of M. J. Hölzer,  
Consultant in manufacturing and testing of high-voltage power cables

Substantive officer: Mr. Gürkök  
Engineering Industries Branch

Backstopping officer: Mr. Koliakine  
Section for Integrated Industrial Projects

United Nations Industrial Development Organization  
Vienna

-----  
\* Mention of company names and commercial products does not imply the endorsement of UNIDO. This document has not been edited.

Table of Contents

Chapter/ Sections	Subject	Page No.
	Abstract	2
	Introduction	5
I.	Activities	7
II.	Conclusions	8
III.	Recommendations	9
IV.	Annexes	
	Annex 1 : - Work programme of the expert	12
	- Procedure for the technical cooperation	13
	Annex 2 : - Recommendations resulting from the period of May 5 th to June 5 th	16
	- Seven protocols about consultations	18
	- Recommended standards	35
	- Recommended equipment	36
	Annex 3 : - Senior counterpart staff	38
	- List of people met	38
	- Currying - out of training programm and some test-results	39

A B S T R A C T

Post title : CONSULTANT IN MANUFACTURING AND TESTING  
OF MEDIUM TENSION POWER CABLES

Number of  
Project : DP/EGY/88/032/11 - 64

Duration : May 2 nd to June 29 th, 1990

Duty Station : Cairo, EGYPT, Electro Cable Egypt (ECE)

Purpose of the  
Project : To improve quality of cross-linked Polyethy-  
lene cable production

- Main  
Conclusions :
1. The basic equipment for the manufacturing and testing of XLPE-insulated medium tension power cables are incomplete. They have to complete in order to secure the existing technique for production and for assurance of quality.  
On the one hand exist modern machines and on the other hand obsoleted equipment
  2. The tests of quality (inspection and testing) performed at present concerning incoming material, production process and ready made cable are not sufficient in order to guarantee the quality of final product (including of quality documentation and records).
  3. Improvement of qualification for the field of work (quality management - executive and management personnel, technical personnel, production supervisors and workers)
  4. In order to increase the quality of XLPE-insulated medium tension power cables the

prompt application of the recommendations would be most advisable, although this seems not to be so easy in the actual given economical situation.

**Main**

- Recommendations :**
1. Completion of basic equipment for the manufacturing and testing of XLPE-insulated medium tension power cables. Further more renewal gradually of the obsoleted equipment. Assurance of systematically maintenance and repair.
  2. Production according to VDE 0273, tests according to VDE 0472 and realization of ISO 9000 " Quality management and quality assurance standards: Guidelines for selection and use " 1987-03-15
  3. Requirement of experts:
    - a) Expert for manufacturing and testing of XLPE-insulated medium/high - voltage power cables. That expert must be a high qualified electrical engineer and should have at least five years of experience.
    - b) Expert for manufacturing of conductors for medium/high - voltage power cables and maintenance for the production equipment. It is recommended that this expert is a high qualified mechanical engineer and should have at least five years of experience in cable plant maintenance.
    - c) Expert for management and economy in the manufacturing of medium/high - voltage power cables.

The experts have also to train the executive and management personnel and to give consul-

tations.

The duration of the experts should be at least six month in order to get a good result for longer time and to have a possibility to find all kinds of problems and to make training with operators.

4. It is recommend to introduce daily " down time reports " and to analyse every week/month the production - down times, quality, maintenance and all problems concerning the medium tension power cables with a final monthly report made by production manager.

## I N T R O D U C T I O N

According to the Job Description DP/EGY/88/o32/11 - 64, the purpose of the project was to improve the quality of cross-linked polyethylene cable production at Eletro Cable Egypt Co. (ECE).

The consultant's mission at the ECE lasted from May 5 th to June 27 th, 1990.

### The consultant had the following duties:

1. Apprise himself of the types of power cable which are produced locally, equipment used, testing capacities.
2. To assist in the introduction of new technology for the manufacture of XLPE insulated medium tension power cables.
3. To recommend to reduce losses in production processes.
4. To assist in the introduction of new testing techniques according to international standards.
5. To provide on-the-job training for production and testing staff of the Electric Cable Company.
6. To prepare an analyses on the expected problems and their trouble shooting in both production and testing stages.
7. To prepare a report summarizing results of his mission and setting-up recommendations concerning the above subject. Prior to the completion of this mission, the expert will also be expected to discuss his findings and recommendations with the counterpart and the Government.

### The main activities of the consultant to perform the foreseen project, were:

1. Tests of materials according to the applied standards
- 1.1. Aluminium - and Copper - wires and Cu - foil

- 1.2. Polyethylene and catalyst
- 1.3. Semiconductive material and semiconductive tape
2. Analysis of the production process
  - 2.1. Wire drawing
  - 2.2. Conductor stranding
  - 2.3. Insulation
  - 2.4. Curing process
  - 2.5. Copper screening
  - 2.6. Core laying
  - 2.7. Filling and armouring
  - 2.8. Outer sheathing
3. Tests of the ready made cable
  - 3.1. Hot-Set-Test
  - 3.2. Partial discharge test
  - 3.3. High-tension-test
  - 3.4. Checking the three layer thickness and the resistance
4. Minimizing of scrap
5. Weekly consultations to the above mentioned points



## I. A C T I V I T I E S

- Based on the Job Description it was assumed that dry curing lines are existing in ECE. But they use the Siloxane bridge curing it means Sioplas process. This method is unusual for the manufacturing of XLPE-insulated medium tension power cables. Normally this method is used for the production of low tension power cables.  
The condition of the technical equipment is not satisfactory for the manufacturing and curing of XLPE-insulated cables, e.g. the exactly measuring and recording of temperature during the curing process was not possible.
- Tests of the incoming material were carried out. But moisture content tests and pollution content tests of the material (PE, semiconductiv material, catalyst) were neglected because the equipment were not available.
- For the manufacturing of wires and conductors (compacting) were used dies (angles and polishing) which were not fitted for a good quality of medium tension power cables.  
On the other hand modern machines were used for the manufacturing of conductors, including welding equipment (cold-process).
- The extruder-lines work not synchronous enough. The consequence is the tolerance of the wall thickness of insulation according to the standard (min./max.) is not guaranteed (see test results in annex 3).
- The tests of crosslinking (hot-set-test) were not carried out continuous because the needed equipment were not all available.  
Analysises of these tests are missing.
- Partial discharge tests were carried out on single cores and ready made cables and also the results were documented. Conditioned by that existent situation the consultant undertook with the cable manufacturer (ECE) the following activities to the focal points:

1. Changes of draw-angles and surface-polishing of the dies.
2. Carrying-out of moisture content measurements by weight changing.
3. Carrying-out of crosslinking tests (hot-set-tests) of the incoming material under laboratory conditions and of samples from the present production.  
The producing samples were carried out with simple equipment by hand.
4. On the grounds of insufficient results of hot-set-tests were caused:
  - a) Tests of material
  - b) Checks of temperatures
  - c) Control of crosslinking process
5. Control of partial discharge tests and guidance to a higher accuracy of measurements.
6. Check of high tension tests.
7. Fault-analyses of ready made cables.

## II. C O N C L U S I O N S

The principal findings are written under the point main conclusion.

In addition there are the following points:

1. The manufacture of XLPE-insulated medium tension cables demand much more cleanness and order.
2. The process of crosslinking and the partial discharge tests have to be carried out more controled.
3. The experts which mentioned in the main recommendations are necessary in order to give an effective help to ECE in technique, production and economy.

4. Manager of ECE ask several times the consultant if the presuppositions of manufacture of 66 KV-XLPE-insulated cables are existent.

At present it is sure that the required conditions for this production are not exist.

### III. R E C O M M E N D A T I O N S

1. The principal recommendations are written under the point main recommendation.
2. Extension of denotation of the medium tension cables according to the standard.  
For example N2XS2Y 1 x 240 RM/25 18/30 KV (acc. to VDE)
3. Use of a closed pipesystem for the transport of granulat for medium tension cable production (box - drier - extruder for XLPE, semiconductive material and catalyst)
4. Drying of XLPE - material and catalyst
5. Use of exact synchronized extruder lines
6. Production of super cleanly conductor (free of metal chips, dust, oil, grease)
7. Assurance of curing and observance of partial discharges limit
8. Use of recommended test-standards for incoming material, manufacture and final test of cables (see annex 2).
9. Introduction of a training-system for qualification on place of employment
10. Delimitation of responsibility in the production process under the consideration of wage payment in dependence upon the achievements and quality.

11. Minimizing of scrap

- Control of quantity of input material
- Calculation of scrap conditioned by the technology (standard scrap)
- Record of faulty production based on the steps of manufacture
- Use of an efficient technology
- Good conditions of machines and equipment

12. Weekly elaboration and evaluation of fault-analyses

IV. A N N E X E S

- Annex 1 : - Work Programme of the expert
- Procedure for the technical cooperation  
bet ween the ECE and the expert

Programme of the expert

Post title : Consultant in manufacturing and testing  
of medium tension power cables

Name of expert : M. J. Hölzer

Post key code : DP/EGY/88/o32/11 - 64

Duration : 59 days / 02.05. 1990 - 29.06. 1990

Duty station : Electro Cable Egypt (ECE), Cairo, EGYPT

02. - 04.05.90 Travel to Vienna and briefing at UNIDO

05.05.90 Arrival to Amman

06.05.90 Introduction at UNDP and ECE in Cairo

07.05.90 Introduction to management at ECE and  
general discussions

08. - 09.05.90 General inspection of the XLPE-insulated  
medium tension power cables and test-methods

10. - 16.05.90 Tests of materials to the applied standards  
in the laboratory

17. - 19.05.90 Drawing of wires

20. - 21.05.90 Conductor stranding

22. - 04.06.90 Insulation

05. - 08.06.90 Curing process

09. - 11.06.90 Copper screening

12. - 13.06.90 Core laying

14. - 17.06.90 Filling and armouring

18. - 19.06.90 Outer sheathing

20. - 24.06.90 Test of the ready made cable

25. - 27.06.90 Final discussions with the management concerning  
report conclusions and recommendations  
Departure from ECE

28.06.90 Departure for Vienna

29.06.90 Debriefing at UNIDO in Vienna

30.06.90 Leave of Vienna

Date : 08.05. 1990  
Subject : Procedure for the technical cooperation between  
Mr. Hölzer the UNIDO representative and ECE  
during the period 05.05. 1990 and 28.05. 1990

Attendant : Mr. Hölzer  
Mr. Iskander Fahmy  
Mr. Ragal Awadallah  
Mr. Ahmed Yousef

Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE ECE Factories sectors director

Technical cooperation between Mr. Hölzer the UNIDO expert and ECE staff will be performed during the period 05.05. 1990 up to 28.06. 1990 through the following subjects concerning the medium tension cables manufacturing and testing in ECE factories.

1. Control of the incoming raw materials production during processes and finished cables testing.
2. Minimizing of scrap.
3. Minimizing of size changing for the sake of maximum productivity.
4. Suitable product mix for the available equipment capabilities.
5. One degree quality for Exportation and local consumers.
6. Equipment quality level should be able to produce quality levels.
7. M/Cs effeiciency.
8. M/Cs and processes capacity to minimize bottle necks.
9. Production flow measures, and quality control reports to be submitted tothe management.

10. Labbling in the production floor for each cable length.
11. Minimizing of the maintenance and repair costs.
12. Plans for preventive maintenance.
13. Operators training and skills.
14. Hospital cleanliness in all production processes.
15. Security of the operations

Mr. Hölzer will check the medium tension cable processes starting by the drawing process ending with finished cable testing and will concerntrats on the areas needing technical assistance.

Weekly meetings attended by concerned staff will be necessary.

Paper received: Copy of ISO 9000



- Annex 2** : - Recommendations resulting from the period  
of May 5<sup>th</sup> to June 5<sup>th</sup>
- Seven protocols about consultations
  - Recommended standards
  - Recommended equipment

05/05 ..... 05/06/90

Recommendations for increasing the quality of XLPE-cables  
in ECE per 05/06/ 1990

---

1. Equipment for testing the incoming material and procedure
  - 1.1. Equipment for preparing the dumb-bell pieces (hot-set-test) and slices (measure of thickness)
  - 1.2. Plasti-Corder 330 of the company BRABENDER, Duisburg, W.-Germany for tests of purity of compounds (XLPE)
  - 1.3. Microscop with measurement reading for counting the particles of pollution of compound-sheet-samples
  - 1.4. A set weights (0.01 ... 10 gr.) for moisture test
  - 1.5. Standards for tests: VDE 0273; VDE 0472; VDE 0207; VDE 0303; VDE 0295  
DIN 53854 ... 57; DIN 53482; DIN 53495; DIN 54305  
ISO/DIS 9073, IEC 502, BS 5468, IEC 540, ASTM IPCEA S-66-524, D 257, D 19286, D 1505, D 638, D 756, D 1238, D 2765 A
  
2. Production process
  - 2.1. Realization of ISO 9000 "Quality management and quality assurance standards - Guidelines for selection and use" 1987-03-15
  - 2.2. Use of a closed pipesystem for the transport of granulat for medium tension cable production (box - drier - extruder for XLPE, semiconductive material and catalyst)
  - 2.3. Exact synchronized extruder lines
  - 2.4. Production of super cleanly conductor (free of metal chips, dust, oil, grease)
  - 2.5. Assurance of curing and observance of partial discharges limit
  - 2.6. Production according to VDE 0273 and tests acc. to VDE 0472
  - 2.7. Production > 30 KV with dry-curing-cv-lines

3. Recommended experts

- 3.1. Expert for manufacturing and testing of medium/high - voltage cables (XLPE)
- 3.2. Expert for maintenance and manufacturing of conductors
- 3.3. Expert for management and economy

Date : 09.05. 1990  
Subject : First meeting between Mr. Hölzer the UNIDO  
Representative and ECE

Attendant : Mr. Hölzer  
Mr. Iskander Fahmy  
Mr. Foaad Khalil  
Mr. Ragai Awadallah  
Mr. Samir Shouhdy

Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE Factories Sectors Director

Discussions were on the stranding process of the compasted conductors for MT-cables and handling of the conductors as follows:

1. Cleaning of the bare conductors and it should be free from metal chips.
2. Trying the compaction of the wires during stranding by successive dies.
3. Dies should be good finishing with an entrance angle where the compaction should come inside the core of the dies and the wires should be parallel to the core surface of the dies.
4. Special equipment should be used for lubricating the wires during stranding before entrance the dies. Drops of thinner (taken from the enamelled wires) should be used.
5. Find a circular motorized cloth brush to be installed after the extrusion line inlet caterpillar and before the extrusion head for cleaning the bare conductor.
6. Think about minimizing the polyethylene scrap coming from the intersection of the L type extruders (to be discussed alone).
7. Mr. Hölzer attended the incoming copper and aluminium testing procedure and he has no comments.

Date : 19.05. 1990  
Subject : Second meeting between Mr. Hölzer the UNIDO  
representative and ECE  
  
Attendant : Mr. Hölzer  
Mr. Iskander Fahmy  
Mr. Ragai Awadallah  
Mr. Foaad Khalil  
  
Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE Factories Sectors Director

Discussions were on the specification of the incoming material and its test in the laboratories and hot-set-test as follows:

1. Copper tape specification: -

Purity and Resistivity:

IEC standard states that the max. value of resistivity of the copper tape should be  $0.017241 \Omega \text{ mm}^2/\text{m}$ .

Mr. Hölzer point of view is that this resistivity cannot be reached by purity lower than 99.95 %.

Also he recommends to follow the IEC 228 only

i.e.,  $\rho = 0.017241 \Omega \text{ mm}^2/\text{m}$  which belong to purity of 99.95 %.

2. Semi conductive extruded material (incoming materials)

The following item should be added:

- Contamination level in the material

In one kg of material the max. level of contamination should not exceed:

max. 20 contaminates pieces	$\geq$ diameter	50 - 100 $\mu\text{m}$
max. 0.5	"	" $\geq$ " 100 - 150 $\mu\text{m}$
zero contaminates		diameter more than 150 $\mu\text{m}$

Equipment: it is advisable to get laboratory extruder from company BRABENDER town Duisburg, W.-germany

- Humidity:

Specification should include the following:

humidity 1 000 ppm (0.1%)

this can be checked by mitsubishi standard  $150^{\circ}\text{C}$  or by balance

- Test were made on actual ECE semi-conductor granuals and they show humidity percent as 0.046 - 0.059 % at 5 hrs 50°C.

So results are acceptable but ECE should add this item to their specification. This means that after drying for 5 hrs 50°C ECE can reach 0.02 % max. humidity which is acceptable and suitable for cable manufacturing.

- Supplied granuals should be packed under vacuum and this should be added to ECE specification.
- ECE should made at least one test for each patch.
- Aging: for semi conductor material
  - a) variation in tensile strength and elongation % after aging 10 days - 155°C should not be more than 20%
  - b) storage of material temperature should be 10 - 30°C

3. Insulation material: (incoming material)

- Break down voltage should be charged to 22KV/mm
- Max. contamination level:  
In one kg of material the max. level of contamination should not exceed:

max. 3 pieces  $\geq$  diameter 120 - 250 m  
max. zero diameter more than 250 m

- ECE speci. should be modified for the a/m item
- Hot-set-test for the incoming material should not be less than 100 % and the rest elongation 10 %
- Humidity:  
Max. humidity for the incoming material should be less than 0.5 % ( 5 000 ppm )
- Add in the speci. that material should be packed under.

Vacuum

Storage temp. 10 - 20 °C or as recommended by the supplier

4. Semi conductive tape: (incoming material)

The following speci. should be added:

Surface resistivity	1 500 $\Omega$ / 500 cm <sup>2</sup>
Volume resistivity (VDE 0303) max.	4 000 cm <sup>2</sup>
Elongation longitudinally	15% min.
Elongation transeverse	25% min.
Humudity	0.5% max.

5. Catalyst: (incoming material) MAC/100 crosspolymer  
- Tests were made after drying the catalyst at 50°C - 5 hrs  
it gives results for humidity % as 0.018 - 0.024 %  
- Max. acceptable humidity % should be 0.1 % for the  
incoming mat.  
- Max. acceptable humidity % should be 0.02 % before extrusion  
- It is to dry the catalyst before extrusion process.
6. Hot-set-test:  
Hot-set-test in XLPE were done in the laboratories as follows:  
a) 7 tests for XLPE mat. from the production  
b) 8 tests for XLPE mat. from the laboratory  
- Samples were taken from cables as follows:  
three samples from the present production  
two samples were taken from production realized since 14 days  
the balance of the samples which is realized since 3 months.  
All samples failed in the hot-set-test  
c) Samples were made from the laboratory as follows:  
4 samples were prepared 100 % in the laboratory from the  
granules (cured also in the laboratory)  
2 samples were taken from the extrusion m/cs  
(XLPE mat.) (line 60/90/150) and cured in the laboratory.  
All the six samples passed successfully the hot-set-test  
range of elongation is 70.1 - 84.00 %  
rest elongation is 5.9 - 8.6 %  
which successful results as per IEC 540  
This that the curing process in the factory is not effective.

Mr. Hölzer will concentrate on the curing process to advise the  
correct process and temperature.

Laboratory needs chipping facility for samples preparation.

Date : 26.05. 1990  
Subject : Third meeting between Mr. Hölzer the UNIDO  
representative and ECE

Attendant : Mr. Hölzer  
Mr. Mohamed A. Khalil  
Mr. Iskander Fahmy  
Mr. Abdallah Nasr  
Mr. Foaad Khalil  
Mr. Ragai Awadallah  
Mr. Samir Shouhdy

Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE Factories Sector Direktor

Discussion were on hot-set-test as IEC specification for MT-cables and the drawing process.

1. Hot-set-test:

- Mr. Hölzer mentioned that we need equipment to prepare dumbball samples.
- One sample could be taken per chamber having
- Mr. Hölzer recommended to make a test sheet to record the following data:
  - . Date of production, date of test
  - . type, cross section and tension
  - . M/C, shift and material supplier
  - . operator name, length and bebbin number
  - . curing temperature and curing times
  - . tester name and signature
  - . hot-set-test results
  - . standards IEC 540/82 or NFC 32 - 321

or BSS 5468 or VDE 0472

from IEC 540/82 condition: 200°C 15 min. lod 20 N/cm<sup>2</sup>

'IEC 502/83

Results should lie between 40 - 175 % (Elongation %)

- Investigation will be done during this week to test samples taken from the production after curing to find cause of the



fail and if it is due to low temp. or due to short time during the curing process.

- Measure the conditions inside the chambers.

- Condition for material:

1. For semi conductor mat.

before drying	max. 1 000 ppm (0.1 %)
after drying	max. 200 ppm (0.02%)
drying time	5 hours
drying temp.	50 °C
Recommending	60 °C and 4 hours

2. For insulation mat.

before drying	max. 5 000 ppm (0.5 %)
after drying	max. 200 ppm (0.02%)

Recommending drying the insulation

by test:

GPE / 400	50 °C	5 hours
before drying		0.2 - 0.3 %
after drying		0.042 - 0.0106 %

- ECE material suppliers never recommended the drying of the insulation material they only asked for the drying of the catalyst.

"ECE will ask the question again to the material suppliers".

3. For catalyst:

Same temp. time as indicated above for insulation

- Record the result of drying test in laboratory in written form including all information:

type of material, charge number,  
test operator and results of percentage  
moisture before and after drying.

- Starting from to date 6 collected cable defects will be analyzed and the cause for defect is defined.

2. Drawing process:

- Drawing dies:

The finishing of dies should be better

- Wires are too dry:

Mr. Hölzer will see the specification of the drawing oil to propose it is suitable or not (to increase the quality).

Date : 02.06. 1990  
Subject : Fourth meeting between Mr. Hölzer the UNIDO representative and ECE  
  
Attendant : Mr. Hölzer  
Mr. Iskander Fahmy  
Mr. Ahmed Yosef  
Mr. Samir Shouhdy  
  
Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE Factories Sector Director

Discussions were on stranding and insulation process of the compacted Conductors for MT-cables and hot-set-test

1. Stranding process:

- ECE are using good M/CS.
- Cold welding equipment are satisfactory.
- Use only one die for copper and another die for aluminium.
- Proportions of the die angles will be advised later.
- Use enamelling thinner insmall draps for the wire/die lubrication. It is preferable to have thin film of lubricating oil as the wires during the drawing process.
- Care should be taken during the handling of the full spools between drawing m/c and stranding m/c. It is advisable to use special pallets.
- ECE quality control system is explained to Mr. Hölzer and he handed a follow up sheet for the production and quality control system used at home.
- Mr. Hölzer recommended to use the insentives system reduction in case of bad quality.

2. Medium tension insulation:

- Insulation checking at successive internals of insulated cores, samples were taken from insulation m/c 60/120/90 - 2. Differences were measured and they change from one point to another and sometimes they are out of tolerances. Measuring sheets were handed to attendant. Those differences are due to unsynchronized inlet/outlet caterpillars are due



Date : 10.06. 1990  
Subject : Fifth meeting between Mr. Hölzer the UNIDO  
representative and ECE  
  
Attendant : Mr. Hölzer  
Mr. Iskander Fahmy  
Mr. Samir shouhdy  
  
Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE Factories Sectors Director

Discussions were on stranding dies, insulation process of MT-cables and hot-set-tests as follows:

1. Stranding carbide die:

- Use only one die for one material.
- The length of the conical drawing part should not be less than 60 %.
- A proposal drawing for the die is handed by Mr. Hölzer
- Shoulders of the should be rounded and surface should be mirror finished.
- A recommended drawing angles are 18° for copper  
and 22 - 25° for aluminium
- The cylindrical part length will be advised later.
- Form for the production follow up is handed by Mr. Hölzer and he recommended to use for different medium tension production process.

2. Cleaning of XLPE extruders:

- Mr. Hölzer handed the cleaning procedure
- CABOT semi conductive material results for curing are not get finished.
- Caring time for the italien XLPE should not be less than 48 hours for 12/20 KV (5.5 mm thickness).
- Exact curing room temperature is not get available. When this temperature know we can exactly fix the curing time.
- Mr. Hölter recommended to use VDE o294/later edition for the medium tension conductor manufacturing.

- For better thickness adjustment during the insulation process, a longitudinal continuous marks are recommended to specify the die direction of adjustment. Height should not be more than 0.08 mm.
- To increase ECE medium tension cables quality follow VDE 0273 for the core thickness.

### 3. Hints for insulation:

- Cleanliness and order: This should be hospital cleaning.
- Cleaning of the conductor before inlet to the extruder. Metal chips should be removed use round rotating plastic brush and compressed air wipers.
- Use the transparent protecting tube between the inner semi conductor head and the XLPE with outer semi conductor head.
- Removal of the extruded material fine accumulated on the outer die during the extrusion process.  
Spray from time to time silicon oil on the exit of the last die.  
Also there should be no sharp edges on the exit of the last die (they should be rounded).
- Mr. Hölzer recommended that the semi conductor granuals should be transmitted by as closed vacuum system from driers to the extruders.  
Mr. Hölzer recommended also to complete the available system.
- Mr. Hölzer recommended to put the incoming material cases or sacs on pallets in a closed chamber.
- Mr. Hölzer recommended to use brass rotating brushes instead of steel brushes which might hurt the screw/head pieces chromium plating and tools.
- As discussed last meeting use silicaon oil spray on the screws c head pieces before mainting the m/c parts prior to extrusion.
- Mr. Hölzer recommended to use a safe spark tester for checking the insulated cores (after an air wipper) this equipment should have a detector to count the defect (contact SIKORA BREMEN W.-germany).
- ECE semi conductive tape specification and quality should be change. Modifications to the available specifications will be handed by Mr. Hölzer.

Date : 16.06. 1990  
Subject : Sixth meeting between Mr. Hölzer the UNIDO representative and ECE  
  
Attendant : Mr. Hölzer  
Mr. Iskander Phahmy  
Mr. Samir Shouhdy  
Mr. Ahmed Yosef  
  
Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE Factories Sectors Director

Discussion were on drawing dies, hot-set-test, insulation thickness, copper fail, screening process and lagging up process of MT conductors as follows:

Drawing dies:

See the attached drawing of drawing dies  
Mr. Hölzer recommended that:

$$\begin{array}{r} I_3 + I_4 \\ I_2 \end{array} \quad \begin{array}{l} 0.60 H \\ (0.3 - 0.33) d \end{array}$$

$$\text{Balance of } H = I_1$$

Hot-set-test:

From the test made on 12.06. 1990 and 13.06. 1990 samples are:  
240 mm<sup>2</sup> 12/20 KV three layers using cabot material 992/1 as semi conducting outer layer and as material on line 60/120/90 - 2

The results were as follow:

1. No curing occurred in the curing chambers (test failed after curing)

2. Tests made in the laboratory should that curing occurring in some samples and not occurring in others it is observed that curing conditions occurred at 55°C for 48 and 72 hours.

Recommendations:

1. Increase the curing temperature to 90°C ± 5°C
2. Check the %age catalyst addition on this line and others during the process.
3. After the execution of 1 and 2 recheck the cross linking.

Insulation thickness difference

From the measuring of thickness sheet dated 12.06. 1990 it is noticed that the inner semi conducting, XLPE insulation and the outer semi conducting thickness are changing.

(Measured on samples displaced 100 mm in between manufacturel on line 60/120/90 - 2

it is noticed that:

the variation in the three layers as follows:

	min (mm)	max (mm)
inner semi conducting	0.695	1.129
insulation	5.292	6.448
outer semi conducting	0.534	0.985

Recommendations:

1. Check line synchronization
2. Check tools tolerances
3. Use the 10 times scalled lens
4. Check the thickness periodically (per eaeah length)

### Copper foil:

VDE o273 states the max. value of resistivity of copper foil is 0.01786  $\Omega \text{ mm}^2/\text{m}$  after processing.

ECE specification stated that min. purity of the tape should be 99.95 % and max. resistivity is 0.01724  $\Omega \text{ mm}^2/\text{m}$ .

Mr. Hölzer recommended eliminate the purity and keep the resistivity as it is because the final resistivity after processes be after lapping, laying up .... uptill the finished cable will increase more than the initiated value and it might reach the max. value stated in the VDE o273

To proof that the max. resistivity of the finished cable after processing is not more than 0.01786  $\Omega \text{ mm}^2/\text{m}$  as per VDE o273, test will be made before and after processing for the measuring of the resistivity.

### Screening Process:

Mr. Hölzer recommended to use polished guiding dies for the screening lines to prevent any damage to the cable components during screening (ex. scratches, hammering the cable surface due to unbalance tension of the used one copper tape).

Also extrimities of the cable on the take - up drum should protected against any chocks or damage.

Difference between cable diameter and used dies should not exceed two mm to prevent the cable damage due to vibration of the cable inside the die.

### Laging up:

Max. lay length is 18 D as per VDE o273

In practice use (16 - 18) D D(is the diameter after laging up - (the cable).

- Use polished assembly dies.
- Adjust the guiding roller of the catarpiller and along the line to be suitable to the cable diameter.



- Some metal chips are observed on the line due to the rough guides.

All parts touching the cable should be cleaned and polished, its vary often to clean minimum once per shift.

Minimizing of scrap:

Calculate the actual value of ECE medium tension  $\%$  age.

Date : 24.06. 1990  
Subject : Seventh meeting between Mr. Hölzer the UNIDO representative and ECE

Attendant : Mr. Hölzer  
Mr. Iskander Fahmy  
Mr. Sanir Shouhdy  
Mr. Admed Yosef

Copies to : Mr. Hassan Helmy ECE President  
Mr. M. A. Khalil ECE Factories Sectors Director

Discussion were on sheathing process, partial discharge test, high voltage test and scrap % age for MT-cables as follows:

1. Over all sheathing process:

- ECE have a good 150 mm line.

It is advisable to add another pay-off and another take-up to sharpen the line efficiency specially when change the cable length under sheathing and of course spare pay-off and take-up will save the changing time.

- Mr. Hölzer advised to use the correct reel size from the barrel diameter point view (ratio of the barrel diameter and the cable diameters).

And also to use suitable reel size for the cable length under sheathing.

It was observed that:

- a) reels with small barrel diameter are used
- b) reels are full of cable and same lay of cable are higher than the flange so the total weight of the reel is supported on the cable and not supported on the wooden flange.

- Over all diameter monitoring equipment feeding back to the extruder main motor is not used.
- Cable identification by embossing or by printing on the cable sheath such as type, cross section, voltage rating, producer and consumer names, cable length and year of

production should be printed on all the cables sheaths.

- It is observed that the wheel printing the cable length is not working.
- Use the proposed quality test certificate from one process to the following process.

## 2. Partial discharge test:

- Use all of the screen range for calibrating the equipment for the cable length and size under measurement.
- Use fixed connectors for the cable screen for both cable ends.
- The sheilding room floor should be covered by epoxy.
- Rectify the sheilding room internal electrical connectors.
- Reffering to the PD tests made during 1. - 19.06. 1990 the average percentage of cables having PD over 20 PC is 18 - 48 % and the international percentage is 1 (one) % max.
- It is understood that ECE locate the places of high PD in the 18 - 48 % cable and cut the cables at mentioned places and retest them and use the good cable but this 18 - 48 % are too high and the whole medium tension processes should be reviewed.

## 3. High voltage test:

- The new WEM equipment are goodones.
- Testing cells places should be sufficiently secured for human safing.
- Make the diemension and construction tests on samples from each finished length.
- Also do the resistance test using mentioned samples.
- Thru cables defects were analysed and the result showed That they are due to contamination in the insulation. Samples are reserved in the laboratory.

## 4. Scrap percentage:

International level of scrap % for different materials and processing steps are as follows:

drawing process	Al	1.0 - 1.5 %
	Cu	0.6 - 1.0 %

stranding process	Al	0.8 - 1.0 %
	Cu	0.5 - 0.8 %
Insulation process		2.0 - 4.0 %
Screening process		0.5 %
laying process		0.5 - 2.0 %
filling process		1.0 %
armouring process		1.0 %
sheathing process		1.0 %
test field		0.3 %

## Recommended standards

### 1. International electrotechnical commission (IEC)

IEC	38	IEC standard voltage
IEC	60	High-voltage test techniques
IEC	183	Guide to the selection of high-voltage cables
IEC	228	Conductors of insulation cables
IEC	229	Test on cable oversheath which have a special protective function and are applied extrusion
IEC	230	Impulse tests on cables and their accessories
IEC	270	Partial discharge measurements
IEC	287	Calculation of the continuous current rating of cables (100 % load factor)
IEC	332	Tests on electric cables under fire conditions
IEC	502	Extruded solid dielectric insulated power cables for rated voltages from 1KV up to 30 KV
IEC	540	Test methods for insulation and sheaths of electric cables and cords (Elastomeric and thermoplastic compounds)

### 2. VDE-Standards

VDE	0207	Insulation and sheathing compounds for cables and lines
VDE	0209	Tests for insulation and sheathing material
VDE	0295	Conductors for cables and lines
VDE	0271	Thermoplastic insulated cables
VDE	0272	Cables with insulation of XLPE 1 KV
VDE	0273	Cables with insulation of XLPE 6/10, 12/20, 18/30 KV
VDE	0427	Tests of cables and lines
VDE	0303	Tests of semiconductiv tape

### 3. British standards (BS)

BS	5467	Armoured cables with thermosetting insulation for electricity supply.
BS	5468	Cross linked polyethylene compounds
BS	5469	6746      6791      1442      4066

4. ASIM-Standards (American society for testing and materials)

- D 149 Tests for dielectric breakdown voltage and dielectric strength of electrical insulating materials at commercial power frequencies
- D 257 Tests for DC-Resistance or conductance of insulating materials
- D 1248 Specification for polyethylene plastic molding and extrusion materials
- ASTM IPCEA S-66-524 ; AEIC CS 5
- D 1928 C ; D 1505 ; D 638 ; D 756 ; D 2765 A ; D 1531 ; D 1238  
150 / D 159073

5. ICEA/NEMA-Standards (Insulated cable engineers association/national electrical manufacturers association) - - - - -

- WC 7 - 1982 Cross-linked-thermosetting-polyethylene-insulated wire and cable for the transmission and distribution of electrical energy
- WC 3 - 1980 Transmission and distribution of electrical energy

6. Deutsche Industrie Norm (DIN)

DIN 53854 ; 53855 ; 53857 ; 53482 ; 53495 ; 54305

All for tests of semiconductiv tape.

Recommended equipment

1. Plastic-corder 330 and rheotron for tests of purity of XLPE - compounds  
Supplier: Comp. BRABENDER, D - 4100 Duisburg 1, Germany
2. Microscope with measurement reading and profil-projector (V - 12)  
Supplier: Comp. LIKON, Chiyoda-Ku, Tokyo 100, Japan
3. Recommended standards according to annex 2

- Annex 3 :
- Senior counterpart staff
  - List of people met -
  - Carrying - out of training programme and  
some test - result

Senior counterpart staff

- |   |                           |
|---|---------------------------|
| 1. Eng. Hassan Hilmy Said<br>Chairman   | ELECTRO CABLE EGYPT (ECE) |
| 2. Eng. Iskander Fahmy<br>Technical Manager and<br>Member of Board of Directors | ECE                       |
| 3. Eng. M. A. Khalil<br>Director of Factories Sectors<br>and Member of Board    | ECE                       |
| 4. Eng. Ragaey Awad Allah Boulas<br>Research and Laboratory Manager             | ECE                       |
| 5. Eng. Samir S. Shehate<br>Research Engineer                                   | ECE                       |
| 6. Eng. Ahmed Hassan Youssef<br>Production Engineer                             | ECE                       |
| 7. Chemist Fouad Khalil<br>Manager of Power Cables Sector                       | ECE                       |

List of people met

- |   |  |
|---|--|
| 1. Mr. Sabry<br>Programme Officer                 | United Nations<br>Development Programme in the<br>Arab Republic of Egypt   |
| 2. Mr. Dr. Mazhar<br>First Under-Secretary        | Ministry of Industry in the<br>Arab Republic of Egypt                      |
| 3. Eng. Brain Roberts<br>Sales Director           | Babcock Wire Equipment<br>Limited<br>England - Lancashire                  |
| 4. Eng. Gary M. Jarvis<br>Commissioning Engineer  | Babcock Wire Equipment<br>Limited<br>England - Lancashire                  |
| 5. Mr. D. J. M. Gargadenec<br>Product Manager     | Comp. Carl Freudenberg<br>Nonwovens Division Wiledon<br>Germany - Weinheim |
| 6. Mr. Ahmed M. Osman<br>General Manager          | Alosmany Modern<br>Building & Trade<br>Egypt - Giza                        |
| 7. Dipl.-Ing. J. Huppertz<br>Anlagenprojektierung | MWB Prüfsysteme GMBH<br>Germany - Bamberg                                  |




Cairo, d. 8.06.90

Procedure of cleaning with cleaning material

1. Type : DFDW 0964 or UNION CARBIDE  
LD 1925 22 BP
2. Quantity : For one times Extruder
- |     |       |
|-----|-------|
| 60  | 10 kg |
| 90  | 15 kg |
| 120 | 50 kg |
| 150 | 50 kg |
3. Action :
- Drive extruder empty ( $< 5$  rpm)
  - Put cleaning material in
  - Temperature slows down to  $105 \dots 110^{\circ}$  C  
and observation the compound pressure (Limit)
  - Drive extruder empty ( $< 5$  rpm)
  - Dismantling the extruder head
  - Pulling out the screw
  - Waiting for cooling about 5 to 10 min.
  - Removing the cleaning material after shrinkage
  - After cleaning use siliconoilspray
  - Put in the screw and assembling the head

Insulation - thickness - test (one example) acc. to VDE

Date : 10/6/90  
 Type : NA2X 240 mm<sup>2</sup> 12/20 KV drum-no. 22  
 Machine : 120/60/90 No. 2  
 Results :



3 Layers:

- 1. Inner Layer IL 0.7 ± 0.1 (0.6 ... 0.8 )
- 2. Insulation IS 5.5 ± 0.65 (4.85 ... 6.15)
- 3. Outer Layer OL 0.8 ± 0.1 (0.7 ... 0.9 )

1 - 3. Thickness th 7.0 ± 0.85 (6.15 ... 7.85)

$$D = 2 th + \bar{d} \quad \bar{d} = 18.3$$

	1	2	3	4	5	6	∅	min.	max.
IL	0.695	1.012	0.964	0.826	0.920	0.873	0.382	0.695	1.012
IS	6.084	6.444	6.603	6.043	5.935	6.133	6.207	5.935	6.603
OL	0.534	0.742	0.808	0.577	0.593	0.570	0.637	0.534	0.808
th	7.313	8.193	8.375	7.446	7.448	7.576	7.726	7.313	8.375

$$D \quad 1 - 3 = 33.988$$

$$D \quad 2 - 4 = 33.944$$

$$D \quad 5 - 6 = 33.324$$

$$\text{max. diff.} = 0.664$$

acc. to VDE 0273 < 0.5

Hot-set-test (one example) acc. to IEC

Type : NA2X 240 mm<sup>2</sup> 12/20 KV drum-no.22

Material : CABOT 892/1 (semiconductiv)  
POLIDAN PE/G 2

Machine : 120/60/90 No. 2

Results	Sample-No.	Date	Curing time	Hot-set	Remark
	1	12/6/90	48 h	206 %	failed
	2	13/6/90	72 h	0 %	failed
	3	13/6/90	72 h	367 %	failed
	4	16/6/90	72 h	253 %	failed
	5	16/6/90	48 h	68,9 %	o.k.
	6	19/6/90	48 h	179,6 %	failed

Result should be between 40 ... 175 %.

Partial Discharge (PD) - Test (one example)

According to VDE 0472 max. 5 pC

According to IEC 540 max.20 pC

No	date	tested numbers of drums	not accepted drums	PD-accepted pC		PD not accepted pC		% not accepted
				min.-max.	min.-max.			
1	2.6.90	17	3	14	20	30	>100	17.65
2	3.6.90	17	1	6	18	>100		5.88
3	4.6.90	16	3	5	18	36	-	18.75
4	5.6.90	33	7	8	20	25	-	21.21
5	6.6.90	26	3	5	20	25	-	11.54
1 - 5		109	17	5	20	25	>100	15.59
6	9.6.90	35	10	12	20	60	-	28.57
7	10.6.90	27	6	4	20	70	-	22.22
8	11.6.90	11	2	12	20	90	-	18.18
9	12.6.90	24	2	3	20	70	-	8.33
10	13.6.90	30	6	3	20	45	-	20.00
6 -10		127	26	3	20	45	>100	20.47
11	16.6.90	23	2	3	20	>100		8.69
12	17.6.90	11	2	10	20	25	-	18.18
13	18.6.90	22	4	3	20	70	-	18.18
14	19.6.90	11	5	10	20	25	-	45.45
11-14		67	13	3	20	25	100	19.4
1-14		303	56	3	20	25	100	18.48

International level is  $\leq 1\%$  not accepted.