



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as “developed”, “industrialized” and “developing” are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

ICAR S.P.A.
Via Isonzo, 10
20052 MONZA (Milano) Italy
tel. (039) 839.251 thx. 333.339 ICARST I
fax (039) 833.227
telegr. Icarcondens Monza



18635

43 P
18635
18635
18635

UNIDO Contract No. 87/134
Project No. DP/VIE/85/010
Activity Code: J13313

DP/VIE/85/010

TECHNOLOGY TRANSFER FOR DESIGN TEST AND
PILOT MANUFACTURE OF HIGH VOLTAGE POWER CAPACITORS
IN THE SOCIALIST REPUBLIC OF VIET NAM

FINAL REPORT

According to point 2.18 f) of Contract 87/134

Monza, September the 1st 1990

DP/VIE/85/010

FINAL REPORT

This report covers the activities subsequent to the commissioning stage and the testing of capacitors in site and at international laboratory according to point 2.18 f) of contract 87/134 and to the section 2.4.b) ii) and iii) of "Terms of reference".

Assistance

The post commissioning operational assistance and on-site training were performed by:

Mr. P. Scarafiotti: ICAR HV components production Manager, in charge of the technical and executive direction of the project.

Mr. G. Borelli : ICAR HV components, field engineer of the project.

Mr. P. Scarafiotti re-visited the pilot plant in Ho Chi Minh City
on 10 - 14 January 1990

Mr. G. Borelli re-visited the pilot plant in Ho Chi Minh City
on 18 - 25 August 1989
9 - 19 November 1989
7 - 23 January 1990
20 - 30 April 1990
5 - 19 August 1990

During these visits ICAR engineers integrated the previous trainings with discussions on all the aspects of the technology transfer :

- a) production on process
- b) testing
- c) quality control
- d) rejection examination and rework
- e) production management

and they also verified that the pilot plant is managed properly and is working at full scale production.

After the commissioning stage, from August 1989 and February 1990, 310 capacitors of 100 Kvar - 8.66 KV were manufactured in full autonomy by the personell of the implementing agency, Power Company No. 2.

All the capacitors manufactured passed the routine tests carried out in the factory laboratory and then they were installed.

Until now only 1 unit was rejected from service. The examination of the failed unit showed that the breakdown was casual and did not depend by a production mistake.

Type tests

Four capacitors, randomly chosen from production, were tested at ICAR HV laboratory under the supervision and witnessed by an inspector from the international laboratory:

CESI - Centro Elettrotecnico Sperimentale Italiano",

which has provided to certify the tests, according to point 2.18 f) of the contract 87/134.

The tests were witnessed also by:

Mr. Y. Shibata, CTA of the project
Mr. Vo Minh Bon from PC2 and NPD of the project
Mr. Ngo Duc Quang from PC2
Mr. Le Dinh Dan from PC2
Mr. To Cong Thanh Loc from PC2

The type test certificate issued by CESI is enclosed, annex 1.

Study tour

Finally a study group composed by:

Mr. Vo Minh Bon from PC2 and NPD of the project
Mr. Ngo Duc Quang from PC2
Mr. Le Dinh Dan from PC2
Mr. To Cong Thanh Loc from PC2






under the supervision and the assistance of the CTA of the project:

Mr. Y. Shibata

carried out a 2 week stage at ICAR factory to study:

- 1) the possibility of expanding the existing pilot plant into full-scale production plant
- 2) the possibility of adding a production line for low-voltage capacitors for diversification of the existing plant
- 3) the ICAR experiences in making customers aware of economic advantage of power factor improvement.

The report of the study group is enclosed, annex 2.





CESI

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO

inspection report

client ICAR s.p.a. - Monza - MI ITALY

object N° 4 Power-factor correction capacitors, manufactured
by POWER COMPANY N° 2 - HO CHI MINH CITY - VIETNAM


purpose Routine tests and type tests

place and inspection date ICAR HV Laboratory Monza, 2-6/7/1990

this document is composed by 8 pages, 1 annexe of 13 pages

milan, 20 july 1990

responsible of the inspection



keywords: 12020V 22525Z 54550D 62001C 62050A

CONTENTS

1. Test object
2. Tests performed
3. Routine Tests
 - 3.1 Voltage test between terminals
 - 3.2 A.C. voltage test between terminals and container
 - 3.3 Capacitance and $\tan \delta$ measurement
 - 3.4 Test of internal discharge device
 - 3.5 Sealing test
4. Type tests
 - 4.1 Thermal stability test
 - 4.2 Capacitor losses measurement at elevated temperature
 - 4.3 A.C. voltage test between terminals and container
 - 4.4 Short-circuit discharge test
 - 4.5 Lightning impulse test between terminals and container
5. Conclusions

Annexe 1: ICAR TEST REPORT N. 2515

1. TEST OBJECT

Power-factor correction capacitors of a.c. power systems.

The main characteristics are the following:

- Manufacturer	:	Power Company N. 2 HO CHI MINH CITY - VIETNAM
- Model	:	PL-1 100/8.66
- Rated output	:	100 kVAr
- Rated voltage	:	8,66 kV
- Rated frequency	:	50 Hz
- Series number	:	070989-030989-090989-010989
- Capacitance	:	4,29 μ F 4,33 μ F 4,26 μ F 4,26 μ F
- Type	:	Single phase capacitor
- Insulation level	:	38/95
- Temperature category	:	- 25 + 45 $^{\circ}$ C
- Service	:	outdoor
- Dielectric	:	all polipropylene film
- Electrodes	:	alluminium foils
- Impregnant	:	Pxe
- Discharge resistor	:	internal
- Internal connection	:	6 series groups, 3 paralleled elements/series
- Weight	:	31 Kg
- Year of manufacture	:	1989

2. TESTS PERFORMED

Tests are performed according to IEC standard, Publication 871-1, 1987

The following tests are performed:

- Routine tests
- Type tests

3. ROUTINE TEST

3.1 Voltage test between terminals

The test was performed applying for 10 S a sinusoidal test voltage.

$$U_c = 18,62 \text{ kV r.m.s. } 50 \text{ Hz}$$

During the test no flashovers or other appreciable phenomena occurred.

Test results : Favourable

Test procedure and results are reported in the annexe 1 page 4 (ICAR Test Report N. 2515).

3.2 A.C. voltage test between terminals and container

The test was performed applying the test voltage for 10 s between the terminals (joined together) and the container.

$$U_t = 38 \text{ kV r.m.s. } 50 \text{ Hz}$$

During the test no flashovers or other appreciable phenomena occurred.

Test results : Favourable

Test procedure and results are reported in the annexe 1 page 4.

3.3 Capacitance and $\tan \delta$ measurement.

The capacitance and $\tan \delta$ measurement after the a.c. voltage tests were made at:

- $U_n = 8.66$ kV r.m.s. 50 Hz
- Ambient temperature = 27°C

Capacitance tolerance admitted - 5 to + 10%.

Test results : Favourable

Test procedure and results are reported in the annexe 1 page 4.

3.4 Test of internal discharge device

The resistance measurement of the internal discharge device was performed with a megaohm meter.

- Voltage measurement 500 V D.C.
- Resistance : $8,24 \div 8,26$ (megaohm)
- Maximum value allowed : 12,56 (megaohm)

Test results: Favourable

Test procedure and results are reported in the annexe 1 page 5.

3.5 Sealing test

The capacitor units n. 030989 and 010989 was heated for 3 hours in an oven for 3 hours.

- Temperature $80 \pm 5^\circ\text{C}$

No leakage occurred.

Test results : Favourable

Test procedure and results are reported in the annexe 1 page 5.

4. TYPE TESTS

4.1 Thermal stability test

The test capacitor n. 070989 was placed in a heated enclosure, with the air temperature of 45 °C.

The capacitor was subjected for a period of 58 hours to a sinusoidal voltage of:

- 10,4 kV r.m.s. 50 Hz

Test results: Favourable

Test procedure and results are reported in the annexe 1 page 6.

4.2 Capacitor losses measurement at elevated temperature.

The $\tan \delta$ was measured on the capacitor n. 070989 at the end of the thermal stability test.

The $\tan \delta$ was made at:

- 10,4 kV r.m.s 50 Hz

- capacitor temperature 49 °C

Maximum $\tan \delta$ admissible : $0.2 \cdot 10^{-3}$.

Test results : Favourable

Test procedure and results are reported in the annexe 1 page 5.

4.3 A.C. voltage test between terminals and container.

The test was performed applying the test voltage for 1 min between the terminals (joined together) and the container.

$$- U_t = 38 \text{ kV r.m.s. } 50 \text{ Hz}$$

During the test no flashovers or other appreciable phenomena occurred.

Test results : Favourable

Test procedure and results are reported in the annexe 1 page 7.

4.4 Short-circuit discharge test

The capacitor 030989 was subjected to 5 such discharges within 10 min.

The unit was charged at D.C. voltage of:

$$- U_t = 2,5 U_n = 21,7 \text{ kV d.c.}$$

Within 5 min after this test, the capacitor was subjected to a voltage test between terminals.

$$- U_t = 2,15 U_n = 18,62 \text{ kV r.m.s. } 50 \text{ Hz}$$

The capacitance was measured before the discharge test and after the voltage test.

Maximum change of capacitance admissible : 2%.

Test results: Favourable

Test procedure and results are reported in the annexe 1 page 7.

4.5 Lightning impulse test between terminals and container.

The lightning impulse test was made with a wave-shape of 1.02/45 μ s having a crest value of:

$$- U_c = 95 \text{ kV}$$

For each polarity 15 impulse voltage are applied

During the test no flashovers other appreciable phenomena occurred.

Test results : Favourable

Test procedure and results are reported in the annexe 1 page 8-11.

5. CONCLUSIONS

The test are performed according to IEC Standard, Publication 871-i, 1987 and test results are favourable.

A N N E X E 1

TEST OBJECT: Capacitors for
Power Factor Correction
model PL-1 100/8.66
manufactured by:
POWER COMPANY N° 2
HO CHI MINH CITY
VIETNAM

TEST SPECIFICATION: The tests were carried out in
accordance with IEC 871-1 edition
1987.

OVERALL RESULTS OF TESTS: The capacitor passed all the tests
in full compliance with the above
mentioned specifications.

TEST DATE: July 2nd - July 6th 1990

TEST PERFORMED AT: ICAR SpA H.V. Laboratory

WITNESSED BY: Mr. A. TULIPANO, Inspector from
C.E.S.I. Centro Elettrotecnico
Sperimentale Italiano.
Mr. Y. SHIBATA, CTA of UNIDO
project DP/VIE/85/010
Mr. VO MINH BON
Mr. NGO DUC QUANG
Mr. LE DINH DAN
Mr. TO CONG THANH LOC
from POWER COMPANY N.2
Mr. L. POZZI
Mr. A. MAGNI
from ICAR SpA (Q.C. Division)

This report is composed by 11 pages and 1 drawing.

Monza, July the 11th 1990.

CESI

inspection service
witnessed by

[Signature]

[Signature]

[Signature]

C O N T E N T S

1. PURPOSE OF THE TESTS
2. CHARACTERISTICS OF THE TESTED CAPACITORS
3. TEST METHODS
4. TESTS AND RESULTS
 - 4.1 Routine Tests
 - 4.2 Type tests

ANNEX

PL-1 100/8.66 CAPACITOR DRAWING

CESIinspection service
witnessed by*[Handwritten signature]*

1. PURPOSE OF THE TESTS

The purpose of the test was the type qualification of power factor correction capacitors model PL-1 100/8.66, manufactured by POWER COMPANY N°2 - HO CHI MINH CITY - VIETNAM, according to IEC 871-1.

2. CHARACTERISTICS OF THE TESTED CAPACITORS

Model : PL-1 100/8.66
Rated output : 100 kvar
Rated voltage : 8660 V
Rated frequency : 50 Hz
Identification number: 070989-030989-090989-010989
Type : single phase capacitor
Insulation level : 38/95
Temperature category : -25 +45°C
Service : outdoor
Dielectric : all polypropylene film
Electrodes : aluminium foils
Impregnant : PXE
discharge resistor : internal
Internal connection : 6 series groups
3 paralleled elements/series group
Weight : 31 Kg
Year of manufacture : 1989

CESI

inspection service
witnessed by
W. H. P. L. M.

3. TEST METHODS

The tests were performed in accordance with IEC 871-1 edition 1987 the corresponding clause of each test is indicated in brackets.

4. TESTS AND RESULTS

4.1 Routine tests

4.1.1. Voltage test between terminals (Sub-clause 9.1)

The test was performed applying an a.c. voltage of 18620 V 50 Hz for 10 seconds.

No breakdown occurred.

4.1.2. A.C. Voltage test between terminals and container (Clause 10)

The test was performed applying an A.C. Voltage of 38 KV 50 Hz for 10 seconds between the terminals (joined together) and the casing.

No Dielectric breakdown or flashover occurred.

4.1.3. Measurement of the capacitance and $\tan\delta$ between terminals (clause 7 and 8)

The capacitance and the loss angle tangent were measured at 27°C after the a.c. voltage tests in order to check the behaviour of the capacitor during the voltage test. The measurements were made with a schering bridge at 8660V - 50Hz.

The results obtained were:


Capacitor (n°)	Capacitance (μF)	Loss angle ($\tan\delta$)
070989	4.330	0.190 · 10 ⁻³
030989	4.343	0.189 · 10 ⁻³
090989	4.304	0.192 · 10 ⁻³
010989	4.300	0.192 · 10 ⁻³

Capacitance tolerance admitted -5 +10 %

CESI

inspection service

witnessed by



4.1.4. Checking of discharge device (clause 11)

The check was performed with a megaohm meter with a d.c. voltage output of 500 V. Maximum value allowed: 12.56 megaohm.

Capacitor (n°)	Resistance (megaohm)
070989	8.24
030989	8.25
090989	8.26
010939	8.24

4.1.5. Sealing test (clause 12)

The capacitors 030989 - 010989 were placed in an oven having constant temperature of $80 \pm 5^\circ\text{C}$ for 3 hours.

No leakage occurred.

4.2 TYPE TESTS

4.2.1. Capacitor losses measurement at high temperature (clause 14)

The capacitor losses were measured at the end of the thermal stability test at 49°C - 10400 V - 50Hz.

The following results were obtained:

Capacitor (n°)	Capacitance (μF)	Loss angle ($\tan \delta$)
070989	4.307	$0.156 \cdot 10^{-3}$

Maximum $\tan \delta$ admitted: $0.2 \cdot 10^{-3}$

CESI

inspection service
witnessed by

[Signature]

4.2.2. Thermal stability test (clause 13)

The capacitor 070989 was placed between two dummy capacitors, each containing resistors, in a heated enclosure where the air temperature was 45°C.

The dissipation in the resistors of the two dummy capacitors was adjusted to a value such that the case temperature of the dummy capacitors near the top opposing faces was equal or higher than the test capacitor.

Throughout the test the air temperature was checked by means of a thermometer.

During the whole test the difference between the measured air temperature and the specific test temperature was in the range of tolerance $\pm 2\%$.

After all parts of the capacitor had attained the temperature of the ambient air, the capacitor was subjected for a period of 58 hours to a voltage of 10400 V at rated frequency.

During the test the temperature of the container near the top was measured and recorded, during the last 6 hours no significant change was noted.

Record of the ambient temperature and of the above container temperature are available.

Before and after the test, the capacitance was measured at a temperature of 27°C. The following results were obtained:

MEASUREMENTS AT 27°C BEFORE THE TEST		MEASUREMENTS AT 27°C AFTER THE TEST	
C μF	Tan δ	C μF	Tan δ
4.330	$0.190 \cdot 10^{-3}$	4.341	$0.162 \cdot 10^{-3}$


Maximum change of capacitance admitted: 2%

Hour		53rd	54th	55th	56th	57th	58th
Ambient temperature	T4	47.2	46.4	44.1	47.0	45.4	45.1
	T5	46.1	45.2	42.9	46.4	44.8	44.3
	T6	45.9	45.3	42.9	46.2	44.7	44.3
Dummy capacitor temperature	T3	51.3	50.2	49.3	52.2	50.9	52.0
Capacitor temperature	T1	49.7	48.6	47.1	49.7	48.3	49.1
	T2	49.0	48.0	46.4	49.4	47.8	49.0



Inspection service

addressed by



4.2.3. A.C. Voltage test between terminals and container
(clause 15)

The test modalities were the same indicated in clause 4.1.2. but the test duration was 1 minute.

No dielectric breakdown or flashover occurred.

4.2.4 Discharge test (clause 17)

The capacitor 030989 was charged by means of a d.c. voltage equal to 21700 V and then discharged through a gap situated as close as possible to the capacitor. It was subjected to 5 such discharges in about 10 minutes. Five minutes after this test, the capacitor was subjected to a voltage test between terminlas, the test modalities were the same indicated in clause 4.1.1.

The capacitance was measured before the discharge test and after the voltage test.

The following results were obtained:

BEFORE THE TEST		AFTER THE TEST	
C µF	Tan δ	C µF	Tan δ
4.343	$0.189 \cdot 10^{-2}$	4.345	$0.187 \cdot 10^{-2}$

Maximum change of capacitance admitted: 2 %

CESI

inspection service

attested by

[Signature]

4.2.5. Lightning impulse test between terminals and container
(clause 16)

The lightning impulse test was made in accordance with IEC publications 60 but with a wave-shape of 1.2/50 usec having a crest value of 95 kV.

Fifteen impulses of positive polarity followed by fifteen impulses of negative polarity was supplied between bushing joined together and the container.

See the pictures of pages 9-10-11.

The pictures of page 9 show the wave-shape of 64 % of test voltage.

The pictures of page 10 show the 15 positive impulses.


The pictures of page 11 show the 15 negative impulses.

No puncture, no flashover and no irregularities on the impulse wave-shape occurred.

CESI


Inspection service
witnessed by

[Signature]



①

10000 / m




②


10000 / m

CESI


inspection service
witnessed by
[Signature]



3




4




5

CESI
inspection service
witnessed by
[Signature]




6

Test



7


Test



8

Test

CESI
inspection service
witnessed by
[Signature]



CESI

inspection service
witnessed by
Muller

DWG in mm	SCALE 1:10	DATE 14/10/88	TITLE OUTLINE DIMENSIONS PL-1 100 - 8.88
APPROVED <i>[Signature]</i>	CHECKED <i>[Signature]</i>	DRAWN <i>[Signature]</i>	DWG. N° PL - 1001
			REV. 00

CESI

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO

Via Rubattino 54 - 20134 Milano - Italy - Tel. +39 2 2125.1 - Telex 310097 CESI I - Telefax +39 2 2125440



U N I D O

REPORT OF THE STUDY TOUR
VIETNAM - DP/VIE/85/010

TRANSFER OF TECHNOLOGY FOR THE DESIGN , TEST AND PILOT
MANUFACTURE OF LOW VOLTAGE POWER CAPACITORS

Report of the study tour

Carried out from 24 June - 7 July 1990

VO MINH BON

NGO DUC QUANG

LE DINH DAN

TO CONG THANH LOC

1. INTRODUCTION

- 1.1 A study tour group from Power Company N°2, Vietnam (PC-2) consisting of

Mr. VO MINH BON , NPD;
Mr NGO DUC QUANG ,
Mr LE DINH DAN ,
Mr TO CONG THANH LOC

visited ICAR Company (Italy) from June 25 to July 7, 1990 within the framework of Project DP/VIE/85/010.

- 1.2 The Project entitled DP/VIE/85/010 (Technology Transfer for the Design, Test and Pilot Manufacture of High Voltage Power Capacitors) was approved and became operational in August 1986. Messrs ICAR Company were selected among 19 leading capacitor manufacturers for the technology transfer, and PC-2 was the project executing agency. A pilot plant for manufacturing H.V. capacitors was established and operational in Ho Chi Minh City for the above-mentioned purpose.

- 1.3 The objectives of the study tour was to revisit and discuss with ICAR Company about the following points:

(a) The possibility of expanding existing pilot plant into full-scale production;

(b) To witness the type test of the H.V. power capacitors samples;

(c) The possibility of adding a production line for Low voltage capacitors for diversification of the existing plant;

(d) To study experiences in making customers aware of economic advantage of power factor improvement.

2. PROGRAMME OF THE STUDY TOUR

During the study tour, the following activities were carried out:

- 24 June 1990, Sunday : Departure from Vietnam.
- 25 June 1990, Monday : Arrival in Milan.
Courtesy visit to ICAR Head Office,
Discussion about working plan.
Check in at Collodi Residence.
- 26 June 1990, Tuesday : First visit to the HV capacitor plant at Monza (conducted by Messrs Scarafiotti and Borelli)
- Visit to ADVIL (Mr Pennati)
Particular attention to metallization process and equipment.
Visit the production line for plastic can, metallized film low voltage capacitors.
- 27 June 1990, Wednesday: Free, in view of a general strike of metal industry workers
- 28 June 1990, Thursday : Visit to the production line for L.V. metallized film capacitors at Monza (conducted by Mr. Beretta)
- Discussion on the production process of metallized film, aluminium can type capacitors and construction of power factor correction units.
(Particular attention to conditions in Vietnam)
- Visit the assembly line for energy saving cabinets.
- 29 June 1990, Friday : Visit to CESI - an independent testing laboratory (conducted by Mr. Umberto Zanaboni, Mr Enrico Bertani)
- 2 July 1990, Monday : Witness the preparation and conduct of the type test of 4 samples sent from PC-2 previously. (CESI Inspector, Mr Antonio Tulipano and ICAR engineers conducted the testing)

- 3 July 1990, Tuesday: Discussion about quality standards (acceptability range) for incoming raw materials, components and subcontracted parts.
Discussion about quality control practice (Mr Pozzi, Mr Scarafiotti)
- 4 July 1990, Wednesday: Discussion about PC-2 low voltage capacitor project. Review of the project pre-feasibility study prepared by PC-2 (Mr Folli, Mr Beretta)
- 5 July 1990, Thursday: Mr Picci talked about Power factor correction with capacitors.
Discuss with Messrs Folli, Beretta, Borelli about the production line for L.V. capacitors (types of product, production flow chart, equipment, extent of automation)
- 6 July 1990, Friday: Discussion about maintenance management
Studying about experience in promoting the company product (pricing, selling, customer service)

Discuss about result of the type test.
- 7 July 1990, Saturday: Departure for Rome.

3. CONCLUSIONS AND RECOMMENDATIONS

The Study tour group had opportunities to visit several ICAR plants, including its subsidiary metallization and plastic can capacitor plant ADVIL; and discussed the relevant issues with the Company management.

- (1) The visits and discussions were very helpful and made it possible for the study tour participants to gain some insight to a technology that never before existed in Vietnam and to be convinced that it is possible to expand the existing high voltage power capacitor plant with a low voltage production line for the need of power factor correction capacitors; and later on A.C. capacitors for general applications.

The types of product that are suitable for conditions in Vietnam are low voltage metallized polypropylene film can (Aluminium can) with overpressure disconnectors

- (1) Due to the high investment versus added value, also environmental conditions, space availability and non-homogeneous technology with respect to the previous project, it is not advisable to set up a metallization plant for local production. Importing metallized films is viable as many low voltage capacitor producers nowadays do not metallize, therefore metallized film is available in the market from several sources.
- (2) In view of the high humidity in Vietnam, the metallized film L.V. capacitors that are to be manufactured in Vietnam should be impregnated.
- (3) In view of the prevailing conditions in Vietnam, a fully automatic plant does not seem very viable as the investment is too high, and less job opportunities are provided. A semi-automatic production line may be more suitable. However, emphasis should be placed on winding, spraying and testing process which necessarily have to be fully automatic.
- (4) The 4 sample capacitors dispatched from Vietnam for type test were unpacked on 2 July 1990 and were found to be in good condition. The tests (routine and type test) carried out afterwards by ICAR engineers and CESI Inspector, witnessed by representatives of PC-2 and the Project CTA- Mr Y. SHIBATA, proved to be satisfactory (See Attachment)

- (5) For transferring from pilot manufacture to full-scale production, another impregnating machine will be needed to improve the productivity. However special attention should be paid in maintenance of equipment and quality control. Quality should be built into the process; rather than relying on inspection. Managers and workers should be provided with the training they need to fully participate in the improvement process. Long-term ties should be established with selected suppliers rather than awarding contracts on price tag alone.

I have read this report, prepared by the PC-2 study tour group, and find it satisfactory.

Monza, July the 6th 1990



Y. SHIBATA

CHIEF TECHNICAL ADVISER
DP/VIE/85/010



4. LIST OF PERSONS CONTACTED

This report will not be completed without a note of special thanks to the following persons, whose patience, kind attendance and hospitality are gratefully appreciated:


ICAR Spa

Mr F.FOLLI	Director General
Mr. SCARAFIOTTI	Production Manager/ HV Capacitors
Mr. BORELLI	Chief Designer/ HV Capacitors
Mr. BERETTA	Production Manager/ LV Capacitors
Mr. POZZI	Quality Control Manager
Mr. PICCI	Technical Manager
Mr. MAGNI	HV capacitor Inspector
Mr. PENNATI	Production Manager /LV Capacitors

CESI

Mr U.ZANABONI	Technical-Commercial Direction
Mr. A.TULIPANO	Inspector / H.V. Division
Mr. E.BERTANI	Inspector/ H.V. Division

L.V. PROJECT PRODUCTION FLOW CHART





PROVE INDIVIDUALI

(e = 2F) (C)

Ponte di Misura Tettex tipo 2811

DATA	Matricola	Prova di tensione		Misure al ponte		Cx (nF)	100 μs	max 14,566
		10 sec. c.a. tra armature	60 sec. c.a. verso massa	lettura per calcolo	Diff. in kV			
2.7.90		18,6 kV	38 kV					
4.19	070989	OK	OK	42,15		4,330	0,0190	8,4
4.23	030989	OK	OK	42,51		4,343	0,0189	8,2
4.26	090989	OK	OK	41,75		4,304	0,0190	8,4
4.26	010989	OK	OK	41,33		4,300	0,0190	8,4
Misure dopo prova di scarica in c.c. a 2,5 kV								
2650 Vca 5 scariche in 10 min. e prova di								
Fessura a 2,15 Vca 10"								
	030989			42,73		4,345	0,0187	
Prova magnetica: 3 ore sui numeri 03-01								
tempo tra due : OK								

NOTE:

MOD.

PL - 1

100 kVav

266 kV

ICAR


condensatori in prova
n° 090989

9. TARIFFATURA DEL CIRCUITO DI MISURA


Condizioni ambientali: temperatura 27 °C
pressione 746 mmHg a 0 °C
pressione 742,7 mmHg a 0°C
fattore di correzione k = 0,955

Sfinterometro a sfere 2150mm		Tensione applicata teorica	Oscillografo			Carica del generatore
Distanza esplos. (mm)	Tens. di seg. rica 50° (kV)		Arretratore	Media ordinate di cresta (mm)	Costante di lettura (kV mm)	
22	64,5	61,5 95				66,25 102,3

10. CARATTERISTICHE DELL'ONDA DELLA TENSIONE DI PROVA




Polantra 1000/cm




Polantra 1000/cm


Y102




Y103




Y104






52



53



54

Cap C = 22 KVAR; S, 66 KV
 PP1 = 13,6 μm ; PP2 = 13,6 μm

REVISIONS CENTER

REF. N° 07.90-A

LEAD CAPACITOR DESIGN

ELECTRICAL AND ENVIRONMENTAL DATA		Element dimension	
Rated output	190 kvar	Element Thickness	17.6 mm
Rated voltage	6.66 kV	Element Width	127.6 mm
Rated frequency	50 Hz	Element Height	555 mm
Rated capacitance	9.06 μF	Pack data	
Capacitance tolerance	-5 +10%		
Minimum capacitance	7.66 μF		
Maximum capacitance	9.97 μF	Wrapping number of 63 μm paper	50
Rated current	21.9 A	Wrapping Thickness	4.7 mm
Highest system voltage	17.5	Pack Length	327.2 mm
Insulation level	38/95	Pack Width	128.2 mm
Temperature category	-25 +40°C	Pack Height	555.0 mm
Service	outdoor	Pack Length after wrapping	337 mm
Altitude	13000 m	Pack Width after wrapping	138 mm
		Pack Height after wrapping	580 mm
INTERNAL CONSTRUCTION		Case data	
Internal connections			
Series sections	5	Case Material	Aluminium
Parallel elements	3	Case Thickness	2 mm
Element capacitance	18.13 μF	Minimum Length of the case	344 mm
Voltage per series section	1443 V	Minimum Width of the case	145 mm
		Minimum height of the case	650 mm
		Length of the case	343 mm
		Width of the case	145 mm
		Height of the case	650 mm
		Discharge device	
PP1 weight thickness	13.6 μm	Time of discharge	600 s
PP1 measured thickness	15 μm	Residual voltage	75 V
PP2 weight thickness	13.6 μm	Maximum discharge resistance	12.6 Mohm
PP2 measured thickness	15 μm	N° 0.75 Mohm-850 V resistors	11
Conv. V/μm ref. to W.Th.	53.06 V/μm	Series connections	11
		Parallel connections	1
		Active and insulation material quantity	
Winding data			
Space factor ref. to M.Th.	19.5 %	Polypropylene 13.6 μm	6.98 kg
Height of the dielectric	550 mm	Polypropylene 13.6 μm	6.98 kg
Height of margin	12.5 mm	Aluminium 6 μm	9.02 kg
Useful Height	525 mm	Insulation paper 63 μm x 760	1.89 kg
Type of winding	EXTENDED FOIL	PXE oil	12.51 kg
Height of aluminium	540 mm		
Thickness of aluminium	6 μm		
Length of winding	26.0 m		
Diameter of mandrel	70 mm		
Number of turns	105		

DATE 05/07/90

DESIGNED BY : Mr DAN

CHECKED BY :

Cap. $C = 200 \text{ nFAR}$; $U = 5 \text{ kV}$
 $PP_1 = 15,2 \mu\text{m}$; $PP_2 = 15,2 \mu\text{m}$

TESTING CENTRE

REF. N° 07.90-A

LEAK CAPACITOR DESIGN

SPECIFIED AND ENVIRONMENTAL DATA				Element dimension		
Rated output	100	kvar	Element Thickness	20.3	mm	
Rated voltage	5.00	kV	Element Width	130.3	mm	
Rated frequency	50	Hz	Element Height	555	mm	
Rated capacitance	15.24	μF				
Capacitance tolerance	-5	+10%	Pack data			
Minimum capacitance	14.46	μF				
Maximum capacitance	16.76	μF	Wrapping number of 63 μm paper	32		
Rated current	37.2	A	Wrapping Thickness	3.0	mm	
Highest system voltage	7.2	kV	Pack Length	334.4	mm	
Insulation level	20/60		Pack Width	130.9	mm	
Temperature category	B5	+40°C	Pack Height	555.0	mm	
Service	outdoor		Pack Length after wrapping	340	mm	
Altitude	1000	m	Pack width after wrapping	137	mm	
			Pack Height after wrapping	580	mm	
INTERNAL CONSTRUCTION				Case data		
Internal connections				Case Material: Aluminium		
Series sections	4		Case Thickness	2	mm	
Parallel elements	4		Minimum Length of the case	347	mm	
Element capacitance	15.24	μF	Minimum Width of the case	144	mm	
Voltage per series section	1275	V	Minimum Height of the case	650	mm	
Dielectric thickness				Length of the case	343	mm
			Width of the case	145	mm	
			Height of the case	650	mm	
PP1 weight thickness	15.2	μm	Discharge device			
PP1 measured thickness	16.8	μm	Time of discharge	300	s	
PP2 weight thickness	15.2	μm	Residual voltage	50	V	
PP2 measured thickness	16.8	μm	Maximum discharge resistance	3.3	Mohm	
Conv. Wip. ref. to w.in.	51.81	μm	N° 0.75 Mohm-850 V resistors	8		
Winding data				Series connections	8	
Space factor ref. to M.Th.	20	%	Parallel connections	1		
Height of the dielectric	550	mm	Active and insulation material quantity			
Height of margin	12.5	mm				
Usefull Height	525	mm				
Type of winding	EXTENDED FOIL		Polypropylene 15.2 μm	7.36	kg	
Height of aluminium	540	mm	Polypropylene 15.2 μm	7.36	kg	
Thickness of aluminium	5	μm	Aluminium 6 μm	8.51	kg	
Length of winding	27.5	m	Insulation paper 63 μm x 760	1.22	kg	
Diameter of mandrel	70	mm	PXE oil	12.30	kg	
Number of turns	110					

DATE 05/07/90

DESIGNED BY : Mr DAN

CHECKED BY :

Cap G = 100 kVAR ; E, 3 kV
 PP1 = 15,2 μm ; PP2 = 15,2 μm

POWER COMPANY S.A.
 TESTING CENTRE

REF. N° 07.90-B

LP-1 CAPACITOR DESIGN

ELECTRICAL AND ENVIRONMENTAL DATA		Element dimension	
Rated output	100 kVar	Element Thickness	18.8 mm
Rated voltage	6.30 kV	Element Width	117.0 mm
Rated frequency	50 Hz	Element Height	355 mm
Rated capacitance	8.02 μF		
Capacitance tolerance	-5 +10%	Pack data	
Minimum capacitance	7.62 μF		
Maximum capacitance	9.82 μF	Wrapping number of 63 μm paper	32
Rated current	15.9 A	Wrapping Thickness	3.0 mm
Highest system voltage	7.2	Pack Length	310.7 mm
Insulation level	20/50	Pack Width	117.6 mm
Temperature category	-25 +40°C	Pack Height	355.0 mm
Service	outdoor	Pack Length after wrapping	317 mm
Altitude	< 1000 m	Pack Width after wrapping	124 mm
		Pack Height after wrapping	380 mm
INTERNAL CONSTRUCTION		Case data	
Internal connections		Case Material	Aluminium
Series sections	4	Case Thickness	2 mm
Parallel elements	4	Minimum Length of the case	324 mm
Element capacitance	8.02 μF	Minimum Width of the case	131 mm
Voltage per series section	1575 V	Minimum Height of the case	450 mm
		Length of the case	325 mm
		Width of the case	145 mm
		Height of the case	650 mm
Dielectric thickness		Discharge device	
PP1 weight thickness	15.2 μm	Time of discharge	300 s
PP1 measured thickness	16.8 μm	Residual voltage	50 V
PP2 weight thickness	15.2 μm	Maximum discharge resistance	6.2 Mohm
PP2 measured thickness	16.8 μm	N° 0.75 Mohm-850 V resistors	8
Conv. V/μm ref. to W.Th.	51.81 V/μm	Series connections	8
		Parallel connections	1
Winding data		Active and insulation material quantity	
Space factor ref. to M.Th.	20 %	Polypropylene 15.2 μm	3.98 kg
Height of the dielectric	350 mm	Polypropylene 15.2 μm	3.98 kg
Height of margin	12.5 mm	Aluminium 5 μm	3.80 kg
Usefull Height	325 mm	Insulation paper 63 μm x 560	0.83 kg
Type of winding	EXTENDED FOIL	PXE oil	19.12 kg
Height of aluminium	340 mm		
Thickness of aluminium	5 μm		
Length of winding	23.5 m		
Diameter of mandrel	62.5 mm		
Number of turns	104		

DATE 05/07/90

DESIGNED BY : Mr DAN

CHECKED BY :

Cap. G = 200 kVAR ; 8,60 KV
 PP1 = 14,5 μm ; PP2 = 13,6 μm

CP-1 CAPACITOR DESIGN

ELECTRICAL AND ENVIRONMENTAL DATA		Element dimension	
Rated output	194 kvar	Element Thickness	17.6 mm
Rated voltage	8.66 KV	Element Width	127.5 mm
Rated frequency	50 Hz	Element Height	606 mm
Rated capacitance	8.23 μF		
Capacitance tolerance	-5 +10%	Pack data	
Minimum capacitance	7.82 μF	Wrapping number of 63 μm paper	50
Maximum capacitance	9.05 μF	Wrapping Thickness	4.1 mm
Rated current	22.4 A	Pack Length	327 mm
Highest system voltage	17.5	Pack Width	128 mm
Insulation level	38/95	Pack Height	606 mm
Temperature category	-25 +40°C	Pack Length after wrapping	335 mm
Service	outdoor	Pack Width after wrapping	136 mm
Altitude	< 1000 m	Pack Height after wrapping	630 mm
INTERNAL CONSTRUCTION		Case data	
Internal connections		Case Material	Aluminium
Series sections	6	Case Thickness	2 mm
Parallel elements	3	Minimum Length of the case	342 mm
Element capacitance	15.47 μF	Minimum Width of the case	143 mm
Voltage per series section	1443 V	Minimum Height of the case	700 mm
Dielectric thickness		Length of the case	343 mm
PP1 weight thickness	14.5 μm	Width of the case	145 mm
PP1 measured thickness	15 μm	Height of the case	700 mm
PP2 weight thickness	13.6 μm	Discharge device	
PP2 measured thickness	15 μm	Time of discharge	600 s
Conv. V/μm ref. to W.Th.	51.36 V/μm	Residual voltage	75 V
Winding data		Maximum discharge resistance	12.4 Moh
Space factor ref. to M.Th.	20 %	N° 0.75 Mohm-850 V resistors	11
Height of the dielectric	600 mm	Series connections	11
Height of margin	12.5 mm	Parallel connections	1
Usefull Height	575 mm	Active and insulation material quantity	
Type of winding	EXTENDED FOIL	Polypropylene 14.5 μm	7.85 kg
Height of aluminium	590 mm	Polypropylene 13.6 μm	7.36 kg
Thickness of aluminium	6 μm	Aluminium 6 μm	9.52 kg
Length of winding	25.2 m	Insulation paper 63 μm x 810	2.00 kg
Diameter of mandrel	70 mm	PXE oil	13.39 kg
Number of turns	102		

DATE 05/07/90

DESIGNED BY : Mr DAN

CHECKED BY :