



TOGETHER
for a sustainable future

OCCASION

This publication has been made available to the public on the occasion of the 50th anniversary of the United Nations Industrial Development Organisation.



TOGETHER
for a sustainable future

DISCLAIMER

This document has been produced without formal United Nations editing. The designations employed and the presentation of the material in this document do not imply the expression of any opinion whatsoever on the part of the Secretariat of the United Nations Industrial Development Organization (UNIDO) concerning the legal status of any country, territory, city or area or of its authorities, or concerning the delimitation of its frontiers or boundaries, or its economic system or degree of development. Designations such as "developed", "industrialized" and "developing" are intended for statistical convenience and do not necessarily express a judgment about the stage reached by a particular country or area in the development process. Mention of firm names or commercial products does not constitute an endorsement by UNIDO.

FAIR USE POLICY

Any part of this publication may be quoted and referenced for educational and research purposes without additional permission from UNIDO. However, those who make use of quoting and referencing this publication are requested to follow the Fair Use Policy of giving due credit to UNIDO.

CONTACT

Please contact publications@unido.org for further information concerning UNIDO publications.

For more information about UNIDO, please visit us at www.unido.org

ECV-Ges.m.b.H., A-8704 Leoben/Austria

19909

TEST REPORT

F6 P
Tabelle
Freie

Subject: **Laboratory Test (10 coal samples test)**
Execution of Services related to
bankable feasibility study of a
second generation integrated steel mill
in West or East Java

Commission: **U N I D O**
Project No.: US/INS/91/193
Purchase Order No: 15-2-2101H
Contract-Nr.: 92/101

Executed by: **ECV**
Energie und chem. Verfahrenstechnik Ges.m.b.H.

Autor: **Mayer Franz-Wolfgang MSc**

Date: **1992 09 21**


ECV-Ges.m.b.H., A-8704 Leoben/Austria

Executed according to UNIDO-Contract-Nr.: 92/101

by ECV-Laboratory

Laboratory-Tests:

Pötzl Gerhard




Analysis:

Pracher Friedrich



Coordinator:

Mayer Franz-Wolfgang MSc



ECV Energies u. chem. Verfahren
Forschungs- u. Beratungs-Ges. m. b. H.
8700 Leoben, Johann-Sacklg. 65-67

1992 - 06 - 22
1992 - 10 - 14

Table of contents

1. Introduction

1.1. Scope of services

2. Summary

2.1. Suitability of the investigated coals for application in the COREX process

3. Laboratory Test

3.1. Description of coal samples as received

3.2. Table of coal analysis summarized

3.3. Tables containing

- Proximate analysis
- Coking behaviour
- Tar content by low temperature destillation
- Ultimate analysis

3.4. Ash composition

3.5. Thermal stability by VOEST-ALPINE standard test

3.5.1. Proximate analysis in different stages of treatment

3.5.2. Agglomeration behaviour and partical size distribution of thermal treated coal

4. Annex

Particle size distribution of raw coal as received

Fig. 1: Classification of coals in accordance of ash and volatiles content

Fig. 2: Classification of coals in accordance of atomic ratios

1. INTRODUCTION

The UNIDO elaborates in co-operation with the government of Indonesia a feasibility study for future steel-making processes, especially the COREX process. For evaluation of the suitability of indigenous raw material, laboratory tests as reported below have been executed.

1.1. Scope of services

From ten Indonesian coal samples the suitability for application in the COREX process has been evaluated by laboratory test including:

- determination of the proximate analysis, comprising the determination of moisture, ash, fixed carbon and volatiles content in accordance with the DIN standards No. 51718, 51719 and 51720
- determination of the ultimate analysis, comprising the determination of the content on hydrogen, carbon, nitrogen, oxygen and sulphur on dry and ash free basis
- evaluation of the caking behaviour on the basis of determination of the caking index (Free Swelling Index) according to DIN standard No 51741
- determination of the ash composition in accordance with DIN standard No 51729, including the ratio of basic and acidic ash components
- determination of the tar content on the basis of the Fischer Assay according to ISO standard No R-647-1968(E).

ECV-Ges.m.b.H.,A-8704 Leoben/Austria

- determination of the thermal stability (decrepitation behaviour) using an internal standard of VOEST-ALPINE Industrieanlagenbau, which basically measures the degradation behaviour of the samples during thermal treatment.

2. SUMMARY

All investigated coal samples show a high content of volatile matters and are characterized as subbituminous to lignite A. Ombilin coal and both Lumut coal are suitable for COREX-process, Prima coal limited and/or mixed with richer coal.

2.1. Suitability for application of Indonesian Coal in the COREX-Process

Referring to the quality figures of the Indonesia coal the following results can be concluded:

- * The Indonesian coal, due to their carbonization, (volatile matter percentage) are situated in the range of subbituminous to lignite A. They are characterized (excepted samples 4, 5 and 7) by a very low ash content and an average low sulphur content. The low swelling index of most investigated coals are related to the low carbonization, only Lumut coal shows swelling index 6.

According to the publication of R. Hauk the most important properties of coal for usage in COREX-process are

- the content of volatile matters
- the atomic ratios H/C and O/C

which both determines the gasifications temperature (gasification to CO and H₂). The higher the gasification temperature, the more suitable the coal is to the COREX process and the lower the coal consumption.

The classification of coal according to its atomic ratios is more accurate than that according to volatile matters because gasification temperatures of coals with equal volatile matters can differ markedly.

Other properties such as swelling index and ash content and composition are of little concern.

- * Even the ratio fixed carbon/ash is high (especially for samples 1, 6 and 8) for the usage of this coal in the Corex-process due to the high content of volatile matters a blending part of hard coal will be necessary.
- * The blending ratio for this coal depends on the quality of the basic coal which is to be used.
- * The moisture content of samples 1, 2, 3 and 5 shall be reduced by pre-drying of this coal (eliminating approx 5 mass% water).
- * Concerning the particle stability index the results of the tests are in normal range. The agglomeration of the coal particles can be an advantage and will be responsible for the desired transport of fixed carbon in the lower part of the COREX-reactor. For sample 6 the figure of particle stability (which is the percentage of - 2 mm after the test) is high but the resulting portion of particles - 2 mm are in average.
- * The ash of all samples are reacting acetous.

* Conclusion

The investigated coals can be classified for suitability in COREX process according to Fig. 1 and 2 as follows

- a) Lumut-A2, Lumut-B can be used unreservedly
- b) Ombililin and possibly Primar coal are theoretically usable, but suitability in practice needs to be confirmed by testing
- c) PINANG, Satui and Senakin coal have to be mixed with coals of higher quality

3. LABORATORY TEST

3.1. Description of coal samples as received

Table of samples

SAMPLE NO 1	PINANG - COAL	39,7 kg
SAMPLE NO 2	PRIMA - COAL	39,9 kg
SAMPLE NO 3	OMBILIN - COAL	41,9 kg
SAMPLE NO 4	SATUI ARUTMIN - COAL	40,2 kg
SAMPLE NO 5	SENAKIN ARUTMIN - COAL	41,2 kg
SAMPLE NO 6	ADARO - COAL	37,5 kg
SAMPLE NO 7	ANTRASIT	34 kg
SAMPLE NO 8	STEAM A2 COAL	33 kg
SAMPLE NO 9	LUMUT A2 COAL	36 kg
SAMPLE NO 10	LUMUT B COAL	23 kg

3.2.

Table of coal analysis summarized

Sample No Name	proximate analysis						elementary analysis				low temp. destillation				Swelling index
	mois- ture	ash	fix. carb.	volat.	sulfur	chlor- ine	carbon	hydro- gen	nitro- gen	oxy- gen	water	tar	coke resid.	gas	
	as recei- ved (%)	d r y (%)													
1/PINAG	11,60	4,32	52,18	43,50	0,479	0,020	73,47	5,24	1,90	14,57	4,30	17,13	69,48	9,19	0
2/PRIMA	7,15	2,71	53,65	43,64	0,634	0	76,69	5,41	1,95	12,61	5,22	17,47	68,50	8,81	0
3/OMBILIN	7,09	3,12	55,04	41,84	0,487	0,012	78,50	5,64	1,64	10,60	6,36	15,71	69,62	8,32	2
4/SATUI	7,74	9,29	45,87	44,84	0,786	0	71,43	5,63	1,28	11,58	7,87	17,36	65,79	8,97	1/2
5/SENAKIN	6,87	16,62	41,46	41,92	0,716	0	65,25	5,31	1,12	10,98	5,52	18,77	72,31	6,85	1/2
6/ADARO	11,87	1,73	50,30	47,97	0,138	0	72,60	5,12	1,11	19,30	10,27	11,54	66,09	12,10	1/2
7/ANTRASIT	3,18	13,78	78,17	8,06	1,501	0,048	70,51	3,50	1,49	9,17	-	-	-	-	-
8/STEAM-A 2	22,76	0,66	49,91	49,43	0,385	0,078	75,90	7,26	1,11	14,61	-	-	-	-	-
9/LUMUT-A 2	3,05	2,38	60,79	36,82	0,191	0,030	82,52	5,56	1,30	8,02	2,42	15,06	75,15	7,36	6
10/LUMUT-B	2,99	6,55	57,29	36,16	0,305	0,055	77,85	5,35	1,21	8,68	6,20	11,42	75,15	7,24	6

3.3. Tables for raw coal as received

3.3.1 sample No. 1 PINANG - COAL

3.3.1.1.

Proximate analysis Sample No. 1		as-received	dry	dry-ash-free
Moisture	% DIN 51718	11,60		
Ash	% DIN 51719	3,82	4,32	
Fixed carbon	% DIN 51720	46,13	52,18	54,54
Volatile	% DIN 51720	38,45	43,50	45,46
Sulfur	% DIN 51724/1	0,423	0,479	
Chlorine	% DIN 51727	0,018	0,020	

3.3.1.2.

Swelling index	DIN 51741	0
----------------	-----------	---

3.3.1.3.

Low temperature distillation ISO 647 Sample No. 1		as-received	dry	dry-ash-free
Moisture	%	11,60		
Ash	%	3,82	4,32	
Water (decomposition)	%	3,80	4,30	
Tar	%	15,41	17,13	17,90
Coke residue	%	61,42	69,48	
Gas (plus errors)	%	8,04	9,10	

3.3.1.4.

Ultimate analysis Sample No. 1			as-received	dry	dry-ash-free
Hydrogen	%	DIN 51721	4,63	5,24	5,48
Carbon	%		65,19	73,74	77,07
Nitrogen	%		1,68	1,90	1,99
Oxygen	%		12,88	14,57	15,23
H : C ratio				0,71	
O : C ratio				1,98	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.2. sample No. 2 PRIMA - COAL

3.3.2.1.

Proximate analysis Sample No. 2		as-received	dry	dry-ash-free
Moisture	% DIN 51718	7,15		
Ash	% DIN 51719	2,52	2,71	
Fixed carbon	% DIN 51720	49,81	53,65	55,14
Volatile	% DIN 51720	40,52	43,64	44,86
Sulfur	% DIN 51724/1	0,589	0,634	
Chlorine	% DIN 51727	0	0	

3.3.2.2.

Swelling index	DIN 51741	0
----------------	-----------	---

3.3.2.3.

Low temperature distillation ISO 647 Sample No. 2		as-received	dry	dry-ash-free
Moisture	%	7,15		
Ash	%	2,52	2,71	
Water (decomposition)	%	4,85	5,22	
Tar	%	16,22	17,47	17,96
Coke residue	%	63,60	68,50	
Gas (plus errors)	%	8,18	8,81	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.2.4.

Ultimate analysis Sample No. 2			as-received	dry	dry-ash-free
Hydrogen	%	DIN 51721	5,02	5,41	5,56
Carbon	%		71,21	76,69	78,83
Nitrogen	%		1,81	1,95	2,00
Oxygen	%		11,71	12,61	12,96
H : C ratio				0,71	
O : C ratio				1,64	

3.3.3. sample No. 3 OMBILIN - COAL

3.3.3.1.

Proximate analysis Sample No. 3		as-received	dry	dry-ash-free
Moisture	% DIN 51718	7,09		
Ash	% DIN 51719	2,90	3,12	
Fixed carbon	% DIN 51720	51,14	55,04	56,82
Volatile	% DIN 51720	38,87	41,84	43,18
Sulfur	% DIN 51724/1	0,452	0,487	
Chlorine	% DIN 51727	0,011	0,012	

3.3.3.2.

Swelling index	DIN 51741	2
----------------	-----------	---

3.3.3.3.

Low temperature distillation ISO 647 Sample No. 3		as-received	dry	dry-ash-free
Moisture	%	7,09		
Ash	%	2,90	3,12	
Water (decomposition)	%	5,91	6,36	
Tar	%	14,60	15,71	16,22
Coke residue	%	64,68	69,62	
Gas (plus errors)	%	7,72	8,31	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.3.4.

Ultimate analysis Sample No. 3		as-received	dry	dry-ash-free
Hydrogen	% DIN 51721	5,24	5,64	5,82
Carbon	%	72,93	78,50	81,03
Nitrogen	%	1,52	1,64	1,69
Oxygen	%	9,85	10,60	10,94
H : C ratio			0,72	
O : C ratio			1,35	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.4. sample No. 4 SATUI ARUTMIN - COAL

3.3.4.1.

Proximate analysis Sample No. 4			as-received	dry	dry-ash-free
Moisture	%	DIN 51718	7,74		
Ash	%	DIN 51719	8,57	9,29	
Fixed carbon	%	DIN 51720	42,32	45,87	50,57
Volatile	%	DIN 51720	41,37	44,84	49,43
Sulfur	%	DIN 51724/1	0,725	0,786	
Chlorine	%	DIN 51727	0	0	

3.3.4.2.

Swelling index	DIN 51741	1/2
----------------	-----------	-----

3.3.4.3.

Low temperature distillation ISO 647 Sample No. 4		as-received	dry	dry-ash-free
Moisture	%	7,74		
Ash	%	8,57	9,29	
Water (decomposition)	%	7,26	7,87	
Tar	%	16,02	17,36	19,14
Coke residue	%	60,70	65,79	
Gas (plus errors)	%	8,28	8,97	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.4.4.

Ultimate analysis Sample No. 4			as-received	dry	dry-ash-free
Hydrogen	%	DIN 51721	5,19	5,63	6,21
Carbon	%		65,90	71,43	78,75
Nitrogen	%		1,18	1,28	1,41
Oxygen	%		10,68	11,58	12,77
H : C ratio				0,79	
O : C ratio				1,62	

3.3.5. sample No. 5 SENAKIN ARUTMIN - COAL

3.3.5.1.

Proximate analysis Sample No. 5			as-received	dry	dry-ash-free
Moisture	%	DIN 51718	6,87		
Ash	%	DIN 51719	15,48	16,62	
Fixed carbon	%	DIN 51720	38,61	41,46	49,72
Volatile	%	DIN 51720	39,04	41,92	50,28
Sulfur	%	DIN 51724/1	0,667	0,716	
Chlorine	%	DIN 51727	0	0	

3.3.5.2.

Swelling index	DIN 51741	1/2
----------------	-----------	-----

3.3.5.3.

Low temperature distillation ISO 647 Sample No. 5		as-received	dry	dry-ash-free
Moisture	%	3,66		
Ash	%	15,48	16,62	
Water (decomposition)	%	5,14	5,52	
Tar	%	17,48	18,77	22,71
Coke residue	%	67,34	72,31	
Gas (plus errors)	%	6,38	6,85	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.5.4.

Ultimate analysis Sample No. 5			as-received	dry	dry-ash-free
Hydrogen	%	DIN 51721	4,95	5,31	6,37
Carbon	%		60,77	65,25	78,26
Nitrogen	%		1,04	1,12	1,34
Oxygen	%		10,26	10,98	13,17
H : C ratio				0,80	
O : C ratio				1,68	

3.3.6. sample No. 6 ADARO - COAL

3.3.6.1.

Proximate analysis Sample No. 6		as-received	dry	dry-ash-free
Moisture	% DIN 51718	18,87		
Ash	% DIN 51719	1,40	1,73	
Fixed carbon	% DIN 51720	40,81	50,30	51,19
Volatile	% DIN 51720	38,92	47,97	48,81
Sulfur	% DIN 51724/1	0,112	0,138	
Chlorine	% DIN 51727	0	0	

3.3.6.2.

Swelling index	DIN 51741	1/2
----------------	-----------	-----

3.3.6.3.

Low temperature distillation ISO 647 Sample No. 6		as-received	dry	dry-ash-free
Moisture	%	18,87		
Ash	%	1,40	1,73	
Water (decomposition)	%	8,33	10,27	
Tar	%	9,36	11,54	11,74
Coke residue	%	53,62	66,09	
Gas (plus errors)	%	9,82	12,10	

ECV-Ges.m.b.H.,A-8704 Leoben/Austria

3.3.6.4.

Ultimate analysis Sample No. 6			as-received	dry	dry-ash-free
Hydrogen	%	DIN 51721	4,15	5,12	5,21
Carbon	%		58,90	72,60	73,88
Nitrogen	%		0,90	1,11	1,13
Oxygen	%		15,66	19,30	19,64
H : C ratio				0,70	
O : C ratio				2,65	

ECV-Ges.m.b.H.,A-8704 Leoben/Austria

3.3.7. sample No. 7 ANTRASIT/B1

3.3.7.1.

Proximate analysis Sample No. 7			as-received	dry	dry-ash-free
Moisture	%	DIN 51718	3,18		
Ash	%	DIN 51719	13,34	13,78	
Fixed carbon	%	DIN 51720	75,68	78,17	90,66
Volatile	%	DIN 51720	7,80	8,06	9,34
Sulfur	%	DIN 51724/1	1,453	1,501	
Chlorine	%	DIN 51727	0,047	0,048	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.7.4.

Ultimate analysis Sample No. 7		as-received	dry	dry-ash-free
Hydrogen	% DIN 51721	3,39	3,50	4,06
Carbon	%	68,27	70,51	81,78
Nitrogen	%	1,44	1,49	1,73
Oxygen	%	8,88	9,17	10,64
H : C ratio			0,50	
O : C ratio			1,30	

ECV-Ges.m.b.H.,A-8704 Leoben/Austria

3.3.8. sample No. 8 STEAM - COAL A2

3.3.8.1.

Proximate analysis Sample No. 8			as-received	dry	dry-ash-free
Moisture	%	DIN 51718	22,76		
Ash	%	DIN 51719	0,51	0,66	
Fixed carbon	%	DIN 51720	38,55	49,91	50,24
Volatile	%	DIN 51720	38,18	49,43	49,76
Sulfur	%	DIN 51724/1	0,298	0,385	
Chlorine	%	DIN 51727	0,06	0,078	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.8.4.

Ultimate analysis Sample No. 8		as-received	dry	dry-ash-free
Hydrogen	% DIN 51721	5,61	7,26	7,31
Carbon	%	58,63	75,90	76,40
Nitrogen	%	0,86	1,11	1,12
Oxygen	%	11,28	14,61	14,71
H : C ratio			0,96	
O : C ratio			1,92	

3.3.9. sample No. 9 LUMUT A2 COAL

3.3.9.1.

Proximate analysis Sample No. 9			as-received	dry	dry-ash-free
Moisture	%	DIN 51718	3,05		
Ash	%	DIN 51719	2,31	2,38	
Fixed carbon	%	DIN 51720	58,94	60,79	62,28
Volatile	%	DIN 51720	35,70	36,82	37,72
Sulfur	%	DIN 51724/1	0,185	0,191	
Chlorine	%	DIN 51727	0,029	0,003	

3.3.9.2.

Swelling index	DIN 51741	6
----------------	-----------	---

3.3.9.3.

Low temperature distillation ISO 647 Sample No. 9		as-received	dry	dry-ash-free
Moisture	%	3,05		
Ash	%	2,31	2,38	
Water (decomposition)	%	2,35	2,42	
Tar	%	14,60	15,06	15,43
Coke residue	%	72,86	75,15	
Gas (plus errors)	%	47,14	7,36	

ECV-Ges.m.b.H.,A-8704 Leoben/Austria

3.3.9.4.

Ultimate analysis Sample No. 9			as-received	dry	dry-ash-free
Hydrogen	%	DIN 51721	5,39	5,56	5,69
Carbon	%		80,00	82,52	84,53
Nitrogen	%		1,26	1,3	1,33
Oxygen	%		7,78	8,02	8,22
H : C ratio				0,67	
O : C ratio				0,97	

3.3.10. sample No. 10 ARUTMIN - COAL

3.3.10.1.

Proximate analysis Sample No. 10			as-received	dry	dry-ash-free
Moisture	%	DIN 51718	2,99		
Ash	%	DIN 51719	6,35	6,55	
Fixed carbon	%	DIN 51720	55,58	57,29	61,31
Volatile	%	DIN 51720	35,08	36,16	38,69
Sulfur	%	DIN 51724/1	0,296	0,305	
Chlorine	%	DIN 51727	0,053	0,055	

3.3.10.2.

Swelling index	DIN 51741	6
----------------	-----------	---

3.3.10.3.

Low temperature distillation ISO 647		as-received	dry	dry-ash-free
Moisture	%	2,99		
Ash	%	6,35	6,55	
Water (decomposition)	%	6,01	6,20	
Tar	%	11,08	11,42	12,22
Coke residue	%	72,90	75,15	
Gas (plus errors)	%	7,02	7,24	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.3.10.4.

Ultimate analysis Sample No. 10		as-received	dry	dry-ash-free
Hydrogen	% DIN 51721	5,19	5,35	5,72
Carbon	%	75,52	77,85	83,31
Nitrogen	%	1,17	1,21	1,29
Oxygen	%	8,42	8,68	9,29
H : C ratio			0,69	
O : C ratio			1,11	

3.4. Ash composition

Chemical composition of ash DIN 517 29									
	Sample No								
	1	2	3	4	5	6	9	10	
SiO ²	54,65	43,68	50,18	45,94	50,20	29,20	43,63	50,03	
CaO	1,67	0,63	1,41	0,34	0,20	25,25	0,18	0,03	
MgO	2,62	2,81	1,17	0,29	0,24	8,02	0,38	0,13	
Al ² O ³	21,98	17,41	28,99	41,64	39,39	16,69	41,57	40,61	
Fe ² O ³	12,75	28,60	11,69	5,21	3,77	7,42	6,73	1,68	
K ² O	1,95	1,70	1,77	0,45	0,41	0,921	0,12	0,19	
Na ² O	0,61	1,37	0,44	0,28	0,49	2,26	0,51	0,26	
TiO ²	0,88	0,76	0,85	2,71	3,29	0,71	1,19	2,94	
SO ³	0,71	0,88	1,90	0,31	1,23	6,84	1,34	1,34	
P ² O ₅	0,19	0,46	0,18	0,25	0,44	0,04	0,40	0,47	

3.5. Thermal stability test (internal VOEST-ALPINE standard)

3.5.1. sample No. 1 PINANG - COAL

3.5.1.1. Proximate analysis in different stages of treatment

Proximate analysis Sample No. 1 feed material		16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	12,36		
Ash	%	DIN 51719	3,35	3,82	
Fixed carbon	%	DIN 51720	45,72	52,17	54,24
Volatile	%	DIN 51720	38,57	44,01	45,76

Proximate analysis Sample No. 1 Treatment: 1000 °C, 2 min.		16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,68		
Ash	%	DIN 51719	2,52	2,54	
Fixed carbon	%	DIN 51720	74,62	75,13	77,09
Volatile	%	DIN 51720	22,18	22,33	22,91

Proximate analysis Sample No. 1 Treatment: 1000 °C, 60 min.		16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,51		
Ash	%	DIN 51719	1,97	1,98	
Fixed carbon	%	DIN 51720	96,63	97,13	99,09
Volatile	%	DIN 51720	0,89	0,89	0,91

3.5.1.2. Particle size distribution and agglomeration behaviour
thermal treated coal

Particle Thermal stability index Sieve analysis of treated coal Sample No 1		
Fraction [mm]	1000 °C, 2 min. [%]	1000 °C, 60 min. [%]
> 20		
16		
12,5		
10		
8		
5,6		
4	not screenable	
2,8		
2		
1,4		
1		
0,5		
0,25		
0,125		
0		

agglomeration behaviour	moderate strong	strong
recovery mass%	61,40	45,82

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.5.2. sample No. 2 PRIMA - COAL

3.5.2.1.

Proximate analysis Sample No. 2 16 - 20 mm feed material			as received	dry	dry-ash-free
Moisture	%	DIN 51718	5,78		
Ash	%	DIN 51719	1,60	1,79	
Fixed carbon	%	DIN 51720	50,84	53,93	54,86
Volatile	%	DIN 51720	41,83	44,37	45,14

Proximate analysis Sample No. 2 16 - 20 mm Treatment: 1000 °C, 2 min.			as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,32		
Ash	%	DIN 51719	2,55	2,56	
Fixed carbon	%	DIN 51720	73,08	73,24	75,16
Volatile	%	DIN 51720	24,15	24,20	24,84

Proximate analysis Sample No. 2 16 - 20 mm Treatment: 1000 °C, 60 min.			as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,32		
Ash	%	DIN 51719	4,11	4,12	
Fixed carbon	%	DIN 51720	95,24	95,55	99,65
Volatile	%	DIN 51720	0,33	0,33	0,35

3.5.2.2.

Particle Thermal stability index Sieve analysis of treated coal Sample No 2		
Fraction [mm]	1000 °C, 2 min. [%]	1000 °C, 60 min. [%]
> 20		
16		
12,5		
10		
8		
5,6		
4	not screenable	
2,8		
2		
1,4		
1		
0,5		
0,25		
0,125		
0		

agglomeration behaviour	strong	strong
mass recovery %	65,53	51,07

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.5.3. sample No. 3 OMBILIN - COAL

3.5.3.1.

Proximate analysis Sample No. 3 feed material			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718		6,63		
Ash	%	DIN 51719		1,08	1,16	
Fixed carbon	%	DIN 51720		51,51	55,17	55,81
Volatile	%	DIN 51720		40,78	43,68	44,19

Proximate analysis Sample No. 3 Treatment: 1000 °C, 2 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718		0,34		
Ash	%	DIN 51719		2,09	2,10	
Fixed carbon	%	DIN 51720		76,79	77,05	78,79
Volatile	%	DIN 51720		20,78	20,85	21,30

Proximate analysis Sample No. 3 Treatment: 1000 °C, 60 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718		0,28		
Ash	%	DIN 51719		3,73	3,74	
Fixed carbon	%	DIN 51720		95,43	95,70	99,42
Volatile	%	DIN 51720		0,56	0,56	0,58

3.5.3.3.

Particle Thermal stability index Sieve analysis of treated coal Sample No 3		
Fraction [mm]	1000 °C, 2 min. [%]	1000 °C, 60 min. [%]
> 20		
16		
12,5		
10		
8		
5,6		
4	not screenable	
2,8		
2		
1,4		
1		
0,5		
0,25		
0,125		
0		

agglomeration behavior	very strong	very strong
mass recovery %	65,49	52,15

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.5.4. sample No. 4 SATUI ARUTMIN - COAL

3.5.4.1.

Proximate analysis Sample No. 4 feed material			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	6,59			
Ash	%	DIN 51719	8,35	8,94		
Fixed carbon	%	DIN 51720	41,18	44,09	48,41	
Volatile	%	DIN 51720	43,88	46,98	51,59	

Proximate analysis Sample No. 4 Treatment: 1000 °C, 2 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,27			
Ash	%	DIN 51719	15,01	15,05		
Fixed carbon	%	DIN 51720	59,07	59,23	69,72	
Volatile	%	DIN 51720	25,65	25,72	30,28	

Proximate analysis Sample No. 4 Treatment: 1000 °C, 60 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,22			
Ash	%	DIN 51719	21,08	21,13		
Fixed carbon	%	DIN 51720	78,06	78,23	99,19	
Volatile	%	DIN 51720	0,64	0,64	0,81	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.5.4.2.

Particle Thermal stability index Sieve analysis of treated coal Sample No 4		
Fraction [mm]	1000 °C, 2 min. [%]	1000 °C, 60 min. [%]
> 20		
16		
12,5		
10		
8		
5,6		
4	not screenable	
2,8		
2		
1,4		
1		
0,5		
0,25		
0,125		
0		

agglomeration behavior	moderate strong	strong
mass recovery %	66,03	47,92

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.5.5. sample No. 5 SENAKIN ARUTMIN - COAL

3.5.5.1.

Proximate analysis Sample No. 5 feed material			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	4,28			
Ash	%	DIN 51719	15,47	16,16		
Fixed carbon	%	DIN 51720	38,77	40,50	48,31	
Volatile	%	DIN 51720	41,48	43,33	51,69	

Proximate analysis Sample No. 5 Treatment: 1000 °C, 2 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,51			
Ash	%	DIN 51719	22,89	23,01		
Fixed carbon	%	DIN 51720	58,51	58,81	76,38	
Volatile	%	DIN 51720	18,09	18,18	23,62	

Proximate analysis Sample No. 5 Treatment: 1000 °C, 60 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,19			
Ash	%	DIN 51719	31,43	31,49		
Fixed carbon	%	DIN 51720	67,97	68,10	99,40	
Volatile	%	DIN 51720	0,41	0,41	0,60	

ECV-Ges.m.b.H., A-8704 Leoben/Austria

3.5.5.2.

Particle Thermal stability index Sieve analysis of treated coal Sample No 5		
Fraction [mm]	1000 °C, 2 min. [m%]	1000 °C, 60 min. [m%]
> 20		
16		
12,5		
10		
8		
5,6		
4	not screenable	
2,8		
2		
1,4		
1		
0,5		
0,25		
0,125		
0		

agglomeration behavior	strong	very strong
mass recovery %	67,83	54,07

3.5.6. sample No. 6 ADARO - COAL

3.5.6.1.

Proximate analysis Sample No. 6 16 - 20 mm feed material			as received	dry	dry-ash-free
Moisture	%	DIN 51718	19,25		
Ash	%	DIN 51719	1,06	1,31	
Fixed carbon	%	DIN 51720	40,11	49,67	50,33
Volatile	%	DIN 51720	39,58	49,02	49,67

Proximate analysis Sample No. 6 16 - 20 mm Treatment: 1000 °C, 2 min.			as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,39		
Ash	%	DIN 51719	2,65	2,66	
Fixed carbon	%	DIN 51720	71,98	72,26	74,24
Volatile	%	DIN 51720	24,98	25,08	25,76

Proximate analysis Sample No. 6 16 - 20 mm Treatment: 1000 °C, 60 min.			as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,39		
Ash	%	DIN 51719	2,30	2,31	
Fixed carbon	%	DIN 51720	95,69	96,06	98,34
Volatile	%	DIN 51720	1,62	1,63	1,66

3.5.6.2.

Particle Thermal stability index Sieve analysis of treated coal Sample No 6		
Fraction [mm]	1000 °C, 2 min. [%]	1000 °C, 60 min. [%]
> 20	-	-
16	9,90	6,33
12,5	15,58	26,17
10	15,93	16,50
8	15,58	16,76
5,6	20,03	17,00
4	11,75	9,00
2,8	5,21	4,25
2	1,97	1,58
1,4	1,22	0,83
1	0,87	0,50
0,5	1,27	0,58
0,25	0,46	0,25
0,125	0,17	0,17
0	0,06	0,08

agglomeration behavior	non agglomeration	non agglomeration
mass recovery %	57,38	40,05

3.5.9. sample No. 9 LUMUT A2 - COAL

3.5.9.1.

Proximate analysis Sample No. 9 feed material			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718		3,02		
Ash	%	DIN 51719		1,42	1,46	
Fixed carbon	%	DIN 51720		59,05	60,89	61,79
Volatile	%	DIN 51720		36,51	37,65	38,21

Proximate analysis Sample No. 9 Treatment: 1000 °C, 2 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718		0,46		
Ash	%	DIN 51719		4,21	4,23	
Fixed carbon	%	DIN 51720		73,75	74,09	77,36
Volatile	%	DIN 51720		21,58	21,68	22,64

Proximate analysis Sample No. 9 Treatment: 1000 °C, 60 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718		0,32		
Ash	%	DIN 51719		3,99	4,00	
Fixed carbon	%	DIN 51720		94,82	95,12	99,09
Volatile	%	DIN 51720		0,87	0,87	0,91

3.5.9.2. Particle size distribution and agglomeration behaviour
thermal treated coal

Particle Thermal stability index Sieve analysis of treated coal Sample No 9		
Fraction [mm]	1000 °C, 2 min. [%]	1000 °C, 60 min. [%]
> 20		
16		
12,5		
10		
8		
5,6		
4	not screenable	
2,8		
2		
1,4		
1		
0,5		
0,25		
0,125		
0		

agglomeration behaviour	very strong	very strong
recovery mass%	75,95	59,99

ECV-Ges.m.b.H.,A-8704 Leoben/Austria

3.5.10. sample No. 10 LUMUT/B COAL

3.5.10.1.

Proximate analysis Sample No. 10 feed material			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	3,21			
Ash	%	DIN 51719	3,99	4,12		
Fixed carbon	%	DIN 51720	57,74	59,65	62,22	
Volatile	%	DIN 51720	35,06	36,22	37,78	

Proximate analysis Sample No. 10 Treatment: 1000 °C, 2 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,30			
Ash	%	DIN 51719	9,45	9,48		
Fixed carbon	%	DIN 51720	69,10	69,31	76,57	
Volatile	%	DIN 51720	21,15	21,21	23,43	

Proximate analysis Sample No. 10 Treatment: 1000 °C, 60 min.			16 - 20 mm	as received	dry	dry-ash-free
Moisture	%	DIN 51718	0,23			
Ash	%	DIN 51719	6,63	6,65		
Fixed carbon	%	DIN 51720	92,82	93,03	99,66	
Volatile	%	DIN 51720	0,32	0,32	0,34	

ECV-Ges.m.b.H., A-8704 Leoben/Austria


3.5.10.2. Particle size distribution and agglomeration behaviour
thermal treated coal

Particle Thermal stability index Sieve analysis of treated coal Sample No 10		
Fraction [mm]	1000 °C, 2 min. [%]	1000 °C, 60 min. [%]
> 20		
16		
12,5		
10		
8		
5,6		
4	not screenable	
2,8		
2		
1,4		
1		
0,5		
0,25		
0,125		
0		

agglomeration behaviour	very strong	very strong
recovery mass%	75,24	60,21


Annex

ARP - Ges.m.b.H. 8700 LEOBEN	Grain size distribution Project: US/INS/91/183	Test No	815
		Rev. by KK	14-Jul-1992




Series

Series
Coefficient of constancy
Size range index



Annex

ARP - Ges.m.b.H. 8700 LEOBEN		Grain size distribution	Test No Rev. by: KK	816 14-Jul-1992
Project: US/INS/91/183				
Material	Sample No. 2, PRIMA-COAL			
Bulk weight:	kg/m ³		Humidity:	7,15 %
Type of machine:	HAND		Specific gravity:	kg/m ³




Series

**Coefficient of constancy
Size range index**

Annex


ARP - Ges.m.b.H. 8700 LEOBEN	Grain size distribution	Test No.	817	
		Rev. by:	KK 14-Jul-1992	
Project: US/INS/91/183				
Material: Sample No. 3. OMBILIN-COAL				
Bulk weight:	kg/m ³	Humidity:	7,09 %	
Type of machine:	HAND	Specific gravity:	kg/m ³	



Series
Coefficient of constancy
Size range index

Annex


ARP - Ges.m.b.H. 8700 LEOBEN	Grain size distribution	Test No.	818
		Rev. by. KK	14-Jul-1992
Project: US/INS/91/183			
Material: Sample No. 4. SATUI ARTUMIN-COAL			
Bulk weight:	kg/m ³	Humidity:	7,74 %
Type of machine:	HAND	Specific gravity:	kg/m ³



Series
Coefficient of constancy:
Size range index:

Annex

ARP - Ges.m.b.H. 8700 LEOBEN	Grain size distribution	Test No.	819	
		Rev. by KK	14-Jul-1992	
Project: US/INS/91/183				
Material: Sample No. 5. SENAKIN ARUTMIN-COAL				
Bulk weight:	kg/m ³	Humidity:	6,87%	
Type of maschine:	HAND	Specific gravity:	kg/m ³	




Series

Coefficient of constancy
Size range index


Annex

ARP - Ges.m.b.H. 8700 LEOBEN	Grain size distribution	Test No.	820
		Rev. by:	KK 14-Jul-1992
Project: US/INS/91/183			
Material	Sample No. 6, ADARO-COAL		
Bulk weight:	kg/m ³	Humidity:	18,87 %
Type of machine:	HAND	Specific gravity:	kg/m ³




Series

Series
Coefficient of constancy:
Size range index



Annex

ARP - Ges.m.b.H. 8700 LEOBEN	Grain size distribution	Test No.	903
		Rev. by: BS	14-Oct-1992
Project: US/INS/91/183			
Material: SAMPLE NO 9 - LUMUT A2 -COAL			
Bulk weight:	kg/m ³	Humidity:	31 %
Type of machine:	BY HAND	Specific gravity:	kg/m ³




Series

Coefficient of constancy:
Size range index

Annex

ARP - Ges.m.b.H. 8700 LEOBEN	Grain size distribution	Test No.	904	
		Rev. by: BS	14-Oct-1992	
Project. US/INS/91/183				
Material: SAMPLE NO. 10 - LUMUT B COAL				
Bulk weight:	kg/m ³	Humidity:	30 %	
Type of machine:	BY HAND	Specific gravity:	kg/m ³	



Series
Coefficient of constancy:
Size range index:




Fig. 1 - Classification of coals in accordance with their contents of ash (dry basis) and volatiles (dry, ash-free basis)

- a) Antracite
- b) Lignite charcoal
- c) High-volatile bituminous coal
- d) Lignite

Annex




Fig. 2 - Classification of coal by its adiabatic gasification temperature ($H_2 + CO_2$) independent of its atomic ratios